

1138444 B.C. A Subsidiary of Mercer Valve Co., Inc. (MCD)

Nameplate Abbreviation: Mercer Valve Co., Inc. Calgary Division

MD Rocky View, AB T1X 0K3Canada

This Company Manufactures or Assembles:

Design Name: 1400 Series

NBCert #

38113

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/11/2030

Design Type

[Safety Relief Valve] 1400 Series
Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 2015
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.291 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5-1 NPS	0.02 in ²		0.06 in	150-10000 psi	Air	UV

Design Name: 81-100000 Series

NBCert #

38001

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/11/2030

Design Type

[Safety Relief Valve] 81-100000 Series
Capacity Tests: Sec. UV at unknown lab on November 21, 1984
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.100 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 - 2 NPS	0.212 in ²	0.52 in	0.19 in	15-3500 psi	Air	UV

Design Name: 81-200000 Series

NBCert #

38023

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/11/2030

Design Type

[Safety Relief Valve] 81-200000 Series
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on February 25, 1985
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 7.210 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2 NPS	0.472 in ²	0.775 in	0.3 in	15-2500 psi	Air	UV

Design Name: 8500 Series NBCert # 38102

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 09/11/2030

Design Type

[Safety Relief Valve] 8500 Series
Capacity Tests: Sec. UV at National Board Testing Lab on February 12, 2013
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.370 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-2 NPS	1, 2 NPS	0.212 in ²	0.52 in	0.24 in	15-2400 psi	Air	UV

Design Name: 9100 NBCert # 38056

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 09/11/2030

Design Type

[Safety Relief Valve] 9100
Capacity Tests: Sec. UV at National Board Testing Lab on July 19, 1991
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.818 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.062 in ²	[C] 0.281 in	0.11 in	15-10000 psi	Air	UV
0.5-1.5 NPS	1 - 2 NPS	0.122 in ²	[D] 0.394 in	0.17 in	15-7500 psi	Air	UV
0.75-2 NPS	1 - 3 NPS	0.212 in ²	[E] 0.52 in	0.19 in	15-6000 psi	Air	UV
1-2 NPS	1-1/2 - 3 NPS	0.337 in ²	[F] 0.655 in	0.27 in	15-5000 psi	Air	UV
1.5-3 NPS	2 - 3 NPS	0.472 in ²	[G] 0.775 in	0.3 in	15-4000 psi	Air	UV
1.5-3 NPS	2 - 3 NPS	0.865 in ²	[H] 1.05 in	0.41 in	15-2750 psi	Air	UV

2-3 NPS	2-1/2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.58 in	15-2700 psi	Air	UV
2-3 NPS	3-4 NPS	1.622 in ²	[JO] 1.437 in	0.6 in	15-1800 psi	Air	UV
3-4 NPS	3,4,6 NPS	2.074 in ²	[K] 1.625 in	0.65 in	15-2200 psi	Air	UV
3-4 NPS	4, 6 NPS	3.205 in ²	[L] 2.02 in	0.8 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.08 in ²	[M] 2.28 in	0.9 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.909 in ²	[N] 2.5 in	0.985 in	15-740 psi	Air	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.2 in	15-525 psi	Air	UV

Design Name:	9100L (Liquids)	NBCert #	38067
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/11/2030

Design Type

[Relief Valve] 9100L (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on June 9, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.707 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.062 in ²	[C] 0.281 in	0.11 in	15-10000 psi	Water	UV
0.5-1 NPS	1 - 2 NPS	0.122 in ²	[D] 0.394 in	0.17 in	15-6500 psi	Water	UV
0.75-2 NPS	1 - 2 NPS	0.212 in ²	[E] 0.52 in	0.25 in	15-3500 psi	Water	UV
1-2 NPS	1.5 - 2.5 NPS	0.337 in ²	[F] 0.655 in	0.32 in	15-5000 psi	Water	UV
1.5-3 NPS	2 - 3 NPS	0.472 in ²	[G] 0.775 in	0.35 in	15-4000 psi	Water	UV
1.5-3 NPS	2 - 3 NPS	0.865 in ²	[H] 1.05 in	0.52 in	15-2750 psi	Water	UV
2-4 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.62 in	15-2700 psi	Water	UV
2-3 NPS	3-4 NPS	1.622 in ²	[JO] 1.437 in	0.64 in	15-1800 psi	Water	UV
3-4 NPS	3, 4 NPS	2.074 in ²	[K] 1.625 in	0.76 in	15-2220 psi	Water	UV
3-4 NPS	4, 6 NPS	3.205 in ²	[L] 2.02 in	0.82 in	15-2000 psi	Water	UV
4-4 NPS	6 NPS	4.08 in ²	[M] 2.28 in	0.95 in	15-2000 psi	Water	UV
4 NPS	6 NPS	4.909 in ²	[N] 2.5 in	0.985 in	15-740 psi	Water	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.2 in	15-525 psi	Water	UV

AABK dba Total Valve Systems (LTV)

Nameplate Abbreviation: Total Valve Systems

Rock Springs, WY 82901 United States

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S	NBCert # 57057
---------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/07/2030

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV

8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam) NBCert # 57260

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/07/2030

Design Type

[Safety Relief Valve] 2600L (Air & Steam)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV

4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids) NBCert # 57068

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/18/2030

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V

12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V
--------	--------	-----------------------	----------	--------	------------	-------	-------

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/07/2030
Design Type		

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/18/2030

Design Type

[Relief Valve] 2700L, 3700L (Liquids)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.676 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800

NBCert # 57024

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

08/07/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3800

Capacity Tests: Sec. UV at unknown lab on May 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.859 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (3): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV

2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name: 4200 / 4400

NBCert # 57282

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	08/07/2030

Design Type

[Safety Valve] 4200 / 4400
Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.872 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V

6 NPS	8 NPS	11.389 in²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V
-------	-------	------------	--------------	----------	-------------	-------	-------

Aalberts Integrated Piping Systems Americas, Inc. (CNB)

Nameplate Abbreviation: Aalberts IPSA, Inc.

Pageland, SC 29728United States

This Company Manufactures or Assembles:

Design Name: 10-102/104 (RVW10)		NBCert # 11002	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	07/24/2029
Design Type			
[Safety Relief Valve] 10-102/104 (RVW10) Capacity Tests: Sec. HV at Ohio State University (Robinson Laboratory) on February 28, 1970 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:14.850 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.442 in²	0.75 in	0.3 in	20-60 psi	Steam	HV

Design Name: 10-301/303 (RVW30)		NBCert # 11024	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	05/07/2030
Design Type			
[Safety Relief Valve] 10-301/303 (RVW30) Capacity Tests: Sec. HV at Ohio State University (Robinson Laboratory) on October 12, 1962 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:11.500 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.442 in²	0.75 in	0.19 in	20-60 psi	Steam	HV

Design Name: 10-321 (RVW32)		NBCert # 11035	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	03/24/2027

Design Type

[Safety Relief Valve] 10-321 (RVW32)
Capacity Tests: Sec. HV at Ohio State University (Robinson Laboratory) on May 8, 1975
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 8.900 PPH/PSIA
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-0.75 NPS	.75 NPS	0.442 in ²	0.75 in	0.14 in	20-60 psi	Steam	HV

Design Name:	10-322 (RVS32)	NBCert #	11046
--------------	----------------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

12/13/2028

Design Type

[Safety Relief Valve] 10-322 (RVS32)
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on May 8, 1975
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 9.000 PPH/PSIA
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.442 in ²	0.75 in	0.14 in	20-60 psi	Steam	UV

Design Name:	10-407 & 10-408 (30 psig)	NBCert #	11057
--------------	---------------------------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

HV

11/17/2030

Design Type

[Safety Relief Valve] 10-407 & 10-408 (30 psig)
Capacity Tests: Sec. HV at National Board Testing Lab (Picaway) on September 28, 1983
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value: 535.00 PPH
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.307 in ²	0.625 in	0.26 in	30-30 psi	Steam	HV

Design Name:	10-417/418 (RVW40)	NBCert #	11451
--------------	--------------------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

HV

09/27/2026

Design Type

[Safety Relief Valve] 10-417/418 (RVW40)
Capacity Tests: Sec. HV at National Board Testing Lab on March 2, 1999
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.000 PPH/PSIA
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.306 in ²	0.624 in	0.156 in	20-80 psi	Steam	HV

Design Name: 10-512 (RVS52) NBCert # 11080

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

11/04/2029

Design Type

[Safety Relief Valve] 10-512 (RVS52)
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on March 23, 1981
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 4.867 PPH/PSIA
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.5 NPS	0.15 in ²	0.437 in	0.1 in	15-60 psi	Steam	UV

Design Name: 10-600 (RVW60) NBCert # 11091

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

HV

11/03/2030

Design Type

[Safety Relief Valve] 10-600 (RVW60)
Capacity Tests: Sec. HV at unknown lab on June 18, 1987
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.630 Unitless
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.535 in ²	0.825 in	0.336 in	15-160 psi	Steam	HV
1.25 NPS	1.25 NPS	1.498 in ²	1.381 in	0.554 in	15-160 psi	Steam	HV
1.5 NPS	1.5 NPS	2.038 in ²	1.611 in	0.659 in	15-160 psi	Steam	HV
2 NPS	2 NPS	3.359 in ²	2.068 in	0.89 in	15-160 psi	Steam	HV

Design Name:	10-610 (RVW61)	NBCert #	11103
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	08/13/2030

Design Type

[Safety Relief Valve] 10-610 (RVW61)
Capacity Tests: Sec. HV at National Board Testing Lab (Picaway) on June 3, 1987
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.739 Unitless
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.535 in ²	0.825 in	0.336 in	15-160 psi	Steam	HV
1 NPS	1.25 NPS	0.866 in ²	1.05 in	0.429 in	15-160 psi	Steam	HV
1.25 NPS	1.5 NPS	1.498 in ²	1.381 in	0.554 in	15-160 psi	Steam	HV
1.5 NPS	2 NPS	2.038 in ²	1.611 in	0.659 in	15-160 psi	Steam	HV
2 NPS	2.5 NPS	3.359 in ²	2.068 in	0.89 in	15-160 psi	Steam	HV

Design Name:	119 Series	NBCert #	11361
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	09/29/2030

Design Type

[Safety Valve] 119 Series
Capacity Tests: Sec. UV, V at National Board Testing Lab on March 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Air	UV
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Steam	UV
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Steam	UV
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Steam	NV
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Steam	UV

3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Steam	V
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Air	UV
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Steam	UV
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Steam	V
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Air	UV
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Steam	UV
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Steam	V
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Air	UV
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Steam	UV
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Steam	V

Design Name:	12-205 (RVS12)	NBCert #	11114
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer HV 11/16/2026

Design Type

[Safety Valve] 12-205 (RVS12)
Capacity Tests: Sec. HV at unknown lab on April 26, 1964
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:2500.0 PPH; Certification Provisions: (HV) Low Pressure Steam
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	2.761 in ²	1.875 in	0.64 in	15-15 psi	Steam	HV

Design Name:	12-208 (RVS12)	NBCert #	11136
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer HV 11/16/2026

Design Type

[Safety Valve] 12-208 (RVS12)
Capacity Tests: Sec. HV at unknown lab on September 5, 1979
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:4100.0 PPH; Certification Provisions: (HV) Low Pressure Steam
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS	3 NPS	6.56 in ²	2.89 in	0.42 in	15-15 psi	Steam	HV

Design Name: 13-101 (RVS13T)		NBCert # 11147
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	11/17/2026
Design Type		
[Safety Valve] 13-101 (RVS13T) Capacity Tests: Sec. HV at unknown lab on August 27, 1961 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:410.00 PPH; Certification Provisions: (HV) Low Pressure Steam Media - Test: Steam; Certified: Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.442 in ²	0.75 in	0.21 in	15-15 psi	Steam	HV

Design Name: 13-202 (RVS13)		NBCert # 11169
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	03/24/2027
Design Type		
[Safety Valve] 13-202 (RVS13) Capacity Tests: Sec. HV at unknown lab on June 19, 1962 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:643.00 PPH; Certification Provisions: (HV) Low Pressure Steam Media - Test: Steam; Certified: Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1 NPS	0.442 in ²	0.75 in	0.37 in	15-15 psi	Steam	HV

Design Name: 13-211 (RVS13)		NBCert # 11170
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	06/21/2026
Design Type		
[Safety Valve] 13-211 (RVS13) Capacity Tests: Sec. HV at unknown lab on June 13, 1984 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:475.00 PPH; Certification Provisions: (HV) Low Pressure Steam Media - Test: Steam; Certified: Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	0.75 NPS	0.442 in ²	0.75 in	0.244 in	15-0 psi	Steam	HV

Design Name: 13-213 (RVS13)		NBCert # 11181
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	11/17/2030
Design Type		
[Safety Valve] 13-213 (RVS13) Capacity Tests: Sec. HV at unknown lab on May 13, 1973 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:1200.0 PPH; Certification Provisions: (HV) Low Pressure Steam Media - Test: Steam; Certified: Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.785 in ²	1 in	0.57 in	15-15 psi	Steam	HV

Design Name: 13-214 (RVS13)		NBCert # 11192
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	11/17/2030
Design Type		
[Safety Valve] 13-214 (RVS13) Capacity Tests: Sec. HV at unknown lab on May 13, 1973 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:1900.0 PPH; Certification Provisions: (HV) Low Pressure Steam Media - Test: Steam; Certified: Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.227 in ²	1.25 in	0.79 in	15-15 psi	Steam	HV

Design Name: 13-511/512 (RVS13L)		NBCert # 11350
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	04/16/2029
Design Type		
[Safety Valve] 13-511/512 (RVS13L) Capacity Tests: Sec. HV at unknown lab on October 2, 1990 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:407.00 PPH; Certification Provisions: (HV) Low Pressure Steam Media - Test: Steam; Certified: Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.272 in ²	0.588 in	0.147 in	15-15 psi	Steam	HV

Design Name:	14-205 (RVS14)	NBCert #	11215
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	11/16/2026

Design Type

[Safety Valve] 14-205 (RVS14)
Capacity Tests: Sec. HV at unknown lab on January 29, 1965
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:3150.0 PPH; Certification Provisions: (HV) Low Pressure Steam
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	2.238 in ²	1.688 in	0.83 in	15-15 psi	Steam	HV

Design Name:	14-206 (RVS14)	NBCert #	11226
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	04/16/2029

Design Type

[Safety Valve] 14-206 (RVS14)
Capacity Tests: Sec. HV at unknown lab on January 2, 1965
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:4676.0 PPH; Certification Provisions: (HV) Low Pressure Steam
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2.5 NPS	2.5 NPS	3.339 in ²	2.062 in	0.52 in	15-15 psi	Steam	HV

Design Name:	14-207 (RVS14)	NBCert #	11237
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	02/09/2026

Design Type

[Safety Valve] 14-207 (RVS14)
Capacity Tests: Sec. HV at unknown lab on January 29, 1965
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:6843.0 PPH; Certification Provisions: (HV) Low Pressure Steam
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3-3 NPS	3 NPS	5.155 in ²	2.562 in	0.64 in	15-15 psi	Steam	HV

Design Name: 15-112 (RVA15)		NBCert #	11248
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	07/31/2030
Design Type			
[Safety Relief Valve] 15-112 (RVA15) Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on April 17, 1975 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.738 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS			0.265 in		15-250 psi	Air	UV

Design Name: 15-115/117 (RVA15)		NBCert #	11259
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	03/16/2028
Design Type			
[Safety Relief Valve] 15-115/117 (RVA15) Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on September 6, 1979 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.849 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-0.5 NPS		0.145 in ²	0.43 in		15-250 psi	Air	UV

Design Name: 15-118 (RVA15)		NBCert #	11372
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	08/28/2025
Design Type			
[Safety Relief Valve] 15-118 (RVA15) Capacity Tests: Sec. UV at National Board Testing Lab on November 5, 1997 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.280 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.219 in ²	0.528 in	0.132 in	15-250 psi	Air	UV

Design Name: 15-119 (RVA15)			NBCert # 11383				
Manufacturer/Assembler		Designators		Expiration Date			
Manufacturer		UV		10/23/2025			
Design Type							
[Safety Relief Valve] 15-119 (RVA15) Capacity Tests: Sec. UV at National Board Testing Lab on November 5, 1997 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 6.780 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.458 in²	0.764 in	0.191 in	15-250 psi	Air	UV

Design Name: 17-402 (RVW17)			NBCert # 11440				
Manufacturer/Assembler		Designators		Expiration Date			
Manufacturer		HV		03/06/2027			
Design Type							
[Safety Relief Valve] 17-402 (RVW17) Capacity Tests: Sec. HV at National Board Testing Lab on March 2, 1999 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.200 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	0.75 NPS	0.173 in²	0.47 in	0.117 in	75-150 psi	Steam	HV

Design Name: 19 Series			NBCert # 11282				
Manufacturer/Assembler		Designators		Expiration Date			
Manufacturer		UV, V		11/13/2029			
Design Type							
[Safety Valve] 19 Series Capacity Tests: Sec. UV, V at unknown lab on March 27, 1980 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.826 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.129 in²	[D] 0.406 in	0.101 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.129 in²	[D] 0.406 in	0.101 in	15-300 psi	Steam	UV, V

0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Air	UV
0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Steam	UV, V
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Air	UV
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Steam	UV, V
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Air	UV
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Steam	UV, V

Design Name: 29-102, 29-202, 29-302 NBCert # 11293

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	11/17/2030

Design Type

[Safety Valve] 29-102, 29-202, 29-302
Capacity Tests: Sec. UV, V at National Board Testing Lab (Picaway) on November 30, 1982
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.596 PPH/PSIA; (alternate medium): 1.280 SCFM/PSIA
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Curtain Area
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-0.75 NPS	1 NPS	0.196 in ²	0.5 in	0.058 in	30-205 psi	Air	UV
0.375-0.75 NPS	1 NPS	0.196 in ²	0.5 in	0.058 in	30-205 psi	Steam	V
0.375-0.75 NPS	1 NPS	0.196 in ²	0.5 in	0.058 in	30-205 psi	Steam	UV

Design Name: 29-303, 29-402, 29-501 NBCert # 11305

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	07/31/2030

Design Type

[Safety Valve] 29-303, 29-402, 29-501
Capacity Tests: Sec. UV, V at National Board Testing Lab (Picaway) on February 14, 1983
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 7.230 PPH/PSIA; (alternate medium): 2.570 SCFM/PSIA
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Curtain Area
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.25 NPS	1.25 NPS	0.203 in ²	0.737 in	0.08 in	30-210 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.203 in ²	0.737 in	0.08 in	30-210 psi	Steam	V
0.75-1.25 NPS	1.25 NPS	0.203 in ²	0.737 in	0.08 in	30-210 psi	Steam	UV

Design Name: 500 Series		NBCert #	11462
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	12/05/2027
Design Type			
[Safety Valve] 500 Series Capacity Tests: Sec. UV at National Board Testing Lab on June 12, 2000 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.861 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.129 in ²	[D] 0.406 in	0.102 in	15-2000 psi	Air	UV
0.5-0.75 NPS	.75, 1 NPS	0.129 in ²	[D] 0.406 in	0.102 in	15-2000 psi	Steam	UV
0.75-1 NPS	1.25 NPS	0.229 in ²	[E] 0.539 in	0.135 in	15-2000 psi	Air	UV
0.75-1 NPS	1.25 NPS	0.229 in ²	[E] 0.539 in	0.135 in	15-2000 psi	Steam	UV
1-1.25 NPS	1.5 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-2000 psi	Air	UV
1-1.25 NPS	1.5 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-2000 psi	Steam	UV
1.25-1.5 NPS	2 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-2000 psi	Air	UV
1.25-1.5 NPS	2 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-2000 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-2000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-2000 psi	Steam	UV
2 NPS	3 NPS	1.504 in ²	[J] 1.384 in	0.346 in	15-2000 psi	Air	UV
2 NPS	3 NPS	1.504 in ²	[J] 1.384 in	0.346 in	15-2000 psi	Steam	UV

Design Name: 500 Series (Liquids)		NBCert #	11473
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	07/31/2027
Design Type			
[Safety Relief Valve] 500 Series (Liquids) Capacity Tests: Sec. UV at National Board Testing Lab on February 25, 2000 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.689 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.129 in ²	[D] 0.406 in	0.102 in	15-1000 psi	Water	UV
0.75-1 NPS	1.25 NPS	0.229 in ²	[E] 0.539 in	0.135 in	15-1000 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-1000 psi	Water	UV
1.25-1.5 NPS	2 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-1000 psi	Water	UV

1.5-2 NPS	2.5 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-1000 psi	Water	UV
2 NPS	3 NPS	1.504 in ²	[J] 1.384 in	0.346 in	15-1000 psi	Water	UV

Admiral Valve Repair and Supply Company, Inc. (ASR)

Nameplate Abbreviation: ADMIRAL VALVE

North Chicago, IL 60064United States

This Company Manufactures or Assembles:

Design Name:	Kunkle 264, 265, 266 & 267	NBCert #	36267
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/16/2027

Design Type

[Safety Relief Valve] Kunkle 264, 265, 266 & 267
Capacity Tests: Sec. UV at unknown lab on July 20, 1956
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.766 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.115 in	15-2000 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.115 in	15-3300 psi	Air	UV

Design Name:	Kunkle 300,600	NBCert #	36076
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	05/06/2027

Design Type

[Safety Valve] Kunkle 300,600
Capacity Tests: Sec. UV, V at unknown lab on February 10, 1961
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	UV
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	UV

1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	V
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	V
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Air	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	V
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Air	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	V
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Air	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	V
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	V
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Air	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	UV

Design Name: Kunkle 337

NBCert # 36278

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/22/2027

Design Type

[Safety Relief Valve] Kunkle 337
Capacity Tests: Sec. UV at unknown lab on February 22, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	1.916 in ²	1.562 in	0.612 in	15-60 psi	Air	UV
2.5 NPS	2.5 NPS	2.786 in ²	1.883 in	0.755 in	15-60 psi	Air	UV
3 NPS	3 NPS	4.037 in ²	2.267 in	0.91 in	15-60 psi	Air	UV

Design Name:	Kunkle 6000, 6252 Series	NBCert #	36324
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV, V	02/24/2027
-----------	-------	------------

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V

4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 910 to 919

NBCert #

36100

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/10/2027

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name: Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)

NBCert #

36111

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/22/2027

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 , 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

Design Name:	Kunkle 920, 921, 927, Agco A (High Temp. water)	NBCert #	36098
Manufacturer/Assembler		Designators	Expiration Date
Assembler		V	02/24/2027

Design Type

[Safety Valve] Kunkle 920, 921, 927, Agco A (High Temp. water)
Capacity Tests: Sec. V at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Forced Flow Steam Generator/High Temp Hot Water (10% BD)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	V

ADVANCE VALVE, INC. (ADV)

Fenton, MO 63026United States

This Company Manufactures or Assembles:

Design Name:	437	NBCert #	37213
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/06/2030

Design Type

[Safety Relief Valve] 437
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on November 8, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.020 SCFM/PSIA; (alternate medium): 2.870 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Air	UV
0.375-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Steam	UV

Design Name:	438 Sub Types 481, 439	NBCert #	37190
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/17/2030

Design Type

[Safety Relief Valve] 438 Sub Types 481, 439
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on November 12, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.904 SCFM/PSIA; (alternate medium): 2.530 PPH/PSIA
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1 NPS	0.5 - 1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Air	UV
0.375-1 NPS	0.5 - 1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Steam	UV

Design Name:	438 Sub Types 481, 439, Liquids	NBCert #	37202
--------------	---------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/11/2030

Design Type

[Safety Relief Valve] 438 Sub Types 481, 439, Liquids
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on November 23, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.490 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.064 in²	0.394 in	0.043 in	15-2610 psi	Water	UV
Design Name: 441/442/444NBCert # 37044							
Manufacturer/Assembler			Designators			Expiration Date	
Assembler			UV			05/26/2026	
Design Type							
[Safety Relief Valve] 441/442/444 Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on February 17, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.699 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5,2 NPS	0.644 in²	0.906 in	0.277 in	15-715 psi	Air	UV
1 NPS	1.5,2 NPS	0.644 in²	0.906 in	0.277 in	15-715 psi	Steam	UV
1.25-1.5 NPS	2 NPS	1.024 in²	1.142 in	0.349 in	15-715 psi	Air	UV
1.25-1.5 NPS	2 NPS	1.024 in²	1.142 in	0.349 in	15-715 psi	Steam	UV
1.5 NPS	2.5,3 NPS	1.667 in²	1.457 in	0.446 in	15-715 psi	Air	UV
1.5 NPS	2.5,3 NPS	1.667 in²	1.457 in	0.446 in	15-715 psi	Steam	UV
2 NPS	3 NPS	2.576 in²	1.811 in	0.554 in	15-715 psi	Air	UV
2 NPS	3 NPS	2.576 in²	1.811 in	0.554 in	15-715 psi	Steam	UV
2.5-3 NPS	4 NPS	4.383 in²	2.362 in	0.723 in	15-500 psi	Air	UV
2.5-3 NPS	4 NPS	4.383 in²	2.362 in	0.723 in	15-500 psi	Steam	UV
3 NPS	5 NPS	6.666 in²	2.913 in	0.891 in	15-500 psi	Air	UV
3 NPS	5 NPS	6.666 in²	2.913 in	0.891 in	15-500 psi	Steam	UV
4 NPS	6 NPS	10.304 in²	3.622 in	1.108 in	15-418 psi	Air	UV
4 NPS	6 NPS	10.304 in²	3.622 in	1.108 in	15-418 psi	Steam	UV
5 NPS	8 NPS	11.692 in²	3.858 in	1.181 in	15-315 psi	Air	UV
5 NPS	8 NPS	11.692 in²	3.858 in	1.181 in	15-315 psi	Steam	UV
6 NPS	10 NPS	19.021 in²	4.921 in	1.506 in	15-290 psi	Air	UV
6 NPS	10 NPS	19.021 in²	4.921 in	1.506 in	15-290 psi	Steam	UV
8 NPS	12 NPS	33.143 in²	6.496 in	1.988 in	15-430 psi	Air	UV
8 NPS	12 NPS	33.143 in²	6.496 in	1.988 in	15-430 psi	Steam	UV
10 NPS	14 NPS	48.695 in²	7.874 in	2.409 in	15-300 psi	Air	UV
10 NPS	14 NPS	48.695 in²	7.874 in	2.409 in	15-300 psi	Steam	UV
12 NPS	16 NPS	67.229 in²	9.252 in	2.831 in	15-310 psi	Air	UV
12 NPS	16 NPS	67.229 in²	9.252 in	2.831 in	15-310 psi	Steam	UV
16 NPS	20 NPS	105.94 in²	11.614 in	3.554 in	15-175 psi	Air	UV
16 NPS	20 NPS	105.94 in²	11.614 in	3.554 in	15-175 psi	Steam	UV

Design Name:	441/442/444 liquids	NBCert #	37055
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/02/2027

Design Type

[Relief Valve] 441/442/444 liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on September 6, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.521 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Water	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Water	UV
1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Water	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Water	UV
2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Water	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Water	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Water	UV
5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Water	UV
6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Water	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Water	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Water	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Water	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Water	UV

Design Name:	459/462	NBCert #	37112
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/08/2026

Design Type

[Safety Relief Valve] 459/462
Capacity Tests: Sec. UV at National Board Testing Lab on February 17, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.811 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Air	UV
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-2900 psi	Steam	UV

0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Air	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Steam	UV

Design Name:	459/462 liquids	NBCert #	37101
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 12/08/2026

Design Type

[Relief Valve] 459/462 liquids
Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.566 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Water	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Water	UV
0.5-1.5 NPS	1-2.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Water	UV
1-2 NPS	1.5-2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Water	UV

Design Name:	483, 484, 485 (0.512 orifice)	NBCert #	37145
--------------	-------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/06/2030

Design Type

[Safety Relief Valve] 483, 484, 485 (0.512 orifice)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on January 4, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.960 SCFM/PSIA; (alternate medium): 5.500 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	1.5 NPS	0.127 in ²	0.512 in	0.079 in	15-232 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.127 in ²	0.512 in	0.079 in	15-232 psi	Steam	UV

Design Name:	483, 484, 485 (0.512 orifice) Liquids	NBCert #	37156
--------------	---------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/06/2030

Design Type

[Relief Valve] 483, 484, 485 (0.512 orifice) Liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on January 8, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.960 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	1.5 NPS	0.157 in ²	0.512 in	0.098 in	15-232 psi	Water	UV

Design Name: 483, 484, 485 (0.984 orifice) NBCert # 37167

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 06/06/2030

Design Type

[Safety Relief Valve] 483, 484, 485 (0.984 orifice)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on February 1, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 4.960 SCFM/PSIA; (alternate medium): 13.930 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2 NPS	0.427 in ²	0.984 in	0.139 in	15-232 psi	Air	UV
1.5-2 NPS	2 NPS	0.427 in ²	0.984 in	0.139 in	15-232 psi	Steam	UV

Design Name: 483, 484, 485 (0.984 orifice) Liquids NBCert # 37178

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 06/15/2030

Design Type

[Relief Valve] 483, 484, 485 (0.984 orifice) Liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on May 1, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 7.460 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2 NPS	0.485 in ²	0.984 in	0.157 in	15-232 psi	Water	UV

Design Name: 488 NBCert # 37022

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 02/20/2027

Design Type

[Safety Relief Valve] 488
 Capacity Tests: Sec. UV at National Board Testing Lab on May 31, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.721 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5 NPS	0.644 in ²	0.906 in	0.256 in	20-232 psi	Air	UV
1 NPS	1.5 NPS	0.644 in ²	0.906 in	0.256 in	20-232 psi	Steam	UV
1.5 NPS	2.5 NPS	1.667 in ²	1.457 in	0.416 in	20-232 psi	Air	UV
1.5 NPS	2.5 NPS	1.667 in ²	1.457 in	0.416 in	20-232 psi	Steam	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.512 in	20-232 psi	Air	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.512 in	20-232 psi	Steam	UV
2.5 NPS	4 NPS	4.383 in ²	2.362 in	0.674 in	20-232 psi	Air	UV
2.5 NPS	4 NPS	4.383 in ²	2.362 in	0.674 in	20-232 psi	Steam	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.832 in	20-232 psi	Air	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.832 in	20-232 psi	Steam	UV
4 NPS	6 NPS	10.3 in ²	3.622 in	1.035 in	20-232 psi	Air	UV
4 NPS	6 NPS	10.3 in ²	3.622 in	1.035 in	20-232 psi	Steam	UV

Design Name: 488 (Liquids) NBCert # 37033

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/20/2027

Design Type

[Relief Valve] 488 (Liquids)
 Capacity Tests: Sec. UV at National Board Testing Lab on June 1, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.472 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5 NPS	0.644 in ²	0.906 in	0.216 in	15-232 psi	Water	UV
1.5 NPS	2.5 NPS	1.667 in ²	1.457 in	0.347 in	15-232 psi	Water	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.431 in	15-232 psi	Water	UV
2.5 NPS	4 NPS	4.383 in ²	2.362 in	0.562 in	15-232 psi	Water	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.693 in	15-232 psi	Water	UV
4 NPS	6 NPS	10.3 in ²	3.622 in	0.862 in	15-232 psi	Water	UV

Design Name: 526	NBCert # 37224
------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/06/2030

Design Type

[Safety Relief Valve] 526
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 22, 2001
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Air	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-2900 psi	Steam	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Air	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-2900 psi	Steam	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Steam	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Air	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Steam	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Air	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Steam	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Air	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Steam	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Air	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Steam	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Air	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Steam	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Air	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Steam	UV

Design Name:	526 (Liquids)	NBCert #	37235
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/06/2030

Design Type

[Relief Valve] 526 (Liquids)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on January 2, 2002
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.579 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Water	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Water	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Water	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Water	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Water	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Water	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.6698 in	15-1850 psi	Water	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Water	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Water	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Water	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.249 in	15-1038.5 psi	Water	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Water	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-914 psi	Water	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Water	UV

Design Name:	560, 570	NBCert #	02080
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	01/24/2026

Design Type

[Safety Valve] 560, 570
Capacity Tests: Sec. UV, V at National Board Testing Lab on November 10, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.856 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aquatrol, Incorporated {AQT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-300 psi	Steam	UV, V

0.75-1 NPS	1 NPS	0.221 in ²	[E] 0.53 in	0.132 in	15-300 psi	Air	UV
0.75-1 NPS	1 NPS	0.221 in ²	[E] 0.53 in	0.132 in	15-300 psi	Steam	UV, V
1-1.25 NPS	1.25 NPS	0.352 in ²	[F] 0.67 in	0.167 in	15-300 psi	Air	UV
1-1.25 NPS	1.25 NPS	0.352 in ²	[F] 0.67 in	0.167 in	15-300 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.567 in ²	[G] 0.85 in	0.212 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.567 in ²	[G] 0.85 in	0.212 in	15-300 psi	Steam	UV, V
1.5-2 NPS	2 NPS	0.899 in ²	[H] 1.07 in	0.267 in	15-300 psi	Air	UV
1.5-2 NPS	2 NPS	0.899 in ²	[H] 1.07 in	0.267 in	15-300 psi	Steam	UV, V
2-2.5 NPS	2.5 NPS	1.463 in ²	[J] 1.365 in	0.41 in	15-300 psi	Air	UV
2-2.5 NPS	2.5 NPS	1.463 in ²	[J] 1.365 in	0.41 in	15-300 psi	Steam	UV, V

Design Name: Kunkle 6000, 6252 Series NBCert # 36324

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	05/27/2026

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV

2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 910 to 919

NBCert #

36100

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

05/29/2026

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV

1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name:	Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)	NBCert #	36111
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 05/29/2026

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 , 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

Design Name:	Series 740	NBCert #	02091
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/24/2026

Design Type

[Safety Relief Valve] Series 740
Capacity Tests: Sec. UV at National Board Testing Lab on November 21, 2012
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aquatrol, Incorporated {AQT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75, 1 NPS	0.125 in ²	[D] 0.4 in	0.105 in	15-1500 psi	Air	UV
0.5-1 NPS	0.75, 1 NPS	0.125 in ²	[D] 0.4 in	0.105 in	15-300 psi	Steam	UV
0.5-1.25 NPS	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-1500 psi	Air	UV
0.5-1.25 NPS	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-300 psi	Steam	UV
0.75-1.5 in	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-1500 psi	Air	UV
0.75-1.5 in	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-300 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.353 in ²	[F] 0.67 in	0.17 in	15-300 psi	Steam	UV

1-1.5 NPS	1.5 NPS	0.353 in ²	[F] 0.67 in	0.17 in	15-750 psi	Air	UV
1-2 in	1.5 NPS	0.353 in ²	[F] 0.67 in	0.017 in	15-750 psi	Air	UV
1-2 in	1.5 NPS	0.353 in ²	[F] 0.67 in	0.017 in	15-300 psi	Steam	UV
1.25-2 NPS	2 NPS	0.554 in ²	[G] 0.84 in	0.215 in	15-300 psi	Steam	UV
1.25-2 NPS	2 NPS	0.554 in ²	[G] 0.84 in	0.215 in	15-700 psi	Air	UV
1.5-2.5 NPS	2, 2.5 NPS	0.923 in ²	[H] 1.084 in	0.28 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2, 2.5 NPS	0.923 in ²	[H] 1.084 in	0.28 in	15-600 psi	Air	UV
2-3 NPS	3 NPS	1.418 in ²	[J] 1.344 in	0.34 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	1.418 in ²	[J] 1.344 in	0.34 in	15-600 psi	Air	UV

Design Name:	Series 740 (Liquid)	NBCert #	02103
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/24/2026

Design Type

[Safety Relief Valve] Series 740 (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on November 20, 2012
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.791 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aquatrol, Incorporated {AQT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75, 1 NPS	0.125 in ²	[D] 0.4 in	0.105 in	15-1500 psi	Water	UV
0.75-1.25 NPS	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-1500 psi	Water	UV
0.75-1.5 in	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-1500 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.353 in ²	[F] 0.67 in	0.17 in	15-750 psi	Water	UV
1-2 in	1.5 NPS	0.353 in ²	[F] 0.67 in	0.017 in	15-750 psi	Water	UV
1.25-2 NPS	2 NPS	0.554 in ²	[G] 0.84 in	0.215 in	15-700 psi	Water	UV
1.5-2.5 NPS	2, 2.5 NPS	0.923 in ²	[H] 1.084 in	0.28 in	15-600 psi	Water	UV
2-3 NPS	3 NPS	1.418 in ²	[J] 1.344 in	0.34 in	15-600 psi	Water	UV

Albert Handtmann Armaturenfabrik GmbH & Co. KG (AHA)

Biberach/Riss, 88400Germany

This Company Manufactures or Assembles:

Design Name:	33551 and 33651	NBCert #	00639
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/06/2028

Design Type

[Safety Relief Valve] 33551 and 33651
Capacity Tests: Sec. UV at National Board Testing Lab on October 2, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.640 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Albert Handtmann Armaturenfabrik GmbH & Co. KG {AHA}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5 NPS	0.5369 in ²	0.8268 in	0.2323 in	15-145 psi	Air	UV
2 NPS	3 NPS	1.3662 in ²	1.3189 in	0.3543 in	15-145 psi	Air	UV
2.5 NPS	3.5 NPS	2.5759 in ²	1.811 in	0.5039 in	15-145 psi	Air	UV
3 NPS	4 NPS	4.2377 in ²	2.3228 in	0.5827 in	15-145 psi	Air	UV
3.5 NPS	5 NPS	6.1367 in ²	2.7953 in	0.7559 in	15-145 psi	Air	UV

Design Name: 33551 and 33651 (Liquid) NBCert # 00640

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

01/06/2028

Design Type

[Safety Relief Valve] 33551 and 33651 (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on March 31, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.436 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Albert Handtmann Armaturenfabrik GmbH & Co. KG {AHA}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5 NPS		0.8268 in	0.2323 in	15-145 psi	Water	UV
2 NPS	3 NPS		1.3189 in	0.3543 in	15-145 psi	Water	UV
2.5 NPS	3.5 NPS		1.811 in	0.5039 in	15-145 psi	Water	UV
3 NPS	4 NPS		2.3228 in	0.5827 in	15-145 psi	Water	UV
3.5 NPS	5 NPS		2.7953 in	0.7559 in	15-145 psi	Water	UV

Allied Valve, Inc. (ALV)Nameplate Abbreviation: Allied Valve
Inc

Joliet, IL 60436United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3 NBCert # 18032

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV, V

04/11/2029

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1811, 1511

NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/12/2029

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA
(Liquids)

NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	02/15/2029

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V

1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

04/12/2029

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV

3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201) NBCert # 18223

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/12/2029

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV

1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name: 19000 Series		NBCert #	18706
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	04/12/2029
Design Type			

[Safety Relief Valve] 19000 Series
 Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

02/15/2029

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/12/2029

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/15/2029

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name:	1900-DM	NBCert #	19066
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/15/2029

Design Type

[Safety Relief Valve] 1900-DM
Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV

1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D

NBCert # 19088

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/15/2029

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name:	1900-DM-E	NBCert #	19099
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/15/2029

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/12/2029

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name:	1900E-2, 1900-30E-2 LA & DALA (Liquids)	NBCert #	18762
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/15/2029

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids) NBCert # 19077

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 02/15/2029

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: Kunkle 264, 265, 266 & 267 NBCert # 36267

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 04/12/2029

Design Type

[Safety Relief Valve] Kunkle 264, 265, 266 & 267
Capacity Tests: Sec. UV at unknown lab on July 20, 1956
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.766 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.115 in	15-2000 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.115 in	15-3300 psi	Air	UV

Design Name: Kunkle 30		NBCert # 36335
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/15/2029
Design Type		
[Safety Relief Valve] Kunkle 30 Capacity Tests: Sec. UV at unknown lab on December 18, 1989 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.186 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS			0.157 in	0.1 in	60-4000 psi	Air	UV

Design Name: Kunkle 300,600		NBCert # 36076
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/12/2029
Design Type		
[Safety Valve] Kunkle 300,600 Capacity Tests: Sec. UV, V at unknown lab on February 10, 1961 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	UV
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	V
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	V
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Air	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	V
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	UV

2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Air	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	V
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Air	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	V
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	V
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Air	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	UV

Design Name: Kunkle 337

NBCert #

36278

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

02/15/2029

Design Type

[Safety Relief Valve] Kunkle 337
Capacity Tests: Sec. UV at unknown lab on February 22, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	1.916 in ²	1.562 in	0.612 in	15-60 psi	Air	UV
2.5 NPS	2.5 NPS	2.786 in ²	1.883 in	0.755 in	15-60 psi	Air	UV
3 NPS	3 NPS	4.037 in ²	2.267 in	0.91 in	15-60 psi	Air	UV

Design Name: Kunkle 541-C/542-C/548-C (.422 Orifice)

NBCert #

36302

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

02/15/2029

Design Type

[Safety Relief Valve] Kunkle 541-C/542-C/548-C (.422 Orifice)
Capacity Tests: Sec. UV at unknown lab on May 20, 1988
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.000 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	Side NPS	0.14 in²	0.422 in	0.2 in	15-400 psi	Air	UV
Design Name: Kunkle 6000, 6252 Series							
				NBCert #	36324		
Manufacturer/Assembler			Designators			Expiration Date	
Assembler			UV, V			04/12/2029	
Design Type							
[Safety Valve] Kunkle 6000, 6252 Series Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2.5, 3 NPS	1.414 in²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V

3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 910 to 919

NBCert #

36100

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

04/12/2029

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name: Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)		NBCert #	36111
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	02/15/2029
Design Type			
[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid) Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.710 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 , 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

Allied Valve, Inc. (AVB)

Bismarck, ND 58501United States

This Company Manufactures or Assembles:

Design Name: 1811, 1511		NBCert #	18122
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV, V	06/24/2026
Design Type			
[Safety Valve] 1811, 1511 Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.877 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV

1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	06/23/2026

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V

8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

06/23/2026

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV

6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/23/2026

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/23/2026

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Allied Valve, Inc. (TPW)

Appleton, WI 54913United States

This Company Manufactures or Assembles:

Design Name:	1700 & 2700	NBCert #	18100
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 09/01/2027

Design Type

[Safety Valve] 1700 & 2700
Capacity Tests: Sec. UV, V at Dresser, Inc. on August 1, 1957
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	15-3000 psi	Steam	UV

1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	50-5800 psi	Steam	V
4 NPS	4 dual NPS	1.84 in ²	[K] 1.531 in	0.383 in	50-5800 psi	Steam	V
2-3 NPS	4, 6 NPS	2.545 in ²	[#3] 1.8 in	0.45 in	50-5800 psi	Steam	UV, V
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-2575 psi	Steam	UV
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	50-5800 psi	Steam	V
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	15-3100 psi	Steam	UV
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	50-5800 psi	Steam	V
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	15-3100 psi	Steam	UV
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	15-1800 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	1.24 in	50-2200 psi	Steam	UV, V
8-10 NPS	10,12 NPS	28.3 in ²	[T] 6 in	1.5 in	50-1500 psi	Steam	UV, V

Design Name: 1700 & 2700 (Restricted Lift version of Cert. # 18100) NBCert # 18111

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 09/01/2027

Design Type

[Safety Valve] 1700 & 2700 (Restricted Lift version of Cert. # 18100)
Capacity Tests: Sec. UV, V at unknown lab on October 13, 1981
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	50-5800 psi	Steam	V

1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	50-5800 psi	Steam	V
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	15-3100 psi	Steam	UV
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	50-5800 psi	Steam	V
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-2575 psi	Steam	UV
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	50-5800 psi	Steam	V
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	15-3100 psi	Steam	UV
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	50-5800 psi	Steam	V
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	15-3100 psi	Steam	UV
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.946 in	0.296 in	15-2000 psi	Steam	UV, V
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	0.372 in	50-2200 psi	Steam	V
8-10 NPS	10, 12 NPS	28.3 in ²	[T] 6 in	0.45 in	50-1500 psi	Steam	UV, V

Design Name: 1811, 1511

NBCert #

18122

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	09/01/2027

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV

2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA (Liquids) NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 11/11/2030

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V

12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V
-----------	--------	------------------------	---------------	----------	------------	-------	-----------

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	11/01/2030
-----------	----	------------

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV

8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/20/2030

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/20/2030

Design Type

[Relief Valve] 19000 Series, Liquid
 Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.673 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1982

NBCert # 18379

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/10/2027

Design Type

[Safety Relief Valve] 1982
 Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at unknown lab on May 6, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Air	NV, UV
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Steam	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Air	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Steam	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Air	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Steam	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Air	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Air	NV, UV

Design Name:	1982 LS, 820000LS	NBCert #	18380
--------------	-------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/20/2030

Design Type

[Relief Valve] 1982 LS, 820000LS
Capacity Tests: Sec. UV at Dresser, Inc. on December 19, 1984
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.758 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	NV
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	UV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	NV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	NV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	UV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	NV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	NV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	UV

Design Name:	3900 (39PV, 39MV pilots)	NBCert #	18447
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/01/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV

1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV

6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid) NBCert # 18458

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/01/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV

2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Design Name: 3900-TM (39PV, 39MV pilots)

NBCert #

01438

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/20/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3900-TM (39PV, 39MV pilots)

Capacity Tests: Sec. UV at Dresser, Inc. on May 19, 1988

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless; (alternate medium): 0.743 Unitless; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV

1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV

6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Design Name: C776 NBCert # 36425

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/10/2027

Design Type

[Safety Relief Valve] C776
Capacity Tests: Sec. UV at Crosby Valve, LLC on July 15, 2002
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.790 Unitless
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Regulator Technologies - Fromex S.A. de C.V. {FCF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.169 in ²	0.465 in	0.116 in	15-600 psi	Air	UV
1 NPS	1.25 NPS	0.34 in ²	0.658 in	0.164 in	15-500 psi	Air	UV
0.75-1 NPS	1.25 NPS	0.486 in ²	0.787 in	0.197 in	15-600 psi	Air	UV
1.25 NPS	1.5 NPS	0.645 in ²	0.906 in	0.227 in	15-500 psi	Air	UV
1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.286 in	15-500 psi	Air	UV
2-2.5 NPS	2.5 NPS	1.667 in ²	1.457 in	0.364 in	15-500 psi	Air	UV

Design Name: Kunkle 6000, 6252 Series NBCert # 36324

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	12/15/2027

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
 Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV

6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name:	Kunkle 910 to 919	NBCert #	36100
--------------	-------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/01/2027

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name:	Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)	NBCert #	36111
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/01/2027

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 , 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

Allied Valve, Inc. (VRS)

Nameplate Abbreviation: ALLIED
VALVE, INC.

Riverdale, IA 52722United States

This Company Manufactures or Assembles:

Design Name: 1811, 1511		NBCert # 18122
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	06/23/2027
Design Type		
<div>[Safety Valve] 1811, 1511</div> <div>Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975</div> <div>Method of Establishing Relieving Capacity: Flow Capacity, K</div> <div>Certified Value: 0.877 Unitless</div> <div>Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam</div> <div>Set Pressure Definition: Pop</div> <div>Blowdown Characteristics: Adjustable</div> <div>Flow Area Configuration: Nozzle/Full Lift</div> <div>Designed by: Dresser, LLC. {DPT}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V

4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/23/2027

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/23/2027

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV

10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/23/2027

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Allied Valve, Inc. (VSS)

Cannon Falls, MN 55009United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3 NBCert # 18032

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 03/28/2030

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1700 & 2700

NBCert # 18100

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	06/29/2026

Design Type

[Safety Valve] 1700 & 2700
 Capacity Tests: Sec. UV, V at Dresser, Inc. on August 1, 1957
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	50-5800 psi	Steam	V
4 NPS	4 dual NPS	1.84 in ²	[K] 1.531 in	0.383 in	50-5800 psi	Steam	V
2-3 NPS	4, 6 NPS	2.545 in ²	[#3] 1.8 in	0.45 in	50-5800 psi	Steam	UV, V
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-2575 psi	Steam	UV
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	50-5800 psi	Steam	V
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	15-3100 psi	Steam	UV
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	50-5800 psi	Steam	V
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	15-3100 psi	Steam	UV
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	15-1800 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	1.24 in	50-2200 psi	Steam	UV, V
8-10 NPS	10,12 NPS	28.3 in ²	[T] 6 in	1.5 in	50-1500 psi	Steam	UV, V

Design Name: 1700 & 2700 (Restricted Lift version of Cert. # 18100) NBCert # 18111

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	06/24/2026

Design Type

[Safety Valve] 1700 & 2700 (Restricted Lift version of Cert. # 18100)
 Capacity Tests: Sec. UV, V at unknown lab on October 13, 1981
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Restricted Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	50-5800 psi	Steam	V
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	15-3100 psi	Steam	UV
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	50-5800 psi	Steam	V
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-2575 psi	Steam	UV
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	50-5800 psi	Steam	V
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	15-3100 psi	Steam	UV
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	50-5800 psi	Steam	V
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	15-3100 psi	Steam	UV
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.946 in	0.296 in	15-2000 psi	Steam	UV, V
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	0.372 in	50-2200 psi	Steam	V
8-10 NPS	10, 12 NPS	28.3 in ²	[T] 6 in	0.45 in	50-1500 psi	Steam	UV, V

Design Name: 1811, 1511

NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	03/28/2030

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA
(Liquids)

NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/28/2030

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V

1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

03/28/2030

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV

3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201) NBCert # 18223

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/21/2026

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV

1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	06/24/2026
-----------	----	------------

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

03/28/2030

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/28/2030

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/22/2026

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/28/2030

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV

1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV
-----------	---------	------------------------	--------------	----------	-------------	-----	--------

Design Name:	1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert #	18762
--------------	--	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	07/19/2026
-----------	----	------------

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name:	2900 (39PV & 39MV pilots) NBCert #	18863
--------------	------------------------------------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	06/24/2026
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV

3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots) NBCert # 18447

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/21/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV

1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV

8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Anderson Greenwood Crosby Sanmar Limited (TYC)

Pudukkottai District, Tamil Nadu, 621316India

This Company Manufactures or Assembles:

Design Name:	243/249/443/449/546/843/849/943/5046/5049/8043/8049	NBCert #	01292
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/12/2029

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049

Capacity Tests: Sec. UV at unknown lab on August 8, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV

8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name:	253/259/453/459/853/859/953/959/5059/8053/8059	NBCert #	01304
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	12/12/2029
--------------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
Capacity Tests: Sec. UV at unknown lab on July 31, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.627 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name:	263/269/463/469/566/863/869/963/969/5066/5069	NBCert #	01315
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	02/12/2029
--------------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069
Capacity Tests: Sec. UV at unknown lab on July 30, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV

2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/13/2029

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.767 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/11/2029

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids) NBCert # 01348

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/06/2027

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids)
 Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.712 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name:	900 Series (Liquid), 7700, SNC	NBCert #	15499
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/09/2029

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name:	900 Series, 7700, SNC	NBCert #	15411
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/13/2029

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: H Series (HCI, HSJ, HCA, HA, HB, HC, HCB, HCP, HJO, HN, HNA, HNB, HNP, HS, NBCert # 15006 HSA, HSB, HSC, HSP)

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	05/31/2031

Design Type

[Safety Valve] H Series (HCI, HSJ, HCA, HA, HB, HC, HCB, HCP, HJO, HN, HNA, HNB, HNP, HS, HSA, HSB, HSC, HSP)
 Capacity Tests: Sec. UV, V at unknown lab on September 1, 1939
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1.5 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-500 psi	Steam	UV, V
0.75 NPS	1.5 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-500 psi	Steam	UV, V
1-1.5 NPS	2 - 3 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-3100 psi	Steam	UV, V
1-2 NPS	2.5, 3 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-3100 psi	Steam	UV, V
1.5-2 NPS	3, 4, 6 NPS	0.785 in ²	[H] 1 in	0.25 in	15-5000 psi	Steam	UV, V
1.5 NPS	3 NPS	0.865 in ²	1.05 in	0.262 in	15-3100 psi	Steam	UV, V
1.5 NPS	3 NPS	0.994 in ²	[H2] 1.125 in	0.281 in	15-3100 psi	Steam	UV, V
2-3 NPS	3, 4, 6 NPS	1.288 in ²	[J] 1.281 in	0.32 in	15-5000 psi	Steam	UV, V

2 NPS	4 NPS	1.431 in ²	[J2] 1.35 in	0.338 in	15-3100 psi	Steam	UV, V
2.5-3 NPS	4, 6 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-6000 psi	Steam	UV, V
2.5 NPS	6 NPS	2.545 in ²	[K2] 1.8 in	0.45 in	15-6800 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.476 in	15-3100 psi	Steam	UV, V
3 NPS	6 NPS	3.341 in ²	[L2] 2.062 in	0.516 in	15-3100 psi	Steam	UV, V
3-4 NPS	6, 8 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-6000 psi	Steam	UV, V
3 NPS	6, 8 NPS	3.976 in ²	[M2] 2.25 in	0.563 in	15-6000 psi	Steam	UV, V
4 NPS	6 NPS	4.341 in ²	[N] 2.351 in	0.588 in	15-3100 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.712 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	7.07 in ²	[P2] 3 in	0.75 in	15-3100 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.937 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	12.25 in ²	[Q2] 3.95 in	0.988 in	15-3100 psi	Steam	UV, V
6 NPS	8, 10 NPS	16 in ²	[R] 4.513 in	1.128 in	15-3100 psi	Steam	UV, V
6 NPS	10 NPS	19.29 in ²	[RR] 4.956 in	1.239 in	15-3100 psi	Steam	UV, V
8 NPS	10, 12 NPS	26 in ²	[T] 5.75 in	1.437 in	15-500 psi	Steam	UV, V
8 NPS	12, 14 NPS	28.274 in ²	6 in	1.5 in	15-2000 psi	Steam	UV, V
10 NPS	14 NPS	44.18 in ²	7.5 in	1.875 in	15-500 psi	Steam	UV, V
12 NPS	16 NPS	63.62 in ²	9 in	2.25 in	15-500 psi	Steam	UV, V
14 NPS	18 NPS	86.59 in ²	10.5 in	2.625 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	95.21 in ²	11.01 in	2.753 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	114.04 in ²	12.05 in	3.02 in	15-500 psi	Steam	UV, V
18 NPS	24 NPS	143.14 in ²	13.5 in	3.375 in	15-500 psi	Steam	UV, V
20 NPS	24 NPS	176.71 in ²	15 in	3.75 in	15-500 psi	Steam	UV, V

Design Name: H Series (Restricted Lift version of Cert # 15006) NBCert # 15567

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 05/31/2031

Design Type

[Safety Valve] H Series (Restricted Lift version of Cert # 15006)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 6, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Restricted Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1.5 NPS	0.11 in ²	[D] 0.375 in	0.08 in	15-500 psi	Steam	UV, V
0.75 NPS	1.5 NPS	0.196 in ²	[E] 0.5 in	0.08 in	15-500 psi	Steam	UV, V
1-1.5 NPS	2, 2.5, 3 NPS	0.307 in ²	[F] 0.625 in	0.08 in	15-3100 psi	Steam	UV, V
1-2 NPS	2.5, 3 NPS	0.503 in ²	[G] 0.8 in	0.08 in	15-3100 psi	Steam	UV, V
1.5-2 NPS	3, 4 NPS	0.785 in ²	[H] 1 in	0.08 in	15-3100 psi	Steam	UV, V
1.5 NPS	3 NPS	0.865 in ²	1.05 in	0.08 in	15-3100 psi	Steam	UV, V

1.5 NPS	3 NPS	0.994 in ²	[H2] 1.125 in	0.084 in	15-3100 psi	Steam	UV, V
2-3 NPS	3,4,6 NPS	1.288 in ²	[J] 1.281 in	0.096 in	15-5000 psi	Steam	UV, V
2 NPS	4 NPS	1.431 in ²	[J2] 1.35 in	0.101 in	15-3100 psi	Steam	UV, V
2.5-3 NPS	4, 6 NPS	1.84 in ²	[K] 1.531 in	0.115 in	15-3100 psi	Steam	UV, V
2.5 NPS	6 NPS	2.545 in ²	[K2] 1.8 in	0.135 in	15-3100 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-3100 psi	Steam	UV, V
3 NPS	6 NPS	3.341 in ²	[L2] 2.062 in	0.155 in	15-3100 psi	Steam	UV, V
3-4 NPS	6 NPS	3.6 in ²	[M] 2.14 in	0.161 in	15-5000 psi	Steam	UV, V
3 NPS	6 NPS	3.976 in ²	[M2] 2.25 in	0.169 in	15-3100 psi	Steam	UV, V
4 NPS	6 NPS	4.341 in ²	[N] 2.351 in	0.176 in	15-3100 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.213 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	7.07 in ²	[P2] 3 in	0.225 in	15-3100 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.281 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	12.25 in ²	[Q2] 3.95 in	0.296 in	15-3100 psi	Steam	UV, V
6 NPS	8, 10 NPS	16 in ²	[R] 4.513 in	0.338 in	15-1200 psi	Steam	UV, V
6 NPS	10 NPS	19.29 in ²	[RR] 4.956 in	0.371 in	15-3100 psi	Steam	UV, V
8 NPS	10, 12 NPS	26 in ²	[T] 5.75 in	0.431 in	15-500 psi	Steam	UV, V
8 NPS	12, 14 NPS	28.274 in ²	6 in	0.45 in	15-2000 psi	Steam	UV, V
10 NPS	14 NPS	44.18 in ²	7.5 in	0.562 in	15-500 psi	Steam	UV, V
12 NPS	16 NPS	63.62 in ²	9 in	0.675 in	15-500 psi	Steam	UV, V
14 NPS	18 NPS	86.59 in ²	10.5 in	0.787 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	95.21 in ²	11.01 in	0.826 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	114.04 in ²	12.05 in	0.906 in	15-500 psi	Steam	UV, V
18 NPS	24 NPS	143.14 in ²	13.5 in	1.012 in	15-500 psi	Steam	UV, V
20 NPS	24 NPS	176.71 in ²	15 in	1.125 in	15-500 psi	Steam	UV, V

Design Name: HE NBCert # 15039

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer V 02/12/2030

Design Type

[Safety Valve] HE
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 15, 1970
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5 NPS	0.307 in ²	0.625 in	0.156 in	15-3100 psi	Steam	NV, V
1.5 NPS	2.5 NPS	0.503 in ²	0.8 in	0.2 in	15-3100 psi	Steam	NV, V
1.5 NPS	3 NPS	0.785 in ²	[H] 1 in	0.25 in	15-3100 psi	Steam	NV, V
2 NPS	4 NPS	1.288 in ²	[J] 1.281 in	0.32 in	15-3100 psi	Steam	NV, V

2.5 NPS	6 NPS	1.84 in ²	[K] 1.531 in	0.382 in	15-3100 psi	Steam	NV, V
2.5 NPS	6 NPS	2.545 in ²	[K2] 1.8 in	0.45 in	15-3100 psi	Steam	NV, V
3 NPS	6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-3100 psi	Steam	NV, V
3 NPS	6 NPS	3.976 in ²	[M2] 2.25 in	0.562 in	15-3100 psi	Steam	NV, V
4 NPS	6 NPS	6.38 in ²	2.85 in	0.712 in	15-3100 psi	Steam	NV, V
4 NPS	6, 8 NPS	7.069 in ²	[P2] 3 in	0.75 in	15-3100 psi	Steam	NV, V
6 NPS	8 NPS	11.045 in ²	3.75 in	0.937 in	15-3100 psi	Steam	NV, V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.513 in	1.128 in	15-1500 psi	Steam	NV, V
8 NPS	10, 12, 14 NPS	19.369 in ²	[R3] 4.966 in	1.242 in	15-3100 psi	Steam	NV, V
8 NPS	10, 12, 14 NPS	21.1 in ²	[R5] 5.183 in	1.295 in	15-3100 psi	Steam	NV, V
8 NPS	14 NPS	22 in ²	[R6] 5.295 in	1.324 in	15-3100 psi	Steam	NV, V
10 NPS	16 NPS	36.4 in ²	[T2] 6.808 in	1.707 in	15-3100 psi	Steam	NV, V

Design Name: JB

NBCert # 15073

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

08/04/2027

Design Type

[Safety Relief Valve] JB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on August 8, 1957
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.856 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Crosby Valve, LLC {CVM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	1-2 NPS	0.1244 in ²	[D] 0.398 in	0.099 in	15-2900 psi	Steam	NV, UV
0.75-1.5 NPS	1-2 NPS	0.1244 in ²	[D] 0.398 in	0.099 in	15-6000 psi	Air	NV, UV
0.75-1.5 NPS	1-2.5 NPS	0.2223 in ²	[E] 0.532 in	0.133 in	15-2900 psi	Steam	NV, UV
0.75-1.5 NPS	1-2.5 NPS	0.2223 in ²	[E] 0.532 in	0.133 in	15-6000 psi	Air	NV, UV
1-1.5 NPS	2 NPS	0.3484 in ²	[F] 0.666 in	0.167 in	15-2900 psi	Steam	NV, UV
1-1.5 NPS	2 NPS	0.3484 in ²	[F] 0.666 in	0.167 in	15-5000 psi	Air	NV, UV
1.5-2 NPS	2-3 NPS	0.57 in ²	[G] 0.852 in	0.213 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2-3 NPS	0.57 in ²	[G] 0.852 in	0.213 in	15-3705 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.891 in ²	[H] 1.065 in	0.266 in	15-2900 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.891 in ²	[H] 1.065 in	0.266 in	15-2900 psi	Steam	NV, UV
2 NPS	3 NPS	1.459 in ²	[J] 1.363 in	0.34 in	15-2900 psi	Air	NV, UV
2 NPS	3 NPS	1.459 in ²	[J] 1.363 in	0.34 in	15-2900 psi	Steam	NV, UV
3 NPS	4 NPS	2.087 in ²	[K] 1.63 in	0.408 in	15-2900 psi	Steam	NV, UV
3 NPS	4 NPS	2.087 in ²	[K] 1.63 in	0.408 in	15-2900 psi	Air	NV, UV
3 NPS	4 NPS	3.237 in ²	[L] 2.03 in	0.508 in	15-1500 psi	Steam	NV, UV
3 NPS	4 NPS	3.237 in ²	[L] 2.03 in	0.508 in	15-1500 psi	Air	NV, UV
4 NPS	6 NPS	4.083 in ²	[M] 2.28 in	0.57 in	15-1100 psi	Steam	NV, UV

4 NPS	6 NPS	4.083 in ²	[M] 2.28 in	0.57 in	15-1100 psi	Air	NV, UV
4 NPS	6 NPS	4.924 in ²	[N] 2.504 in	0.626 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	4.924 in ²	[N] 2.504 in	0.626 in	15-1000 psi	Air	NV, UV
4 NPS	6 NPS	7.234 in ²	[P] 3.035 in	0.759 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	7.234 in ²	[P] 3.035 in	0.759 in	15-1000 psi	Air	NV, UV
6 NPS	8 NPS	12.53 in ²	[Q] 3.994 in	0.999 in	15-600 psi	Steam	NV, UV
6 NPS	8 NPS	12.53 in ²	[Q] 3.994 in	0.999 in	15-600 psi	Air	NV, UV
6 NPS	8-10 NPS	18.148 in ²	[R] 4.807 in	1.2 in	15-500 psi	Steam	NV, UV
6 NPS	8-10 NPS	18.148 in ²	[R] 4.807 in	1.2 in	15-500 psi	Air	NV, UV
8 NPS	10 NPS	29.494 in ²	[T] 6.128 in	1.532 in	15-500 psi	Steam	NV, UV
8 NPS	10 NPS	29.494 in ²	[T] 6.128 in	1.532 in	15-500 psi	Air	NV, UV
10-12 NPS	14 NPS	38.485 in ²	7 in	1.75 in	15-600 psi	Steam	NV, UV
10-12 NPS	14 NPS	38.485 in ²	7 in	1.75 in	15-600 psi	Air	NV, UV
10-12 NPS	14 NPS	47.85 in ²	[V] 7.805 in	1.951 in	15-500 psi	Steam	NV, UV
10-12 NPS	14 NPS	47.85 in ²	[V] 7.805 in	1.951 in	15-500 psi	Air	NV, UV
12 NPS	16 NPS	68.9 in ²	[W] 9.366 in	2.341 in	15-500 psi	Steam	NV, UV
12 NPS	16 NPS	68.9 in ²	[W] 9.366 in	2.341 in	15-500 psi	Air	NV, UV
12 NPS	16 NPS	72 in ²	[W1] 9.575 in	2.394 in	15-400 psi	Steam	NV, UV
12 NPS	16 NPS	72 in ²	[W1] 9.575 in	2.394 in	15-400 psi	Air	NV, UV
14 NPS	18 NPS	93.78 in ²	[Y] 10.927 in	2.732 in	15-400 psi	Air	NV, UV
14 NPS	18 NPS	93.78 in ²	[Y] 10.927 in	2.732 in	15-400 psi	Steam	NV, UV
16 NPS	18 NPS	103.15 in ²	[Z] 11.46 in	2.865 in	15-400 psi	Air	NV, UV
16 NPS	18 NPS	103.15 in ²	[Z] 11.46 in	2.865 in	15-400 psi	Steam	NV, UV
18-20 NPS	24 NPS	108.434 in ²	11.75 in	2.938 in	15-600 psi	Air	NV, UV
18-20 NPS	24 NPS	108.434 in ²	11.75 in	2.938 in	15-600 psi	Steam	NV, UV
16 NPS	18 NPS	110 in ²	[Z1] 11.835 in	2.959 in	15-400 psi	Air	NV, UV
16 NPS	18 NPS	110 in ²	[Z1] 11.835 in	2.959 in	15-400 psi	Steam	NV, UV
16 NPS	20-22 NPS	123.47 in ²	[Z2] 12.538 in	3.135 in	15-400 psi	Air	NV, UV
16 NPS	20-22 NPS	123.47 in ²	[Z2] 12.538 in	3.135 in	15-400 psi	Steam	NV, UV
18-20 NPS	24 NPS	155.04 in ²	[AA] 14.05 in	3.513 in	15-400 psi	Steam	NV, UV
18-20 NPS	24 NPS	155.04 in ²	[AA] 14.05 in	3.513 in	15-400 psi	Air	NV, UV
20 NPS	24 NPS	191.38 in ²	[BB] 15.61 in	3.902 in	15-400 psi	Air	NV, UV
20 NPS	24 NPS	191.38 in ²	[BB] 15.61 in	3.902 in	15-400 psi	Steam	NV, UV
20 NPS	24 NPS	213.82 in ²	[BB2] 16.5 in	4.125 in	15-300 psi	Air	NV, UV
20 NPS	24 NPS	213.82 in ²	[BB2] 16.5 in	4.125 in	15-300 psi	Steam	NV, UV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	11/15/2029

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.656 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/25/2027

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV

6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

APPARECCHI DI SICUREZZA E TENUTA SPA (A.S.T. SPA) (ADS)

Nameplate Abbreviation: A.S.T. Spa

Cornaredo (Milano), 20007Italy

This Company Manufactures or Assembles:

Design Name: SHL-7000 / SUL-7000			NBCert # 07232				
Manufacturer/Assembler		Designators		Expiration Date			
Manufacturer		UV		10/26/2028			
Design Type							
[Safety Relief Valve] SHL-7000 / SUL-7000 Capacity Tests: Sec. UV at National Board Testing Lab on February 7, 2017 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.901 SCFM/PSIA; (alternate medium): 5.340 PPH/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: APPARECCHI DI SICUREZZA E TENUTA SPA (A.S.T. SPA) {ADS}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1-1.5 NPS	0.121 in²	[D] 0.394 in	0.102 in	15-10000 psi	Air	UV
0.75-1 NPS	1-1.5 NPS	0.121 in²	[D] 0.394 in	0.102 in	15-6000 psi	Steam	UV

Design Name:	SHL-7000 / SUL-7000 (Liquid)	NBCert #	07243
--------------	------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 10/26/2028

Design Type

[Relief Valve] SHL-7000 / SUL-7000 (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on February 7, 2017
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.166 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: APPARECCHI DI SICUREZZA E TENUTA SPA (A.S.T. SPA) {ADS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1-1.5 NPS	0.121 in ²	[D] 0.394 in	0.102 in	15-10000 psi	Water	UV

Design Name:	SMG-7000	NBCert #	07175
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/25/2027

Design Type

[Safety Relief Valve] SMG-7000
Capacity Tests: Sec. UV at National Board Testing Lab on May 13, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.869 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: APPARECCHI DI SICUREZZA E TENUTA SPA (A.S.T. SPA) {ADS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2-3 NPS	0.335 in ²	[F] 0.654 in	0.213 in	15-6000 psi	Steam	UV
1-2 NPS	2-3 NPS	0.335 in ²	[F] 0.654 in	0.213 in	15-6291 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.547 in ²	[G] 0.835 in	0.217 in	15-6000 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.547 in ²	[G] 0.835 in	0.217 in	15-6291 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 1.043 in	0.299 in	15-3775 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 1.043 in	0.299 in	15-3775 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[J] 1.339 in	0.35 in	15-3775 psi	Air	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[J] 1.339 in	0.35 in	15-3775 psi	Steam	UV
3 NPS	4, 6 NPS	2.007 in ²	[K] 1.598 in	0.419 in	15-3775 psi	Air	UV
3 NPS	4, 6 NPS	2.007 in ²	[K] 1.598 in	0.419 in	15-3775 psi	Steam	UV
3 NPS	4, 6 NPS	2.576 in ²	[K2] 1.811 in	0.472 in	15-3775 psi	Air	UV
3 NPS	4, 6 NPS	2.576 in ²	[K2] 1.811 in	0.472 in	15-3775 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.117 in ²	[L] 1.992 in	0.52 in	15-3775 psi	Air	UV
3-4 NPS	4, 6 NPS	3.117 in ²	[L] 1.992 in	0.52 in	15-3775 psi	Steam	UV
4 NPS	6 NPS	3.928 in ²	[M] 2.236 in	0.583 in	15-2264 psi	Air	UV

4 NPS	6 NPS	3.928 in ²	[M] 2.236 in	0.583 in	15-2264 psi	Steam	UV
4 NPS	6 NPS	4.74 in ²	[N] 2.457 in	0.643 in	15-2264 psi	Air	UV
4 NPS	6 NPS	4.74 in ²	[N] 2.457 in	0.643 in	15-2264 psi	Steam	UV
4 NPS	6 NPS	6.976 in ²	[P] 2.98 in	0.778 in	15-2264 psi	Air	UV
4 NPS	6 NPS	6.976 in ²	[P] 2.98 in	0.778 in	15-2264 psi	Steam	UV
6 NPS	8, 10 NPS	9.861 in ²	[P2] 3.543 in	0.923 in	15-3775 psi	Air	UV
6 NPS	8, 10 NPS	9.861 in ²	[P2] 3.543 in	0.923 in	15-3775 psi	Steam	UV
6 NPS	8 NPS	12.077 in ²	[Q] 3.921 in	1.024 in	15-1509 psi	Air	UV
6 NPS	8 NPS	12.077 in ²	[Q] 3.921 in	1.024 in	15-1509 psi	Steam	UV
6 NPS	8, 10 NPS	14.784 in ²	[Q2] 4.339 in	1.134 in	15-3775 psi	Air	UV
6 NPS	8, 10 NPS	14.784 in ²	[Q2] 4.339 in	1.134 in	15-3775 psi	Steam	UV
6 NPS	8, 10 NPS	17.472 in ²	[R] 4.717 in	1.228 in	15-1509 psi	Air	UV
6 NPS	8, 10 NPS	17.472 in ²	[R] 4.717 in	1.228 in	15-1509 psi	Steam	UV
8 NPS	10 NPS	22.949 in ²	[R2] 5.406 in	1.411 in	15-754 psi	Air	UV
8 NPS	10 NPS	22.949 in ²	[R2] 5.406 in	1.411 in	15-754 psi	Steam	UV
8 NPS	10, 12 NPS	28.423 in ²	[T] 6.016 in	1.569 in	15-754 psi	Air	UV
8 NPS	10, 12 NPS	28.423 in ²	[T] 6.016 in	1.569 in	15-754 psi	Steam	UV
8 NPS	10 NPS	30.97 in ²	[T2] 6.28 in	1.638 in	15-754 psi	Air	UV
8 NPS	10 NPS	30.97 in ²	[T2] 6.28 in	1.638 in	15-754 psi	Steam	UV

Design Name: SMG-7000 (Restricted Lift)

NBCert #

07197

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

07/12/2027

Design Type

[Safety Relief Valve] SMG-7000 (Restricted Lift)
Capacity Tests: Sec. UV at National Board Testing Lab on May 13, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.869 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: APPARECCHI DI SICUREZZA E TENUTA SPA (A.S.T. SPA) {ADS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2-3 NPS	0.335 in ²	[E] 0.654 in	0.138 in	15-6000 psi	Steam	UV
1-2 NPS	2-3 NPS	0.335 in ²	[E] 0.654 in	0.138 in	15-6291 psi	Air	UV
1-2 NPS	2-3 NPS	0.335 in ²	[D1] 0.654 in	0.087 in	15-6000 psi	Steam	UV
1-2 NPS	2-3 NPS	0.335 in ²	[D1] 0.654 in	0.087 in	15-6291 psi	Air	UV
1-2 NPS	2-3 NPS	0.335 in ²	[D2] 0.654 in	0.118 in	15-6000 psi	Steam	UV
1-2 NPS	2-3 NPS	0.335 in ²	[D2] 0.654 in	0.118 in	15-6291 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[G3] 1.043 in	0.264 in	15-3775 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[G3] 1.043 in	0.264 in	15-3775 psi	Steam	UV
1.5-2 NPS	3 NPS	0.855 in ²	[G4] 1.043 in	0.28 in	15-3775 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[G4] 1.043 in	0.28 in	15-3775 psi	Steam	UV

1.5-2 NPS	3 NPS	0.855 in ²	[G2] 1.043 in	0.244 in	15-3775 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[G2] 1.043 in	0.244 in	15-3775 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[H1] 1.339 in	0.236 in	15-3775 psi	Air	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[H1] 1.339 in	0.236 in	15-3775 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[H4] 1.339 in	0.299 in	15-3775 psi	Air	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[H4] 1.339 in	0.299 in	15-3775 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[H3] 1.339 in	0.268 in	15-3775 psi	Air	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[H3] 1.339 in	0.268 in	15-3775 psi	Steam	UV
4 NPS	6 NPS	6.976 in ²	[L] 2.98 in	0.346 in	15-2264 psi	Air	UV
4 NPS	6 NPS	6.976 in ²	[L] 2.98 in	0.346 in	15-2264 psi	Steam	UV
4 NPS	6 NPS	6.976 in ²	[N2] 2.98 in	0.622 in	15-2264 psi	Air	UV
4 NPS	6 NPS	6.976 in ²	[N2] 2.98 in	0.622 in	15-2264 psi	Steam	UV
4 NPS	6 NPS	6.976 in ²	[M] 2.98 in	0.437 in	15-2264 psi	Air	UV
4 NPS	6 NPS	6.976 in ²	[M] 2.98 in	0.437 in	15-2264 psi	Steam	UV
4 NPS	6 NPS	6.976 in ²	[N] 2.98 in	0.528 in	15-2264 psi	Air	UV
4 NPS	6 NPS	6.976 in ²	[N] 2.98 in	0.528 in	15-2264 psi	Steam	UV
6 NPS	8, 10 NPS	17.472 in ²	[P2] 4.717 in	0.693 in	15-1509 psi	Air	UV
6 NPS	8, 10 NPS	17.472 in ²	[P2] 4.717 in	0.693 in	15-1509 psi	Steam	UV
6 NPS	8, 10 NPS	17.472 in ²	[Q] 4.717 in	0.846 in	15-1509 psi	Air	UV
6 NPS	8, 10 NPS	17.472 in ²	[Q] 4.717 in	0.846 in	15-1509 psi	Steam	UV
6 NPS	8, 10 NPS	17.472 in ²	[Q2] 4.717 in	1.039 in	15-1509 psi	Air	UV
6 NPS	8, 10 NPS	17.472 in ²	[Q2] 4.717 in	1.039 in	15-1509 psi	Steam	UV

Design Name: SML-7000 (Liquid)	NBCert # 07186
--------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	09/25/2027

Design Type

[Relief Valve] SML-7000 (Liquid)
 Capacity Tests: Sec. UV at National Board Testing Lab on May 13, 2015
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.699 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: APPARECCHI DI SICUREZZA E TENUTA SPA (A.S.T. SPA) {ADS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.121 in ²	[D] 0.394 in	0.15 in	15-10660 psi	Water	UV
1-1.5 NPS	2-3 NPS	0.215 in ²	[E] 0.524 in	0.196 in	15-6291 psi	Water	UV
1-2 NPS	2-3 NPS	0.335 in ²	[F] 0.654 in	0.24 in	15-6291 psi	Water	UV
1-2 NPS	2-3 NPS	0.547 in ²	[G] 0.835 in	0.265 in	15-6291 psi	Water	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 1.043 in	0.299 in	15-3775 psi	Water	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[J] 1.339 in	0.425 in	15-3775 psi	Water	UV
3 NPS	4, 6 NPS	2.007 in ²	[K] 1.598 in	0.501 in	15-3775 psi	Water	UV

3 NPS	4, 6 NPS	2.576 in ²	[K2] 1.811 in	0.576 in	15-3775 psi	Water	UV
3-4 NPS	4, 6 NPS	3.117 in ²	[L] 1.992 in	0.633 in	15-3775 psi	Water	UV
4 NPS	6 NPS	3.928 in ²	[M] 2.236 in	0.712 in	15-2264 psi	Water	UV
4 NPS	6 NPS	4.74 in ²	[N] 2.547 in	0.781 in	15-2264 psi	Water	UV
4 NPS	6 NPS	6.976 in ²	[P] 2.98 in	0.948 in	15-2264 psi	Water	UV
6 NPS	8, 10 NPS	9.861 in ²	[P2] 3.543 in	1.124 in	15-3775 psi	Water	UV
6 NPS	8 NPS	12.077 in ²	[Q] 3.921 in	1.244 in	15-1509 psi	Water	UV
6 NPS	8, 10 NPS	14.784 in ²	[Q2] 4.339 in	1.38 in	15-3775 psi	Water	UV
6 NPS	8, 10 NPS	17.472 in ²	[R] 4.717 in	1.502 in	15-1509 psi	Water	UV
8 NPS	10 NPS	22.949 in ²	[R2] 5.406 in	1.732 in	15-754 psi	Water	UV
8 NPS	10, 12 NPS	28.423 in ²	[T] 6.016 in	1.937 in	15-754 psi	Water	UV
8 NPS	10 NPS	30.97 in ²	[T2] 6.28 in	2.004 in	15-754 psi	Water	UV

Design Name: SML-7000 (Liquid) (Restricted Lift) NBCert # 07209

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/25/2027

Design Type

[Relief Valve] SML-7000 (Liquid) (Restricted Lift)
Capacity Tests: Sec. UV at National Board Testing Lab on May 13, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.699 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: APPARECCHI DI SICUREZZA E TENUTA SPA (A.S.T. SPA) {ADS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2-3 NPS	0.335 in ²	[E] 0.654 in	0.154 in	15-6291 psi	Water	UV
1-2 NPS	2-3 NPS	0.335 in ²	[D1] 0.654 in	0.098 in	15-6291 psi	Water	UV
1-2 NPS	2-3 NPS	0.335 in ²	[D2] 0.654 in	0.134 in	15-6291 psi	Water	UV
1.5-2 NPS	3 NPS	0.855 in ²	[G4] 1.043 in	0.28 in	15-3775 psi	Water	UV
1.5-2 NPS	3 NPS	0.855 in ²	[G3] 1.043 in	0.264 in	15-3775 psi	Water	UV
1.5-2 NPS	3 NPS	0.855 in ²	[G2] 1.043 in	0.244 in	15-3775 psi	Water	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[H3] 1.339 in	0.327 in	15-3775 psi	Water	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[H1] 1.339 in	0.287 in	15-3775 psi	Water	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[H4] 1.339 in	0.362 in	15-3775 psi	Water	UV
4 NPS	6 NPS	6.976 in ²	[M] 2.98 in	0.535 in	15-2264 psi	Water	UV
4 NPS	6 NPS	6.976 in ²	[L] 2.98 in	0.425 in	15-2264 psi	Water	UV
4 NPS	6 NPS	6.976 in ²	[N] 2.98 in	0.646 in	15-2264 psi	Water	UV
4 NPS	6 NPS	6.976 in ²	[N2] 2.98 in	0.76 in	15-2264 psi	Water	UV
6 NPS	8, 10 NPS	17.472 in ²	[P2] 4.717 in	0.846 in	15-1509 psi	Water	UV
6 NPS	8, 10 NPS	17.472 in ²	[Q] 4.717 in	1.039 in	15-1509 psi	Water	UV
6 NPS	8, 10 NPS	17.472 in ²	[Q2] 4.717 in	1.272 in	15-1509 psi	Water	UV

Design Name:	SML-7000 (Steam & Air/Gas)	NBCert #	07210
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	11/30/2028
--------------	----	------------

Design Type

[Safety Relief Valve] SML-7000 (Steam & Air/Gas)
Capacity Tests: Sec. UV at National Board Testing Lab on September 14, 2016
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.869 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: APPARECCHI DI SICUREZZA E TENUTA SPA (A.S.T. SPA) {ADS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.121 in ²	[D] 0.394 in	0.15 in	15-10660 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.121 in ²	[D] 0.394 in	0.15 in	15-6000 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.215 in ²	[E] 0.524 in	0.196 in	15-6000 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.215 in ²	[E] 0.524 in	0.196 in	15-6291 psi	Air	UV
1-2 NPS	2-3 NPS	0.335 in ²	[F] 0.654 in	0.24 in	15-6000 psi	Steam	UV
1-2 NPS	2-3 NPS	0.335 in ²	[F] 0.654 in	0.24 in	15-6291 psi	Air	UV
1-2 NPS	2-3 NPS	0.547 in ²	[G] 0.835 in	0.265 in	15-6000 psi	Steam	UV
1-2 NPS	2-3 NPS	0.547 in ²	[G] 0.835 in	0.265 in	15-6291 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 1.043 in	0.299 in	15-3775 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 1.043 in	0.299 in	15-3775 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[J] 1.339 in	0.425 in	15-3775 psi	Air	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[J] 1.339 in	0.425 in	15-3775 psi	Steam	UV
3 NPS	4, 6 NPS	2.007 in ²	[K] 1.598 in	0.501 in	15-3775 psi	Air	UV
3 NPS	4, 6 NPS	2.007 in ²	[K] 1.598 in	0.501 in	15-3775 psi	Steam	UV
3 NPS	4, 6 NPS	2.576 in ²	[K2] 1.811 in	0.576 in	15-3775 psi	Air	UV
3 NPS	4, 6 NPS	2.576 in ²	[K2] 1.811 in	0.576 in	15-3775 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.117 in ²	[L] 1.992 in	0.633 in	15-3775 psi	Air	UV
3-4 NPS	4, 6 NPS	3.117 in ²	[L] 1.992 in	0.633 in	15-3775 psi	Steam	UV
4 NPS	6 NPS	3.928 in ²	[M] 2.236 in	0.712 in	15-2264 psi	Air	UV
4 NPS	6 NPS	3.928 in ²	[M] 2.236 in	0.712 in	15-2264 psi	Steam	UV
4 NPS	6 NPS	4.74 in ²	[N] 2.547 in	0.781 in	15-2264 psi	Air	UV
4 NPS	6 NPS	4.74 in ²	[N] 2.547 in	0.781 in	15-2264 psi	Steam	UV
4 NPS	6 NPS	6.976 in ²	[P] 2.98 in	0.948 in	15-2264 psi	Air	UV
4 NPS	6 NPS	6.976 in ²	[P] 2.98 in	0.948 in	15-2264 psi	Steam	UV
6 NPS	8, 10 NPS	9.861 in ²	[P2] 3.543 in	1.124 in	15-3775 psi	Air	UV
6 NPS	8, 10 NPS	9.861 in ²	[P2] 3.543 in	1.124 in	15-3775 psi	Steam	UV
6 NPS	8 NPS	12.077 in ²	[Q] 3.921 in	1.244 in	15-1509 psi	Air	UV
6 NPS	8 NPS	12.077 in ²	[Q] 3.921 in	1.244 in	15-1509 psi	Steam	UV
6 NPS	8, 10 NPS	14.784 in ²	[Q2] 4.339 in	1.38 in	15-3775 psi	Air	UV

6 NPS	8, 10 NPS	14.784 in ²	[Q2] 4.339 in	1.38 in	15-3775 psi	Steam	UV
6 NPS	8, 10 NPS	17.472 in ²	[R] 4.717 in	1.502 in	15-1509 psi	Air	UV
6 NPS	8, 10 NPS	17.472 in ²	[R] 4.717 in	1.502 in	15-1509 psi	Steam	UV
8 NPS	10 NPS	22.949 in ²	[R2] 5.406 in	1.732 in	15-754 psi	Air	UV
8 NPS	10 NPS	22.949 in ²	[R2] 5.406 in	1.732 in	15-754 psi	Steam	UV
8 NPS	10, 12 NPS	28.423 in ²	[T] 6.016 in	1.937 in	15-754 psi	Air	UV
8 NPS	10, 12 NPS	28.423 in ²	[T] 6.016 in	1.937 in	15-754 psi	Steam	UV
8 NPS	10 NPS	30.97 in ²	[T2] 6.28 in	2.004 in	15-754 psi	Air	UV
8 NPS	10 NPS	30.97 in ²	[T2] 6.28 in	2.004 in	15-754 psi	Steam	UV

Design Name:	SML-7000 (Steam & Air/Gas) (Restricted Lift)	NBCert #	07221
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 10/26/2028

Design Type

[Safety Relief Valve] SML-7000 (Steam & Air/Gas) (Restricted Lift)
Capacity Tests: Sec. UV at National Board Testing Lab on September 14, 2016
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.869 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: APPARECCHI DI SICUREZZA E TENUTA SPA (A.S.T. SPA) {ADS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2-3 NPS	0.335 in ²	[D1] 0.654 in	0.098 in	15-6000 psi	Steam	UV
1-2 NPS	2-3 NPS	0.335 in ²	[D1] 0.654 in	0.098 in	15-6291 psi	Air	UV
1-2 NPS	2-3 NPS	0.335 in ²	[E] 0.654 in	0.154 in	15-6000 psi	Steam	UV
1-2 NPS	2-3 NPS	0.335 in ²	[E] 0.654 in	0.154 in	15-6291 psi	Air	UV
1-2 NPS	2-3 NPS	0.335 in ²	[D2] 0.654 in	0.134 in	15-6000 psi	Steam	UV
1-2 NPS	2-3 NPS	0.335 in ²	[D2] 0.654 in	0.134 in	15-6291 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[G3] 1.043 in	0.264 in	15-3775 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[G3] 1.043 in	0.264 in	15-3775 psi	Steam	UV
1.5-2 NPS	3 NPS	0.855 in ²	[G4] 1.043 in	0.28 in	15-3775 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[G4] 1.043 in	0.28 in	15-3775 psi	Steam	UV
1.5-2 NPS	3 NPS	0.855 in ²	[G2] 1.043 in	0.244 in	15-3775 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[G2] 1.043 in	0.244 in	15-3775 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[H1] 1.339 in	0.287 in	15-3775 psi	Air	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[H1] 1.339 in	0.287 in	15-3775 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[H3] 1.339 in	0.327 in	15-3775 psi	Air	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[H3] 1.339 in	0.327 in	15-3775 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[H4] 1.339 in	0.362 in	15-3775 psi	Air	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[H4] 1.339 in	0.362 in	15-3775 psi	Steam	UV
4 NPS	6 NPS	6.976 in ²	[N] 2.98 in	0.646 in	15-2264 psi	Air	UV
4 NPS	6 NPS	6.976 in ²	[N] 2.98 in	0.646 in	15-2264 psi	Steam	UV

4 NPS	6 NPS	6.976 in ²	[L] 2.98 in	0.425 in	15-2264 psi	Air	UV
4 NPS	6 NPS	6.976 in ²	[L] 2.98 in	0.425 in	15-2264 psi	Steam	UV
4 NPS	6 NPS	6.976 in ²	[M] 2.98 in	0.535 in	15-2264 psi	Air	UV
4 NPS	6 NPS	6.976 in ²	[M] 2.98 in	0.535 in	15-2264 psi	Steam	UV
4 NPS	6 NPS	6.976 in ²	[N2] 2.98 in	0.76 in	15-2264 psi	Air	UV
4 NPS	6 NPS	6.976 in ²	[N2] 2.98 in	0.76 in	15-2264 psi	Steam	UV
6 NPS	8, 10 NPS	17.472 in ²	[Q] 4.717 in	1.039 in	15-1509 psi	Air	UV
6 NPS	8, 10 NPS	17.472 in ²	[Q] 4.717 in	1.039 in	15-1509 psi	Steam	UV
6 NPS	8, 10 NPS	17.472 in ²	[P2] 4.717 in	0.846 in	15-1509 psi	Air	UV
6 NPS	8, 10 NPS	17.472 in ²	[P2] 4.717 in	0.846 in	15-1509 psi	Steam	UV
6 NPS	8, 10 NPS	17.472 in ²	[Q2] 4.717 in	1.272 in	15-1509 psi	Air	UV
6 NPS	8, 10 NPS	17.472 in ²	[Q2] 4.717 in	1.272 in	15-1509 psi	Steam	UV

Design Name: SVP-7200 (Full Lift)

NBCert #

07131

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

03/19/2026

Design Type

[Pilot Operated Pressure Relief Valve] SVP-7200 (Full Lift)
Capacity Tests: Sec. UV at National Board Testing Lab on May 15, 2013
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: APPARECCHI DI SICUREZZA E TENUTA SPA (A.S.T. SPA) {ADS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2, 3 NPS	0.1217 in ²	[D] 0.394 in	0.087 in	15-15000 psi	Air	UV
1-1.8125 NPS	2, 3 NPS	0.1217 in ²	[D] 0.394 in	0.087 in	15-6000 psi	Steam	UV
1-1.8125 NPS	2, 3 NPS	0.2385 in ²	[E] 0.551 in	0.114 in	15-15000 psi	Air	UV
1-1.8125 NPS	2, 3 NPS	0.2385 in ²	[E] 0.551 in	0.114 in	15-6000 psi	Steam	UV
1-1.8125 NPS	2, 3 NPS	0.3945 in ²	[F1] 0.709 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2, 3 NPS	0.3945 in ²	[F1] 0.709 in	0.25 in	15-6000 psi	Steam	UV
1.5-2.0625 NPS	2, 3 NPS	0.5892 in ²	[G1] 0.866 in	0.41 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	2, 3 NPS	0.5892 in ²	[G1] 0.866 in	0.41 in	15-6000 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9207 in ²	[H2] 1.083 in	0.512 in	15-15000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9207 in ²	[H2] 1.083 in	0.512 in	15-6000 psi	Steam	UV
1.5 NPS	2 NPS	1.3257 in ²	[B4] 1.299 in	0.803 in	15-3775 psi	Air	UV
1.5 NPS	2 NPS	1.3257 in ²	[B4] 1.299 in	0.803 in	15-3775 psi	Steam	UV
1.5-3 NPS	2-4 NPS	1.4913 in ²	[J1] 1.378 in	0.709 in	15-15000 psi	Air	UV
1.5-3 NPS	2-4 NPS	1.4913 in ²	[J1] 1.378 in	0.709 in	15-6000 psi	Steam	UV
2.5625-4 NPS	4, 6 NPS	2.0465 in ²	[K1] 1.614 in	0.776 in	15-10000 psi	Air	UV
2.5625-4 NPS	4, 6 NPS	2.0465 in ²	[K1] 1.614 in	0.776 in	15-6000 psi	Steam	UV
2 NPS	3 NPS	2.576 in ²	[B6] 1.811 in	1.157 in	15-3775 psi	Air	UV

2 NPS	3 NPS	2.576 in ²	[B6] 1.811 in	1.157 in	15-3775 psi	Steam	UV
2 NPS	3 NPS	2.8049 in ²	[B5] 1.89 in	1.157 in	15-1509 psi	Air	UV
2 NPS	3 NPS	2.8049 in ²	[B5] 1.89 in	1.157 in	15-1509 psi	Steam	UV
2.5625-4 NPS	4, 6 NPS	3.2917 in ²	[L2] 2.047 in	0.984 in	15-10000 psi	Air	UV
2.5625-4 NPS	4, 6 NPS	3.2917 in ²	[L2] 2.047 in	0.984 in	15-6000 psi	Steam	UV
4-5.125 NPS	6 NPS	3.9553 in ²	[M1] 2.244 in	1.017 in	15-10000 psi	Air	UV
4-5.125 NPS	6 NPS	3.9553 in ²	[M1] 2.244 in	1.017 in	15-3775 psi	Steam	UV
4-5.125 NPS	6 NPS	4.8317 in ²	[N1] 2.48 in	1.124 in	15-10000 psi	Air	UV
4-5.125 NPS	6 NPS	4.8317 in ²	[N1] 2.48 in	1.124 in	15-3775 psi	Steam	UV
3 NPS	4 NPS	5.7959 in ²	[B9] 2.717 in	1.622 in	15-3775 psi	Air	UV
3 NPS	4 NPS	5.7959 in ²	[B9] 2.717 in	1.622 in	15-3775 psi	Steam	UV
3 NPS	4 NPS	6.3108 in ²	[B8] 2.835 in	1.622 in	15-2264 psi	Air	UV
3 NPS	4 NPS	6.3108 in ²	[B8] 2.835 in	1.622 in	15-2264 psi	Steam	UV
3 NPS	4 NPS	6.6663 in ²	[B7] 2.913 in	1.622 in	15-1509 psi	Air	UV
3 NPS	4 NPS	6.6663 in ²	[B7] 2.913 in	1.622 in	15-1509 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.5977 in ²	[P3] 3.11 in	1.409 in	15-6000 psi	Air	UV
4-6 NPS	6, 8 NPS	7.5977 in ²	[P3] 3.11 in	1.409 in	15-3775 psi	Steam	UV
4 NPS	6 NPS	10.7567 in ²	[BA] 3.701 in	2.035 in	15-3775 psi	Air	UV
4 NPS	6 NPS	10.7567 in ²	[BA] 3.701 in	2.035 in	15-3775 psi	Steam	UV
6 NPS	8 NPS	14.7838 in ²	[Q2] 4.339 in	1.901 in	15-3775 psi	Air	UV
6 NPS	8 NPS	14.7838 in ²	[Q2] 4.339 in	1.901 in	15-3775 psi	Steam	UV
6 NPS	8 NPS	18.4176 in ²	[R3] 4.843 in	2.122 in	15-3775 psi	Air	UV
6 NPS	8 NPS	18.4176 in ²	[R3] 4.843 in	2.122 in	15-3775 psi	Steam	UV
6 NPS	8 NPS	23.1836 in ²	[BF] 5.433 in	3 in	15-2604 psi	Air	UV
6 NPS	8 NPS	23.1836 in ²	[BF] 5.433 in	3 in	15-2604 psi	Steam	UV
8 NPS	10, 12 NPS	30.3905 in ²	[T1] 6.22 in	2.713 in	15-3775 psi	Air	UV
8 NPS	10, 12 NPS	30.3905 in ²	[T1] 6.22 in	2.713 in	15-3775 psi	Steam	UV
8 NPS	8 NPS	31.9487 in ²	[BG] 6.378 in	3.52 in	15-1509 psi	Air	UV
8 NPS	8 NPS	31.9487 in ²	[BG] 6.378 in	3.52 in	15-1509 psi	Steam	UV
8 NPS	10 NPS	43.9471 in ²	[BK] 7.48 in	4.126 in	15-1509 psi	Air	UV
8 NPS	10 NPS	43.9471 in ²	[BK] 7.48 in	4.126 in	15-1509 psi	Steam	UV

Design Name: SVP-7200 (Full Lift) (Liquid) NBCert # 07120

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/17/2025

Design Type

[Pilot Operated Pressure Relief Valve] SVP-7200 (Full Lift) (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on May 14, 2013
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.765 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: APPARECCHI DI SICUREZZA E TENUTA SPA (A.S.T. SPA) {ADS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2, 3 NPS	0.1217 in ²	[D] 0.394 in	0.087 in	15-15000 psi	Water	UV
1-1.8125 NPS	2, 3 NPS	0.2385 in ²	[E] 0.551 in	0.114 in	15-15000 psi	Water	UV
1-1.8125 NPS	2, 3 NPS	0.3945 in ²	[F1] 0.709 in	0.25 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	2, 3 NPS	0.5892 in ²	[G1] 0.866 in	0.41 in	15-15000 psi	Water	UV
1.5-2 NPS	3 NPS	0.9207 in ²	[H2] 1.083 in	0.512 in	15-15000 psi	Water	UV
1.5 NPS	2 NPS	1.3257 in ²	[B4] 1.299 in	0.803 in	15-3775 psi	Water	UV
1.5-3 NPS	2-4 NPS	1.4913 in ²	[J1] 1.378 in	0.709 in	15-15000 psi	Water	UV
2.5625-4 NPS	4, 6 NPS	2.0465 in ²	[K1] 1.614 in	0.776 in	15-10000 psi	Water	UV
2 NPS	3 NPS	2.576 in ²	[B6] 1.811 in	1.157 in	15-3775 psi	Water	UV
2 NPS	3 NPS	2.8049 in ²	[B5] 1.89 in	1.157 in	15-1509 psi	Water	UV
2.5625-4 NPS	4, 6 NPS	3.2917 in ²	[L2] 2.047 in	0.984 in	15-10000 psi	Water	UV
4-5.125 NPS	6 NPS	3.9553 in ²	[M1] 2.244 in	1.017 in	15-10000 psi	Water	UV
4-5.125 NPS	6 NPS	4.8317 in ²	[N1] 2.48 in	1.124 in	15-10000 psi	Water	UV
3 NPS	4 NPS	5.7959 in ²	[B9] 2.717 in	1.622 in	15-3775 psi	Water	UV
3 NPS	4 NPS	6.3108 in ²	[B8] 2.835 in	1.622 in	15-2264 psi	Water	UV
3 NPS	4 NPS	6.6663 in ²	[B7] 2.913 in	1.622 in	15-1509 psi	Water	UV
4-6 NPS	6, 8 NPS	7.5977 in ²	[P3] 3.11 in	1.409 in	15-6000 psi	Water	UV
4 NPS	6 NPS	10.7567 in ²	[BA] 3.701 in	2.035 in	15-3775 psi	Water	UV
6 NPS	8 NPS	14.7838 in ²	[Q2] 4.339 in	1.901 in	15-3775 psi	Water	UV
6 NPS	8 NPS	18.4176 in ²	[R3] 4.843 in	2.122 in	15-3775 psi	Water	UV
6 NPS	8 NPS	23.1836 in ²	[BF] 5.433 in	3 in	15-2264 psi	Water	UV
8 NPS	10, 12 NPS	30.3905 in ²	[T1] 6.22 in	2.713 in	15-3775 psi	Water	UV
8 NPS	8 NPS	31.9487 in ²	[BG] 6.378 in	3.52 in	15-1509 psi	Water	UV
8 NPS	10 NPS	43.9471 in ²	[BK] 7.48 in	4.126 in	15-1509 psi	Water	UV

Design Name:	SVP-7200 Restrict Lift	NBCert #	07119
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	03/19/2026
--------------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] SVP-7200 Restrict Lift
Capacity Tests: Sec. UV at National Board Testing Lab on May 15, 2013
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Restricted Lift
Designed by: APPARECCHI DI SICUREZZA E TENUTA SPA (A.S.T. SPA) {ADS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2, 3 NPS	0.3945 in ²	[D] 0.709 in	0.077 in	15-15000 psi	Air	UV
1-1.8125 NPS	2, 3 NPS	0.3945 in ²	[D] 0.709 in	0.077 in	15-6000 psi	Steam	UV
1-1.8125 NPS	2, 3 NPS	0.3945 in ²	[E] 0.709 in	0.151 in	15-15000 psi	Air	UV

1-1.8125 NPS	2, 3 NPS	0.3945 in ²	[E] 0.709 in	0.151 in	15-6000 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9207 in ²	[G1] 1.083 in	0.328 in	15-15000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9207 in ²	[G1] 1.083 in	0.328 in	15-6000 psi	Steam	UV
1.8125-2.0625 NPS	3 NPS	1.4913 in ²	[G1] 1.378 in	0.28 in	15-15000 psi	Air	UV
1.8125-2.0625 NPS	3 NPS	1.4913 in ²	[G1] 1.378 in	0.28 in	15-6000 psi	Steam	UV
1.8125-2.0625 NPS	3 NPS	1.4913 in ²	[H1] 1.378 in	0.454 in	15-15000 psi	Air	UV
1.8125-2.0625 NPS	3 NPS	1.4913 in ²	[H1] 1.378 in	0.454 in	15-6000 psi	Steam	UV
2.5625-4 NPS	4,6 NPS	3.2917 in ²	[J1] 2.047 in	0.446 in	15-10000 psi	Air	UV
2.5625-4 NPS	4,6 NPS	3.2917 in ²	[J1] 2.047 in	0.446 in	15-3697 psi	Steam	UV
2.5625-4 NPS	4, 6 NPS	3.2917 in ²	[K1] 2.047 in	0.612 in	15-10000 psi	Air	UV
2.5625-4 NPS	4, 6 NPS	3.2917 in ²	[K1] 2.047 in	0.612 in	15-3697 psi	Steam	UV
2.5625-4 NPS	4, 6 NPS	3.2917 in ²	[K2] 2.047 in	0.77 in	15-10000 psi	Air	UV
2.5625-4 NPS	4, 6 NPS	3.2917 in ²	[K2] 2.047 in	0.77 in	15-3697 psi	Steam	UV
4 NPS	6 NPS	7.5977 in ²	[L2] 3.11 in	0.61 in	15-6000 psi	Air	UV
4 NPS	6 NPS	7.5977 in ²	[L2] 3.11 in	0.61 in	15-3775 psi	Steam	UV
4 NPS	6 NPS	7.5977 in ²	[M1] 3.11 in	0.734 in	15-6000 psi	Air	UV
4 NPS	6 NPS	7.5977 in ²	[M1] 3.11 in	0.734 in	15-3775 psi	Steam	UV
4 NPS	6 NPS	7.5977 in ²	[N1] 3.11 in	0.896 in	15-6000 psi	Air	UV
4 NPS	6 NPS	7.5977 in ²	[N1] 3.11 in	0.896 in	15-3775 psi	Steam	UV
6 NPS	8 NPS	18.4176 in ²	[P2] 4.843 in	1.136 in	15-3775 psi	Air	UV
6 NPS	8 NPS	18.4176 in ²	[P2] 4.843 in	1.136 in	15-3775 psi	Steam	UV
6 NPS	8 NPS	18.4176 in ²	[Q1] 4.843 in	1.403 in	15-3775 psi	Air	UV
6 NPS	8 NPS	18.4176 in ²	[Q1] 4.843 in	1.403 in	15-3775 psi	Steam	UV
6 NPS	8 NPS	18.4176 in ²	[Q2] 4.843 in	1.703 in	15-3775 psi	Air	UV
6 NPS	8 NPS	18.4176 in ²	[Q2] 4.843 in	1.703 in	15-3775 psi	Steam	UV
8 NPS	10, 12 NPS	30.3905 in ²	[R2] 6.22 in	2.049 in	15-3775 psi	Air	UV
8 NPS	10, 12 NPS	30.3905 in ²	[R2] 6.22 in	2.049 in	15-3775 psi	Steam	UV

Design Name:	SVP-7200 Restrict Lift (Liquid)	NBCert #	07108
--------------	---------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/17/2025

Design Type

[Pilot Operated Pressure Relief Valve] SVP-7200 Restrict Lift (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on May 14, 2013
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.765 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: APPARECCHI DI SICUREZZA E TENUTA SPA (A.S.T. SPA) {ADS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2, 3 NPS	0.3945 in ²	[D] 0.709 in	0.077 in	15-15000 psi	Water	UV

1-1.8125 NPS	2, 3 NPS	0.3945 in ²	[E] 0.709 in	0.151 in	15-15000 psi	Water	UV
1.5-2 NPS	3 NPS	0.9207 in ²	[G1] 1.083 in	0.328 in	15-15000 psi	Water	UV
1.8125-2.0625 NPS	3 NPS	1.4913 in ²	[G1] 1.378 in	0.28 in	15-15000 psi	Water	UV
1.8125-2.0625 NPS	3 NPS	1.4913 in ²	[H1] 1.378 in	0.454 in	15-15000 psi	Water	UV
2.5625-4 NPS	4, 6 NPS	3.2917 in ²	[K1] 2.047 in	0.612 in	15-10000 psi	Water	UV
2.5625-4 NPS	4, 6 NPS	3.2917 in ²	[J1] 2.047 in	0.446 in	15-10000 psi	Water	UV
2.5625-4 NPS	4, 6 NPS	3.2917 in ²	[K2] 2.047 in	0.77 in	15-10000 psi	Water	UV
4 NPS	6 NPS	7.5977 in ²	[M1] 3.11 in	0.734 in	15-6000 psi	Water	UV
4 NPS	6 NPS	7.5977 in ²	[L2] 3.11 in	0.61 in	15-6000 psi	Water	UV
4 NPS	6 NPS	7.5977 in ²	[N1] 3.11 in	0.896 in	15-6000 psi	Water	UV
6 NPS	8 NPS	18.4176 in ²	[Q1] 4.843 in	1.403 in	15-3775 psi	Water	UV
6 NPS	8 NPS	18.4176 in ²	[P2] 4.843 in	1.136 in	15-3775 psi	Water	UV
6 NPS	8 NPS	18.4176 in ²	[Q2] 4.843 in	1.703 in	15-3775 psi	Water	UV
8 NPS	10, 12 NPS	30.3905 in ²	[R2] 6.22 in	2.049 in	15-3775 psi	Water	UV

Applied Control Equipment, LLLP (APP)

Nameplate Abbreviation: Applied Control

Commerce City, CO 80022United States

This Company Manufactures or Assembles:

Design Name:	243/249/443/449/546/843/849/943/5046/5049/8043/8049	NBCert #	01292
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	02/05/2031
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
Capacity Tests: Sec. UV at unknown lab on August 8, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV

4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name: 253/259/453/459/853/859/953/959/5059/8053/8059 NBCert # 01304

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/05/2031

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059

Capacity Tests: Sec. UV at unknown lab on July 31, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.627 Unitless

Media - Test: Air/Gas; Certified: Air, Gas

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Curtain Area

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 263/269/463/469/566/863/869/963/969/5066/5069 NBCert # 01315

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/05/2031

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069

Capacity Tests: Sec. UV at unknown lab on July 30, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.860 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/06/2031

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.767 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/02/2025

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids) NBCert # 01348

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/05/2031

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids)
 Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.712 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name: 81, 81P, 83, 84 NBCert # 01089

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

02/05/2031

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
 Capacity Tests: Sec. UV at unknown lab on July 8, 1965
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.816 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}
 Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name:	81P (Liquids)	NBCert #	01102
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 12/02/2025

Design Type

[Relief Valve] 81P (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: 93% of pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name:	900 Series (Liquid), 7700, SNC	NBCert #	15499
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 12/02/2025

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV

1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name: 900 Series, 7700, SNC NBCert # 15411

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/05/2031

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/06/2031

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/05/2031

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
 Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.870 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/05/2031

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.865 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV

1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV

12-14 NPS	16. 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16. 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Applied Control Equipment, LLLP (TSR)

Nameplate Abbreviation: Applied Control

Everett, WA 98203United States

This Company Manufactures or Assembles:

Design Name:	243/249/443/449/546/843/849/943/5046/5049/8043/8049	NBCert #	01292
Manufacturer/Assembler	Designators	Expiration Date	

AssemblerUV01/31/2031

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
Capacity Tests: Sec. UV at unknown lab on August 8, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name:	253/259/453/459/853/859/953/959/5059/8053/8059	NBCert #	01304
Manufacturer/Assembler	Designators	Expiration Date	

AssemblerUV01/31/2031

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
Capacity Tests: Sec. UV at unknown lab on July 31, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.627 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 263/269/463/469/566/863/869/963/969/506
6/5069 NBCert # 01315

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/31/2031

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069
Capacity Tests: Sec. UV at unknown lab on July 30, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV

8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/14/2031

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.767 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/14/2031

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.491 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name:	463/469/566/863/869/963/969/5066/5069 (Liquids)	NBCert #	01348
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	01/11/2031
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids)
Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.712 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV

8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name: 81, 81P, 83, 84 NBCert # 01089

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/31/2031

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 81P (Liquids) NBCert # 01102

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/19/2031

Design Type

[Relief Valve] 81P (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: 93% of pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V

0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name: 900 Series (Liquid), 7700, SNC NBCert # 15499

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/31/2031

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name: 900 Series, 7700, SNC NBCert # 15411

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/31/2031

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/11/2031

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.656 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV

1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/09/2030

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV

2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/02/2031

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV

3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Design Name: Kunkle 337

NBCert # 36278

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/31/2031

Design Type

[Safety Relief Valve] Kunkle 337
Capacity Tests: Sec. UV at unknown lab on February 22, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	1.916 in ²	1.562 in	0.612 in	15-60 psi	Air	UV
2.5 NPS	2.5 NPS	2.786 in ²	1.883 in	0.755 in	15-60 psi	Air	UV
3 NPS	3 NPS	4.037 in ²	2.267 in	0.91 in	15-60 psi	Air	UV

Design Name: Kunkle 6000, 6252 Series NBCert # 36324

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	02/02/2031

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV

3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 910 to 919

NBCert #

36100

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

01/31/2031

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name:	Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)	NBCert #	36111
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	01/31/2031	

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 , 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

Applied Valve Technology, Inc. (AVT)

Nameplate Abbreviation: Applied Valve Technology

Chattanooga, TN 37406United States

This Company Manufactures or Assembles:

Design Name:	Kunkle 6000, 6252 Series	NBCert #	36324
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV, V	06/20/2030	

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV

0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 910 to 919

NBCert # 36100

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/01/2030

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name: Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid) NBCert # 36111

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/20/2030

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

Aquatrol, Incorporated (AQT)

Nameplate Abbreviation: Aquatrol

Elburn, IL 60119United States

This Company Manufactures or Assembles:

Design Name: 120, 121, 125, 126		NBCert # 02068	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	11/26/2030
Design Type			
[Safety Relief Valve] 120, 121, 125, 126 Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on February 3, 1982 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.037 SCFM/PSIA; (alternate medium): 2.910 PPH/PSIA Media - Test: Air/Gas; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Aquatrol, Incorporated {AQT}			
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia. Lift Set Pressure Range Media Designator
0.5-1 NPS	.75, top NPS		0.75 in 0.045 in 15-200 psi Air UV
0.5-1 NPS	.75, top NPS		0.75 in 0.045 in 15-200 psi Steam UV
Design Name: 130, 132, 133, 135		NBCert # 02079	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	11/26/2030
Design Type			
[Safety Relief Valve] 130, 132, 133, 135 Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on October 15, 1980 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.403 SCFM/PSIA; (alternate medium): 1.130 PPH/PSIA Media - Test: Air/Gas; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Aquatrol, Incorporated {AQT}			
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia. Lift Set Pressure Range Media Designator
0.25-0.5 NPS	.5, Top NPS		0.5 in 0.024 in 15-200 psi Air UV
0.25-0.5 NPS	.5, Top NPS		0.5 in 0.024 in 15-200 psi Steam UV
Design Name: 140-A		NBCert # 02114	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	02/22/2031

Design Type

[Safety Relief Valve] 140-A
 Capacity Tests: Sec. UV at National Board Testing Lab on August 20, 2018
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 0.924 SCFM/PSIA
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Aquatrol, Incorporated {AQT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.5 NPS		0.0604 in ²	0.281 in	0.09 in	15-450 psi	Air	UV

Design Name: 140-B NBCert # 02125

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/22/2031

Design Type

[Safety Relief Valve] 140-B
 Capacity Tests: Sec. UV at National Board Testing Lab on August 20, 2018
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 1.487 SCFM/PSIA
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Aquatrol, Incorporated {AQT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-0.75 NPS		0.0837 in ²	0.39 in	0.12 in	15-450 psi	Air	UV

Design Name: 560, 570 NBCert # 02080

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV, V

01/19/2028

Design Type

[Safety Valve] 560, 570
 Capacity Tests: Sec. UV, V at National Board Testing Lab on November 10, 2005
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.856 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Aquatrol, Incorporated {AQT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-300 psi	Steam	UV, V
0.75-1 NPS	1 NPS	0.221 in ²	[E] 0.53 in	0.132 in	15-300 psi	Air	UV
0.75-1 NPS	1 NPS	0.221 in ²	[E] 0.53 in	0.132 in	15-300 psi	Steam	UV, V
1-1.25 NPS	1.25 NPS	0.352 in ²	[F] 0.67 in	0.167 in	15-300 psi	Air	UV
1-1.25 NPS	1.25 NPS	0.352 in ²	[F] 0.67 in	0.167 in	15-300 psi	Steam	UV, V

1.25-1.5 NPS	1.5 NPS	0.567 in ²	[G] 0.85 in	0.212 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.567 in ²	[G] 0.85 in	0.212 in	15-300 psi	Steam	UV, V
1.5-2 NPS	2 NPS	0.899 in ²	[H] 1.07 in	0.267 in	15-300 psi	Air	UV
1.5-2 NPS	2 NPS	0.899 in ²	[H] 1.07 in	0.267 in	15-300 psi	Steam	UV, V
2-2.5 NPS	2.5 NPS	1.463 in ²	[J] 1.365 in	0.41 in	15-300 psi	Air	UV
2-2.5 NPS	2.5 NPS	1.463 in ²	[J] 1.365 in	0.41 in	15-300 psi	Steam	UV, V

Design Name:	88A, 89A	NBCert #	02002
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/26/2030

Design Type

[Safety Relief Valve] 88A, 89A
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on October 15, 1980
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.644 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Aquatrol, Incorporated {AQT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS		0.5 in	0.036 in	15-250 psi	Air	UV

Design Name:	88B, 89B	NBCert #	02013
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/26/2030

Design Type

[Safety Relief Valve] 88B, 89B
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on October 15, 1980
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.930 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Aquatrol, Incorporated {AQT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS		0.75 in	0.04 in	15-250 psi	Air	UV

Design Name:	88C, 89C	NBCert #	02024
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/26/2030

Design Type

[Safety Relief Valve] 88C, 89C
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on October 14, 1980
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.274 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Aquatrol, Incorporated {AQT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.25 NPS		1 in	0.075 in	15-250 psi	Air	UV

Design Name: 88D, 89D NBCert # 02035

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer UV 11/26/2030

Design Type

[Safety Relief Valve] 88D, 89D
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on October 14, 1980
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.504 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Aquatrol, Incorporated {AQT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS		1.25 in	0.086 in	15-250 psi	Air	UV

Design Name: 88E, 89E NBCert # 02046

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer UV 11/26/2030

Design Type

[Safety Relief Valve] 88E, 89E
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on October 14, 1980
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 4.900 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Aquatrol, Incorporated {AQT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS		1.5 in	0.1 in	15-250 psi	Air	UV

Design Name: 88F, 89F NBCert # 02057

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer UV 11/26/2030

Design Type

[Safety Relief Valve] 88F, 89F
 Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on October 14, 1981
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 7.404 SCFM/PSIA
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Aquatrol, Incorporated {AQT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2.5 NPS		2 in	0.12 in	15-250 psi	Air	UV

Design Name: Series 740 NBCert # 02091

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/11/2031

Design Type

[Safety Relief Valve] Series 740
 Capacity Tests: Sec. UV at National Board Testing Lab on November 21, 2012
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Aquatrol, Incorporated {AQT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75, 1 NPS	0.125 in ²	[D] 0.4 in	0.105 in	15-1500 psi	Air	UV
0.5-1 NPS	0.75, 1 NPS	0.125 in ²	[D] 0.4 in	0.105 in	15-300 psi	Steam	UV
0.5-1.25 NPS	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-1500 psi	Air	UV
0.5-1.25 NPS	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-300 psi	Steam	UV
0.75-1.5 in	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-1500 psi	Air	UV
0.75-1.5 in	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-300 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.353 in ²	[F] 0.67 in	0.17 in	15-300 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.353 in ²	[F] 0.67 in	0.17 in	15-750 psi	Air	UV
1-2 in	1.5 NPS	0.353 in ²	[F] 0.67 in	0.017 in	15-750 psi	Air	UV
1-2 in	1.5 NPS	0.353 in ²	[F] 0.67 in	0.017 in	15-300 psi	Steam	UV
1.25-2 NPS	2 NPS	0.554 in ²	[G] 0.84 in	0.215 in	15-300 psi	Steam	UV
1.25-2 NPS	2 NPS	0.554 in ²	[G] 0.84 in	0.215 in	15-700 psi	Air	UV
1.5-2.5 NPS	2, 2.5 NPS	0.923 in ²	[H] 1.084 in	0.28 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2, 2.5 NPS	0.923 in ²	[H] 1.084 in	0.28 in	15-600 psi	Air	UV
2-3 NPS	3 NPS	1.418 in ²	[J] 1.344 in	0.34 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	1.418 in ²	[J] 1.344 in	0.34 in	15-600 psi	Air	UV

Design Name: Series 740 (Liquid)		NBCert #	02103
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	02/11/2031
Design Type			
[Safety Relief Valve] Series 740 (Liquid) Capacity Tests: Sec. UV at National Board Testing Lab on November 20, 2012 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.791 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Flow Area Configuration: Nozzle/Full Lift Designed by: Aquatrol, Incorporated {AQT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75, 1 NPS	0.125 in ²	[D] 0.4 in	0.105 in	15-1500 psi	Water	UV
0.75-1.25 NPS	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-1500 psi	Water	UV
0.75-1.5 in	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-1500 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.353 in ²	[F] 0.67 in	0.17 in	15-750 psi	Water	UV
1-2 in	1.5 NPS	0.353 in ²	[F] 0.67 in	0.017 in	15-750 psi	Water	UV
1.25-2 NPS	2 NPS	0.554 in ²	[G] 0.84 in	0.215 in	15-700 psi	Water	UV
1.5-2.5 NPS	2, 2.5 NPS	0.923 in ²	[H] 1.084 in	0.28 in	15-600 psi	Water	UV
2-3 NPS	3 NPS	1.418 in ²	[J] 1.344 in	0.34 in	15-600 psi	Water	UV

ARI-Armaturen Albert Richter GmbH & Co. KG (ARI)

Schloss Holte-Stukenbrock, 33758Germany

This Company Manufactures or Assembles:

Design Name: 901/902/911/912		NBCert #	08008
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	12/12/2029
Design Type			
[Safety Relief Valve] 901/902/911/912 Capacity Tests: Sec. UV at National Board Testing Lab on November 9, 2001 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.817 Unitless Media - Test: Air/Gas; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: ARI-Armaturen Albert Richter GmbH & Co. KG {ARI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5, 2.0 NPS	0.617 in ²	0.886 in	0.22 in	30-493 psi	Air	UV
1 NPS	1.5, 2.0 NPS	0.617 in ²	0.886 in	0.22 in	30-493 psi	Steam	UV
1.25 NPS	2.0 NPS	1.024 in ²	1.142 in	0.29 in	30-493 psi	Air	UV

1.25 NPS	2.0 NPS	1.024 in ²	1.142 in	0.29 in	30-493 psi	Steam	UV
1.5 NPS	2, 2.5 NPS	1.024 in ²	1.142 in	0.29 in	30-493 psi	Air	UV
1.5 NPS	2, 2.5 NPS	1.024 in ²	1.142 in	0.29 in	30-493 psi	Steam	UV
1.5 NPS	2.5, 3.0 NPS	1.578 in ²	1.417 in	0.37 in	30-493 psi	Air	UV
1.5 NPS	2.5, 3.0 NPS	1.578 in ²	1.417 in	0.37 in	30-493 psi	Steam	UV
2 NPS	3 NPS	2.465 in ²	1.772 in	0.45 in	30-493 psi	Air	UV
2 NPS	3 NPS	2.465 in ²	1.772 in	0.45 in	30-493 psi	Steam	UV
2.5-3 NPS	4 NPS	4.166 in ²	2.303 in	0.61 in	30-406 psi	Air	UV
2.5-3 NPS	4 NPS	4.166 in ²	2.303 in	0.61 in	30-406 psi	Steam	UV
4 NPS	6 NPS	9.861 in ²	3.543 in	0.98 in	30-276 psi	Air	UV
4 NPS	6 NPS	9.861 in ²	3.543 in	0.98 in	30-276 psi	Steam	UV
5-6 NPS	8 NPS	13.678 in ²	4.173 in	1.34 in	30-392 psi	Air	UV
5-6 NPS	8 NPS	13.678 in ²	4.173 in	1.34 in	30-392 psi	Steam	UV
6 NPS	10 NPS	19.022 in ²	4.921 in	1.46 in	30-305 psi	Air	UV
6 NPS	10 NPS	19.022 in ²	4.921 in	1.46 in	30-305 psi	Steam	UV

Design Name: 901/902/911/912 (1" liquid) NBCert # 08020

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/12/2028

Design Type

[Relief Valve] 901/902/911/912 (1" liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on August 24, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 14.410 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Opening Pressure
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen Albert Richter GmbH & Co. KG {ARI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5, 2.0 NPS	0.617 in ²	0.886 in	0.22 in	15-493 psi	Water	UV

Design Name: 901/902/911/912 (Liquids) NBCert # 08019

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/12/2029

Design Type

[Relief Valve] 901/902/911/912 (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on October 15, 2001
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.545 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Opening Pressure
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen Albert Richter GmbH & Co. KG {ARI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	2 NPS	1.024 in ²	1.142 in	0.29 in	15-493 psi	Water	UV
1.5 NPS	2, 2.5 NPS	1.024 in ²	1.142 in	0.29 in	15-493 psi	Water	UV
1.5 NPS	2.5, 3 NPS	1.578 in ²	1.417 in	0.37 in	15-493 psi	Water	UV
2 NPS	3 NPS	2.465 in ²	1.772 in	0.45 in	15-493 psi	Water	UV
2.5-3 NPS	4 NPS	4.166 in ²	2.303 in	0.61 in	15-406 psi	Water	UV
4 NPS	6 NPS	9.861 in ²	3.543 in	0.98 in	15-276 psi	Water	UV
5-6 NPS	8 NPS	13.678 in ²	4.173 in	1.34 in	15-392 psi	Water	UV
6 NPS	10 NPS	19.022 in ²	4.921 in	1.46 in	15-305 psi	Water	UV

Design Name:	901/902/911/912 {15-30}	NBCert #	08031
--------------	-------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/29/2029

Design Type

[Safety Relief Valve] 901/902/911/912 {15-30}
Capacity Tests: Sec. UV at National Board Testing Lab on May 9, 2007
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.769 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen Albert Richter GmbH & Co. KG {ARI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5, 2.0 NPS	0.394 in ²	0.709 in	0.205 in	15-30 psi	Air	UV
1 NPS	1.5, 2.0 NPS	0.394 in ²	0.709 in	0.205 in	15-30 psi	Steam	UV
1.25 NPS	2.0 NPS	1.024 in ²	1.142 in	0.29 in	15-30 psi	Air	UV
1.25 NPS	2.0 NPS	1.024 in ²	1.142 in	0.29 in	15-30 psi	Steam	UV
1.5 NPS	2, 2.5 NPS	1.024 in ²	1.142 in	0.29 in	15-30 psi	Air	UV
1.5 NPS	2, 2.5 NPS	1.024 in ²	1.142 in	0.29 in	15-30 psi	Steam	UV
1.5 NPS	2.5, 3.0 NPS	1.578 in ²	1.417 in	0.37 in	15-30 psi	Air	UV
1.5 NPS	2.5, 3.0 NPS	1.578 in ²	1.417 in	0.37 in	15-30 psi	Steam	UV
2 NPS	3 NPS	2.465 in ²	1.772 in	0.45 in	15-30 psi	Air	UV
2 NPS	3 NPS	2.465 in ²	1.772 in	0.45 in	15-30 psi	Steam	UV
2.5-3 NPS	4 NPS	4.166 in ²	2.303 in	0.61 in	15-30 psi	Air	UV
2.5-3 NPS	4 NPS	4.166 in ²	2.303 in	0.61 in	15-30 psi	Steam	UV
4 NPS	6 NPS	9.861 in ²	3.543 in	0.98 in	15-30 psi	Air	UV
4 NPS	6 NPS	9.861 in ²	3.543 in	0.98 in	15-30 psi	Steam	UV
5-6 NPS	8 NPS	13.678 in ²	4.173 in	1.34 in	15-30 psi	Air	UV
5-6 NPS	8 NPS	13.678 in ²	4.173 in	1.34 in	15-30 psi	Steam	UV
6 NPS	10 NPS	19.022 in ²	4.921 in	1.46 in	15-30 psi	Air	UV
6 NPS	10 NPS	19.022 in ²	4.921 in	1.46 in	15-30 psi	Steam	UV

Design Name: Reyco R, RB & RO (Fig. 971, 973, 974) NBCert # 73000

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	06/17/2030

Design Type

[Safety Relief Valve] Reyco R, RB & RO (Fig. 971, 973, 974)
Capacity Tests: Sec. UV at National Board Testing Lab on March 19, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.122 in ²	[D] 0.394 in	0.12 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.122 in ²	[D] 0.394 in	0.12 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.217 in ²	[E] 0.526 in	0.16 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.217 in ²	[E] 0.526 in	0.16 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.34 in ²	[F] 0.658 in	0.2 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.34 in ²	[F] 0.658 in	0.2 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.558 in ²	[G] 0.843 in	0.26 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.558 in ²	[G] 0.843 in	0.26 in	15-4905 psi	Air	UV
1.5-2 NPS	3 NPS	0.869 in ²	[H] 1.052 in	0.32 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.869 in ²	[H] 1.052 in	0.32 in	15-3300 psi	Air	UV
2-3 NPS	3, 4 NPS	1.427 in ²	[J] 1.348 in	0.41 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.427 in ²	[J] 1.348 in	0.41 in	15-3300 psi	Air	UV
3 NPS	4, 6 NPS	2.036 in ²	[K] 1.61 in	0.49 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.036 in ²	[K] 1.61 in	0.49 in	15-3300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.16 in ²	[L] 2.006 in	0.61 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.16 in ²	[L] 2.006 in	0.61 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	3.987 in ²	[M] 2.253 in	0.69 in	15-1600 psi	Air	UV
4 NPS	6 NPS	3.987 in ²	[M] 2.253 in	0.69 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.807 in ²	[N] 2.474 in	0.75 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.807 in ²	[N] 2.474 in	0.75 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.07 in ²	[P] 3 in	0.92 in	15-1600 psi	Air	UV
4 NPS	6 NPS	7.07 in ²	[P] 3 in	0.92 in	15-1600 psi	Steam	UV
6 NPS	8 NPS	12.24 in ²	[Q] 3.948 in	1.2 in	15-925 psi	Air	UV
6 NPS	8 NPS	12.24 in ²	[Q] 3.948 in	1.2 in	15-925 psi	Steam	UV
6 NPS	8, 10 NPS	17.72 in ²	[R] 4.75 in	1.45 in	15-350 psi	Air	UV
6 NPS	8, 10 NPS	17.72 in ²	[R] 4.75 in	1.45 in	15-350 psi	Steam	UV
8 NPS	10 NPS	29.75 in ²	[T] 6.155 in	1.84 in	15-325 psi	Air	UV
8 NPS	10 NPS	29.75 in ²	[T] 6.155 in	1.84 in	15-325 psi	Steam	UV

Design Name:	Reyco R, RB, RO, RBO (Fig. 971, 973, 974) (liquid)	NBCert #	73011
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/15/2029

Design Type

[Relief Valve] Reyco R, RB, RO, RBO (Fig. 971, 973, 974) (liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on September 27, 2001
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.724 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 2.5, 3 NPS	0.122 in ²	[D] 0.394 in	0.12 in	15-6250 psi	Water	UV
1-1.5 NPS	2, 2.5, 3 NPS	0.217 in ²	[E] 0.526 in	0.16 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.34 in ²	[F] 0.658 in	0.2 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5, 3 NPS	0.558 in ²	[G] 0.843 in	0.26 in	15-4905 psi	Water	UV
1.5-2 NPS	3 NPS	0.869 in ²	[H] 1.052 in	0.32 in	15-3300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.427 in ²	[J] 1.348 in	0.41 in	15-3300 psi	Water	UV
3 NPS	4, 6 NPS	2.036 in ²	[K] 1.61 in	0.49 in	15-3300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.16 in ²	[L] 2.006 in	0.61 in	15-2900 psi	Water	UV
4 NPS	6 NPS	3.987 in ²	[M] 2.253 in	0.69 in	15-1600 psi	Water	UV
4 NPS	6 NPS	4.807 in ²	[N] 2.474 in	0.75 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.07 in ²	[P] 3 in	0.92 in	15-1600 psi	Water	UV
6 NPS	8 NPS	12.24 in ²	[Q] 3.948 in	1.2 in	15-925 psi	Water	UV
6 NPS	8, 10 NPS	17.72 in ²	[R] 4.75 in	1.45 in	15-350 psi	Water	UV
8 NPS	10 NPS	29.75 in ²	[T] 6.155 in	1.84 in	15-325 psi	Water	UV

Design Name:	RL-14 & RLO-14 (0.315 in. orifice)	NBCert #	73044
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	07/26/2029

Design Type

[Safety Relief Valve] RL-14 & RLO-14 (0.315 in. orifice)
Capacity Tests: Sec. UV at National Board Testing Lab on June 8, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.230 SCFM/PSIA; (alternate medium): 3.460 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.078 in ²	0.315 in	0.078 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.078 in ²	0.315 in	0.078 in	15-5000 psi	Air	UV

Design Name: RL-14 & RLO-14 (0.315 in. orifice) (Liquids) NBCert # 73055		
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	07/26/2029
Design Type		
[Relief Valve] RL-14 & RLO-14 (0.315 in. orifice) (Liquids) Capacity Tests: Sec. UV at National Board Testing Lab on June 4, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.880 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: ARI-Armaturen USA LP {TAR}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.078 in ²	0.315 in	0.078 in	15-5000 psi	Water	UV

Design Name: RL14 & RLO14 (0.394 in. orifice) NBCert # 73202		
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	07/26/2029
Design Type		
[Safety Relief Valve] RL14 & RLO14 (0.394 in. orifice) Capacity Tests: Sec. UV at National Board Testing Lab on September 30, 2014 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.637 SCFM/PSIA; (alternate medium): 4.600 PPH/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: ARI-Armaturen USA LP {TAR}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.122 in ²	0.394 in	0.0985 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.122 in ²	0.394 in	0.0985 in	15-5000 psi	Air	UV

Design Name: RL14 & RLO14 (0.394 in. orifice) (Liquid) NBCert # 73213		
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	07/26/2029
Design Type		
[Relief Valve] RL14 & RLO14 (0.394 in. orifice) (Liquid) Capacity Tests: Sec. UV at National Board Testing Lab on September 30, 2014 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.021 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: ARI-Armaturen USA LP {TAR}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.122 in ²	0.394 in	0.0985 in	15-5000 psi	Water	UV

Design Name:	RL40, RL040 (0.847 in. orifice)	NBCert #	73167
--------------	---------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/19/2030

Design Type

[Safety Relief Valve] RL40, RL040 (0.847 in. orifice)
Capacity Tests: Sec. UV at National Board Testing Lab on November 3, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 8.860 SCFM/PSIA; (alternate medium): 24.890 PPH/PSIA
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2 NPS	0.563 in ²	0.847 in		15-1500 psi	Air	UV
1.5-2 NPS	2 NPS	0.563 in ²	0.847 in		15-1500 psi	Steam	UV

Design Name:	RL40, RL040 (0.847 in. orifice) (liquid)	NBCert #	73178
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	07/26/2029

Design Type

[Relief Valve] RL40, RL040 (0.847 in. orifice) (liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on November 3, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 13.050 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2 NPS	0.563 in ²	0.847 in		15-1500 psi	Water	UV

Design Name:	RL40, RLO40, RL41, RLO41 (0.44 in. orifice)	NBCert #	73145
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	07/26/2029

Design Type

[Safety Relief Valve] RL40, RLO40, RL41, RLO41 (0.44 in. orifice)
Capacity Tests: Sec. UV at National Board Testing Lab on June 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.860 SCFM/PSIA; (alternate medium): 5.230 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1-2 NPS	0.152 in ²	[] 0.44 in	0.365 in	15-2900 psi	Steam	UV

0.75-1 NPS	1-2 NPS	0.152 in ²	[] 0.44 in	0.365 in	15-5000 psi	Air	UV
------------	---------	-----------------------	-------------	----------	-------------	-----	----

Design Name:	RL40, RLO40, RL41, RLO41 (0.44 in. orifice) (Liquids)		NBCert #	73156	
Manufacturer/Assembler			Designators		Expiration Date
Manufacturer			UV		07/26/2029
Design Type					
[Relief Valve] RL40, RLO40, RL41, RLO41 (0.44 in. orifice) (Liquids) Capacity Tests: Sec. UV at National Board Testing Lab on July 26, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.684 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: ARI-Armaturen USA LP {TAR}					

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1-2 NPS	0.152 in ²	0.44 in		15-5000 psi	Water	UV

Design Name:	RL40, RLO40, RL41, RLO41 (0.547 in. orifice) (Liquid), Design Rev. A		NBCert #	73235	
Manufacturer/Assembler			Designators		Expiration Date
Manufacturer			UV		07/26/2029
Design Type					
[Relief Valve] RL40, RLO40, RL41, RLO41 (0.547 in. orifice) (Liquid), Design Rev. A					
Capacity Tests: Sec. UV at National Board Testing Lab on March 4, 2014					
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method					
Certified Value: 5.635 GPM/SQ.RT. PSID					
Media - Test: Liquid; Certified: Liquid					
Set Pressure Definition: First Steady Stream					
Blowdown Characteristics: Fixed					
Flow Area Configuration: Nozzle/Full Lift					
Designed by: ARI-Armaturen USA LP {TAR}					

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	1.5, 2 NPS	0.235 in ²	0.547 in	0.137 in	15-3000 psi	Water	UV

ARI-Armaturen USA LP (TAR)							
Webster, TX 77598United States							

This Company Manufactures or Assembles:

Design Name: 901/902/911/912		NBCert #	08008
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	11/07/2030

Design Type

[Safety Relief Valve] 901/902/911/912
 Capacity Tests: Sec. UV at National Board Testing Lab on November 9, 2001
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.817 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas, Steam
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: ARI-Armaturen Albert Richter GmbH & Co. KG {ARI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5, 2.0 NPS	0.617 in ²	0.886 in	0.22 in	30-493 psi	Air	UV
1 NPS	1.5, 2.0 NPS	0.617 in ²	0.886 in	0.22 in	30-493 psi	Steam	UV
1.25 NPS	2.0 NPS	1.024 in ²	1.142 in	0.29 in	30-493 psi	Air	UV
1.25 NPS	2.0 NPS	1.024 in ²	1.142 in	0.29 in	30-493 psi	Steam	UV
1.5 NPS	2, 2.5 NPS	1.024 in ²	1.142 in	0.29 in	30-493 psi	Air	UV
1.5 NPS	2, 2.5 NPS	1.024 in ²	1.142 in	0.29 in	30-493 psi	Steam	UV
1.5 NPS	2.5, 3.0 NPS	1.578 in ²	1.417 in	0.37 in	30-493 psi	Air	UV
1.5 NPS	2.5, 3.0 NPS	1.578 in ²	1.417 in	0.37 in	30-493 psi	Steam	UV
2 NPS	3 NPS	2.465 in ²	1.772 in	0.45 in	30-493 psi	Air	UV
2 NPS	3 NPS	2.465 in ²	1.772 in	0.45 in	30-493 psi	Steam	UV
2.5-3 NPS	4 NPS	4.166 in ²	2.303 in	0.61 in	30-406 psi	Air	UV
2.5-3 NPS	4 NPS	4.166 in ²	2.303 in	0.61 in	30-406 psi	Steam	UV
4 NPS	6 NPS	9.861 in ²	3.543 in	0.98 in	30-276 psi	Air	UV
4 NPS	6 NPS	9.861 in ²	3.543 in	0.98 in	30-276 psi	Steam	UV
5-6 NPS	8 NPS	13.678 in ²	4.173 in	1.34 in	30-392 psi	Air	UV
5-6 NPS	8 NPS	13.678 in ²	4.173 in	1.34 in	30-392 psi	Steam	UV
6 NPS	10 NPS	19.022 in ²	4.921 in	1.46 in	30-305 psi	Air	UV
6 NPS	10 NPS	19.022 in ²	4.921 in	1.46 in	30-305 psi	Steam	UV

Design Name: 901/902/911/912 (1" liquid) NBCert # 08020

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/21/2029

Design Type

[Relief Valve] 901/902/911/912 (1" liquid)
 Capacity Tests: Sec. UV at National Board Testing Lab on August 24, 2001
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 14.410 GPM/SQ.RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: Opening Pressure
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: ARI-Armaturen Albert Richter GmbH & Co. KG {ARI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5, 2.0 NPS	0.617 in ²	0.886 in	0.22 in	15-493 psi	Water	UV

Design Name: 901/902/911/912 (Liquids)		NBCert #	08019
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	08/07/2029
Design Type			
[Relief Valve] 901/902/911/912 (Liquids) Capacity Tests: Sec. UV at National Board Testing Lab on October 15, 2001 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.545 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: Opening Pressure Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: ARI-Armaturen Albert Richter GmbH & Co. KG {ARI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	2 NPS	1.024 in ²	1.142 in	0.29 in	15-493 psi	Water	UV
1.5 NPS	2, 2.5 NPS	1.024 in ²	1.142 in	0.29 in	15-493 psi	Water	UV
1.5 NPS	2.5, 3 NPS	1.578 in ²	1.417 in	0.37 in	15-493 psi	Water	UV
2 NPS	3 NPS	2.465 in ²	1.772 in	0.45 in	15-493 psi	Water	UV
2.5-3 NPS	4 NPS	4.166 in ²	2.303 in	0.61 in	15-406 psi	Water	UV
4 NPS	6 NPS	9.861 in ²	3.543 in	0.98 in	15-276 psi	Water	UV
5-6 NPS	8 NPS	13.678 in ²	4.173 in	1.34 in	15-392 psi	Water	UV
6 NPS	10 NPS	19.022 in ²	4.921 in	1.46 in	15-305 psi	Water	UV

Design Name: 901/902/911/912 {15-30}		NBCert #	08031
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	11/21/2029
Design Type			
[Safety Relief Valve] 901/902/911/912 {15-30} Capacity Tests: Sec. UV at National Board Testing Lab on May 9, 2007 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.769 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: ARI-Armaturen Albert Richter GmbH & Co. KG {ARI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5, 2.0 NPS	0.394 in ²	0.709 in	0.205 in	15-30 psi	Air	UV
1 NPS	1.5, 2.0 NPS	0.394 in ²	0.709 in	0.205 in	15-30 psi	Steam	UV
1.25 NPS	2.0 NPS	1.024 in ²	1.142 in	0.29 in	15-30 psi	Air	UV
1.25 NPS	2.0 NPS	1.024 in ²	1.142 in	0.29 in	15-30 psi	Steam	UV
1.5 NPS	2, 2.5 NPS	1.024 in ²	1.142 in	0.29 in	15-30 psi	Air	UV
1.5 NPS	2, 2.5 NPS	1.024 in ²	1.142 in	0.29 in	15-30 psi	Steam	UV
1.5 NPS	2.5, 3.0 NPS	1.578 in ²	1.417 in	0.37 in	15-30 psi	Air	UV
1.5 NPS	2.5, 3.0 NPS	1.578 in ²	1.417 in	0.37 in	15-30 psi	Steam	UV

2 NPS	3 NPS	2.465 in ²	1.772 in	0.45 in	15-30 psi	Air	UV
2 NPS	3 NPS	2.465 in ²	1.772 in	0.45 in	15-30 psi	Steam	UV
2.5-3 NPS	4 NPS	4.166 in ²	2.303 in	0.61 in	15-30 psi	Air	UV
2.5-3 NPS	4 NPS	4.166 in ²	2.303 in	0.61 in	15-30 psi	Steam	UV
4 NPS	6 NPS	9.861 in ²	3.543 in	0.98 in	15-30 psi	Air	UV
4 NPS	6 NPS	9.861 in ²	3.543 in	0.98 in	15-30 psi	Steam	UV
5-6 NPS	8 NPS	13.678 in ²	4.173 in	1.34 in	15-30 psi	Air	UV
5-6 NPS	8 NPS	13.678 in ²	4.173 in	1.34 in	15-30 psi	Steam	UV
6 NPS	10 NPS	19.022 in ²	4.921 in	1.46 in	15-30 psi	Air	UV
6 NPS	10 NPS	19.022 in ²	4.921 in	1.46 in	15-30 psi	Steam	UV

Design Name: Reyco R, RB & RO (Fig. 971, 973, 974) NBCert # 73000

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/19/2027

Design Type

[Safety Relief Valve] Reyco R, RB & RO (Fig. 971, 973, 974)
Capacity Tests: Sec. UV at National Board Testing Lab on March 19, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.122 in ²	[D] 0.394 in	0.12 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.122 in ²	[D] 0.394 in	0.12 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.217 in ²	[E] 0.526 in	0.16 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.217 in ²	[E] 0.526 in	0.16 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.34 in ²	[F] 0.658 in	0.2 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.34 in ²	[F] 0.658 in	0.2 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.558 in ²	[G] 0.843 in	0.26 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.558 in ²	[G] 0.843 in	0.26 in	15-4905 psi	Air	UV
1.5-2 NPS	3 NPS	0.869 in ²	[H] 1.052 in	0.32 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.869 in ²	[H] 1.052 in	0.32 in	15-3300 psi	Air	UV
2-3 NPS	3, 4 NPS	1.427 in ²	[J] 1.348 in	0.41 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.427 in ²	[J] 1.348 in	0.41 in	15-3300 psi	Air	UV
3 NPS	4, 6 NPS	2.036 in ²	[K] 1.61 in	0.49 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.036 in ²	[K] 1.61 in	0.49 in	15-3300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.16 in ²	[L] 2.006 in	0.61 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.16 in ²	[L] 2.006 in	0.61 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	3.987 in ²	[M] 2.253 in	0.69 in	15-1600 psi	Air	UV
4 NPS	6 NPS	3.987 in ²	[M] 2.253 in	0.69 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.807 in ²	[N] 2.474 in	0.75 in	15-1600 psi	Air	UV

4 NPS	6 NPS	4.807 in ²	[N] 2.474 in	0.75 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.07 in ²	[P] 3 in	0.92 in	15-1600 psi	Air	UV
4 NPS	6 NPS	7.07 in ²	[P] 3 in	0.92 in	15-1600 psi	Steam	UV
6 NPS	8 NPS	12.24 in ²	[Q] 3.948 in	1.2 in	15-925 psi	Air	UV
6 NPS	8 NPS	12.24 in ²	[Q] 3.948 in	1.2 in	15-925 psi	Steam	UV
6 NPS	8, 10 NPS	17.72 in ²	[R] 4.75 in	1.45 in	15-350 psi	Air	UV
6 NPS	8, 10 NPS	17.72 in ²	[R] 4.75 in	1.45 in	15-350 psi	Steam	UV
8 NPS	10 NPS	29.75 in ²	[T] 6.155 in	1.84 in	15-325 psi	Air	UV
8 NPS	10 NPS	29.75 in ²	[T] 6.155 in	1.84 in	15-325 psi	Steam	UV

Design Name:	Reyco R, RB, RO, RBO (Fig. 971, 973, 974) (liquid)	NBCert #	73011
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/25/2026

Design Type

[Relief Valve] Reyco R, RB, RO, RBO (Fig. 971, 973, 974) (liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on September 27, 2001
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.724 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 2.5, 3 NPS	0.122 in ²	[D] 0.394 in	0.12 in	15-6250 psi	Water	UV
1-1.5 NPS	2, 2.5, 3 NPS	0.217 in ²	[E] 0.526 in	0.16 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.34 in ²	[F] 0.658 in	0.2 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5, 3 NPS	0.558 in ²	[G] 0.843 in	0.26 in	15-4905 psi	Water	UV
1.5-2 NPS	3 NPS	0.869 in ²	[H] 1.052 in	0.32 in	15-3300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.427 in ²	[J] 1.348 in	0.41 in	15-3300 psi	Water	UV
3 NPS	4, 6 NPS	2.036 in ²	[K] 1.61 in	0.49 in	15-3300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.16 in ²	[L] 2.006 in	0.61 in	15-2900 psi	Water	UV
4 NPS	6 NPS	3.987 in ²	[M] 2.253 in	0.69 in	15-1600 psi	Water	UV
4 NPS	6 NPS	4.807 in ²	[N] 2.474 in	0.75 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.07 in ²	[P] 3 in	0.92 in	15-1600 psi	Water	UV
6 NPS	8 NPS	12.24 in ²	[Q] 3.948 in	1.2 in	15-925 psi	Water	UV
6 NPS	8, 10 NPS	17.72 in ²	[R] 4.75 in	1.45 in	15-350 psi	Water	UV
8 NPS	10 NPS	29.75 in ²	[T] 6.155 in	1.84 in	15-325 psi	Water	UV

Design Name:	RL-14 & RLO-14 (0.315 in. orifice)	NBCert #	73044
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/29/2028

Design Type

[Safety Relief Valve] RL-14 & RLO-14 (0.315 in. orifice)
Capacity Tests: Sec. UV at National Board Testing Lab on June 8, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.230 SCFM/PSIA; (alternate medium): 3.460 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.078 in ²	0.315 in	0.078 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.078 in ²	0.315 in	0.078 in	15-5000 psi	Air	UV

Design Name: RL-14 & RLO-14 (0.315 in. orifice) (Liquids) NBCert # 73055

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

08/30/2028

Design Type

[Relief Valve] RL-14 & RLO-14 (0.315 in. orifice) (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on June 4, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.880 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.078 in ²	0.315 in	0.078 in	15-5000 psi	Water	UV

Design Name: RL14 & RLO14 (0.394 in. orifice) NBCert # 73202

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

11/21/2026

Design Type

[Safety Relief Valve] RL14 & RLO14 (0.394 in. orifice)
Capacity Tests: Sec. UV at National Board Testing Lab on September 30, 2014
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.637 SCFM/PSIA; (alternate medium): 4.600 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.122 in ²	0.394 in	0.0985 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.122 in ²	0.394 in	0.0985 in	15-5000 psi	Air	UV

Design Name: RL14 & RLO14 (0.394 in. orifice) (Liquid) NBCert # 73213

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/21/2026

Design Type

[Relief Valve] RL14 & RLO14 (0.394 in. orifice) (Liquid)
 Capacity Tests: Sec. UV at National Board Testing Lab on September 30, 2014
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 3.021 GPM/SQ.RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.122 in ²	0.394 in	0.0985 in	15-5000 psi	Water	UV

Design Name: RL40, RL040 (0.847 in. orifice) NBCert # 73167

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/29/2028

Design Type

[Safety Relief Valve] RL40, RL040 (0.847 in. orifice)
 Capacity Tests: Sec. UV at National Board Testing Lab on November 3, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 8.860 SCFM/PSIA; (alternate medium): 24.890 PPH/PSIA
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2 NPS	0.563 in ²	0.847 in		15-1500 psi	Air	UV
1.5-2 NPS	2 NPS	0.563 in ²	0.847 in		15-1500 psi	Steam	UV

Design Name: RL40, RL040 (0.847 in. orifice) (liquid) NBCert # 73178

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/29/2028

Design Type

[Relief Valve] RL40, RL040 (0.847 in. orifice) (liquid)
 Capacity Tests: Sec. UV at National Board Testing Lab on November 3, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 13.050 GPM/SQ.RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2 NPS	0.563 in ²	0.847 in		15-1500 psi	Water	UV

Design Name:	RL40, RLO40, RL41, RLO41 (0.44 in. orifice)	NBCert #	73145
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	07/26/2028	
Design Type			
[Safety Relief Valve] RL40, RLO40, RL41, RLO41 (0.44 in. orifice) Capacity Tests: Sec. UV at National Board Testing Lab on June 10, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.860 SCFM/PSIA; (alternate medium): 5.230 PPH/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: ARI-Armaturen USA LP {TAR}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1-2 NPS	0.152 in ²	[] 0.44 in	0.365 in	15-2900 psi	Steam	UV
0.75-1 NPS	1-2 NPS	0.152 in ²	[] 0.44 in	0.365 in	15-5000 psi	Air	UV

Design Name:	RL40, RLO40, RL41, RLO41 (0.44 in. orifice) (Liquids)	NBCert #	73156
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	07/26/2028	
Design Type			
[Relief Valve] RL40, RLO40, RL41, RLO41 (0.44 in. orifice) (Liquids) Capacity Tests: Sec. UV at National Board Testing Lab on July 26, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.684 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: ARI-Armaturen USA LP {TAR}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1-2 NPS	0.152 in ²	0.44 in		15-5000 psi	Water	UV

Design Name:	RL40, RLO40, RL41, RLO41 (0.547 in. orifice) (Liquid), Design Rev. A	NBCert #	73235
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	04/10/2029	
Design Type			
[Relief Valve] RL40, RLO40, RL41, RLO41 (0.547 in. orifice) (Liquid), Design Rev. A Capacity Tests: Sec. UV at National Board Testing Lab on March 4, 2014 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.635 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: ARI-Armaturen USA LP {TAR}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	1.5, 2 NPS	0.235 in ²	0.547 in	0.137 in	15-3000 psi	Water	UV

Design Name: RL40, RLO40, RL41, RLO41 (0.547 in. orifice), Design Rev. A			NBCert #		73224		
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			09/29/2026	
Design Type							
[Safety Relief Valve] RL40, RLO40, RL41, RLO41 (0.547 in. orifice), Design Rev. A Capacity Tests: Sec. UV at National Board Testing Lab on March 4, 2014 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.760 SCFM/PSIA; (alternate medium): 10.560 PPH/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: ARI-Armaturen USA LP {TAR}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	1.5, 2 NPS	0.235 in²	0.547 in	0.137 in	15-2900 psi	Steam	UV
1-1.5 NPS	1.5, 2 NPS	0.235 in²	0.547 in	0.137 in	15-3000 psi	Air	UV

Atlantic Valve Services LLC (AGN)

Nameplate Abbreviation: Atlantic Valve Services

Swedesboro, NJ 08085United States

This Company Manufactures or Assembles:

Design Name: 243/249/443/449/546/843/849/943/5046/5049/8043/8049		NBCert # 01292					
Manufacturer/Assembler		Designators	Expiration Date				
Assembler		UV	03/22/2031				
Design Type							
[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049 Capacity Tests: Sec. UV at unknown lab on August 8, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Air/Gas; Certified: Air, Gas, Steam Set Pressure Definition(1): Pop; (2): Initial Audible Discharge Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV

4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name: 253/259/453/459/853/859/953/959/5059/8053/8059 NBCert # 01304

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/22/2031

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
Capacity Tests: Sec. UV at unknown lab on July 31, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.627 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 263/269/463/469/566/863/869/963/969/5066/5069 NBCert # 01315

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/22/2031

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069
Capacity Tests: Sec. UV at unknown lab on July 30, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name:	81, 81P, 83, 84	NBCert #	01089
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 05/08/2031

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV

0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 900 Series (Liquid), 7700, SNC NBCert # 15499

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/22/2031

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name: 900 Series, 7700, SNC NBCert # 15411

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/22/2031

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: HL, HSL

NBCert # 15589

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	02/18/2031

Design Type

[Safety Valve] HL, HSL
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on November 3, 1999
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.869 Unitless
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	1.5 NPS	0.339 in ²	[F] 0.657 in	0.164 in	15-725 psi	Steam	UV, V
1.25-2 NPS	1.5 NPS	0.553 in ²	[G] 0.839 in	0.21 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.868 in ²	[H] 1.051 in	0.263 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.327 in ²	[J] 1.3 in	0.325 in	15-725 psi	Steam	UV, V
2-3 NPS	3-4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-725 psi	Steam	UV, V
2.5-4 NPS	4-6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-725 psi	Steam	UV, V
3 NPS	4-6 NPS	3.955 in ²	[M] 2.244 in	0.561 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	4.831 in ²	[N] 2.48 in	0.62 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	7.031 in ²	[P] 2.992 in	0.748 in	15-725 psi	Steam	UV, V

6 NPS	8 NPS	11.045 in ²	[QQ] 3.75 in	0.937 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	0.984 in	15-725 psi	Steam	UV, V

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Liquids)	NBCert #	15095
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/29/2031

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V

6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/22/2031

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV

4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

AVP Valve, Inc. (AVP)

Nameplate Abbreviation: AVP Valve, Inc.

Lakeland, FL 33813United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3		NBCert #	18032
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV, V	06/27/2030	

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1700 & 2700

NBCert # 18100

Manufacturer/Assembler	Designators	Expiration Date
Assembler	V	07/30/2030

Design Type

[Safety Valve] 1700 & 2700
 Capacity Tests: Sec. UV, V at Dresser, Inc. on August 1, 1957
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	50-5800 psi	Steam	V
4 NPS	4 dual NPS	1.84 in ²	[K] 1.531 in	0.383 in	50-5800 psi	Steam	V
2-3 NPS	4, 6 NPS	2.545 in ²	[#3] 1.8 in	0.45 in	50-5800 psi	Steam	UV, V
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-2575 psi	Steam	UV
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	50-5800 psi	Steam	V
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	15-3100 psi	Steam	UV
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	50-5800 psi	Steam	V
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	15-3100 psi	Steam	UV
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	15-1800 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	1.24 in	50-2200 psi	Steam	UV, V
8-10 NPS	10,12 NPS	28.3 in ²	[T] 6 in	1.5 in	50-1500 psi	Steam	UV, V

Design Name: 1700 & 2700 (Restricted Lift version of Cert. # 18100) NBCert # 18111

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	07/30/2030

Design Type

[Safety Valve] 1700 & 2700 (Restricted Lift version of Cert. # 18100)
 Capacity Tests: Sec. UV, V at unknown lab on October 13, 1981
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Restricted Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	50-5800 psi	Steam	V
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	15-3100 psi	Steam	UV
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	50-5800 psi	Steam	V
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-2575 psi	Steam	UV
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	50-5800 psi	Steam	V
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	15-3100 psi	Steam	UV
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	50-5800 psi	Steam	V
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	15-3100 psi	Steam	UV
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.946 in	0.296 in	15-2000 psi	Steam	UV, V
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	0.372 in	50-2200 psi	Steam	V
8-10 NPS	10, 12 NPS	28.3 in ²	[T] 6 in	0.45 in	50-1500 psi	Steam	UV, V

Design Name: 1811, 1511

NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	07/30/2030

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA (Liquids) NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/31/2030

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V

1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

07/30/2030

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV

3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/30/2030

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert #

18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

06/14/2027

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 3900 (39PV, 39MV pilots)

NBCert #

18447

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

06/15/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV

4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name:	3900 (39PV, 39MV pilots, liquid)	NBCert #	18458
Manufacturer/Assembler	Designators	Expiration Date	

Assembler UV 06/16/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV

1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

AWC, Inc. (AWI)

Baton Rouge, LA 70809United States

This Company Manufactures or Assembles:

Design Name: 2400		NBCert # 57451	
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	05/26/2026

Design Type

[Safety Relief Valve] 2400

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on August 28, 2019

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.817 Unitless

Media - Test: Air/Gas; Certified: Air, Gas

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75-1 NPS	0.049 in ²	[B] 0.25 in	0.08 in	20-2000 psi	Air	UV
0.5-1 NPS	1-2 NPS	0.11 in ²	[D] 0.375 in	0.12 in	20-1410 psi	Air	UV
0.75-1 NPS	1-2 NPS	0.196 in ²	[E] 0.5 in	0.175 in	20-600 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.295 in	20-4000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.365 in	20-3000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.435 in	20-2500 psi	Air	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

03/18/2031

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV

3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids)	NBCert # 57068
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/18/2031

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V

8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/18/2031

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/18/2031

Design Type

[Relief Valve] 2700L, 3700L (Liquids)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.676 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800

NBCert # 57024

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

03/18/2031

Design Type

[Pilot Operated Pressure Relief Valve] 3800

Capacity Tests: Sec. UV at unknown lab on May 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.859 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (3): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV

2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name: 4200 / 4400

NBCert # 57282

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV, V

05/27/2026

Design Type

[Safety Valve] 4200 / 4400
Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.872 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V

6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V
-------	-------	------------------------	--------------	----------	-------------	-------	-------

Design Name:	6400/6600 (previously 2500 & 4600)	NBCert #	57046
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV, V	05/26/2026
-----------	-------	------------

Design Type

[Safety Valve] 6400/6600 (previously 2500 & 4600)
Capacity Tests: Sec. UV, V at Ohio State University (Robinson Laboratory) on January 28, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	V
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	V
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	V
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Air	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	V
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Air	UV

3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Air	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	V
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	V
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	UV

AWC, Inc. (ACI)

Corpus Christi, TX 78409United States

This Company Manufactures or Assembles:

Design Name:	2600 & 2600S	NBCert #	57057
Manufacturer/Assembler	Designators	Expiration Date	

Assembler	UV	10/03/2029
-----------	----	------------

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV

1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)			NBCert # 57260	
Manufacturer/Assembler		Designators		Expiration Date
Assembler		UV		10/03/2029

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids)				NBCert # 57068			
Manufacturer/Assembler			Designators		Expiration Date		
Assembler			UV		10/03/2029		
Design Type							
[Relief Valve] 2600L (Liquids) Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.652 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S		NBCert # 57237
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/03/2029
Design Type		
[Safety Relief Valve] 2700, 2700S, 3700, 3700S Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	10/03/2029
-----------	----	------------

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800L, PCL, PCM pilots		NBCert # 57215
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/03/2029
Design Type		
[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.782 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition(1): Pop; (2): First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Design Name: 4200 / 4400		NBCert # 57282
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	10/03/2029
Design Type		
[Safety Valve] 4200 / 4400 Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.872 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

Design Name: 6400/6600 (previously 2500 & 4600) NBCert # 57046

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	10/03/2029

Design Type

[Safety Valve] 6400/6600 (previously 2500 & 4600)
Capacity Tests: Sec. UV, V at Ohio State University (Robinson Laboratory) on January 28, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	V
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	V
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	V

2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Air	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	V
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Air	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	V
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	V
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	UV

AWC, Inc. (AIN)

Westlake, LA 70669United States

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S		NBCert # 57057
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/02/2031
Design Type		

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV

18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam) NBCert # 57260

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/02/2031

Design Type

[Safety Relief Valve] 2600L (Air & Steam)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV

8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name:	2600L (Liquids)	NBCert #	57068
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/02/2031

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/02/2031

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids)

NBCert #

57248

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/02/2031

Design Type

[Relief Valve] 2700L, 3700L (Liquids)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.676 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV

0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800	NBCert # 57024
-------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/02/2031

Design Type

[Pilot Operated Pressure Relief Valve] 3800
Capacity Tests: Sec. UV at unknown lab on May 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV

4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name: 3800L, PCL, PCM pilots

NBCert #

57215

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

04/02/2031

Design Type

[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.782 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

AWC, Inc. (INP)

Port Arthur, TX 77640United States

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S				NBCert # 57057			
Manufacturer/Assembler			Designators		Expiration Date		
Assembler			UV		02/27/2030		
Design Type							
[Safety Relief Valve] 2600 & 2600S Capacity Tests: Sec. UV at unknown lab on June 11, 1972 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.858 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV

6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

02/27/2030

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV

2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids) NBCert # 57068

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/27/2030

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V

4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/27/2030

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids)		NBCert #	57248
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	02/27/2030	
Design Type			
[Relief Valve] 2700L, 3700L (Liquids) Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.676 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800FP		NBCert #	57035
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	02/27/2030	
Design Type			
[Pilot Operated Pressure Relief Valve] 3800FP Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on April 26, 1994 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.801 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition(1): Pop; (3): Initial Audible Discharge Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-1050 psi	Steam	UV
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-11300 psi	Air	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-1050 psi	Steam	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-11300 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-1050 psi	Steam	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-11300 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-1050 psi	Steam	UV

3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-11300 psi	Air	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-6300 psi	Air	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-6300 psi	Air	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-2300 psi	Air	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1500 psi	Air	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-800 psi	Steam	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-1500 psi	Air	UV

Design Name: 3800L, PCL, PCM pilots NBCert # 57215

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/27/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.782 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Design Name:	4200 / 4400	NBCert #	57282
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 11/13/2030

Design Type

[Safety Valve] 4200 / 4400
Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.872 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

Design Name:	6400/6600 (previously 2500 & 4600)	NBCert #	57046
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 01/15/2031

Design Type

[Safety Valve] 6400/6600 (previously 2500 & 4600)
Capacity Tests: Sec. UV, V at Ohio State University (Robinson Laboratory) on January 28, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV

1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	V
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	V
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	V
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Air	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	V
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Air	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	V
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	V
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	UV

AWC, Inc. (ITG)

Deer Park, TX 77536United States

This Company Manufactures or Assembles:

Design Name:	1890, 1892, 1895, 1896	NBCert #	57013
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/09/2027

Design Type

[Safety Relief Valve] 1890, 1892, 1895, 1896
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 4.410 PPH/PSIA; (alternate medium): 1.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.094 in	15-800 psi	Air	UV
0.5-0.75 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.094 in	15-800 psi	Air	NV
0.5-0.75 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.094 in	15-800 psi	Steam	UV
0.5-0.75 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.094 in	15-800 psi	Steam	NV

Design Name:	1890L, 1892L, 1895L, 1896L (Liquids)	NBCert #	57192
--------------	--------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/09/2027

Design Type

[Relief Valve] 1890L, 1892L, 1895L, 1896L (Liquids)
Capacity Tests: Sec. UV at unknown lab on January 14, 1993
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.210 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	3/4, 1 NPS	0.11 in ²	0.375 in	0.08 in	15-800 psi	Water	UV

Design Name:	2600 & 2600S	NBCert #	57057
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/28/2030

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV

18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600 Series Restricted Lift version of Cert Number 57057 NBCert # 57406

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/09/2027

Design Type

[Safety Relief Valve] 2600 Series Restricted Lift version of Cert Number 57057

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 10, 2017

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable (Single Ring)

Flow Area Configuration: Restricted Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Air	UV
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Steam	UV
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Air	UV
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Steam	UV
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Air	UV
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Steam	UV
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.08 in	15-7000 psi	Air	UV
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.08 in	15-7000 psi	Steam	UV
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.095 in	15-6000 psi	Air	UV
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.095 in	15-6000 psi	Steam	UV
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.122 in	15-6000 psi	Air	UV
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.122 in	15-6000 psi	Steam	UV
3 in	4, 6 in	2.042 in ²	[K] 1.612 in	0.145 in	15-5000 psi	Air	UV
3 in	4, 6 in	2.042 in ²	[K] 1.612 in	0.145 in	15-5000 psi	Steam	UV
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.181 in	15-4000 psi	Air	UV
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.181 in	15-4000 psi	Steam	UV
4 in	6 in	4 in ²	[M] 2.257 in	0.203 in	15-3000 psi	Air	UV
4 in	6 in	4 in ²	[M] 2.257 in	0.203 in	15-3000 psi	Steam	UV
4 in	6 in	4.822 in ²	[N] 2.478 in	0.223 in	15-3000 psi	Air	UV
4 in	6 in	4.822 in ²	[N] 2.478 in	0.223 in	15-3000 psi	Steam	UV
4 in	6 in	7.087 in ²	[P] 3.004 in	0.27 in	15-2500 psi	Air	UV
4 in	6 in	7.087 in ²	[P] 3.004 in	0.27 in	15-2500 psi	Steam	UV
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.356 in	15-2000 psi	Air	UV
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.356 in	15-2000 psi	Steam	UV
6 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.428 in	15-1500 psi	Air	UV
6 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.428 in	15-1500 psi	Steam	UV

8 in	10 in	28.94 in ²	[T] 6.07 in	0.546 in	15-1000 psi	Air	UV
8 in	10 in	28.94 in ²	[T] 6.07 in	0.546 in	15-1000 psi	Steam	UV
8 in	10 in	31.5 in ²	[U] 6.333 in	0.57 in	15-300 psi	Air	UV
8 in	10 in	31.5 in ²	[U] 6.333 in	0.57 in	15-300 psi	Steam	UV
10 in	14 in	49.4 in ²	[V] 7.93 in	0.714 in	15-1000 psi	Air	UV
10 in	14 in	49.4 in ²	[V] 7.93 in	0.714 in	15-1000 psi	Steam	UV
12 in	16 in	63.62 in ²	[W] 9 in	0.81 in	15-1000 psi	Air	UV
12 in	16 in	63.62 in ²	[W] 9 in	0.81 in	15-1000 psi	Steam	UV
16 in	18 in	104 in ²	[W2] 11.507 in	1.036 in	15-750 psi	Air	UV
16 in	18 in	104 in ²	[W2] 11.507 in	1.036 in	15-750 psi	Steam	UV
16 in	20 in	113.1 in ²	[X] 12 in	1.08 in	15-750 psi	Air	UV
16 in	20 in	113.1 in ²	[X] 12 in	1.08 in	15-750 psi	Steam	UV
18 in	24 in	143.1 in ²	[Y] 13.5 in	1.215 in	15-750 psi	Air	UV
18 in	24 in	143.1 in ²	[Y] 13.5 in	1.215 in	15-750 psi	Steam	UV
20 in	24 in	176.7 in ²	[Z] 15 in	1.35 in	15-750 psi	Air	UV
20 in	24 in	176.7 in ²	[Z] 15 in	1.35 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam) NBCert # 57260

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/28/2030

Design Type

[Safety Relief Valve] 2600L (Air & Steam)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV

3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name:	2600L (Air & Steam) Series Restricted Lift version of Cert Number 57260	NBCert #	57439
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	08/20/2027
-----------	----	------------

Design Type

[Safety Relief Valve] 2600L (Air & Steam) Series Restricted Lift version of Cert Number 57260
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 6, 2018
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.08 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.08 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.08 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.089 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.089 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.111 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.111 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.142 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.142 in	15-6000 psi	Air	UV

3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.169 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.169 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.211 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.211 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.237 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.237 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.26 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.26 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.315 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.315 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.415 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.415 in	15-2000 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	0.5 in	15-1500 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	0.5 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	0.638 in	15-1000 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	0.638 in	15-1000 psi	Steam	UV
8 NPS	10 NPS	31.5 in ²	[U] 6.333 in	0.665 in	15-300 psi	Air	UV
8 NPS	10 NPS	31.5 in ²	[U] 6.333 in	0.665 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids) NBCert # 57068

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/28/2030

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V

6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name:	2600L (Liquids) Series Restricted Lift version of Cert Number 57068.	NBCert #	57417
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/09/2027

Design Type

[Safety Relief Valve] 2600L (Liquids) Series Restricted Lift version of Cert Number 57068.
Capacity Tests: Sec. UV, V at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on January 23, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Water	UV, V
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-6000 psi	Water	UV, V
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-5000 psi	Water	UV, V
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.098 in	15-3600 psi	Water	UV, V
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.122 in	15-2750 psi	Water	UV, V
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.156 in	15-2700 psi	Water	UV, V
3 in	4, 6 in	2.041 in ²	[K] 1.612 in	0.187 in	15-2200 psi	Water	UV, V
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.232 in	15-1500 psi	Water	UV, V
4 in	6 in	4 in ²	[M] 2.257 in	0.261 in	15-1100 psi	Water	UV, V
4 in	6 in	4.822 in ²	[N] 2.478 in	0.287 in	15-1000 psi	Water	UV, V
4 in	6 in	7.087 in ²	[P] 3.004 in	0.348 in	15-1000 psi	Water	UV, V
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.458 in	15-900 psi	Water	UV, V
6-8 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.551 in	15-600 psi	Water	UV, V
8 in	10 in	28.94 in ²	[T] 6.07 in	0.702 in	15-300 psi	Water	UV, V
8 in	10 in	31.5 in ²	[U] 6.333 in	0.741 in	15-300 psi	Water	UV, V

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/28/2030

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids)

NBCert #

57248

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/28/2030

Design Type

[Relief Valve] 2700L, 3700L (Liquids)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.676 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV

0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800	NBCert # 57024
-------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/28/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3800
Capacity Tests: Sec. UV at unknown lab on May 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV

4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name:	3800FP	NBCert #	57035
--------------	--------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/28/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3800FP
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on April 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-1050 psi	Steam	UV
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-11300 psi	Air	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-1050 psi	Steam	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-11300 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-1050 psi	Steam	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-11300 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-1050 psi	Steam	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-11300 psi	Air	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-6300 psi	Air	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-6300 psi	Air	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-2300 psi	Air	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1500 psi	Air	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-800 psi	Steam	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-1500 psi	Air	UV

Design Name: 3800L, PCL, PCM pilots				NBCert # 57215			
Manufacturer/Assembler			Designators		Expiration Date		
Assembler			UV		06/28/2030		
Design Type							
[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.782 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition(1): Pop; (2): First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Design Name: 4200 / 4400		NBCert # 57282
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/30/2031
Design Type		
<p>[Safety Valve] 4200 / 4400 Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.872 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}</p>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

Design Name: 6400/6600 (previously 2500 & 4600) NBCert # 57046

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/30/2031

Design Type

[Safety Valve] 6400/6600 (previously 2500 & 4600)
Capacity Tests: Sec. UV, V at Ohio State University (Robinson Laboratory) on January 28, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	V
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	V
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	V

2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Air	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	V
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Air	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	V
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	V
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	UV

Baird Valve and Regulator, LLC (BRD)

Nameplate Abbreviation: BAIRD

Tulsa, OK 74103United States

This Company Manufactures or Assembles:

Design Name: 7100-2 G/GS		NBCert #	04048
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	05/31/2029	
Design Type			

[Safety Relief Valve] 7100-2 G/GS
Capacity Tests: Sec. UV at unknown lab on December 4, 1971
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.970 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Baird Valve and Regulator, LLC {BRD}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	0.442 in²	0.75 in	0.218 in	20-600 psi	Air	UV
Design Name: 731-1 G/GS NBCert # 04004							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			08/29/2029	
Design Type							
[Safety Relief Valve] 731-1 G/GS Capacity Tests: Sec. UV at unknown lab on October 10, 1984 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.963 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Baird Valve and Regulator, LLC {BRD}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.066 in²	0.456 in	0.125 in	25-2500 psi	Air	UV

Baker Hughes Solutions (Singapore) Pte. Ltd. (DSP)

Singapore, 628631Singapore

Nameplate Abbreviation: BHSS

This Company Manufactures or Assembles:

Design Name: 1900, 1900-30 1900-35 LA & DALA (Liquids)			NBCert # 18784				
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		04/24/2031		
Design Type							
[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids) Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.670 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V

3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35 NBCert # 18201

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 04/24/2031

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV

4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	04/24/2031
--------------	----	------------

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV

1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 07/24/2025

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 10/03/2031

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert # 18751

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	06/07/2027

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 3.256 GPM/SQ.RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM NBCert # 19066

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/25/2030

Design Type

[Safety Relief Valve] 1900-DM
 Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
 Set Pressure Definition(1): Pop; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D

NBCert #

19088

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

03/25/2030

Design Type

[Safety Relief Valve] 1900-DM-D

Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Curtain Area

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2

NBCert #

18166

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

04/24/2031

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2

Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable (Single Ring)

Flow Area Configuration: Curtain Area

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/24/2031

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids) NBCert # 19077

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/26/2027

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 2900 (39PV & 39MV pilots - Liquid) NBCert # 18874

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/17/2026

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots - Liquid)
 Capacity Tests: Sec. UV, V at Dresser, Inc. on June 25, 1999
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.670 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.127 in	15-6250 psi	Water	UV, V
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	UV, V
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.205 in	15-6250 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-6250 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-6000 psi	Water	UV, V
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-6000 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-3750 psi	Water	UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-2250 psi	Water	UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-1500 psi	Water	UV, V
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.738 in	15-1500 psi	Water	UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-905 psi	Water	UV, V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV, V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.93 in	15-675 psi	Water	UV, V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-535 psi	Water	UV, V

Design Name: 2900 (39PV & 39MV pilots) NBCert # 18863

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/17/2026

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
 Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV

1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots) NBCert # 18447

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/17/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV

4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid) NBCert # 18458

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/17/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV

1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

BAPTEEC LTD (BAP)

Beijing, 100176People's Republic of China

This Company Manufactures or Assembles:

Design Name: HT Series		NBCert #	12407
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	07/06/2030

Design Type

[Safety Relief Valve] HT Series
 Capacity Tests: Sec. UV at National Board Testing Lab on August 20, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.872 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: BAPTEEC LTD {BAP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.134 in ²	[D] 0.4134 in	0.124 in	15-2900 psi	Steam	UV
1-1.5 NPS	2, 3 NPS	0.134 in ²	[D] 0.4134 in	0.124 in	15-6000 psi	Air	UV
1-1.5 NPS	2, 3 NPS	0.239 in ²	[E] 0.5512 in	0.165 in	15-2900 psi	Steam	UV
1-1.5 NPS	2, 3 NPS	0.239 in ²	[E] 0.5512 in	0.165 in	15-6000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.352 in ²	[F] 0.6693 in	0.201 in	15-2900 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.352 in ²	[F] 0.6693 in	0.201 in	15-5000 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.589 in ²	[G] 0.866 in	0.26 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.589 in ²	[G] 0.866 in	0.26 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.319 in	15-2750 psi	Steam	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.319 in	15-2750 psi	Air	UV
2-3 NPS	3, 4 NPS	1.448 in ²	[J] 1.358 in	0.407 in	15-2700 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.448 in ²	[J] 1.358 in	0.407 in	15-2700 psi	Air	UV
3 NPS	4, 6 NPS	2.097 in ²	[K] 1.634 in	0.49 in	15-2220 psi	Air	UV
3 NPS	4, 6 NPS	2.097 in ²	[K] 1.634 in	0.49 in	15-2220 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.23 in ²	[L] 2.028 in	0.608 in	15-1500 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.23 in ²	[L] 2.028 in	0.608 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.097 in ²	[M] 2.284 in	0.685 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	4.097 in ²	[M] 2.284 in	0.685 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.988 in ²	[N] 2.52 in	0.756 in	15-1000 psi	Air	UV
4 NPS	6 NPS	4.988 in ²	[N] 2.52 in	0.756 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	7.22 in ²	[P] 3.032 in	0.909 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	7.22 in ²	[P] 3.032 in	0.909 in	15-1000 psi	Air	UV
6 NPS	8 NPS	12.667 in ²	[Q] 4.016 in	1.206 in	15-600 psi	Steam	UV
6 NPS	8 NPS	12.667 in ²	[Q] 4.016 in	1.206 in	15-600 psi	Air	UV
6 NPS	8, 10 NPS	18.118 in ²	[R] 4.803 in	1.441 in	15-300 psi	Air	UV
6 NPS	8, 10 NPS	18.118 in ²	[R] 4.803 in	1.441 in	15-300 psi	Steam	UV
8 NPS	10 NPS	29.628 in ²	[T] 6.142 in	1.843 in	15-300 psi	Steam	UV
8 NPS	10 NPS	29.628 in ²	[T] 6.142 in	1.843 in	15-300 psi	Air	UV
10 NPS	14 NPS	43.943 in ²	[V] 7.48 in	2.244 in	15-285 psi	Steam	UV
10 NPS	14 NPS	43.943 in ²	[V] 7.48 in	2.244 in	15-285 psi	Air	UV
12 NPS	16 NPS	61.626 in ²	[W] 8.858 in	2.658 in	15-285 psi	Air	UV
12 NPS	16 NPS	61.626 in ²	[W] 8.858 in	2.658 in	15-285 psi	Steam	UV
14 NPS	18 NPS	82.291 in ²	[Y] 10.236 in	3.071 in	15-145 psi	Steam	UV

14 NPS	18 NPS	82.291 in ²	[Y] 10.236 in	3.071 in	15-145 psi	Air	UV
16 NPS	18 NPS	95.448 in ²	[Z] 11.024 in	3.307 in	15-145 psi	Steam	UV
16 NPS	18 NPS	95.448 in ²	[Z] 11.024 in	3.307 in	15-145 psi	Air	UV
16 NPS	20 NPS	109.563 in ²	[Z1] 11.811 in	3.543 in	15-145 psi	Air	UV
16 NPS	20 NPS	109.563 in ²	[Z1] 11.811 in	3.543 in	15-145 psi	Steam	UV
18 NPS	24 NPS	140.732 in ²	[AA] 13.386 in	4.016 in	15-145 psi	Steam	UV
18 NPS	24 NPS	140.732 in ²	[AA] 13.386 in	4.016 in	15-145 psi	Air	UV
20 NPS	24 NPS	166.66 in ²	[BB] 14.567 in	4.37 in	15-145 psi	Steam	UV
20 NPS	24 NPS	166.66 in ²	[BB] 14.567 in	4.37 in	15-145 psi	Air	UV

Design Name: HT Series (Liquid) NBCert # 12429

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/13/2026

Design Type

[Safety Relief Valve] HT Series (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on May 20, 2014
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.751 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: BAPTEEC LTD {BAP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.134 in ²	[D] 0.4134 in	0.124 in	15-6000 psi	Water	UV
1-1.5 NPS	2-3 NPS	0.239 in ²	[E] 0.5512 in	0.165 in	15-6000 psi	Water	UV
1.5 NPS	2-3 NPS	0.352 in ²	[F] 0.6693 in	0.201 in	15-5000 psi	Water	UV
1.5-2 NPS	2.5-3 NPS	0.589 in ²	[G] 0.8661 in	0.26 in	15-3705 psi	Water	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.319 in	15-2750 psi	Water	UV
2-3 NPS	3-4 NPS	1.448 in ²	[J] 1.358 in	0.407 in	15-2700 psi	Water	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.49 in	15-2220 psi	Water	UV
3-4 NPS	4-6 NPS	3.23 in ²	[L] 2.028 in	0.608 in	15-1500 psi	Water	UV
4 NPS	6 NPS	4.097 in ²	[M] 2.284 in	0.685 in	15-1100 psi	Water	UV
4 NPS	6 NPS	4.988 in ²	[N] 2.52 in	0.756 in	15-1000 psi	Water	UV
4 NPS	6 NPS	7.22 in ²	[P] 3.032 in	0.909 in	15-1000 psi	Water	UV
6 NPS	8 NPS	12.667 in ²	[Q] 4.016 in	1.206 in	15-600 psi	Water	UV
6 NPS	8-10 NPS	18.118 in ²	[R] 4.803 in	1.441 in	15-600 psi	Water	UV
8 NPS	10 NPS	29.628 in ²	[T] 6.142 in	1.843 in	15-600 psi	Water	UV
10 NPS	14 NPS	43.943 in ²	[V] 7.48 in	2.244 in	15-500 psi	Water	UV
12 NPS	16 NPS	61.626 in ²	[W] 8.858 in	2.658 in	15-500 psi	Water	UV
14 NPS	18 NPS	82.291 in ²	[Y] 10.236 in	3.071 in	15-145 psi	Water	UV
16 NPS	18 NPS	95.448 in ²	[Z] 11.024 in	3.307 in	15-145 psi	Water	UV
16 NPS	20 NPS	109.563 in ²	[Z1] 11.811 in	3.543 in	15-145 psi	Water	UV
18 NPS	24 NPS	140.732 in ²	[AA] 13.386 in	4.016 in	15-145 psi	Water	UV

Design Name: HTBPO		NBCert #	12463
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	05/17/2029
Design Type			
[Buckling Pin Non-reclosing Device] HTBPO Capacity Tests: Sec. UD at National Board Testing Lab on November 1, 2016 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.790 Unitless Media - Test: Air/Gas; Certified: Air/Gas Set Pressure Definition: Buckling Pressure Flow Area Configuration: Nozzle/Full Lift Designed by: BAPTEEC LTD {BAP}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1 NPS	2 NPS	0.77 in ²	0.99 in	0.81 in	50-1480 psi	Air	UD
1.5 NPS	2, 3 NPS	1.89 in ²	1.55 in	0.98 in	15-1480 psi	Air	UD
2 NPS	3 NPS	2.92 in ²	1.93 in	1.09 in	15-1480 psi	Air	UD
3 NPS	4 NPS	7.63 in ²	3.12 in	1.45 in	15-1480 psi	Air	UD
4 NPS	6 NPS	11.74 in ²	3.87 in	1.67 in	15-1480 psi	Air	UD
6 NPS	8 NPS	27.03 in ²	5.87 in	2.27 in	15-1480 psi	Air	UD
8 NPS	10 NPS	45.52 in ²	7.61 in	2.8 in	15-1480 psi	Air	UD
10 NPS	12 NPS	72.58 in ²	9.61 in	3.4 in	15-1480 psi	Air	UD
12 NPS	14 NPS	101.42 in ²	11.36 in	3.92 in	15-1480 psi	Air	UD
14 NPS	16 NPS	140.26 in ²	13.36 in	4.52 in	15-740 psi	Air	UD
16 NPS	18 NPS	185.38 in ²	15.36 in	5.12 in	15-740 psi	Air	UD
18 NPS	20 NPS	239.55 in ²	17.46 in	5.75 in	15-740 psi	Air	UD
20 NPS	24 NPS	297.55 in ²	19.46 in	6.35 in	15-285 psi	Air	UD
24 NPS	30 NPS	431.87 in ²	23.44 in	7.55 in	15-285 psi	Air	UD
26 NPS	32 NPS	508.68 in ²	25.44 in	8.15 in	15-285 psi	Air	UD
28 NPS	34 NPS	554.34 in ²	26.57 in	8.48 in	15-285 psi	Air	UD
30 NPS	36 NPS	633.72 in ²	28.41 in	9.03 in	15-285 psi	Air	UD

Design Name: HTBP-R (12" to 78" NPS)		NBCert #	12531
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	09/17/2025
Design Type			
[Buckling Pin Non-reclosing Device] HTBP-R (12" to 78" NPS) Capacity Tests: Sec. UD at National Board Testing Lab on March 27, 2019 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 1.850 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Buckling Pressure Flow Area Configuration: MNFA Designed by: BAPTEEC LTD {BAP}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
12 NPS		69.499 in ²			0.5-2250 psi		UD
14 NPS		87.582 in ²			0.5-2250 psi		UD
16 NPS		131.194 in ²			0.5-2250 psi		UD
18 NPS		159.002 in ²			0.5-2250 psi		UD
20 NPS		203.962 in ²			0.5-2250 psi		UD
24 NPS		300.948 in ²			0.5-2250 psi		UD
26 NPS		346.158 in ²			0.5-1440 psi		UD
28 NPS		409.581 in ²			0.5-1440 psi		UD
30 NPS		471.939 in ²			0.5-1440 psi		UD
32 NPS		538.459 in ²			0.5-1440 psi		UD
34 NPS		616.345 in ²			0.5-1440 psi		UD
36 NPS		695.963 in ²			0.5-1440 psi		UD
38 NPS		766.379 in ²			0.5-1440 psi		UD
40 NPS		838.094 in ²			0.5-1440 psi		UD
42 NPS		939.041 in ²			0.5-1440 psi		UD
44 NPS		1045.61 in ²			0.5-1440 psi		UD
46 NPS		1157.81 in ²			0.5-1440 psi		UD
48 NPS		1249.77 in ²			0.5-1440 psi		UD
50 NPS		1368.57 in ²			0.5-720 psi		UD
52 NPS		1500.77 in ²			0.5-720 psi		UD
54 NPS		1618.93 in ²			0.5-720 psi		UD
56 NPS		1745.04 in ²			0.5-720 psi		UD
58 NPS		1887.79 in ²			0.5-720 psi		UD
60 NPS		2001.59 in ²			0.5-720 psi		UD
64 NPS		2276.45 in ²			0.5-720 psi		UD
68 NPS		2559.78 in ²			0.5-720 psi		UD
72 NPS		2880.38 in ²			0.5-720 psi		UD
78 NPS		3167.95 in ²			0.5-720 psi		UD

Design Name:	HTBP-R (2" to 10" NPS)	NBCert #	12496
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	05/24/2027

Design Type

[Buckling Pin Non-reclosing Device] HTBP-R (2" to 10" NPS)
 Capacity Tests: Sec. UD at National Board Testing Lab on March 27, 2019
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 12.130 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Buckling Pressure
 Flow Area Configuration: MNFA
 Designed by: BAPTEEC LTD {BAP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS		47.584 mm ²			0.5-2250 psi		UD
2 NPS		1.002 in ²			0.5-2250 psi		UD
2.5 NPS		1.423 in ²			0.5-2250 psi		UD
3 NPS		2.811 in ²			0.5-2250 psi		UD
4 NPS		5.064 in ²			0.5-2250 psi		UD
6 NPS		15.029 in ²			0.5-2250 psi		UD
8 NPS		28.586 in ²			0.5-2250 psi		UD

Design Name: HTPBX	NBCert # 12474
--------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	05/17/2029
--------------	----	------------

Design Type

[Buckling Pin Non-reclosing Device] HTPBX
Capacity Tests: Sec. UD at National Board Testing Lab on November 1, 2016
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 1.860 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: Nozzle/Full Lift
Designed by: BAPTEEC LTD {BAP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 NPS	4 NPS	11.74 in ²	3.87 in	2.87 in	15-720 psi	Air	UD
6 NPS	6 NPS	27.03 in ²	5.87 in	4.06 in	5-720 psi	Air	UD
8 NPS	8 NPS	45.52 in ²	7.61 in	5.24 in	5-720 psi	Air	UD
10 NPS	10 NPS	72.58 in ²	9.61 in	6.42 in	5-720 psi	Air	UD
12 NPS	12 NPS	101.42 in ²	11.36 in	7.6 in	5-720 psi	Air	UD
14 NPS	14 NPS	140.26 in ²	13.36 in	8.78 in	5-720 psi	Air	UD
16 NPS	16 NPS	185.38 in ²	15.36 in	9.96 in	5-720 psi	Air	UD
18 NPS	18 NPS	239.55 in ²	17.46 in	11.14 in	5-720 psi	Air	UD
20 NPS	20 NPS	297.55 in ²	19.46 in	12.32 in	5-720 psi	Air	UD
24 NPS	24 NPS	431.87 in ²	23.44 in	14.69 in	5-720 psi	Air	UD
26 NPS	26 NPS	508.65 in ²	25.44 in	15.87 in	5-720 psi	Air	UD
28 NPS	28 NPS	554.34 in ²	26.57 in	17.05 in	5-720 psi	Air	UD
30 NPS	30 NPS	631.08 in ²	28.35 in	18.23 in	5-145 psi	Air	UD
32 NPS	32 NPS	722.53 in ²	30.33 in	19.41 in	5-145 psi	Air	UD
34 NPS	34 NPS	813.97 in ²	32.19 in	20.59 in	5-145 psi	Air	UD
36 NPS	36 NPS	912.55 in ²	34.09 in	21.77 in	5-145 psi	Air	UD
38 NPS	38 NPS	1014.65 in ²	35.94 in	22.95 in	5-145 psi	Air	UD
40 NPS	40 NPS	1126.61 in ²	37.87 in	24.13 in	5-145 psi	Air	UD
42 NPS	42 NPS	1249.84 in ²	39.89 in	25.31 in	5-145 psi	Air	UD
44 NPS	44 NPS	1366.03 in ²	41.7 in	26.5 in	5-145 psi	Air	UD

46 NPS	46 NPS	1469.14 in²	43.65 in	27.68 in	5-145 psi	Air	UD
48 NPS	48 NPS	1632.45 in²	45.59 in	28.86 in	5-145 psi	Air	UD

Design Name:	HTGS	NBCert #	12485
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV, V	08/01/2030
--------------	-------	------------

Design Type

[Safety Valve] HTGS
Capacity Tests: Sec. UV, V at National Board Testing Lab on January 25, 2018
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.869 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: BAPTEEC LTD {BAP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2-3 NPS	0.352 in²	[F] 0.669 in	0.167 in	145-6525 psi	Steam	UV, V
1.5 NPS	2.5, 3 NPS	0.589 in²	[G] 0.866 in	0.217 in	145-6525 psi	Steam	UV, V
1.5 NPS	3, 4 NPS	0.887 in²	[H] 1.063 in	0.266 in	145-6525 psi	Steam	UV, V
1.5 NPS	3, 4 NPS	1.024 in²	[H2] 1.142 in	0.285 in	145-6525 psi	Steam	UV, V
2 NPS	3-6 NPS	1.449 in²	[J] 1.358 in	0.34 in	145-6525 psi	Steam	UV, V
2 NPS	3-6 NPS	1.578 in²	[J2] 1.417 in	0.354 in	145-6525 psi	Steam	UV, V
2.5-3 NPS	4, 6 NPS	2.097 in²	[K] 1.634 in	0.408 in	145-6525 psi	Steam	UV, V
2.5-3 NPS	4, 6 NPS	2.689 in²	[K2] 1.85 in	0.463 in	145-6525 psi	Steam	UV, V
3 NPS	4, 6 NPS	3.229 in²	[L] 2.028 in	0.507 in	145-6525 psi	Steam	UV, V
3 NPS	4, 6 NPS	3.55 in²	[L2] 2.126 in	0.531 in	145-6525 psi	Steam	UV, V
3 NPS	4, 6 NPS	4.095 in²	[M] 2.283 in	0.571 in	145-6525 psi	Steam	UV, V
4 NPS	6 NPS	4.986 in²	[N] 2.52 in	0.63 in	145-6525 psi	Steam	UV, V
4 NPS	6,8 NPS	7.218 in²	[P] 3.031 in	0.758 in	145-6525 psi	Steam	UV, V
4 NPS	6, 8 NPS	7.598 in²	[P2] 3.11 in	0.778 in	145-6525 psi	Steam	UV, V
6 NPS	8 NPS	12.666 in²	[Q] 4.016 in	1.004 in	145-2000 psi	Steam	UV, V
6 NPS	8, 10 NPS	18.119 in²	[R] 4.803 in	1.201 in	145-2000 psi	Steam	UV, V
6 NPS	8, 10 NPS	19.945 in²	[R2] 5.039 in	1.26 in	145-2000 psi	Steam	UV, V
8 NPS	10, 12 NPS	29.626 in²	[T] 6.142 in	1.535 in	145-2000 psi	Steam	UV, V
10 NPS	14 NPS	46.766 in²	[V] 7.717 in	1.929 in	145-500 psi	Steam	UV, V
12 NPS	16 NPS	67.229 in²	[W] 9.252 in	2.313 in	145-500 psi	Steam	UV, V
14 NPS	18 NPS	91.395 in²	[Y] 10.787 in	2.697 in	145-500 psi	Steam	UV, V
16 NPS	18 NPS	100.974 in²	[Z] 11.339 in	2.835 in	145-500 psi	Steam	UV, V
16 NPS	20 NPS	120.793 in²	[ZZ] 12.402 in	3.1 in	145-500 psi	Steam	UV, V
18 NPS	24 NPS	151.695 in²	[AA] 13.898 in	3.474 in	145-500 psi	Steam	UV, V
20 NPS	24 NPS	187.066 in²	[BB] 15.433 in	3.858 in	145-500 psi	Steam	UV, V

Design Name: HTXD Series		NBCert # 12441
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/24/2027

Design Type

[Pilot Operated Pressure Relief Valve] HTXD Series
Capacity Tests: Sec. UV at National Board Testing Lab on June 30, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.853 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: BAPTEEC LTD {BAP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.134 in ²	[D] 0.4134 in	0.165 in	30-6170 psi	Air	UV
1-1.5 NPS	2 NPS	0.239 in ²	[E] 0.5512 in	0.22 in	30-6170 psi	Air	UV
1-1.5 NPS	2 NPS	0.373 in ²	[F] 0.689 in	0.276 in	30-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.8858 in	0.355 in	30-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.954 in ²	[H] 1.1024 in	0.441 in	30-6170 psi	Air	UV
2-3 NPS	3, 4 NPS	1.578 in ²	[J] 1.4173 in	0.567 in	30-4620 psi	Air	UV
3 NPS	4 NPS	2.251 in ²	[K] 1.6929 in	0.677 in	30-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.484 in ²	[L] 2.1063 in	0.843 in	30-3705 psi	Air	UV
4 NPS	6 NPS	4.383 in ²	[M] 2.3622 in	0.945 in	30-3705 psi	Air	UV
4 NPS	6 NPS	5.303 in ²	[N] 2.5984 in	1.04 in	30-3705 psi	Air	UV
4 NPS	6 NPS	7.791 in ²	[P] 3.1496 in	1.26 in	30-3705 psi	Air	UV
6 NPS	8 NPS	13.421 in ²	[Q] 4.1339 in	1.653 in	30-1480 psi	Air	UV
6 NPS	8 NPS	19.327 in ²	[R] 4.9606 in	1.984 in	30-1020 psi	Air	UV
8 NPS	10 NPS	30.39 in ²	[T] 6.2205 in	2.488 in	30-985 psi	Air	UV
10 NPS	14 NPS	43.943 in ²	[V] 7.48 in	2.992 in	30-765 psi	Air	UV
12 NPS	16 NPS	61.626 in ²	[W] 8.858 in	3.543 in	30-765 psi	Air	UV
14 NPS	18 NPS	82.291 in ²	[Y] 10.236 in	4.095 in	30-765 psi	Air	UV
16 NPS	18 NPS	95.448 in ²	[Z] 11.024 in	4.409 in	30-765 psi	Air	UV
16 NPS	20 NPS	109.563 in ²	[Z1] 11.811 in	4.724 in	30-765 psi	Air	UV
18 NPS	24 NPS	140.732 in ²	[AA] 13.386 in	5.355 in	30-765 psi	Air	UV
20 NPS	24 NPS	166.66 in ²	[BB] 14.567 in	5.827 in	30-765 psi	Air	UV

Design Name: HTXD Series (Liquid)		NBCert # 12430
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/13/2026

Design Type

[Pilot Operated Pressure Relief Valve] HTXD Series (Liquid)
 Capacity Tests: Sec. UV at National Board Testing Lab on May 21, 2014
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.763 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: BAPTEEC LTD {BAP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.134 in ²	[D] 0.4134 in	0.165 in	30-6170 psi	Water	UV
1-1.5 NPS	2 NPS	0.239 in ²	[E] 0.5512 in	0.22 in	30-6170 psi	Water	UV
1-1.5 NPS	2 NPS	0.373 in ²	[F] 0.689 in	0.276 in	30-6170 psi	Water	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.8858 in	0.355 in	30-6170 psi	Water	UV
1.5-2 NPS	3 NPS	0.954 in ²	[H] 1.102 in	0.441 in	30-6170 psi	Water	UV
2-3 NPS	3, 4 NPS	1.578 in ²	[J] 1.4173 in	0.567 in	30-4620 psi	Water	UV
3-3 NPS	4 NPS	2.251 in ²	[K] 1.693 in	0.677 in	30-3705 psi	Water	UV
3-4 NPS	4, 6 NPS	3.484 in ²	[L] 2.1063 in	0.843 in	30-3705 psi	Water	UV
4-4 NPS	6 NPS	4.383 in ²	[M] 2.3622 in	0.945 in	30-3705 psi	Water	UV
4-4 NPS	6 NPS	5.303 in ²	[N] 2.5984 in	1.04 in	30-3705 psi	Water	UV
4-4 NPS	6 NPS	7.791 in ²	[P] 3.1496 in	1.26 in	30-3705 psi	Water	UV
6-6 NPS	8 NPS	13.421 in ²	[Q] 4.1339 in	1.653 in	30-1480 psi	Water	UV
6-6 NPS	8 NPS	19.327 in ²	[R] 4.961 in	1.984 in	30-1020 psi	Water	UV
8-8 NPS	10 NPS	30.39 in ²	[T] 6.2205 in	2.488 in	30-985 psi	Water	UV
10-10 NPS	14 NPS	43.943 in ²	[V] 7.48 in	2.992 in	30-765 psi	Water	UV
12-12 NPS	16 NPS	61.626 in ²	[W] 8.858 in	3.543 in	30-765 psi	Water	UV
14-14 NPS	18 NPS	82.291 in ²	[Y] 10.236 in	4.095 in	30-765 psi	Water	UV
16-16 NPS	18 NPS	95.448 in ²	[Z] 11.024 in	4.409 in	30-765 psi	Water	UV
16-16 NPS	20 NPS	109.563 in ²	[Z1] 11.811 in	4.724 in	30-765 psi	Water	UV
18-18 NPS	24 NPS	140.732 in ²	[AA] 13.386 in	5.355 in	30-765 psi	Water	UV
20-20 NPS	24 NPS	166.66 in ²	[BB] 14.567 in	5.827 in	30-765 psi	Water	UV

Design Name: HTXO Series

NBCert # 12452

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/24/2027

Design Type

[Safety Relief Valve] HTXO Series
 Capacity Tests: Sec. UV at National Board Testing Lab on June 30, 2015
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 1.823 SCFM/PSIA
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: BAPTEEC LTD {BAP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5-1 NPS	0.122 in²	0.394 in	0.118 in	15-6000 psi	Air	UV
Design Name: HTXO Series (Liquid)NBCert #12418							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			11/13/2026	
Design Type							
[Safety Relief Valve] HTXO Series (Liquid) Capacity Tests: Sec. UV at National Board Testing Lab on May 20, 2014 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.300 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: BAPTEEC LTD {BAP}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5-1.0 NPS	0.122 in²	0.394 in	0.118 in	15-6000 psi	Water	UV
Baro Controls, Inc. (BAC)Nameplate Abbreviation: Baro Controls							
Stafford, TX 77477United States							
This Company Manufactures or Assembles:							
Design Name: 438 Sub Types 481, 439NBCert #37190							
Manufacturer/Assembler			Designators			Expiration Date	
Assembler			UV			05/01/2031	
Design Type							
[Safety Relief Valve] 438 Sub Types 481, 439 Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on November 12, 2001 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.904 SCFM/PSIA; (alternate medium): 2.530 PPH/PSIA Media - Test: Air/Gas; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: LESER GmbH & Co. KG {LES}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1 NPS	0.5 - 1 NPS	0.064 in²	0.394 in	0.043 in	15-2610 psi	Air	UV
0.375-1 NPS	0.5 - 1 NPS	0.064 in²	0.394 in	0.043 in	15-2610 psi	Steam	UV
Design Name: 459/462NBCert #37112							
Manufacturer/Assembler			Designators			Expiration Date	
Assembler			UV			05/01/2031	

Design Type

[Safety Relief Valve] 459/462
Capacity Tests: Sec. UV at National Board Testing Lab on February 17, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.811 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Air	UV
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Air	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Steam	UV

Design Name: 459/462 liquids NBCert # 37101

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

05/01/2031

Design Type

[Relief Valve] 459/462 liquids
Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.566 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Water	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Water	UV
0.5-1.5 NPS	1-2.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Water	UV
1-2 NPS	1.5-2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Water	UV

Design Name: 526 NBCert # 37224

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

05/01/2031

Design Type

[Safety Relief Valve] 526
 Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 22, 2001
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.801 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Air	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-2900 psi	Steam	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Air	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-2900 psi	Steam	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Steam	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Air	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Steam	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Air	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Steam	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Air	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Steam	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Air	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Steam	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Air	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Steam	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Air	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Steam	UV

Design Name: 526 (Liquids) NBCert # 37235

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/01/2031

Design Type

[Relief Valve] 526 (Liquids)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on January 2, 2002
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.579 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Water	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Water	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Water	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Water	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Water	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Water	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.6698 in	15-1850 psi	Water	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Water	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Water	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Water	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.249 in	15-1038.5 psi	Water	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Water	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-914 psi	Water	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Water	UV

Basin Valve Company (BAK)

Bakersfield, CA 93308United States

This Company Manufactures or Assembles:

Design Name: 2400		NBCert # 57451
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/18/2029

Design Type

[Safety Relief Valve] 2400
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on August 28, 2019
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.817 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75-1 NPS	0.049 in ²	[B] 0.25 in	0.08 in	20-2000 psi	Air	UV

0.5-1 NPS	1-2 NPS	0.11 in ²	[D] 0.375 in	0.12 in	20-1410 psi	Air	UV
0.75-1 NPS	1-2 NPS	0.196 in ²	[E] 0.5 in	0.175 in	20-600 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.295 in	20-4000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.365 in	20-3000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.435 in	20-2500 psi	Air	UV

Design Name: 2600 & 2600S

NBCert #

57057

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

08/02/2030

Design Type

[Safety Relief Valve] 2600 & 2600S

Capacity Tests: Sec. UV at unknown lab on June 11, 1972

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable (Single Ring)

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV

6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600 Series Restricted Lift version of Cert Number 57057 NBCert # 57406

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/02/2030

Design Type

[Safety Relief Valve] 2600 Series Restricted Lift version of Cert Number 57057
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 10, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Air	UV
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Steam	UV
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Air	UV
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Steam	UV
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Air	UV
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Steam	UV
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.08 in	15-7000 psi	Air	UV
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.08 in	15-7000 psi	Steam	UV
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.095 in	15-6000 psi	Air	UV
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.095 in	15-6000 psi	Steam	UV
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.122 in	15-6000 psi	Air	UV

2-3 in	3. 4 in	1.43 in ²	[J] 1.35 in	0.122 in	15-6000 psi	Steam	UV
3 in	4, 6 in	2.042 in ²	[K] 1.612 in	0.145 in	15-5000 psi	Air	UV
3 in	4, 6 in	2.042 in ²	[K] 1.612 in	0.145 in	15-5000 psi	Steam	UV
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.181 in	15-4000 psi	Air	UV
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.181 in	15-4000 psi	Steam	UV
4 in	6 in	4 in ²	[M] 2.257 in	0.203 in	15-3000 psi	Air	UV
4 in	6 in	4 in ²	[M] 2.257 in	0.203 in	15-3000 psi	Steam	UV
4 in	6 in	4.822 in ²	[N] 2.478 in	0.223 in	15-3000 psi	Air	UV
4 in	6 in	4.822 in ²	[N] 2.478 in	0.223 in	15-3000 psi	Steam	UV
4 in	6 in	7.087 in ²	[P] 3.004 in	0.27 in	15-2500 psi	Air	UV
4 in	6 in	7.087 in ²	[P] 3.004 in	0.27 in	15-2500 psi	Steam	UV
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.356 in	15-2000 psi	Air	UV
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.356 in	15-2000 psi	Steam	UV
6 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.428 in	15-1500 psi	Air	UV
6 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.428 in	15-1500 psi	Steam	UV
8 in	10 in	28.94 in ²	[T] 6.07 in	0.546 in	15-1000 psi	Air	UV
8 in	10 in	28.94 in ²	[T] 6.07 in	0.546 in	15-1000 psi	Steam	UV
8 in	10 in	31.5 in ²	[U] 6.333 in	0.57 in	15-300 psi	Air	UV
8 in	10 in	31.5 in ²	[U] 6.333 in	0.57 in	15-300 psi	Steam	UV
10 in	14 in	49.4 in ²	[V] 7.93 in	0.714 in	15-1000 psi	Air	UV
10 in	14 in	49.4 in ²	[V] 7.93 in	0.714 in	15-1000 psi	Steam	UV
12 in	16 in	63.62 in ²	[W] 9 in	0.81 in	15-1000 psi	Air	UV
12 in	16 in	63.62 in ²	[W] 9 in	0.81 in	15-1000 psi	Steam	UV
16 in	18 in	104 in ²	[W2] 11.507 in	1.036 in	15-750 psi	Air	UV
16 in	18 in	104 in ²	[W2] 11.507 in	1.036 in	15-750 psi	Steam	UV
16 in	20 in	113.1 in ²	[X] 12 in	1.08 in	15-750 psi	Air	UV
16 in	20 in	113.1 in ²	[X] 12 in	1.08 in	15-750 psi	Steam	UV
18 in	24 in	143.1 in ²	[Y] 13.5 in	1.215 in	15-750 psi	Air	UV
18 in	24 in	143.1 in ²	[Y] 13.5 in	1.215 in	15-750 psi	Steam	UV
20 in	24 in	176.7 in ²	[Z] 15 in	1.35 in	15-750 psi	Air	UV
20 in	24 in	176.7 in ²	[Z] 15 in	1.35 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

09/18/2029

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids)		NBCert #	57068
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	09/18/2029

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2600L (Liquids) Series Restricted Lift version of Cert Number 57068. NBCert # 57417

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/18/2029

Design Type

[Safety Relief Valve] 2600L (Liquids) Series Restricted Lift version of Cert Number 57068.
Capacity Tests: Sec. UV, V at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on January 23, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Water	UV, V
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-6000 psi	Water	UV, V
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-5000 psi	Water	UV, V
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.098 in	15-3600 psi	Water	UV, V
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.122 in	15-2750 psi	Water	UV, V

2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.156 in	15-2700 psi	Water	UV, V
3 in	4, 6 in	2.041 in ²	[K] 1.612 in	0.187 in	15-2200 psi	Water	UV, V
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.232 in	15-1500 psi	Water	UV, V
4 in	6 in	4 in ²	[M] 2.257 in	0.261 in	15-1100 psi	Water	UV, V
4 in	6 in	4.822 in ²	[N] 2.478 in	0.287 in	15-1000 psi	Water	UV, V
4 in	6 in	7.087 in ²	[P] 3.004 in	0.348 in	15-1000 psi	Water	UV, V
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.458 in	15-900 psi	Water	UV, V
6-8 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.551 in	15-600 psi	Water	UV, V
8 in	10 in	28.94 in ²	[T] 6.07 in	0.702 in	15-300 psi	Water	UV, V
8 in	10 in	31.5 in ²	[U] 6.333 in	0.741 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S NBCert # 57237

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/18/2029

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids)		NBCert #	57248
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	01/03/2030	
Design Type			
[Relief Valve] 2700L, 3700L (Liquids) Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.676 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800		NBCert #	57024
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	09/18/2029	
Design Type			
[Pilot Operated Pressure Relief Valve] 3800 Capacity Tests: Sec. UV at unknown lab on May 20, 1994 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.859 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition(1): Pop; (3): Initial Audible Discharge Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV

1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name: 3800L, PCL, PCM pilots

NBCert #

57215

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

09/18/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.782 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV

1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Design Name: 4200 / 4400

NBCert # 57282

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

V

08/02/2030

Design Type

[Safety Valve] 4200 / 4400
Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.872 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

Basin Valve Company (BVN)

Benicia, CA 94510 United States

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S	NBCert # 57057
---------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	11/01/2030
-----------	----	------------

Design Type

[Safety Relief Valve] 2600 & 2600S
 Capacity Tests: Sec. UV at unknown lab on June 11, 1972
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.858 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV

8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/01/2030

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV

4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2700, 2700S, 3700, 3700S NBCert # 57237

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/01/2030

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV

2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids) NBCert # 57248

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/01/2030

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Basin Valve Company (BVS)

Signal Hill, CA 90755United States

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S NBCert # 57057

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/17/2028

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV

18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam) NBCert # 57260

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/05/2029

Design Type

[Safety Relief Valve] 2600L (Air & Steam)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV

8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids) NBCert # 57068

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/05/2029

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S NBCert # 57237

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/17/2028

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids)

NBCert #

57248

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/08/2029

Design Type

[Relief Valve] 2700L, 3700L (Liquids)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.676 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV

0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name:	4200 / 4400	NBCert #	57282
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	V	11/17/2028

Design Type

[Safety Valve] 4200 / 4400
Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.872 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

Beaumont Manufacturing and Distribution Company, LLC (MPV)

Nameplate Abbreviation: BMD

Beaumont, TX 77701 United States

This Company Manufactures or Assembles:

Design Name:	RV10	NBCert #	00910
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/03/2028

Design Type

[Safety Relief Valve] RV10
Capacity Tests: Sec. UV at National Board Testing Lab on July 6, 2016
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.756 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Beaumont Manufacturing and Distribution Company, LLC {MPV}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-2 NPS	.75-2 NPS	0.13 in ²	[D] 0.407 in	0.2 in	15-3000 psi	Air	UV
0.75-2 NPS	.75-2 NPS	0.22 in ²	[E] 0.529 in	0.23 in	15-2400 psi	Air	UV
1.5-2 NPS	1.5-2.5 NPS	0.357 in ²	[F] 0.674 in	0.31 in	15-2400 psi	Air	UV
1.5-2 NPS	1.5- 2.5 NPS	0.478 in ²	[G] 0.78 in	0.35 in	15-2000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.913 in ²	[H] 1.078 in	0.44 in	15-2000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.44 in ²	[J] 1.354 in	0.61 in	15-1800 psi	Air	UV
3-3 NPS	3, 4 NPS	2.1 in ²	[K] 1.635 in	0.72 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.3 in ²	[L] 2.05 in	0.895 in	15-1250 psi	Air	UV
4-4 NPS	6 NPS	4.1 in ²	[M] 2.285 in	1.01 in	15-1000 psi	Air	UV
4 NPS	6 NPS	7.07 in ²	[P] 3 in	1.3 in	15-1000 psi	Air	UV
6 NPS	8 NPS	13.2 in ²	[Q] 4.1 in	1.77 in	15-600 psi	Air	UV

Design Name: RV10 (Liquid)

NBCert #

02271

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/11/2025

Design Type

[Safety Relief Valve] RV10 (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on September 11, 2019
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.658 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Beaumont Manufacturing and Distribution Company, LLC {MPV}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-2 NPS	.75-2 NPS	0.13 in ²	[D] 0.407 in	0.2 in	15-3000 psi	Water	UV
0.75-2 NPS	.75-2 NPS	0.22 in ²	[E] 0.529 in	0.23 in	15-2400 psi	Water	UV
1.5-2 NPS	1.5-2.5 NPS	0.357 in ²	[F] 0.674 in	0.31 in	15-2400 psi	Water	UV
1.5-2 NPS	1.5- 2.5 NPS	0.478 in ²	[G] 0.78 in	0.35 in	15-2000 psi	Water	UV
1.5-2 NPS	2-3 NPS	0.913 in ²	[H] 1.078 in	0.44 in	15-2000 psi	Water	UV
2-3 NPS	3, 4 NPS	1.44 in ²	[J] 1.354 in	0.61 in	15-1800 psi	Water	UV
3-3 NPS	3, 4 NPS	2.1 in ²	[K] 1.635 in	0.72 in	15-1500 psi	Water	UV
3-4 NPS	4, 6 NPS	3.3 in ²	[L] 2.05 in	0.895 in	15-1250 psi	Water	UV
4-4 NPS	6 NPS	4.1 in ²	[M] 2.285 in	1.01 in	15-1000 psi	Water	UV
4 NPS	6 NPS	7.07 in ²	[P] 3 in	1.3 in	15-1000 psi	Water	UV

Bellofram Acquisition Company II (WHI)

Oklahoma City, OK 73149United States

This Company Manufactures or Assembles:

Design Name: P2500		NBCert # 01966	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	04/25/2028
Design Type			
[Safety Relief Valve] P2500 Capacity Tests: Sec. UV at National Board Testing Lab on February 1, 2021 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.850 Unitless Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Bellofram Acquisition Company II {WHI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.068 in²	[C] 0.295 in	0.074 in	25-2500 psi	Air	UV
0.5-1 NPS	1 NPS	0.125 in²	[D] 0.4 in	0.1 in	25-2500 psi	Air	UV
0.5-2 NPS	1-2 NPS	0.223 in²	[E] 0.534 in	0.134 in	50-2500 psi	Air	UV
1.25-2 NPS	2 NPS	0.354 in²	[F] 0.672 in	0.168 in	15-1600 psi	Air	UV
1.25-2 NPS	2 NPS	0.576 in²	[G] 0.857 in	0.214 in	75-1500 psi	Air	UV

Design Name: P2500 (Liquid)		NBCert # 01977	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	06/29/2027
Design Type			
[Relief Valve] P2500 (Liquid) Capacity Tests: Sec. UV at National Board Testing Lab on February 1, 2021 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.591 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Bellofram Acquisition Company II {WHI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.125 in²	[D] 0.4 in	0.1 in	25-2500 psi	Water	UV
0.5-2 NPS	1-2 NPS	0.223 in²	[E] 0.534 in	0.134 in	50-2500 psi	Water	UV
1.25-2 NPS	2 NPS	0.354 in²	[F] 0.672 in	0.168 in	15-1600 psi	Water	UV
1.25-2 NPS	2 NPS	0.576 in²	[G] 0.857 in	0.214 in	75-1500 psi	Water	UV

Birmingham Controls, Inc. (LSL)

Cerritos, CA 90703United States

This Company Manufactures or Assembles:

Design Name:	1541, 1543, 1541-3, 1543-3	NBCert #	18032
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV, V	02/28/2028	

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V

2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV
-----------	---------	-----------------------	---------------	---------	------------	-----	--------

Design Name:	1700 & 2700 (Restricted Lift version of Cert. # 18100)	NBCert #	18111
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV, V	07/29/2028
-----------	-------	------------

Design Type

[Safety Valve] 1700 & 2700 (Restricted Lift version of Cert. # 18100)
Capacity Tests: Sec. UV, V at unknown lab on October 13, 1981
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	50-5800 psi	Steam	V
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	15-3100 psi	Steam	UV
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	50-5800 psi	Steam	V
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-2575 psi	Steam	UV
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	50-5800 psi	Steam	V
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	15-3100 psi	Steam	UV
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	50-5800 psi	Steam	V
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	15-3100 psi	Steam	UV
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.946 in	0.296 in	15-2000 psi	Steam	UV, V
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	0.372 in	50-2200 psi	Steam	V
8-10 NPS	10, 12 NPS	28.3 in ²	[T] 6 in	0.45 in	50-1500 psi	Steam	UV, V

Design Name:	1811, 1511	NBCert #	18122
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 02/28/2028

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/04/2028

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/04/2028

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV

1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series			NBCert # 18706	
Manufacturer/Assembler		Designators		Expiration Date
Assembler		UV		02/28/2028

Design Type

[Safety Relief Valve] 19000 Series
 Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/14/2028

Design Type

[Relief Valve] 19000 Series, Liquid
 Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.673 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV

1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/04/2028

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/04/2028

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name:	1900-DM	NBCert #	19066
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/28/2028

Design Type

[Safety Relief Valve] 1900-DM
Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D		NBCert # 19088
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/28/2028

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E NBCert # 19099

Manufacturer/Assembler

Designators

Expiration Date

Assembler

UV

05/20/2028

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2 NBCert # 18166

Manufacturer/Assembler

Designators

Expiration Date

Assembler

UV

04/04/2028

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/28/2028

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 5.798 GPM/SQ.RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids) NBCert # 19077

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/04/2028

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
 Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 2.264 GPM/SQ.RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 3900-TM (39PV, 39MV pilots) NBCert # 01438

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/09/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3900-TM (39PV, 39MV pilots)
 Capacity Tests: Sec. UV at Dresser, Inc. on May 19, 1988
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless; (alternate medium): 0.743 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV

3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Binzagr Factory for Insulation Materials Co. Ltd. (BFI)

Jubail, Eastern Province, 31961Saudi Arabia

This Company Manufactures or Assembles:

Design Name: 437		NBCert # 37213
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/15/2025

Design Type

[Safety Relief Valve] 437
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on November 8, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.020 SCFM/PSIA; (alternate medium): 2.870 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Air	UV
0.375-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Steam	UV

Design Name: 437 (Liquids) NBCert # 37189

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/16/2025

Design Type

[Relief Valve] 437 (Liquids)
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on November 22, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.540 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Water	UV

Design Name: 438 Sub Types 481, 439 NBCert # 37190

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/15/2025

Design Type

[Safety Relief Valve] 438 Sub Types 481, 439
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on November 12, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.904 SCFM/PSIA; (alternate medium): 2.530 PPH/PSIA
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1 NPS	0.5 - 1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Air	UV
0.375-1 NPS	0.5 - 1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Steam	UV

Design Name:	438 Sub Types 481, 439, Liquids	NBCert #	37202
--------------	---------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/16/2025

Design Type

[Safety Relief Valve] 438 Sub Types 481, 439, Liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 23, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.490 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Water	UV

Design Name:	441/442/444	NBCert #	37044
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/16/2025

Design Type

[Safety Relief Valve] 441/442/444
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on February 17, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.699 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Air	UV
1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Steam	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Air	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Steam	UV
1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Air	UV
1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Steam	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Air	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Steam	UV
2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Air	UV
2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Steam	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Air	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Steam	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Air	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Steam	UV
5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Air	UV

5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Steam	UV
6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Air	UV
6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Steam	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Air	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Steam	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Air	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Steam	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Air	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Steam	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Air	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Steam	UV

Design Name: 441/442/444 liquids NBCert # 37055

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/16/2025

Design Type

[Relief Valve] 441/442/444 liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on September 6, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.521 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Water	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Water	UV
1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Water	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Water	UV
2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Water	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Water	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Water	UV
5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Water	UV
6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Water	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Water	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Water	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Water	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Water	UV

Design Name: 459/462 NBCert # 37112

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/16/2025

Design Type

[Safety Relief Valve] 459/462
Capacity Tests: Sec. UV at National Board Testing Lab on February 17, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.811 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Air	UV
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Air	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Steam	UV

Design Name: 459/462 liquidsNBCert # 37101

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

AssemblerUV07/16/2025

Design Type

[Relief Valve] 459/462 liquids
Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.566 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Water	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Water	UV
0.5-1.5 NPS	1-2.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Water	UV
1-2 NPS	1.5-2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Water	UV

Design Name: 526NBCert # 37224

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

AssemblerUV07/16/2025

Design Type

[Safety Relief Valve] 526
 Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 22, 2001
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.801 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Air	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-2900 psi	Steam	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Air	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-2900 psi	Steam	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Steam	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Air	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Steam	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Air	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Steam	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Air	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Steam	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Air	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Steam	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Air	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Steam	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Air	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Steam	UV

Design Name: 526 (Liquids) NBCert # 37235

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/16/2025

Design Type

[Relief Valve] 526 (Liquids)
 Capacity Tests: Sec. UV at Leser GmbH & Co., KG on January 2, 2002
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.579 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Water	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Water	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Water	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Water	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Water	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Water	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.6698 in	15-1850 psi	Water	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Water	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Water	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Water	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.249 in	15-1038.5 psi	Water	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Water	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-914 psi	Water	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Water	UV

Design Name: 526D

NBCert # 37246

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/15/2025

Design Type

[Safety Relief Valve] 526D
 Capacity Tests: Sec. UV at Leser GmbH & Co., KG on March 4, 2002
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 1.990 SCFM/PSIA; (alternate medium): 5.590 PPH/PSIA
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Curtain Area
 Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-10878 psi	Air	UV

Design Name: 526D Liquids

NBCert # 37257

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/15/2025

Design Type

[Relief Valve] 526D Liquids
 Capacity Tests: Sec. UV at Leser GmbH & Co., KG on March 4, 2002
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 3.110 GPM/SQ.RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-10878 psi	Water	UV

Design Name: 810/820 (811/814/821/824) NBCert # 37280

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/09/2025

Design Type

[Pilot Operated Pressure Relief Valve] 810/820 (811/814/821/824)
 Capacity Tests: Sec. UV at Leser GmbH & Co., KG on October 31, 2009
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.820 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.394 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.394 in	15-740 psi	Steam	UV
1-1 NPS	2 NPS	0.147 in ²	[D] 0.433 mm	0.315 in	15-10000 psi	Air	UV
1-1 NPS	2 NPS	0.147 in ²	[D] 0.433 mm	0.315 in	15-740 psi	Steam	UV
1 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.315 in	15-10000 psi	Air	UV
1 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.315 in	15-740 psi	Steam	UV
1.5 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.394 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.394 in	15-740 psi	Steam	UV
1 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.315 in	15-10000 psi	Air	UV
1 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.315 in	15-740 psi	Steam	UV
1.5 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.394 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.394 in	15-740 psi	Steam	UV
1 NPS	2 NPS	0.644 in ²	[FB] 0.906 in	0.453 in	15-10000 psi	Air	UV
1 NPS	2 NPS	0.644 in ²	[FB] 0.906 in	0.453 in	15-740 psi	Steam	UV
1.5 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.472 in	15-10000 psi	Air	UV
1.5 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.472 in	15-740 psi	Steam	UV
2 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.591 in	15-10000 psi	Air	UV
2 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.591 in	15-740 psi	Steam	UV
1.5 NPS	2 NPS	1.024 in ²	[FB] 1.142 in	0.571 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	1.024 in ²	[FB] 1.142 in	0.571 in	15-740 psi	Steam	UV

1.5 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.472 in	15-10000 psi	Air	UV
1.5 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.472 in	15-740 psi	Steam	UV
2 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.591 in	15-10000 psi	Air	UV
2 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.591 in	15-740 psi	Steam	UV
1.5 NPS	3 NPS	1.552 in ²	[FB] 1.406 in	0.709 in	15-10000 psi	Air	UV
1.5 NPS	3 NPS	1.552 in ²	[FB] 1.406 in	0.709 in	15-740 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.758 in ²	[J] 1.496 in	0.591 in	15-10000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.758 in ²	[J] 1.496 in	0.591 in	15-740 psi	Steam	UV
3 NPS	4 NPS	2.465 in ²	[K] 1.772 in	0.866 in	15-10000 psi	Air	UV
3 NPS	4 NPS	2.465 in ²	[K] 1.772 in	0.866 in	15-740 psi	Steam	UV
2 NPS	3 NPS	2.805 in ²	[FB] 1.89 in	0.866 in	15-10000 psi	Air	UV
2 NPS	3 NPS	2.805 in ²	[FB] 1.89 in	0.866 in	15-740 psi	Steam	UV
3 NPS	4 NPS	3.818 in ²	[L] 2.205 in	0.866 in	15-10000 psi	Air	UV
3 NPS	4 NPS	3.818 in ²	[L] 2.205 in	0.866 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	3.818 in ²	[L] 2.205 in	0.787 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	3.818 in ²	[L] 2.205 in	0.787 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	4.832 in ²	[M] 2.48 in	0.787 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	4.832 in ²	[M] 2.48 in	0.787 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	5.796 in ²	[N] 2.717 in	0.787 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	5.796 in ²	[N] 2.717 in	0.787 in	15-740 psi	Steam	UV
3 NPS	4 NPS	6.848 in ²	[FB] 2.953 in	1.339 in	15-10000 psi	Air	UV
3 NPS	4 NPS	6.848 in ²	[FB] 2.953 in	1.339 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	8.386 in ²	[P] 3.268 in	1.339 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	8.386 in ²	[P] 3.268 in	1.339 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	10.987 in ²	[FB] 3.74 in	1.693 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	10.987 in ²	[FB] 3.74 in	1.693 in	15-740 psi	Steam	UV
6 NPS	8, 8 Dual NPS	14.73 in ²	[Q] 4.331 in	2.165 in	15-1500 psi	Air	UV
6 NPS	8, 8 Dual NPS	14.73 in ²	[Q] 4.331 in	2.165 in	15-740 psi	Steam	UV
6 NPS	8, 8 Dual NPS	21.534 in ²	[R] 5.236 in	2.165 in	15-1500 psi	Air	UV
6 NPS	8, 8 Dual NPS	21.534 in ²	[R] 5.236 in	2.165 in	15-740 psi	Steam	UV
6 NPS	8, 8 Dual NPS	24.547 in ²	[FB] 5.591 in	2.559 in	15-1500 psi	Air	UV
6 NPS	8, 8 Dual NPS	24.547 in ²	[FB] 5.591 in	2.559 in	15-740 psi	Steam	UV
8 NPS	10, 10 Dual NPS	34.359 in ²	[T] 6.614 in	3.15 in	15-1500 psi	Air	UV
8 NPS	10, 10 Dual NPS	34.359 in ²	[T] 6.614 in	3.15 in	15-740 psi	Steam	UV
8 NPS	10, 10 Dual NPS	39.443 in ²	[FB] 7.087 in	3.15 in	15-1500 psi	Air	UV
8 NPS	10, 10 Dual NPS	39.443 in ²	[FB] 7.087 in	3.15 in	15-740 psi	Steam	UV

Design Name: 820 (liquid) (821/824)

NBCert #

37268

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/09/2025

Design Type

[Pilot Operated Pressure Relief Valve] 820 (liquid) (821/824)
 Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 6, 2009
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.689 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.315 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.394 in	15-10000 psi	Water	UV
1 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.315 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.394 in	15-10000 psi	Water	UV
1 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.315 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.394 in	15-10000 psi	Water	UV
1 NPS	2 NPS	0.644 in ²	[FB] 0.906 in	0.453 in	15-10000 psi	Water	UV
1.5 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.472 in	15-10000 psi	Water	UV
2 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.591 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	1.142 in ²	[FB] 1.142 in	0.571 in	15-10000 psi	Water	UV
1.5 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.472 in	15-10000 psi	Water	UV
2 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.591 in	15-10000 psi	Water	UV
1.5 NPS	3 NPS	1.552 in ²	[FB] 1.406 in	0.709 in	15-10000 psi	Water	UV
2-3 NPS	3, 4 NPS	1.758 in ²	[J] 1.496 in	0.591 in	15-10000 psi	Water	UV
3 NPS	4 NPS	2.465 in ²	[K] 1.772 in	0.866 in	15-10000 psi	Water	UV
2 NPS	3 NPS	2.805 in ²	[FB] 1.89 in	0.866 in	15-10000 psi	Water	UV
3 NPS	4 NPS	3.818 in ²	[L] 2.205 in	0.866 in	15-10000 psi	Water	UV
4 NPS	6, 6 Dual NPS	3.818 in ²	[L] 2.205 in	0.787 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	4.832 in ²	[M] 2.48 in	0.787 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	5.796 in ²	[N] 2.717 in	0.787 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.848 in ²	[FB] 2.953 in	1.339 in	15-10000 psi	Water	UV
4 NPS	6, 6 Dual NPS	8.386 in ²	[P] 3.268 in	1.339 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	10.987 in ²	[FB] 3.74 in	1.693 in	15-3750 psi	Water	UV
6 NPS	8, 8 Dual NPS	14.73 in ²	[Q] 4.331 in	2.165 in	15-1500 psi	Water	UV
6 NPS	8, 8 Dual NPS	21.534 in ²	[R] 5.236 in	2.165 in	15-1500 psi	Water	UV
6 NPS	8, 8 Dual NPS	24.547 in ²	[FB] 5.591 in	2.559 in	15-1500 psi	Water	UV
8 NPS	10, 10 Dual NPS	34.359 in ²	[T] 6.614 in	3.15 in	15-1500 psi	Water	UV
8 NPS	10, 10 Dual NPS	39.443 in ²	[FB] 7.087 in	3.15 in	15-1500 psi	Water	UV

Bawal, Haryana, 123501India

This Company Manufactures or Assembles:

Design Name:	2600 & 2600S	NBCert #	57057
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/29/2026

Design Type

[Safety Relief Valve] 2600 & 2600S
 Capacity Tests: Sec. UV at unknown lab on June 11, 1972
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.858 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV

6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

03/10/2026

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV

2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids) NBCert # 57068

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 04/03/2026

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V

4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 04/02/2026

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids)		NBCert #	57248
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	04/02/2026
Design Type			
[Relief Valve] 2700L, 3700L (Liquids) Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.676 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 28L Series		NBCert #	00987
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	10/23/2029
Design Type			
[Relief Valve] 28L Series Capacity Tests: Sec. UV at National Board Testing Lab on May 9, 2023 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.801 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Bliss Anand Private Limited {BLS}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.115 in ²	[D] 0.383 in	0.096 in	15-10000 psi	Water	UV
1-1.5 NPS	2, 3 NPS	0.208 in ²	[E] 0.514 in	0.129 in	15-10000 psi	Water	UV
1.5 NPS	2, 3 NPS	0.328 in ²	[F] 0.646 in	0.162 in	15-10000 psi	Water	UV
1.5-2 NPS	3 NPS	0.545 in ²	[G] 0.833 in	0.208 in	15-7000 psi	Water	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 1.043 in	0.261 in	15-6000 psi	Water	UV
2-3 NPS	3, 4 NPS	1.408 in ²	[J] 1.339 in	0.335 in	15-6000 psi	Water	UV
3 NPS	4, 6 NPS	2.013 in ²	[K] 1.601 in	0.4 in	15-5000 psi	Water	UV

3-4 NPS	4, 6 NPS	3.136 in ²	[L] 1.998 in	0.5 in	15-4000 psi	Water	UV
4 NPS	6 NPS	3.959 in ²	[M] 2.245 in	0.561 in	15-3000 psi	Water	UV
4 NPS	6 NPS	4.777 in ²	[N] 2.466 in	0.617 in	15-2500 psi	Water	UV
4 NPS	6 NPS	7.037 in ²	[P] 2.993 in	0.748 in	15-2000 psi	Water	UV
6 NPS	8 NPS	12.2 in ²	[Q] 3.941 in	0.985 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	17.686 in ²	[R] 4.745 in	1.186 in	15-600 psi	Water	UV
8 NPS	10 NPS	28.761 in ²	[T] 6.051 in	1.513 in	15-500 psi	Water	UV
8-10 NPS	10-12 NPS	30.78 in ²	[U] 6.26 in	1.565 in	15-300 psi	Water	UV

Design Name: 28L Series (Air,Gas) NBCert # 00998

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/11/2029

Design Type

[Safety Relief Valve] 28L Series (Air,Gas)
Capacity Tests: Sec. UV at National Board Testing Lab on September 21, 2022
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.849 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.115 in ²	[D] 0.383 in	0.096 in	15-10000 psi	Air	UV
1-1.5 NPS	2, 3 NPS	0.208 in ²	[E] 0.514 in	0.129 in	15-10000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.328 in ²	[F] 0.646 in	0.162 in	15-10000 psi	Air	UV
1.5-2 NPS	3 NPS	0.545 in ²	[G] 0.833 in	0.208 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 1.043 in	0.261 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.408 in ²	[J] 1.339 in	0.335 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.013 in ²	[K] 1.601 in	0.4 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.136 in ²	[L] 1.998 in	0.5 in	15-4000 psi	Air	UV
4 NPS	6 NPS	3.959 in ²	[M] 2.245 in	0.561 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.777 in ²	[N] 2.466 in	0.617 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.037 in ²	[P] 2.993 in	0.748 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.2 in ²	[Q] 3.941 in	0.985 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.686 in ²	[R] 4.745 in	1.186 in	15-600 psi	Air	UV
8 NPS	10 NPS	28.761 in ²	[T] 6.051 in	1.513 in	15-500 psi	Air	UV
8-10 NPS	10-12 NPS	30.78 in ²	[U] 6.26 in	1.565 in	15-300 psi	Air	UV

Design Name: 28V Series NBCert # 00392

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/19/2030

Design Type

[Safety Relief Valve] 28V Series
 Capacity Tests: Sec. UV at National Board Testing Lab on September 21, 2022
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.850 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.115 in ²	[D] 0.383 in	0.096 in	15-10000 psi	Air	UV
1-1.5 NPS	2, 3 NPS	0.208 in ²	[E] 0.514 in	0.129 in	15-10000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.328 in ²	[F] 0.646 in	0.162 in	15-10000 psi	Air	UV
1.5-2 NPS	3 NPS	0.545 in ²	[G] 0.833 in	0.208 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 1.043 in	0.261 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.408 in ²	[J] 1.339 in	0.335 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.013 in ²	[K] 1.601 in	0.4 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.136 in ²	[L] 1.998 in	0.5 in	15-4000 psi	Air	UV
4 NPS	6 NPS	3.959 in ²	[M] 2.245 in	0.561 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.777 in ²	[N] 2.466 in	0.617 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.037 in ²	[P] 2.993 in	0.748 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.2 in ²	[Q] 3.941 in	0.985 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.686 in ²	[R] 4.745 in	1.186 in	15-600 psi	Air	UV
8 NPS	10 NPS	28.761 in ²	[T] 6.051 in	1.513 in	15-500 psi	Air	UV
8-10 NPS	10-12 NPS	30.78 in ²	[U] 6.26 in	1.565 in	15-300 psi	Air	UV
10 NPS	14 NPS	48.945 in ²	[V] 7.894 in	1.973 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.848 in ²	[W] 9.016 in	2.254 in	15-1000 psi	Air	UV
16 NPS	18 NPS	104.524 in ²	[W2] 11.535 in	2.884 in	15-750 psi	Air	UV
16 NPS	20 NPS	114.004 in ²	[X] 12.047 in	3.012 in	15-750 psi	Air	UV
18 NPS	24 NPS	144.077 in ²	[Y] 13.543 in	3.386 in	15-750 psi	Air	UV
20 NPS	24 NPS	177.666 in ²	[Z] 15.039 in	3.76 in	15-750 psi	Air	UV

Design Name: 29L Series

NBCert #

01090

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/23/2029

Design Type

[Relief Valve] 29L Series
 Capacity Tests: Sec. UV at National Board Testing Lab on May 9, 2023
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.646 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.071 in ²	[C] 0.3 in	0.075 in	15-10000 psi	Water	UV
0.5-1 NPS	1 NPS	0.129 in ²	[D] 0.405 in	0.101 in	15-10000 psi	Water	UV
1 NPS	1.5 NPS	0.227 in ²	[E] 0.538 in	0.135 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.356 in ²	[F] 0.673 in	0.168 in	15-7000 psi	Water	UV

Design Name: 29V Series	NBCert # 01078
-------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/11/2029

Design Type

[Safety Relief Valve] 29V Series
Capacity Tests: Sec. UV at National Board Testing Lab on March 11, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.071 in ²	[C] 0.3 in	0.075 in	15-10000 psi	Air	UV
0.5-1 NPS	1 NPS	0.129 in ²	[D] 0.405 in	0.101 in	15-10000 psi	Air	UV
1 NPS	1.5 NPS	0.227 in ²	[E] 0.538 in	0.135 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.356 in ²	[F] 0.673 in	0.168 in	15-7000 psi	Air	UV

Design Name: 31L Series	NBCert # 01180
-------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 10/23/2029

Design Type

[Pilot Operated Pressure Relief Valve] 31L Series
Capacity Tests: Sec. UV at National Board Testing Lab on January 11, 2023
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.738 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.156 in ²	[D] 0.445 in	0.111 in	15-6170 psi	Water	UV
1-1.5 NPS	2 NPS	0.232 in ²	[E] 0.543 in	0.136 in	15-6170 psi	Water	UV
1-1.5 NPS	2 NPS	0.379 in ²	[F] 0.695 in	0.174 in	15-6170 psi	Water	UV
1.5-2 NPS	3 NPS	0.57 in ²	[G] 0.852 in	0.213 in	15-6170 psi	Water	UV
1.5-2 NPS	3 NPS	0.886 in ²	[H] 1.062 in	0.266 in	15-6170 psi	Water	UV
2-3 NPS	3, 4 NPS	1.449 in ²	[J] 1.358 in	0.34 in	15-4620 psi	Water	UV

3 NPS	4 NPS	2.061 in ²	[K] 1.62 in	0.405 in	15-3705 psi	Water	UV
3-4 NPS	4, 6 NPS	3.196 in ²	[L] 2.017 in	0.504 in	15-3705 psi	Water	UV
4 NPS	6 NPS	4.03 in ²	[M] 2.265 in	0.566 in	15-3705 psi	Water	UV
4 NPS	6 NPS	4.855 in ²	[N] 2.486 in	0.622 in	15-3705 psi	Water	UV
4 NPS	6 NPS	7.126 in ²	[P] 3.012 in	0.753 in	15-3705 psi	Water	UV
6 NPS	8, 8 Dual NPS	12.318 in ²	[Q] 3.96 in	0.99 in	15-1480 psi	Water	UV
6 NPS	8, 8 Dual NPS	17.842 in ²	[R] 4.766 in	1.192 in	15-1020 psi	Water	UV
8 NPS	10, 10 Dual NPS	29.018 in ²	[T] 6.078 in	1.52 in	15-985 psi	Water	UV

Design Name: 31V Series NBCert # 01168

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/11/2029

Design Type

[Pilot Operated Pressure Relief Valve] 31V Series
Capacity Tests: Sec. UV at National Board Testing Lab on June 15, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.857 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.156 in ²	[D] 0.445 in	0.111 in	15-6170 psi	Air	UV
1-1.5 NPS	2 NPS	0.232 in ²	[E] 0.543 in	0.136 in	15-6170 psi	Air	UV
1-1.5 NPS	2 NPS	0.379 in ²	[F] 0.695 in	0.174 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.57 in ²	[G] 0.852 in	0.213 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.886 in ²	[H] 1.062 in	0.266 in	15-6170 psi	Air	UV
2-3 NPS	3, 4 NPS	1.449 in ²	[J] 1.358 in	0.34 in	15-4620 psi	Air	UV
3 NPS	4 NPS	2.061 in ²	[K] 1.62 in	0.405 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.196 in ²	[L] 2.017 in	0.504 in	15-3705 psi	Air	UV
4 NPS	6 NPS	4.03 in ²	[M] 2.265 in	0.566 in	15-3705 psi	Air	UV
4 NPS	6 NPS	4.855 in ²	[N] 2.486 in	0.622 in	15-3705 psi	Air	UV
4 NPS	6 NPS	7.126 in ²	[P] 3.012 in	0.753 in	15-3705 psi	Air	UV
6 NPS	8, 8 Dual NPS	12.318 in ²	[Q] 3.96 in	0.99 in	15-1480 psi	Air	UV
6 NPS	8, 8 Dual NPS	17.842 in ²	[R] 4.766 in	1.192 in	15-1020 psi	Air	UV
8 NPS	10, 10 Dual NPS	29.018 in ²	[T] 6.078 in	1.52 in	15-985 psi	Air	UV

Design Name: 3800 NBCert # 57024

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/24/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3800
 Capacity Tests: Sec. UV at unknown lab on May 20, 1994
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.859 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name:	3800L, PCL, PCM pilots	NBCert #	57215
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/03/2026

Design Type
[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.782 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition(1): Pop; (2): First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Bopp & Reuther Valves GmbH (BOP)	Nameplate Abbreviation: Bopp & Reuther
Mannheim, 68305Germany	

This Company Manufactures or Assembles:

Design Name:	Si 25/ Si 63RL (High Press., Restricted lift)	NBCert #	72199
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV	12/06/2030

Design Type

[Safety Relief Valve] Si 25/ Si 63RL (High Press., Restricted lift)
 Capacity Tests: Sec. NV, -Class 2, -Class 3 at National Board Testing Lab on December 6, 2012
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.819 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Restricted Lift
 Designed by: Bopp & Reuther Valves GmbH {BOP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75, 1.5 NPS	0.175 in ²	0.472 in	0.08 in	15-4350 psi	Air	NV, -Class 2, -Class 3
0.75-1 NPS	1-2 NPS	0.312 in ²	0.63 in	0.08 in	15-4350 psi	Air	NV, -Class 2, -Class 3
1-1.5 NPS	1.25-2 NPS	0.487 in ²	0.787 in	0.083 in	15-3625 psi	Air	NV, -Class 2, -Class 3
1.25-1.5 NPS	1.5, 2 NPS	0.761 in ²	0.984 in	0.1 in	15-3625 psi	Air	NV, -Class 2, -Class 3
1.5-2 NPS	2-3 NPS	1.247 in ²	1.26 in	0.13 in	15-3190 psi	Air	NV, -Class 2, -Class 3
2-2.5 NPS	3, 4 NPS	1.948 in ²	1.575 in	0.165 in	15-2900 psi	Air	NV, -Class 2, -Class 3
2.5-3 NPS	4 NPS	3.043 in ²	1.969 in	0.201 in	15-2320 psi	Air	NV, -Class 2, -Class 3
3-4 NPS	5, 6 NPS	4.832 in ²	2.48 in	0.254 in	15-1740 psi	Air	NV, -Class 2, -Class 3
4 NPS	6 NPS	7.218 in ²	3.031 in	0.313 in	15-1305 psi	Air	NV, -Class 2, -Class 3
5-6 NPS	8 NPS	10.529 in ²	3.661 in	0.378 in	15-870 psi	Air	NV, -Class 2, -Class 3

Design Name: Si 25/ Si 63RL (Liquid) (High Press., Restricted lift) NBCert # 72289

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 2, -Class 3	01/27/2031

Design Type

[Relief Valve] Si 25/ Si 63RL (Liquid) (High Press., Restricted lift)
 HolderDesignation:
 Capacity Tests: Sec. NV, -Class 2, -Class 3 at National Board Testing Lab on January 29, 2025
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.595 Unitless; (alternate medium): 0.000
 Media - Test: Water/Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Restricted Lift
 Designed by: Bopp & Reuther Valves GmbH {BOP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75, 1.5 NPS	0.175 in ²	0.472 in	0.08 in	15-4350 psi	Water	NV, -Class 2, -Class 3
0.75-1 NPS	1-2 NPS	0.312 in ²	0.63 in	0.08 in	15-4350 psi	Water	NV, -Class 2, -Class 3
1-1.5 NPS	1.25-2 NPS	0.487 in ²	0.787 in	0.083 in	15-3625 psi	Water	NV, -Class 2, -Class 3
1.25-1.5 NPS	1.5, 2 NPS	0.761 in ²	0.984 in	0.1 in	15-3625 psi	Water	NV, -Class 2, -Class 3
1.5-2 NPS	2-3 NPS	1.247 in ²	1.26 in	0.13 in	15-3190 psi	Water	NV, -Class 2, -Class 3
2-2.5 NPS	3, 4 NPS	1.948 in ²	1.575 in	0.165 in	15-2900 psi	Water	NV, -Class 2, -Class 3
2.5-3 NPS	4 NPS	3.043 in ²	1.969 in	0.201 in	15-2320 psi	Water	NV, -Class 2, -Class 3
3-4 NPS	5, 6 NPS	4.832 in ²	2.48 in	0.254 in	15-1740 psi	Water	NV, -Class 2, -Class 3
4 NPS	6 NPS	7.218 in ²	3.031 in	0.313 in	15-1305 psi	Water	NV, -Class 2, -Class 3
5-6 NPS	8 NPS	10.529 in ²	3.661 in	0.378 in	15-870 psi	Water	NV, -Class 2, -Class 3

Design Name: Si 25/ Si 63RL (Low Press., Restricted lift) NBCert # 72188

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV	12/06/2030

Design Type

[Safety Relief Valve] Si 25/ Si 63RL (Low Press., Restricted lift)
 Capacity Tests: Sec. NV, -Class 2, -Class 3 at National Board Testing Lab on December 6, 2012
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.701 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Restricted Lift
 Designed by: Bopp & Reuther Valves GmbH {BOP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75, 1.5 NPS	0.175 in ²	0.472 in	0.08 in	6-15 psi	Air	NV, -Class 2, -Class 3
0.75-1 NPS	1-2 NPS	0.312 in ²	0.63 in	0.08 in	6-15 psi	Air	NV, -Class 2, -Class 3
1-1.5 NPS	1.25-2 NPS	0.487 in ²	0.787 in	0.083 in	6-15 psi	Air	NV, -Class 2, -Class 3
1.25-1.5 NPS	1.5, 2 NPS	0.761 in ²	0.984 in	0.1 in	6-15 psi	Air	NV, -Class 2, -Class 3
1.5-2 NPS	2-3 NPS	1.247 in ²	1.26 in	0.13 in	6-15 psi	Air	NV, -Class 2, -Class 3
2-2.5 NPS	3, 4 NPS	1.948 in ²	1.575 in	0.165 in	6-15 psi	Air	NV, -Class 2, -Class 3
2.5-3 NPS	4 NPS	3.043 in ²	1.969 in	0.201 in	6-15 psi	Air	NV, -Class 2, -Class 3
3-4 NPS	5, 6 NPS	4.832 in ²	2.48 in	0.254 in	6-15 psi	Air	NV, -Class 2, -Class 3
4 NPS	6 NPS	7.218 in ²	3.031 in	0.313 in	6-15 psi	Air	NV, -Class 2, -Class 3
5-6 NPS	8 NPS	10.529 in ²	3.661 in	0.378 in	6-15 psi	Air	NV, -Class 2, -Class 3

Design Name: Si 41/43/44 02-05 NBCert # 72098

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/14/2027

Design Type

[Safety Valve] Si 41/43/44 02-05
 Capacity Tests: Sec. UV at National Board Testing Lab on May 18, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.848 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Bopp & Reuther Valves GmbH {BOP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1.25 NPS	0.351 in ²	0.669 in	0.22 in	15-4351 psi	Air	UV
0.75-1 NPS	1.25 NPS	0.351 in ²	0.669 in	0.22 in	15-4351 psi	Steam	UV
1 NPS	2 NPS	0.486 in ²	0.787 in	0.26 in	15-4351 psi	Air	UV
1 NPS	2 NPS	0.486 in ²	0.787 in	0.26 in	15-4351 psi	Steam	UV
1 NPS	1.5 NPS	0.588 in ²	0.866 in	0.287 in	15-4351 psi	Air	UV
1 NPS	1.5 NPS	0.588 in ²	0.866 in	0.287 in	15-4351 psi	Steam	UV

1.25-1.5 NPS	2 NPS	0.92 in ²	1.083 in	0.358 in	15-3626 psi	Air	UV
1.25-1.5 NPS	2 NPS	0.92 in ²	1.083 in	0.358 in	15-3626 psi	Steam	UV
1.5-2 NPS	3 NPS	1.49 in ²	1.378 in	0.457 in	15-3191 psi	Air	UV
1.5-2 NPS	3 NPS	1.49 in ²	1.378 in	0.457 in	15-3191 psi	Steam	UV
2 NPS	3 NPS	1.947 in ²	1.575 in	0.52 in	15-2321 psi	Air	UV
2 NPS	3 NPS	1.947 in ²	1.575 in	0.52 in	15-2321 psi	Steam	UV
2 NPS	3 NPS	2.147 in ²	1.654 in	0.547 in	15-2321 psi	Air	UV
2 NPS	3 NPS	2.147 in ²	1.654 in	0.547 in	15-2321 psi	Steam	UV
2.5-3 NPS	4 NPS	3.289 in ²	2.047 in	0.677 in	15-2321 psi	Air	UV
2.5-3 NPS	4 NPS	3.289 in ²	2.047 in	0.677 in	15-2321 psi	Steam	UV
3 NPS	4 NPS	3.816 in ²	2.205 in	0.728 in	15-1668 psi	Air	UV
3 NPS	4 NPS	3.816 in ²	2.205 in	0.728 in	15-1668 psi	Steam	UV
3 NPS	5,6 NPS	5.14 in ²	2.559 in	0.846 in	15-1668 psi	Air	UV
3 NPS	5,6 NPS	5.14 in ²	2.559 in	0.846 in	15-1668 psi	Steam	UV
4 NPS	6 NPS	5.962 in ²	2.756 in	0.909 in	15-1160 psi	Air	UV
4 NPS	6 NPS	5.962 in ²	2.756 in	0.909 in	15-1160 psi	Steam	UV
4 NPS	6 NPS	7.592 in ²	3.11 in	1.028 in	15-1160 psi	Air	UV
4 NPS	6 NPS	7.592 in ²	3.11 in	1.028 in	15-1160 psi	Steam	UV
5-6 NPS	8,9,10 NPS	10.521 in ²	3.661 in	1.209 in	15-943 psi	Air	UV
5-6 NPS	8,9,10 NPS	10.521 in ²	3.661 in	1.209 in	15-943 psi	Steam	UV
6 NPS	10 NPS	15.259 in ²	4.409 in	1.457 in	15-943 psi	Air	UV
6 NPS	10 NPS	15.259 in ²	4.409 in	1.457 in	15-943 psi	Steam	UV
8 NPS	10 NPS	19.009 in ²	4.921 in	1.626 in	15-435 psi	Air	UV
8 NPS	10 NPS	19.009 in ²	4.921 in	1.626 in	15-435 psi	Steam	UV
8 NPS	12 NPS	29.61 in ²	6.142 in	2.028 in	15-435 psi	Air	UV
8 NPS	12 NPS	29.61 in ²	6.142 in	2.028 in	15-435 psi	Steam	UV
10-12 NPS	14, 16 NPS	39.42 in ²	7.087 in	2.339 in	15-290 psi	Air	UV
10-12 NPS	14, 16 NPS	39.42 in ²	7.087 in	2.339 in	15-290 psi	Steam	UV
12 NPS	16 NPS	58.88 in ²	8.661 in	2.22 in	15-290 psi	Air	UV
12 NPS	16 NPS	58.88 in ²	8.661 in	2.22 in	15-290 psi	Steam	UV
14 NPS	20 NPS	67.19 in ²	9.252 in	3.055 in	15-290 psi	Air	UV
14 NPS	20 NPS	67.19 in ²	9.252 in	3.055 in	15-290 psi	Steam	UV
16 NPS	20 NPS	79.11 in ²	10.039 in	3.315 in	15-290 psi	Air	UV
16 NPS	20 NPS	79.11 in ²	10.039 in	3.315 in	15-290 psi	Steam	UV
16 NPS	20 NPS	95.39 in ²	11.024 in	3.638 in	15-290 psi	Air	UV
16 NPS	20 NPS	95.39 in ²	11.024 in	3.638 in	15-290 psi	Steam	UV

Design Name: Si 41/43/44 02-05 (Liquids) NBCert # 72100

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/17/2027

Design Type

[Safety Valve] Si 41/43/44 02-05 (Liquids)

Capacity Tests: Sec. UV at National Board Testing Lab on May 17, 2010

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.575 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: Opening Pressure

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Bopp & Reuther Valves GmbH {BOP}

Comments: Opening pressure as defined by the manufacturer: Disc starts to lift from seat / first water drop.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1.25, 1.50 NPS	0.352 in ²	0.669 in	0.22 in	15-4351 psi	Water	UV
1 NPS	2 NPS	0.486 in ²	0.787 in	0.26 in	15-4351 psi	Water	UV
1 NPS	1.5 NPS	0.589 in ²	0.866 in	0.287 in	15-4351 psi	Water	UV
1.25-1.5 NPS	2 NPS	0.921 in ²	1.083 in	0.358 in	15-3626 psi	Water	UV
1.5-2 NPS	2 NPS	1.491 in ²	1.378 in	0.457 in	15-3626 psi	Water	UV
2 NPS	3 NPS	1.948 in ²	1.575 in	0.52 in	15-2321 psi	Water	UV
2 NPS	3 NPS	2.149 in ²	1.654 in	547 in	15-2321 psi	Water	UV
2.5-3 NPS	4 NPS	3.291 in ²	2.047 in	0.677 in	15-2321 psi	Water	UV
3 NPS	4 NPS	3.819 in ²	2.205 in	0.728 in	15-1668 psi	Water	UV
3 NPS	5,6 NPS	5.143 in ²	2.559 in	0.846 in	15-1668 psi	Water	UV
4 NPS	6 NPS	5.966 in ²	2.756 in	0.909 in	15-1160 psi	Water	UV
4 NPS	6 NPS	7.596 in ²	3.11 in	1.028 in	15-1160 psi	Water	UV
5-6 NPS	8, 10 NPS	10.53 in ²	3.661 in	1.209 in	15-943 psi	Water	UV
6 NPS	10 NPS	15.27 in ²	4.409 in	1.457 in	15-943 psi	Water	UV
8 NPS	10 NPS	19.02 in ²	4.921 in	1.626 in	15-435 psi	Water	UV
8 NPS	12 NPS	29.63 in ²	6.142 in	2.028 in	15-435 psi	Water	UV
10-12 NPS	16 NPS	39.45 in ²	7.087 in	2.339 in	15-290 psi	Water	UV
12 NPS	16 NPS	58.92 in ²	8.661 in	2.858 in	15-290 psi	Water	UV
14 NPS	20 NPS	67.23 in ²	9.252 in	3.055 in	15-290 psi	Water	UV
16 NPS	20 NPS	95.44 in ²	11.024 in	3.638 in	15-290 psi	Water	UV

Design Name: Si 63 (High Press.)

NBCert #

72166

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV	12/06/2030

Design Type

[Safety Relief Valve] Si 63 (High Press.)

Capacity Tests: Sec. NV, -Class 2, -Class 3 at National Board Testing Lab on December 6, 2012

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.819 Unitless

Media - Test: Air/Gas; Certified: Air, Gas

Set Pressure Definition: Initial Audible Discharge

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Bopp & Reuther Valves GmbH {BOP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75, 1.5 NPS	0.175 in ²	0.472 in	0.158 in	15-4350 psi	Air	NV, -Class 2, -Class 3
0.75-1 NPS	1-2 NPS	0.312 in ²	0.63 in	0.217 in	15-4350 psi	Air	NV, -Class 2, -Class 3
1-1.5 NPS	1.25-2 NPS	0.487 in ²	0.787 in	0.276 in	15-3625 psi	Air	NV, -Class 2, -Class 3
1.25-1.5 NPS	1.5, 2 NPS	0.761 in ²	0.984 in	0.335 in	15-3625 psi	Air	NV, -Class 2, -Class 3
1.5-2 NPS	2-3 NPS	1.247 in ²	1.26 in	0.434 in	15-3190 psi	Air	NV, -Class 2, -Class 3
2-2.5 NPS	3, 4 NPS	1.948 in ²	1.575 in	0.552 in	15-2900 psi	Air	NV, -Class 2, -Class 3
2.5-3 NPS	4 NPS	3.043 in ²	1.969 in	0.67 in	15-2320 psi	Air	NV, -Class 2, -Class 3
3-4 NPS	5, 6 NPS	4.832 in ²	2.48 in	0.847 in	15-1740 psi	Air	NV, -Class 2, -Class 3
4 NPS	6 NPS	7.218 in ²	3.031 in	1.044 in	15-1305 psi	Air	NV, -Class 2, -Class 3
5-6 NPS	8 NPS	10.529 in ²	3.661 in	1.26 in	15-870 psi	Air	NV, -Class 2, -Class 3

Design Name:	Si 63 (Liquid) (High Press.)	NBCert #	72267
--------------	------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 2, -Class 3	01/27/2031

Design Type

[Relief Valve] Si 63 (Liquid) (High Press.)
HolderDesignation:
Capacity Tests: Sec. NV, -Class 2, -Class 3 at National Board Testing Lab on January 29, 2025
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.595 Unitless; (alternate medium): 0.000
Media - Test: Water/Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bopp & Reuther Valves GmbH {BOP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75, 1.5 NPS	0.175 in ²	0.472 in	0.158 in	15-4350 psi	Water	NV, -Class 2, -Class 3
0.75-1 NPS	1-2 NPS	0.312 in ²	0.63 in	0.217 in	15-4350 psi	Water	NV, -Class 2, -Class 3
1-1.5 NPS	1.25-2 NPS	0.487 in ²	0.787 in	0.276 in	15-3625 psi	Water	NV, -Class 2, -Class 3
1.25-1.5 NPS	1.5, 2 NPS	0.761 in ²	0.984 in	0.335 in	15-3625 psi	Water	NV, -Class 2, -Class 3
1.5-2 NPS	2-3 NPS	1.247 in ²	1.26 in	0.434 in	15-3190 psi	Water	NV, -Class 2, -Class 3
2-2.5 NPS	3, 4 NPS	1.948 in ²	1.575 in	0.552 in	15-2900 psi	Water	NV, -Class 2, -Class 3
2.5-3 NPS	4 NPS	3.043 in ²	1.969 in	0.67 in	15-2320 psi	Water	NV, -Class 2, -Class 3
3-4 NPS	5, 6 NPS	4.832 in ²	2.48 in	0.847 in	15-1740 psi	Water	NV, -Class 2, -Class 3
4 NPS	6 NPS	7.218 in ²	3.031 in	1.044 in	15-1305 psi	Water	NV, -Class 2, -Class 3
5-6 NPS	8 NPS	10.529 in ²	3.661 in	1.26 in	15-870 psi	Water	NV, -Class 2, -Class 3

Design Name:	Si 63 (Low Press.)	NBCert #	72177
--------------	--------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV	12/04/2030

Design Type

[Safety Relief Valve] Si 63 (Low Press.)
 Capacity Tests: Sec. NV, -Class 2, -Class 3 at National Board Testing Lab on December 4, 2012
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.701 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Bopp & Reuther Valves GmbH {BOP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75, 1.5 NPS	0.175 in ²	0.472 in	0.158 in	6-15 psi	Air	NV, -Class 2, -Class 3
0.75-1 NPS	1-2 NPS	0.312 in ²	0.63 in	0.217 in	6-15 psi	Air	NV, -Class 2, -Class 3
1-1.5 NPS	1.25-2 NPS	0.487 in ²	0.787 in	0.276 in	6-15 psi	Air	NV, -Class 2, -Class 3
1.25-1.5 NPS	1.5, 2 NPS	0.761 in ²	0.984 in	0.335 in	6-15 psi	Air	NV, -Class 2, -Class 3
1.5-2 NPS	2-3 NPS	1.247 in ²	1.26 in	0.434 in	6-15 psi	Air	NV, -Class 2, -Class 3
2-2.5 NPS	3, 4 NPS	1.948 in ²	1.575 in	0.552 in	6-15 psi	Air	NV, -Class 2, -Class 3
2.5-3 NPS	4 NPS	3.043 in ²	1.969 in	0.67 in	6-15 psi	Air	NV, -Class 2, -Class 3
3-4 NPS	5, 6 NPS	4.832 in ²	2.48 in	0.847 in	6-15 psi	Air	NV, -Class 2, -Class 3
4 NPS	6 NPS	7.218 in ²	3.031 in	1.044 in	6-15 psi	Air	NV, -Class 2, -Class 3
5-6 NPS	8 NPS	10.529 in ²	3.661 in	1.26 in	6-15 psi	Air	NV, -Class 2, -Class 3

Design Name: Si 81/83/84

NBCert # 72009

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

NV, -Class 2, -Class 3, UV

03/23/2027

Design Type

[Safety Relief Valve] Si 81/83/84
 Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at National Board Testing Lab on June 19, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.860 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Bopp & Reuther Valves GmbH {BOP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.2252 in ²	[E] 0.535 in	0.185 in	15-2900 psi	Steam	UV
1-1.5 NPS	2, 3 NPS	0.2252 in ²	[E] 0.535 in	0.185 in	15-2900 psi	Steam	NV
1-1.5 NPS	2, 3 NPS	0.2252 in ²	[E] 0.535 in	0.185 in	15-7500 psi	Air	UV
1-1.5 NPS	2, 3 NPS	0.2252 in ²	[E] 0.535 in	0.185 in	15-6000 psi	Air	NV
1.5 NPS	2, 2.5, 3 NPS	0.3518 in ²	[F] 0.669 in	0.236 in	15-2900 psi	Steam	UV
1.5 NPS	2, 2.5, 3 NPS	0.3518 in ²	[F] 0.669 in	0.236 in	15-2900 psi	Steam	NV
1.5 NPS	2, 2.5, 3 NPS	0.3518 in ²	[F] 0.669 in	0.236 in	15-5000 psi	Air	NV
1.5 NPS	2, 2.5, 3 NPS	0.3518 in ²	[F] 0.669 in	0.236 in	15-5500 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5785 in ²	[G] 0.858 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.5785 in ²	[G] 0.858 in	0.295 in	15-2900 psi	Steam	NV
1.5-2 NPS	2.5, 3 NPS	0.5785 in ²	[G] 0.858 in	0.295 in	15-5500 psi	Air	UV

1.5-2 NPS	2.5, 3 NPS	0.5785 in ²	[G] 0.858 in	0.295 in	15-3705 psi	Air	NV
1.5-2 NPS	3 NPS	0.9007 in ²	[H] 1.071 in	0.374 in	15-2750 psi	Air	NV
1.5-2 NPS	3 NPS	0.9007 in ²	[H] 1.071 in	0.374 in	15-2750 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9007 in ²	[H] 1.071 in	0.374 in	15-2750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.9007 in ²	[H] 1.071 in	0.374 in	15-5080 psi	Air	UV
2-3 NPS	3, 4 NPS	1.4743 in ²	[J] 1.37 in	0.472 in	15 psi	Steam	NV
2-3 NPS	3, 4 NPS	1.4743 in ²	[J] 1.37 in	0.472 in	15-5500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.4743 in ²	[J] 1.37 in	0.472 in	15-2700 psi	Air	NV
2-3 NPS	3, 4 NPS	1.4743 in ²	[J] 1.37 in	0.472 in	15-2700 psi	Steam	UV
3 NPS	4, 6 NPS	2.1067 in ²	[K] 1.638 in	0.571 in	15-2220 psi	Air	UV
3 NPS	4, 6 NPS	2.1067 in ²	[K] 1.638 in	0.571 in	15-2220 psi	Air	NV
3 NPS	4, 6 NPS	2.1067 in ²	[K] 1.638 in	0.571 in	15-2220 psi	Steam	UV
3 NPS	4, 6 NPS	2.1067 in ²	[K] 1.638 in	0.571 in	15-2220 psi	Steam	NV
3-4 NPS	4, 6 NPS	3.2665 in ²	[L] 2.039 in	0.709 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.2665 in ²	[L] 2.039 in	0.709 in	15-1500 psi	Air	NV
3-4 NPS	4, 6 NPS	3.2665 in ²	[L] 2.039 in	0.709 in	15-1500 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.2665 in ²	[L] 2.039 in	0.709 in	15-1500 psi	Steam	NV
4 NPS	6 NPS	4.1235 in ²	[M] 2.291 in	0.787 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.1235 in ²	[M] 2.291 in	0.787 in	15-1100 psi	Air	NV
4 NPS	6 NPS	4.1235 in ²	[M] 2.291 in	0.787 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	4.1235 in ²	[M] 2.291 in	0.787 in	15-1100 psi	Steam	NV
4 NPS	6 NPS	4.9708 in ²	[N] 2.516 in	0.866 in	15-1000 psi	Air	UV
4 NPS	6 NPS	4.9708 in ²	[N] 2.516 in	0.866 in	15-1000 psi	Air	NV
4 NPS	6 NPS	4.9708 in ²	[N] 2.516 in	0.866 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	4.9708 in ²	[N] 2.516 in	0.866 in	15-1000 psi	Steam	NV
4 NPS	6 NPS	7.3118 in ²	[P] 3.051 in	1.063 in	15-1000 psi	Air	UV
4 NPS	6 NPS	7.3118 in ²	[P] 3.051 in	1.063 in	15-1000 psi	Air	NV
4 NPS	6 NPS	7.3118 in ²	[P] 3.051 in	1.063 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	7.3118 in ²	[P] 3.051 in	1.063 in	15-1000 psi	Steam	NV
6 NPS	8 NPS	12.6655 in ²	[Q] 4.016 in	1.417 in	15-600 psi	Air	UV
6 NPS	8 NPS	12.6655 in ²	[Q] 4.016 in	1.417 in	15-600 psi	Air	NV
6 NPS	8 NPS	12.6655 in ²	[Q] 4.016 in	1.417 in	15-600 psi	Steam	UV
6 NPS	8 NPS	12.6655 in ²	[Q] 4.016 in	1.417 in	15-600 psi	Steam	NV
6 NPS	8, 10 NPS	18.3279 in ²	[R] 4.831 in	1.693 in	15-300 psi	Air	UV
6 NPS	8, 10 NPS	18.3279 in ²	[R] 4.831 in	1.693 in	15-300 psi	Air	NV
6 NPS	8, 10 NPS	18.3279 in ²	[R] 4.831 in	1.693 in	15-300 psi	Steam	UV
6 NPS	8, 10 NPS	18.3279 in ²	[R] 4.831 in	1.693 in	15-300 psi	Steam	NV
8 NPS	10 NPS	29.778 in ²	[T] 6.157 in	2.165 in	15-300 psi	Air	UV
8 NPS	10 NPS	29.778 in ²	[T] 6.157 in	2.165 in	15-300 psi	Air	NV
8 NPS	10 NPS	29.778 in ²	[T] 6.157 in	2.165 in	15-300 psi	Steam	UV
8 NPS	10 NPS	29.778 in ²	[T] 6.157 in	2.165 in	15-300 psi	Steam	NV

10 NPS	14 NPS	49087 mm ²	[V] 204.5 mm	72 mm	15-300 psi	Air	UV
12 NPS	16 NPS	125664 mm ²	[W] 245 mm	86 mm	15-300 psi	Air	UV

Design Name:	Si 81/83/84 (Liquids)	NBCert #	72065
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV, UV 09/20/2027

Design Type

[Relief Valve] Si 81/83/84 (Liquids)
Capacity Tests: Sec. NV, UV at National Board Testing Lab on June 13, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.675 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Opening Pressure
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bopp & Reuther Valves GmbH {BOP}
Comments: Opening pressure as defined by the manufacturer: Disc starts to lift from seat / first water drop.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.2252 in ²	[E] 0.535 in	0.185 in	15-7500 psi	Water	UV
1-1.5 NPS	2, 3 NPS	0.2252 in ²	[E] 0.535 in	0.185 in	15-6000 psi	Water	NV
1-1.5 NPS	2, 2.5, 3 NPS	0.3518 in ²	[F] 0.669 in	0.236 in	15-5000 psi	Water	UV
1-1.5 NPS	2, 2.5, 3 NPS	0.3518 in ²	[F] 0.669 in	0.236 in	15-5000 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5785 in ²	[G] 0.858 in	0.295 in	15-3705 psi	Water	UV
1.5-2 NPS	2.5, 3 NPS	0.5785 in ²	[G] 0.858 in	0.295 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.9007 in ²	[H] 1.071 in	0.374 in	15-2750 psi	Water	UV
1.5-2 NPS	3 NPS	0.9007 in ²	[H] 1.071 in	0.374 in	15-2750 psi	Water	NV
2-3 NPS	3, 4 NPS	1.4743 in ²	[J] 1.37 in	0.472 in	15-2700 psi	Water	UV
2-3 NPS	3, 4 NPS	1.4743 in ²	[J] 1.37 in	0.472 in	15-2700 psi	Water	NV
3 NPS	4, 6 NPS	2.1067 in ²	[K] 1.638 in	0.571 in	15-2220 psi	Water	UV
3 NPS	4, 6 NPS	2.1067 in ²	[K] 1.638 in	0.571 in	15-2220 psi	Water	NV
3-4 NPS	4, 6 NPS	3.2665 in ²	[L] 2.039 in	0.709 in	15-1500 psi	Water	UV
3-4 NPS	4, 6 NPS	3.2665 in ²	[L] 2.039 in	0.709 in	15-1500 psi	Water	NV
4 NPS	6 NPS	4.1235 in ²	[M] 2.291 in	0.787 in	15-1100 psi	Water	UV
4 NPS	6 NPS	4.1235 in ²	[M] 2.291 in	0.787 in	15-1100 psi	Water	NV
4 NPS	6 NPS	4.9708 in ²	[N] 2.516 in	0.866 in	15-1000 psi	Water	UV
4 NPS	6 NPS	4.9708 in ²	[N] 2.516 in	0.866 in	15-1000 psi	Water	NV
4 NPS	6 NPS	7.3118 in ²	[P] 3.051 in	1.063 in	15-1000 psi	Water	UV
4 NPS	6 NPS	7.3118 in ²	[P] 3.051 in	1.063 in	15-1000 psi	Water	NV
6 NPS	8 NPS	12.6655 in ²	[Q] 4.016 in	1.417 in	15-600 psi	Water	UV
6 NPS	8 NPS	12.6655 in ²	[Q] 4.016 in	1.417 in	15-600 psi	Water	NV
6 NPS	8, 10 NPS	18.3279 in ²	[R] 4.831 in	1.693 in	15-300 psi	Water	UV
6 NPS	8, 10 NPS	18.3279 in ²	[R] 4.831 in	1.693 in	15-300 psi	Water	NV
8 NPS	10 NPS	29.778 in ²	[T] 6.157 in	2.165 in	15-300 psi	Water	UV
8 NPS	10 NPS	29.778 in ²	[T] 6.157 in	2.165 in	15-300 psi	Water	NV

10 NPS	14 NPS	49087 mm ²	[V] 204.5 mm	72 mm	15-300 psi	Water	UV
12 NPS	16 NPS	125664 mm ²	[W] 245 mm	86 mm	15-300 psi	Air	UV

Design Name:	Si 81/83/84 (Liquids) (RL)	NBCert #	72021
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV, -Class 1, -Class 2, -Class 3, UV 09/20/2027

Design Type

[Relief Valve] Si 81/83/84 (Liquids) (RL)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at National Board Testing Lab on June 14, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.510 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Opening Pressure
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Bopp & Reuther Valves GmbH {BOP}
Comments: Opening pressure as defined by the manufacturer: Disc starts to lift from seat / first water drop.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1267 in ²	[D] 0.54 in	0.087 in	1600-1635 psi	Water	NV, -Class 1
1-1.5 NPS	2, 3 NPS	0.1267 in ²	[D] 0.54 in	0.087 in	15-6000 psi	Water	UV
1-1.5 NPS	2, 3 NPS	0.1267 in ²	[D] 0.54 in	0.087 in	15-6000 psi	Water	NV, -Class 2, -Class 3

Design Name:	Si 91 / 95, SiZ 2507	NBCert #	72201
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV 01/27/2027

Design Type

[Safety Valve] Si 91 / 95, SiZ 2507
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3 at National Board Testing Lab on January 27, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.843 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bopp & Reuther Valves GmbH {BOP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5, 3 NPS	0.486 in ²	0.787 in	0.236 in	44-4785 psi		NV
1.5 NPS	2.5, 3 NPS	0.76 in ²	0.984 in	0.295 in	44-4785 psi		NV
1.5 NPS	2.5, 3 NPS	1.247 in ²	1.26 in	0.378 in	44-4785 psi		NV
2 NPS	3 NPS	1.577 in ²	1.417 in	0.425 in	44-4785 psi		NV
2 NPS	3 NPS	1.948 in ²	1.575 in	0.472 in	44-4785 psi		NV
2.5-3 NPS	4 NPS	2.466 in ²	1.772 in	0.531 in	44-4785 psi		NV
2.5-3 NPS	4 NPS	3.291 in ²	2.047 in	0.614 in	44-4785 psi		NV
3 NPS	6 NPS	4.094 in ²	2.283 in	0.685 in	44-3915 psi		NV
3 NPS	6 NPS	4.831 in ²	2.48 in	0.744 in	44-3915 psi		NV
4 NPS	6 NPS	5.628 in ²	2.677 in	0.803 in	44-3625 psi		NV
4 NPS	6 NPS	6.487 in ²	2.874 in	0.862 in	44-3625 psi		NV

4 NPS	6 NPS	7.596 in ²	3.11 in	0.933 in	44-3625 psi	NV
6 NPS	8, 8 (Dual) NPS	9.005 in ²	3.386 in	1.016 in	44-2610 psi	NV
6 NPS	8, 8 (Dual) NPS	10.986 in ²	3.74 in	1.122 in	44-2610 psi	NV
6 NPS	8, 8 (Dual) NPS	13.422 in ²	4.134 in	1.24 in	44-2610 psi	NV
6 NPS	10, 10 (Dual) NPS	15.268 in ²	4.409 in	1.323 in	44-2175 psi	NV
6 NPS	10, 10 (Dual) NPS	17.527 in ²	4.724 in	1.417 in	44-2175 psi	NV
8 NPS	10-14, 10-14 (Dual) NPS	21.213 in ²	5.197 in	1.559 in	44-1885 psi	NV
8 NPS	12-14, 12-14 (Dual) NPS	21.862 in ²	5.276 in	1.583 in	44-1885 psi	NV
8 NPS	12, 12 (Dual) NPS	24.201 in ²	5.551 in	1.665 in	44-1595 psi	NV
8 NPS	12, 12 (Dual) NPS	24.271 in ²	5.559 in	1.669 in	44-1595 psi	NV
8 NPS	10-14, 10-14 (Dual) NPS	25.598 in ²	5.709 in	1.713 in	44-1595 psi	NV
8 NPS	10-14, 10-14 (Dual) NPS	30.386 in ²	6.22 in	1.866 in	44-1595 psi	NV
10 NPS	16, 16 (Dual) NPS	35.183 in ²	6.693 in	2.008 in	44-1305 psi	NV
10 NPS	16, 16 (Dual) NPS	40.772 in ²	7.205 in	2.161 in	44-1305 psi	NV
10 NPS	16, 16 (Dual) NPS	47.246 in ²	7.756 in	2.327 in	44-870 psi	NV
12 NPS	20, 20 (Dual) NPS	57.859 in ²	8.583 in	2.575 in	44-870 psi	NV
12 NPS	20, 20 (Dual) NPS	67.23 in ²	9.252 in	2.776 in	44-870 psi	NV

Design Name: Si 91 / 95, SiZ 2507 (Restricted Lift) NBCert # 72212

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 2, -Class 3	01/27/2027

Design Type

[Safety Valve] Si 91 / 95, SiZ 2507 (Restricted Lift)
Capacity Tests: Sec. NV, -Class 2, -Class 3 at National Board Testing Lab on January 27, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.843 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Bopp & Reuther Valves GmbH {BOP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5, 3 NPS	0.486 in ²	0.787 in	0.08 in	44-4785 psi		NV
1.5 NPS	2.5, 3 NPS	0.76 in ²	0.984 in	0.089 in	44-4785 psi		NV
1.5 NPS	2.5, 3 NPS	1.247 in ²	1.26 in	0.113 in	44-4785 psi		NV
2 NPS	3 NPS	1.577 in ²	1.417 in	0.128 in	44-4785 psi		NV
2 NPS	3 NPS	1.948 in ²	1.575 in	0.142 in	44-4785 psi		NV
2.5-3 NPS	4 NPS	2.466 in ²	1.772 in	0.159 in	44-4785 psi		NV
2.5-3 NPS	4 NPS	3.291 in ²	2.047 in	0.184 in	44-4785 psi		NV
3 NPS	6 NPS	4.094 in ²	2.283 in	0.205 in	44-3915 psi		NV
3 NPS	6 NPS	4.831 in ²	2.48 in	0.223 in	44-3915 psi		NV
4 NPS	6 NPS	5.628 in ²	2.677 in	0.241 in	44-3625 psi		NV

4 NPS	6 NPS	6.487 in ²	2.874 in	0.259 in	44-3625 psi	NV
4 NPS	6 NPS	7.596 in ²	3.11 in	0.28 in	44-3625 psi	NV
6 NPS	8, 8 (Dual) NPS	9.005 in ²	3.386 in	0.305 in	44-2610 psi	NV
6 NPS	8, 8 (Dual) NPS	10.986 in ²	3.74 in	0.337 in	44-2610 psi	NV
6 NPS	8, 8 (Dual) NPS	13.422 in ²	4.134 in	0.372 in	44-2610 psi	NV
6 NPS	10, 10 (Dual) NPS	15.268 in ²	4.409 in	0.37 in	44-2175 psi	NV
6 NPS	10, 10 (Dual) NPS	17.527 in ²	4.724 in	0.425 in	44-2175 psi	NV
8 NPS	10-14, 10-14 (Dual) NPS	21.213 in ²	5.197 in	0.468 in	44-1885 psi	NV
8 NPS	12-14, 12-14 (Dual) NPS	21.862 in ²	5.276 in	0.475 in	44-1885 psi	NV
8 NPS	12, 12 (Dual) NPS	24.201 in ²	5.551 in	0.5 in	44-1595 psi	NV
8 NPS	12, 12 (Dual) NPS	24.271 in ²	5.559 in	0.501 in	44-1595 psi	NV
8 NPS	10-14, 10-14 (Dual) NPS	25.598 in ²	5.709 in	0.514 in	44-1595 psi	NV
8 NPS	10-14, 10-14 (Dual) NPS	30.386 in ²	6.22 in	0.56 in	44-1595 psi	NV
10 NPS	16, 16 (Dual) NPS	35.183 in ²	6.693 in	0.602 in	44-1305 psi	NV
10 NPS	16, 16 (Dual) NPS	40.772 in ²	7.205 in	0.648 in	44-1305 psi	NV
10 NPS	16, 16 (Dual) NPS	47.246 in ²	7.756 in	0.698 in	44-870 psi	NV
12 NPS	20, 20 (Dual) NPS	57.859 in ²	8.583 in	0.773 in	44-870 psi	NV
12 NPS	20, 20 (Dual) NPS	67.23 in ²	9.252 in	0.833 in	44-870 psi	NV

Design Name: Si 91/95, SiZ 2507 RL

NBCert #

72076

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

NV, UV, V

08/09/2027

Design Type

[Safety Valve] Si 91/95, SiZ 2507 RL

Capacity Tests: Sec. NV, -Class 2, -Class 3, UV, V at National Board Testing Lab on April 7, 2005

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.826 Unitless

Media - Test: Steam; Certified: Steam

Set Pressure Definition: Initial Audible Discharge

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Bopp & Reuther Valves GmbH {BOP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5, 3 NPS	0.487 in ²	0.787 in	0.236 in	44-4351 psi	Steam	V
1.5 NPS	2.5, 3 NPS	0.487 in ²	0.787 in	0.236 in	44-4351 psi	Steam	NV
1.5 NPS	2.5, 3 NPS	0.487 in ²	0.787 in	0.236 in	44-4351 psi	Steam	UV
1.5 NPS	2.5, 3 NPS	0.761 in ²	0.984 in	0.295 in	44-4351 psi	Steam	NV
1.5 NPS	2.5, 3 NPS	0.761 in ²	0.984 in	0.295 in	44-4351 psi	Steam	UV
1.5 NPS	2.5, 3 NPS	0.761 in ²	0.984 in	0.295 in	44-4351 psi	Steam	V
1.5 NPS	2.5, 3 NPS	1.247 in ²	1.26 in	0.378 in	44-4351 psi	Steam	V
1.5 NPS	2.5, 3 NPS	1.247 in ²	1.26 in	0.378 in	44-4351 psi	Steam	NV
1.5 NPS	2.5, 3 NPS	1.247 in ²	1.26 in	0.378 in	44-4351 psi	Steam	UV

2 NPS	3 NPS	1.578 in ²	1.417 in	0.425 in	44-3626 psi	Steam	NV
2 NPS	3 NPS	1.578 in ²	1.417 in	0.425 in	44-3626 psi	Steam	UV
2 NPS	3 NPS	1.578 in ²	1.417 in	0.425 in	44-3626 psi	Steam	V
2 NPS	3 NPS	1.948 in ²	1.575 in	0.472 in	44-3626 psi	Steam	V
2 NPS	3 NPS	1.948 in ²	1.575 in	0.472 in	44-3626 psi	Steam	NV
2 NPS	3 NPS	1.948 in ²	1.575 in	0.472 in	44-3626 psi	Steam	UV
2.5 NPS	3, 4 NPS	2.465 in ²	1.772 in	0.531 in	44-4786 psi	Steam	NV
2.5 NPS	3, 4 NPS	2.465 in ²	1.772 in	0.531 in	44-4786 psi	Steam	UV
2.5 NPS	3, 4 NPS	2.465 in ²	1.772 in	0.531 in	44-4786 psi	Steam	V
2.5 NPS	3, 4 NPS	3.292 in ²	2.047 in	0.614 in	44-4786 psi	Steam	V
2.5 NPS	3, 4 NPS	3.292 in ²	2.047 in	0.614 in	44-4786 psi	Steam	NV
2.5 NPS	3, 4 NPS	3.292 in ²	2.047 in	0.614 in	44-4786 psi	Steam	UV
3 NPS	6 NPS	4.095 in ²	2.283 in	0.685 in	44-3916 psi	Steam	NV
3 NPS	6 NPS	4.095 in ²	2.283 in	0.685 in	44-3916 psi	Steam	UV
3 NPS	6 NPS	4.095 in ²	2.283 in	0.685 in	44-3916 psi	Steam	V
3 NPS	6 NPS	4.832 in ²	2.48 in	0.744 in	44-3916 psi	Steam	V
3 NPS	6 NPS	4.832 in ²	2.48 in	0.744 in	44-3916 psi	Steam	NV
3 NPS	6 NPS	4.832 in ²	2.48 in	0.744 in	44-3916 psi	Steam	UV
4 NPS	6 NPS	5.629 in ²	2.677 in	0.803 in	44-3626 psi	Steam	NV
4 NPS	6 NPS	5.629 in ²	2.677 in	0.803 in	44-3626 psi	Steam	UV
4 NPS	6 NPS	5.629 in ²	2.677 in	0.803 in	44-3626 psi	Steam	V
4 NPS	6 NPS	6.487 in ²	2.874 in	0.862 in	44-3626 psi	Steam	V
4 NPS	6 NPS	6.487 in ²	2.874 in	0.862 in	44-3626 psi	Steam	NV
4 NPS	6 NPS	6.487 in ²	2.874 in	0.862 in	44-3626 psi	Steam	UV
4 NPS	6 NPS	7.598 in ²	3.11 in	0.933 in	44-3626 psi	Steam	NV
4 NPS	6 NPS	7.598 in ²	3.11 in	0.933 in	44-3626 psi	Steam	UV
4 NPS	6 NPS	7.598 in ²	3.11 in	0.933 in	44-3626 psi	Steam	V
6 NPS	8, 8 Dual NPS	9.004 in ²	3.386 in	1.016 in	44-2611 psi	Steam	V
6 NPS	8, 8 Dual NPS	9.004 in ²	3.386 in	1.016 in	44-2611 psi	Steam	NV
6 NPS	8, 8 Dual NPS	9.004 in ²	3.386 in	1.016 in	44-2611 psi	Steam	UV
6 NPS	8, 8 Dual NPS	10.99 in ²	3.74 in	1.122 in	44-2611 psi	Steam	NV
6 NPS	8, 8 Dual NPS	10.99 in ²	3.74 in	1.122 in	44-2611 psi	Steam	UV
6 NPS	8, 8 Dual NPS	10.99 in ²	3.74 in	1.122 in	44-2611 psi	Steam	V
6 NPS	8, 8 Dual NPS	13.42 in ²	4.134 in	1.24 in	44-2611 psi	Steam	V
6 NPS	8, 8 Dual NPS	13.42 in ²	4.134 in	1.24 in	44-2611 psi	Steam	NV
6 NPS	8, 8 Dual NPS	13.42 in ²	4.134 in	1.24 in	44-2611 psi	Steam	UV
6 NPS	10, 10 Dual NPS	15.27 in ²	4.409 in	1.323 in	44-2176 psi	Steam	NV
6 NPS	10, 10 Dual NPS	15.27 in ²	4.409 in	1.323 in	44-2176 psi	Steam	UV
6 NPS	10, 10 Dual NPS	15.27 in ²	4.409 in	1.323 in	44-2176 psi	Steam	V
6 NPS	10, 10 Dual NPS	17.53 in ²	4.724 in	1.417 in	44-2176 psi	Steam	V
6 NPS	10, 10 Dual NPS	17.53 in ²	4.724 in	1.417 in	44-2176 psi	Steam	NV

6 NPS	10, 10 Dual NPS	17.53 in ²	4.724 in	1.417 in	44-2176 psi	Steam	UV
8 NPS	10, 12, 14, 10 Dual, NPS	21.21 in ²	5.197 in	1.559 in	44-1870 psi	Steam	NV
8 NPS	10, 12, 14, 10 Dual, NPS	21.21 in ²	5.197 in	1.559 in	44-1870 psi	Steam	UV
8 NPS	10, 12, 14, 10 Dual, NPS	21.21 in ²	5.197 in	1.559 in	44-1870 psi	Steam	V
8 NPS	12, 14, 12 Dual, 14 NPS	21.86 in ²	5.276 in	1.583 in	44-1814 psi	Steam	V
8 NPS	12, 14, 12 Dual, 14 NPS	21.86 in ²	5.276 in	1.583 in	44-1814 psi	Steam	NV
8 NPS	12, 14, 12 Dual, 14 NPS	21.86 in ²	5.276 in	1.583 in	44-1814 psi	Steam	UV
8 NPS	12, 12 Dual NPS	24.271 in ²	5.559 in	1.668 in	44-1549 psi	Steam	V
8 NPS	12, 12 Dual NPS	24.271 in ²	5.559 in	1.668 in	44-1549 psi	Steam	NV
8 NPS	12, 12 Dual NPS	24.271 in ²	5.559 in	1.668 in	44-1549 psi	Steam	UV
8 NPS	10 Dual, 12, 14, 12 NPS	25.6 in ²	5.709 in	1.713 in	44-1549 psi	Steam	V
8 NPS	10 Dual, 12, 14, 12 NPS	25.6 in ²	5.709 in	1.713 in	44-1549 psi	Steam	NV
8 NPS	10 Dual, 12, 14, 12 NPS	25.6 in ²	5.709 in	1.713 in	44-1549 psi	Steam	UV
8 NPS	10 Dual, 12, 14, 12 NPS	30.39 in ²	6.22 in	1.866 in	44-1450 psi	Steam	NV
8 NPS	10 Dual, 12, 14, 12 NPS	30.39 in ²	6.22 in	1.866 in	44-1450 psi	Steam	UV
8 NPS	10 Dual, 12, 14, 12 NPS	30.39 in ²	6.22 in	1.866 in	44-1450 psi	Steam	V
10 NPS	16, 16 Dual NPS	35.18 in ²	6.693 in	2.008 in	44-1450 psi	Steam	NV
10 NPS	16, 16 Dual NPS	35.18 in ²	6.693 in	2.008 in	44-1450 psi	Steam	UV
10 NPS	16, 16 Dual NPS	35.18 in ²	6.693 in	2.008 in	44-1450 psi	Steam	V
10 NPS	16, 16 Dual NPS	40.77 in ²	7.205 in	2.161 in	44-1450 psi	Steam	V
10 NPS	16, 16 Dual NPS	40.77 in ²	7.205 in	2.161 in	44-1450 psi	Steam	NV
10 NPS	16, 16 Dual NPS	40.77 in ²	7.205 in	2.161 in	44-1450 psi	Steam	UV
10 NPS	16, 16 Dual NPS	47.25 in ²	7.756 in	2.327 in	44-1450 psi	Steam	NV
10 NPS	16, 16 Dual NPS	47.25 in ²	7.756 in	2.327 in	44-1450 psi	Steam	UV
10 NPS	16, 16 Dual NPS	47.25 in ²	7.756 in	2.327 in	44-1450 psi	Steam	V
12 NPS	20, 20 Dual NPS	57.85 in ²	8.583 in	2.575 in	44-609 psi	Steam	V
12 NPS	20, 20 Dual NPS	57.85 in ²	8.583 in	2.575 in	44-609 psi	Steam	NV
12 NPS	20, 20 Dual NPS	57.85 in ²	8.583 in	2.575 in	44-609 psi	Steam	UV
12 NPS	20, 20 Dual NPS	67.23 in ²	9.252 in	2.776 in	44-609 psi	Steam	UV
12 NPS	20, 20 Dual NPS	67.23 in ²	9.252 in	2.776 in	44-609 psi	Steam	NV
12 NPS	20, 20 Dual NPS	67.23 in ²	9.252 in	2.776 in	44-609 psi	Steam	V

Design Name: Si 91/95, SiZ 2507 RL (Restricted Lift) NBCert # 72087

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 2, -Class 3, UV, V	05/12/2029

Design Type

[Safety Valve] Si 91/95, SiZ 2507 RL (Restricted Lift)

Capacity Tests: Sec. NV, -Class 2, -Class 3, UV, V at National Board Testing Lab on August 3, 2010

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.826 Unitless

Media - Test: Steam; Certified: Steam

Set Pressure Definition: Initial Audible Discharge

Blowdown Characteristics: Fixed

Flow Area Configuration: Restricted Lift

Designed by: Bopp & Reuther Valves GmbH {BOP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5, 3 NPS	0.487 in ²	0.787 in	0.083 in	44-4351 psi	Steam	UV
1.5 NPS	2.5, 3 NPS	0.487 in ²	0.787 in	0.083 in	44-4351 psi	Steam	V
1.5 NPS	2.5, 3 NPS	0.487 in ²	0.787 in	0.083 in	44-4351 psi	Steam	NV
1.5 NPS	2.5, 3 NPS	0.761 in ²	0.984 in	0.091 in	44-4351 psi	Steam	NV
1.5 NPS	2.5, 3 NPS	0.761 in ²	0.984 in	0.091 in	44-4351 psi	Steam	UV
1.5 NPS	2.5, 3 NPS	0.761 in ²	0.984 in	0.091 in	44-4351 psi	Steam	V
1.5 NPS	2.5, 3 NPS	1.247 in ²	1.26 in	0.115 in	44-4351 psi	Steam	V
1.5 NPS	2.5, 3 NPS	1.247 in ²	1.26 in	0.115 in	44-4351 psi	Steam	NV
1.5 NPS	2.5, 3 NPS	1.247 in ²	1.26 in	0.115 in	44-4351 psi	Steam	UV
2 NPS	3 NPS	1.578 in ²	1.417 in	0.13 in	44-3626 psi	Steam	NV
2 NPS	3 NPS	1.578 in ²	1.417 in	0.13 in	44-3626 psi	Steam	UV
2 NPS	3 NPS	1.578 in ²	1.417 in	0.13 in	44-3626 psi	Steam	V
2 NPS	3 NPS	1.948 in ²	1.575 in	0.142 in	44-3626 psi	Steam	V
2 NPS	3 NPS	1.948 in ²	1.575 in	0.142 in	44-3626 psi	Steam	NV
2 NPS	3 NPS	1.948 in ²	1.575 in	0.142 in	44-3626 psi	Steam	UV
2.5 NPS	3, 4 NPS	2.465 in ²	1.772 in	0.162 in	44-4786 psi	Steam	NV
2.5 NPS	3, 4 NPS	2.465 in ²	1.772 in	0.162 in	44-4786 psi	Steam	UV
2.5 NPS	3, 4 NPS	2.465 in ²	1.772 in	0.162 in	44-4786 psi	Steam	V
2.5 NPS	3, 4 NPS	3.292 in ²	2.047 in	0.186 in	44-4786 psi	Steam	V
2.5 NPS	3, 4 NPS	3.292 in ²	2.047 in	0.186 in	44-4786 psi	Steam	NV
2.5 NPS	3, 4 NPS	3.292 in ²	2.047 in	0.186 in	44-4786 psi	Steam	UV
3 NPS	6 NPS	4.095 in ²	2.283 in	0.209 in	44-3916 psi	Steam	NV
3 NPS	6 NPS	4.095 in ²	2.283 in	0.209 in	44-3916 psi	Steam	UV
3 NPS	6 NPS	4.095 in ²	2.283 in	0.209 in	44-3916 psi	Steam	V
3 NPS	6 NPS	4.832 in ²	2.48 in	0.225 in	44-3916 psi	Steam	V
3 NPS	6 NPS	4.832 in ²	2.48 in	0.225 in	44-3916 psi	Steam	NV
3 NPS	6 NPS	4.832 in ²	2.48 in	0.225 in	44-3916 psi	Steam	UV
4 NPS	6 NPS	5.629 in ²	2.677 in	0.245 in	44-3626 psi	Steam	NV
4 NPS	6 NPS	5.629 in ²	2.677 in	0.245 in	44-3626 psi	Steam	UV
4 NPS	6 NPS	5.629 in ²	2.677 in	0.245 in	44-3626 psi	Steam	V
4 NPS	6 NPS	6.487 in ²	2.874 in	0.26 in	44-3626 psi	Steam	V
4 NPS	6 NPS	6.487 in ²	2.874 in	0.26 in	44-3626 psi	Steam	NV
4 NPS	6 NPS	6.487 in ²	2.874 in	0.26 in	44-3626 psi	Steam	UV

4 NPS	6 NPS	7.598 in ²	3.11 in	0.284 in	44-3626 psi	Steam	NV
4 NPS	6 NPS	7.598 in ²	3.11 in	0.284 in	44-3626 psi	Steam	UV
4 NPS	6 NPS	7.598 in ²	3.11 in	0.284 in	44-3626 psi	Steam	V
6 NPS	8, 8 Dual NPS	9.004 in ²	3.386 in	0.308 in	44-2611 psi	Steam	V
6 NPS	8, 8 Dual NPS	9.004 in ²	3.386 in	0.308 in	44-2611 psi	Steam	NV
6 NPS	8, 8 Dual NPS	9.004 in ²	3.386 in	0.308 in	44-2611 psi	Steam	UV
6 NPS	8, 8 Dual NPS	10.99 in ²	3.74 in	0.339 in	44-2611 psi	Steam	NV
6 NPS	8, 8 Dual NPS	10.99 in ²	3.74 in	0.339 in	44-2611 psi	Steam	UV
6 NPS	8, 8 Dual NPS	10.99 in ²	3.74 in	0.339 in	44-2611 psi	Steam	V
6 NPS	8, 8 Dual NPS	13.42 in ²	4.134 in	0.375 in	44-2611 psi	Steam	V
6 NPS	8, 8 Dual NPS	13.42 in ²	4.134 in	0.375 in	44-2611 psi	Steam	NV
6 NPS	8, 8 Dual NPS	13.42 in ²	4.134 in	0.375 in	44-2611 psi	Steam	UV
6 NPS	10, 10 Dual NPS	15.27 in ²	4.409 in	0.398 in	44-2176 psi	Steam	NV
6 NPS	10, 10 Dual NPS	15.27 in ²	4.409 in	0.398 in	44-2176 psi	Steam	UV
6 NPS	10, 10 Dual NPS	15.27 in ²	4.409 in	0.398 in	44-2176 psi	Steam	V
6 NPS	10, 10 Dual NPS	17.53 in ²	4.724 in	0.426 in	44-2176 psi	Steam	V
6 NPS	10, 10 Dual NPS	17.53 in ²	4.724 in	0.426 in	44-2176 psi	Steam	NV
6 NPS	10, 10 Dual NPS	17.53 in ²	4.724 in	0.426 in	44-2176 psi	Steam	UV
8 NPS	10, 12, 14, 10 Dual, NPS	21.21 in ²	5.197 in	0.469 in	44-1870 psi	Steam	NV
8 NPS	10, 12, 14, 10 Dual, NPS	21.21 in ²	5.197 in	0.469 in	44-1870 psi	Steam	UV
8 NPS	10, 12, 14, 10 Dual, NPS	21.21 in ²	5.197 in	0.469 in	44-1870 psi	Steam	V
8 NPS	12, 14, 12 Dual, 14 NPS	21.86 in ²	5.276 in	0.468 in	44-1814 psi	Steam	V
8 NPS	12, 14, 12 Dual, 14 NPS	21.86 in ²	5.276 in	0.468 in	44-1814 psi	Steam	NV
8 NPS	12, 14, 12 Dual, 14 NPS	21.86 in ²	5.276 in	0.468 in	44-1814 psi	Steam	UV
8 NPS	12, 12 Dual NPS	24.271 in ²	5.559 in	0.5 in	44-1549 psi	Steam	V
8 NPS	12, 12 Dual NPS	24.271 in ²	5.559 in	0.5 in	44-1549 psi	Steam	NV
8 NPS	12, 12 Dual NPS	24.271 in ²	5.559 in	0.5 in	44-1549 psi	Steam	UV
8 NPS	10 Dual, 12, 14, 12 NPS	25.6 in ²	5.709 in	0.516 in	44-1549 psi	Steam	V
8 NPS	10 Dual, 12, 14, 12 NPS	25.6 in ²	5.709 in	0.516 in	44-1549 psi	Steam	NV
8 NPS	10 Dual, 12, 14, 12 NPS	25.6 in ²	5.709 in	0.516 in	44-1549 psi	Steam	UV
8 NPS	10 Dual, 12, 14, 12 NPS	30.39 in ²	6.22 in	0.563 in	44-1450 psi	Steam	NV
8 NPS	10 Dual, 12, 14, 12 NPS	30.39 in ²	6.22 in	0.563 in	44-1450 psi	Steam	UV
8 NPS	10 Dual, 12, 14, 12 NPS	30.39 in ²	6.22 in	0.563 in	44-1450 psi	Steam	V
10 NPS	16, 16 Dual NPS	35.18 in ²	6.693 in	0.603 in	44-1450 psi	Steam	NV
10 NPS	16, 16 Dual NPS	35.18 in ²	6.693 in	0.603 in	44-1450 psi	Steam	UV
10 NPS	16, 16 Dual NPS	35.18 in ²	6.693 in	0.603 in	44-1450 psi	Steam	V
10 NPS	16, 16 Dual NPS	40.77 in ²	7.205 in	0.65 in	44-1450 psi	Steam	V
10 NPS	16, 16 Dual NPS	40.77 in ²	7.205 in	0.65 in	44-1450 psi	Steam	NV
10 NPS	16, 16 Dual NPS	40.77 in ²	7.205 in	0.65 in	44-1450 psi	Steam	UV
10 NPS	16, 16 Dual NPS	47.25 in ²	7.756 in	0.701 in	44-1450 psi	Steam	NV

10 NPS	16, 16 Dual NPS	47.25 in ²	7.756 in	0.701 in	44-1450 psi	Steam	UV
10 NPS	16, 16 Dual NPS	47.25 in ²	7.756 in	0.701 in	44-1450 psi	Steam	V
12 NPS	20, 20 Dual NPS	57.85 in ²	8.583 in	0.776 in	44-609 psi	Steam	V
12 NPS	20, 20 Dual NPS	57.85 in ²	8.583 in	0.776 in	44-609 psi	Steam	NV
12 NPS	20, 20 Dual NPS	57.85 in ²	8.583 in	0.776 in	44-609 psi	Steam	UV
12 NPS	20, 20 Dual NPS	67.23 in ²	9.252 in	0.835 in	44-609 psi	Steam	UV
12 NPS	20, 20 Dual NPS	67.23 in ²	9.252 in	0.835 in	44-609 psi	Steam	NV
12 NPS	20, 20 Dual NPS	67.23 in ²	9.252 in	0.835 in	44-609 psi	Steam	V

Design Name:	Si/83/84/81 (RL)	NBCert #	72010
--------------	------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, UV	03/23/2027

Design Type

[Safety Relief Valve] Si/83/84/81 (RL)
Capacity Tests: Sec. NV, UV at National Board Testing Lab on June 19, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.200 SCFM/PSIA; (alternate medium): 6.180 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Bopp & Reuther Valves GmbH {BOP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1267 in ²	[D] 0.54 in	0.087 in	15-2900 psi	Steam	UV
1-1.5 NPS	2, 3 NPS	0.1267 in ²	[D] 0.54 in	0.087 in	15-2900 psi	Steam	NV
1-1.5 NPS	2, 3 NPS	0.1267 in ²	[D] 0.54 in	0.087 in	15-6000 psi	Air	UV
1-1.5 NPS	2, 3 NPS	0.1267 in ²	[D] 0.54 in	0.087 in	15-6000 psi	Air	NV

Design Name:	SiC 11/13/14	NBCert #	72043
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, UV	10/15/2026

Design Type

[Safety Relief Valve] SiC 11/13/14
Capacity Tests: Sec. NV, UV at National Board Testing Lab on July 19, 2000
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bopp & Reuther Valves GmbH {BOP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1 NPS	0.099 in ²	0.355 in	0.107 in	15-2900 psi	Air	UV
0.5-0.75 NPS	1 NPS	0.099 in ²	0.355 in	0.107 in	15-2900 psi	Air	NV
0.5-0.75 NPS	1 NPS	0.099 in ²	0.355 in	0.107 in	15-2900 psi	Steam	UV
0.5-0.75 NPS	1 NPS	0.099 in ²	0.355 in	0.107 in	15-2900 psi	Steam	NV

0.75-1 NPS	1 NPS	0.181 in ²	0.481 in	0.146 in	15-1500 psi	Air	UV
0.75-1 NPS	1 NPS	0.181 in ²	0.481 in	0.146 in	15-1500 psi	Air	NV
0.75-1 NPS	1 NPS	0.181 in ²	0.481 in	0.146 in	15-1500 psi	Steam	UV
0.75-1 NPS	1 NPS	0.181 in ²	0.481 in	0.146 in	15-1500 psi	Steam	NV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.67 in	0.201 in	15-750 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.67 in	0.201 in	15-750 psi	Air	NV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.67 in	0.201 in	15-750 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.67 in	0.201 in	15-750 psi	Steam	NV

Design Name: SiC 11/13/14 (Liquids) NBCert # 72054

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV, UV 04/15/2028

Design Type

[Relief Valve] SiC 11/13/14 (Liquids)
Capacity Tests: Sec. NV, UV at National Board Testing Lab on July 19, 2000
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.647 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Opening Pressure
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bopp & Reuther Valves GmbH {BOP}
Comments: Opening pressure as defined by the manufacturer: Disc starts to lift from seat / first water drop.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1 NPS	0.099 in ²	0.355 in	0.107 in	15-2900 psi	Water	UV
0.5-0.75 NPS	1 NPS	0.099 in ²	0.355 in	0.107 in	15-2900 psi	Water	NV
0.75-1 NPS	1 NPS	0.181 in ²	0.481 in	0.146 in	15-1500 psi	Water	UV
0.75-1 NPS	1 NPS	0.181 in ²	0.481 in	0.146 in	15-1500 psi	Water	NV
1 NPS	1.5 NPS	0.352 in ²	0.67 in	0.201 in	15-750 psi	Water	UV
1 NPS	1.5 NPS	0.352 in ²	0.67 in	0.201 in	15-750 psi	Water	NV

Design Name: SiZ 2507 NBCert # 72032

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV 11/30/2028

Design Type

[Safety Valve] SiZ 2507
Capacity Tests: Sec. NV at National Board Testing Lab on January 31, 2000
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bopp & Reuther Valves GmbH {BOP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
200 mm	300 mm	24.2 in ²	141 mm	51 mm	726-745 psi	Steam	NV

Branch of Bliss Anand America LLC. (BBA)

Dammam, 34847Saudi Arabia

This Company Manufactures or Assembles:

Design Name: 28L Series		NBCert #	00987
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	10/29/2030	
Design Type			
[Relief Valve] 28L Series Capacity Tests: Sec. UV at National Board Testing Lab on May 9, 2023 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.801 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Bliss Anand Private Limited {BLS}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.115 in ²	[D] 0.383 in	0.096 in	15-10000 psi	Water	UV
1-1.5 NPS	2, 3 NPS	0.208 in ²	[E] 0.514 in	0.129 in	15-10000 psi	Water	UV
1.5 NPS	2, 3 NPS	0.328 in ²	[F] 0.646 in	0.162 in	15-10000 psi	Water	UV
1.5-2 NPS	3 NPS	0.545 in ²	[G] 0.833 in	0.208 in	15-7000 psi	Water	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 1.043 in	0.261 in	15-6000 psi	Water	UV
2-3 NPS	3, 4 NPS	1.408 in ²	[J] 1.339 in	0.335 in	15-6000 psi	Water	UV
3 NPS	4, 6 NPS	2.013 in ²	[K] 1.601 in	0.4 in	15-5000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.136 in ²	[L] 1.998 in	0.5 in	15-4000 psi	Water	UV
4 NPS	6 NPS	3.959 in ²	[M] 2.245 in	0.561 in	15-3000 psi	Water	UV
4 NPS	6 NPS	4.777 in ²	[N] 2.466 in	0.617 in	15-2500 psi	Water	UV
4 NPS	6 NPS	7.037 in ²	[P] 2.993 in	0.748 in	15-2000 psi	Water	UV
6 NPS	8 NPS	12.2 in ²	[Q] 3.941 in	0.985 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	17.686 in ²	[R] 4.745 in	1.186 in	15-600 psi	Water	UV
8 NPS	10 NPS	28.761 in ²	[T] 6.051 in	1.513 in	15-500 psi	Water	UV
8-10 NPS	10-12 NPS	30.78 in ²	[U] 6.26 in	1.565 in	15-300 psi	Water	UV

Design Name: 28L Series (Air,Gas)		NBCert #	00998
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	10/29/2030	

Design Type

[Safety Relief Valve] 28L Series (Air,Gas)
Capacity Tests: Sec. UV at National Board Testing Lab on September 21, 2022
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.849 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.115 in ²	[D] 0.383 in	0.096 in	15-10000 psi	Air	UV
1-1.5 NPS	2, 3 NPS	0.208 in ²	[E] 0.514 in	0.129 in	15-10000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.328 in ²	[F] 0.646 in	0.162 in	15-10000 psi	Air	UV
1.5-2 NPS	3 NPS	0.545 in ²	[G] 0.833 in	0.208 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 1.043 in	0.261 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.408 in ²	[J] 1.339 in	0.335 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.013 in ²	[K] 1.601 in	0.4 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.136 in ²	[L] 1.998 in	0.5 in	15-4000 psi	Air	UV
4 NPS	6 NPS	3.959 in ²	[M] 2.245 in	0.561 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.777 in ²	[N] 2.466 in	0.617 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.037 in ²	[P] 2.993 in	0.748 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.2 in ²	[Q] 3.941 in	0.985 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.686 in ²	[R] 4.745 in	1.186 in	15-600 psi	Air	UV
8 NPS	10 NPS	28.761 in ²	[T] 6.051 in	1.513 in	15-500 psi	Air	UV
8-10 NPS	10-12 NPS	30.78 in ²	[U] 6.26 in	1.565 in	15-300 psi	Air	UV

Design Name: 28V Series

NBCert # 00392

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/29/2030

Design Type

[Safety Relief Valve] 28V Series
Capacity Tests: Sec. UV at National Board Testing Lab on September 21, 2022
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.850 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.115 in ²	[D] 0.383 in	0.096 in	15-10000 psi	Air	UV
1-1.5 NPS	2, 3 NPS	0.208 in ²	[E] 0.514 in	0.129 in	15-10000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.328 in ²	[F] 0.646 in	0.162 in	15-10000 psi	Air	UV
1.5-2 NPS	3 NPS	0.545 in ²	[G] 0.833 in	0.208 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 1.043 in	0.261 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.408 in ²	[J] 1.339 in	0.335 in	15-6000 psi	Air	UV

3 NPS	4, 6 NPS	2.013 in ²	[K] 1.601 in	0.4 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.136 in ²	[L] 1.998 in	0.5 in	15-4000 psi	Air	UV
4 NPS	6 NPS	3.959 in ²	[M] 2.245 in	0.561 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.777 in ²	[N] 2.466 in	0.617 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.037 in ²	[P] 2.993 in	0.748 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.2 in ²	[Q] 3.941 in	0.985 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.686 in ²	[R] 4.745 in	1.186 in	15-600 psi	Air	UV
8 NPS	10 NPS	28.761 in ²	[T] 6.051 in	1.513 in	15-500 psi	Air	UV
8-10 NPS	10-12 NPS	30.78 in ²	[U] 6.26 in	1.565 in	15-300 psi	Air	UV
10 NPS	14 NPS	48.945 in ²	[V] 7.894 in	1.973 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.848 in ²	[W] 9.016 in	2.254 in	15-1000 psi	Air	UV
16 NPS	18 NPS	104.524 in ²	[W2] 11.535 in	2.884 in	15-750 psi	Air	UV
16 NPS	20 NPS	114.004 in ²	[X] 12.047 in	3.012 in	15-750 psi	Air	UV
18 NPS	24 NPS	144.077 in ²	[Y] 13.543 in	3.386 in	15-750 psi	Air	UV
20 NPS	24 NPS	177.666 in ²	[Z] 15.039 in	3.76 in	15-750 psi	Air	UV

Design Name: 29L Series NBCert # 01090

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 10/29/2030

Design Type

[Relief Valve] 29L Series
Capacity Tests: Sec. UV at National Board Testing Lab on May 9, 2023
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.646 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.071 in ²	[C] 0.3 in	0.075 in	15-10000 psi	Water	UV
0.5-1 NPS	1 NPS	0.129 in ²	[D] 0.405 in	0.101 in	15-10000 psi	Water	UV
1 NPS	1.5 NPS	0.227 in ²	[E] 0.538 in	0.135 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.356 in ²	[F] 0.673 in	0.168 in	15-7000 psi	Water	UV

Design Name: 29V Series NBCert # 01078

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 10/29/2030

Design Type

[Safety Relief Valve] 29V Series
 Capacity Tests: Sec. UV at National Board Testing Lab on March 11, 2021
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.870 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.071 in ²	[C] 0.3 in	0.075 in	15-10000 psi	Air	UV
0.5-1 NPS	1 NPS	0.129 in ²	[D] 0.405 in	0.101 in	15-10000 psi	Air	UV
1 NPS	1.5 NPS	0.227 in ²	[E] 0.538 in	0.135 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.356 in ²	[F] 0.673 in	0.168 in	15-7000 psi	Air	UV

Design Name: 31L Series NBCert # 01180

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/29/2030

Design Type

[Pilot Operated Pressure Relief Valve] 31L Series
 Capacity Tests: Sec. UV at National Board Testing Lab on January 11, 2023
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.738 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.156 in ²	[D] 0.445 in	0.111 in	15-6170 psi	Water	UV
1-1.5 NPS	2 NPS	0.232 in ²	[E] 0.543 in	0.136 in	15-6170 psi	Water	UV
1-1.5 NPS	2 NPS	0.379 in ²	[F] 0.695 in	0.174 in	15-6170 psi	Water	UV
1.5-2 NPS	3 NPS	0.57 in ²	[G] 0.852 in	0.213 in	15-6170 psi	Water	UV
1.5-2 NPS	3 NPS	0.886 in ²	[H] 1.062 in	0.266 in	15-6170 psi	Water	UV
2-3 NPS	3, 4 NPS	1.449 in ²	[J] 1.358 in	0.34 in	15-4620 psi	Water	UV
3 NPS	4 NPS	2.061 in ²	[K] 1.62 in	0.405 in	15-3705 psi	Water	UV
3-4 NPS	4, 6 NPS	3.196 in ²	[L] 2.017 in	0.504 in	15-3705 psi	Water	UV
4 NPS	6 NPS	4.03 in ²	[M] 2.265 in	0.566 in	15-3705 psi	Water	UV
4 NPS	6 NPS	4.855 in ²	[N] 2.486 in	0.622 in	15-3705 psi	Water	UV
4 NPS	6 NPS	7.126 in ²	[P] 3.012 in	0.753 in	15-3705 psi	Water	UV
6 NPS	8, 8 Dual NPS	12.318 in ²	[Q] 3.96 in	0.99 in	15-1480 psi	Water	UV
6 NPS	8, 8 Dual NPS	17.842 in ²	[R] 4.766 in	1.192 in	15-1020 psi	Water	UV
8 NPS	10, 10 Dual NPS	29.018 in ²	[T] 6.078 in	1.52 in	15-985 psi	Water	UV

Design Name:	31V Series	NBCert #	01168
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/29/2030

Design Type

[Pilot Operated Pressure Relief Valve] 31V Series
Capacity Tests: Sec. UV at National Board Testing Lab on June 15, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.857 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.156 in ²	[D] 0.445 in	0.111 in	15-6170 psi	Air	UV
1-1.5 NPS	2 NPS	0.232 in ²	[E] 0.543 in	0.136 in	15-6170 psi	Air	UV
1-1.5 NPS	2 NPS	0.379 in ²	[F] 0.695 in	0.174 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.57 in ²	[G] 0.852 in	0.213 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.886 in ²	[H] 1.062 in	0.266 in	15-6170 psi	Air	UV
2-3 NPS	3, 4 NPS	1.449 in ²	[J] 1.358 in	0.34 in	15-4620 psi	Air	UV
3 NPS	4 NPS	2.061 in ²	[K] 1.62 in	0.405 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.196 in ²	[L] 2.017 in	0.504 in	15-3705 psi	Air	UV
4 NPS	6 NPS	4.03 in ²	[M] 2.265 in	0.566 in	15-3705 psi	Air	UV
4 NPS	6 NPS	4.855 in ²	[N] 2.486 in	0.622 in	15-3705 psi	Air	UV
4 NPS	6 NPS	7.126 in ²	[P] 3.012 in	0.753 in	15-3705 psi	Air	UV
6 NPS	8, 8 Dual NPS	12.318 in ²	[Q] 3.96 in	0.99 in	15-1480 psi	Air	UV
6 NPS	8, 8 Dual NPS	17.842 in ²	[R] 4.766 in	1.192 in	15-1020 psi	Air	UV
8 NPS	10, 10 Dual NPS	29.018 in ²	[T] 6.078 in	1.52 in	15-985 psi	Air	UV

Branch of Emerson Al-Arabia for Manufacturing (BAA)

Nameplate Abbreviation: EMRS

Dammam, 33226Saudi Arabia

This Company Manufactures or Assembles:

Design Name:	243/249/443/449/546/843/849/943/5046/5049/8043/8049	NBCert #	01292
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/15/2031

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
 Capacity Tests: Sec. UV at unknown lab on August 8, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name: 253/259/453/459/853/859/953/959/5059/8053/8059 NBCert # 01304

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/15/2031

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
 Capacity Tests: Sec. UV at unknown lab on July 31, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.627 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV

4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 263/269/463/469/566/863/869/963/969/5066/5069 NBCert # 01315

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/15/2031

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069

Capacity Tests: Sec. UV at unknown lab on July 30, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.860 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/15/2031

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.767 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

05/15/2031

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV

4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids) NBCert # 01348

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/15/2031

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids)
Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.712 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name: 900 Series (Liquid), 7700, SNC NBCert # 15499

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/15/2031

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name:	900 Series, 7700, SNC	NBCert #	15411
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	05/15/2031
--------------	----	------------

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Liquids)	NBCert #	15095
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	05/15/2031
--------------	----	------------

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V

8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/15/2031

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/ABNBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/15/2031

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV

6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Broady Flow Control Limited (BVL)	Nameplate Abbreviation: BROADY
--	---------------------------------------

East Yorkshire, HU3 2DUUnited Kingdom

This Company Manufactures or Assembles:

Design Name: 3500	NBCert # 93002
-------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/12/2029

Design Type

[Safety Relief Valve] 3500
Capacity Tests: Sec. UV at National Board Testing Lab on February 1, 2001
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.861 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Broady Flow Control Limited {BVL}
Comments: 6R10 added 8/11/17

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.121 in ²	[D] 10 mm	2.5 mm	15-2900 psi	Steam	UV
1-1.5 NPS	2, 3 NPS	0.121 in ²	[D] 10 mm	2.5 mm	15-6400 psi	Air	UV
1-1.5 NPS	2, 3 NPS	0.215 in ²	[E] 13.3 mm	3.32 mm	15-2900 psi	Steam	UV
1-1.5 NPS	2, 3 NPS	0.215 in ²	[E] 13.3 mm	3.32 mm	15-6200 psi	Air	UV
1.5 NPS	2, 3 NPS	0.335 in ²	[F] 16.6 mm	4.15 mm	15-2900 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.335 in ²	[F] 16.6 mm	4.15 mm	15-5100 psi	Air	UV
1.5-2 NPS	3 NPS	0.547 in ²	[G] 21.2 mm	5.3 mm	15-2800 psi	Air	UV
1.5-2 NPS	3 NPS	0.547 in ²	[G] 21.2 mm	5.3 mm	15-2800 psi	Steam	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 26.5 mm	6.63 mm	15-2800 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 26.5 mm	6.63 mm	15-2800 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.405 in ²	[J] 34 mm	8.5 mm	15-2850 psi	Air	UV

2-3 NPS	3, 4 NPS	1.405 in ²	[J] 34 mm	8.5 mm	15-2850 psi	Steam	UV
3 NPS	4, 6 NPS	2.003 in ²	[K] 40.6 mm	10.2 mm	15-2160 psi	Air	UV
3 NPS	4, 6 NPS	2.003 in ²	[K] 40.6 mm	10.2 mm	15-2160 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.115 in ²	[L] 50.6 mm	12.7 mm	15-1560 psi	Air	UV
3-4 NPS	4, 6 NPS	3.115 in ²	[L] 50.6 mm	12.7 mm	15-1560 psi	Air	UV
4 NPS	6 NPS	3.927 in ²	[M] 56.8 in	14.2 mm	15-1140 psi	Air	UV
4 NPS	6 NPS	3.927 in ²	[M] 56.8 in	14.2 mm	15-1140 psi	Steam	UV
4 NPS	6 NPS	4.73 in ²	[N] 62.4 mm	15.7 mm	15-1050 psi	Air	UV
4 NPS	6 NPS	4.73 in ²	[N] 62.4 mm	15.7 mm	15-1050 psi	Steam	UV
4 NPS	6 NPS	6.97 in ²	[P] 75.7 mm	19 mm	15-1020 psi	Air	UV
4 NPS	6 NPS	6.97 in ²	[P] 75.7 mm	19 mm	15-1020 psi	Steam	UV
6 NPS	8 NPS	12.06 in ²	[Q] 99.6 mm	25 mm	15-630 psi	Air	UV
6 NPS	8 NPS	12.06 in ²	[Q] 99.6 mm	25 mm	15-630 psi	Steam	UV
6 NPS	8, 10 NPS	17.42 in ²	[R] 119.8 mm	30 mm	15-630 psi	Air	UV
6 NPS	8, 10 NPS	17.42 in ²	[R] 119.8 mm	30 mm	15-630 psi	Steam	UV
8 NPS	10 NPS	28.4 in ²	[T] 152.8 mm	38.5 mm	15-300 psi	Air	UV
8 NPS	10 NPS	28.4 in ²	[T] 152.8 mm	38.5 mm	15-300 psi	Steam	UV

Design Name: 3500 (Liquid)

NBCert #

93013

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

11/17/2025

Design Type

[Safety Relief Valve] 3500 (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on February 11, 2011
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.635 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Broady Flow Control Limited {BVL}
Comments: 6R10 added 8/11/17

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 10 mm	2.5 mm	15-6400 psi	Water	UV
1-1.5 NPS	2,3 NPS	0.215 in ²	[E] 13.3 mm	3.32 mm	15-6200 psi	Water	UV
1.5 NPS	2,3 NPS	0.335 in ²	[F] 16.6 mm	4.15 mm	15-5100 psi	Water	UV
1.5-2 NPS	3 NPS	0.547 in ²	[G] 21.2 mm	5.3 mm	15-2800 psi	Water	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 26.5 mm	6.63 mm	15-2800 psi	Water	UV
2-3 NPS	3,4 NPS	1.405 in ²	[J] 34 mm	8.5 mm	15-2850 psi	Water	UV
3 NPS	4,6 NPS	2.003 in ²	[K] 40.6 mm	10.2 mm	15-2160 psi	Water	UV
3-4 NPS	4,6 NPS	3.115 in ²	[L] 50.6 mm	12.7 mm	15-1560 psi	Water	UV
4 NPS	6 NPS	3.927 in ²	[M] 56.8 mm	14.2 mm	15-1140 psi	Water	UV
4 NPS	6 NPS	4.73 in ²	[N] 62.4 mm	15.7 mm	15-1050 psi	Water	UV
4 NPS	6 NPS	6.97 in ²	[P] 75.7 mm	19 mm	15-1020 psi	Water	UV

6 NPS	8 NPS	12.06 in ²	[Q] 99.6 in	25 mm	15-630 psi	Water	UV
6 NPS	8, 10 NPS	17.42 in ²	[R] 119.8 mm	30 mm	15-630 psi	Water	UV
8 NPS	10 NPS	28.4 in ²	[T] 152.8 mm	38.5 mm	15-300 psi	Water	UV

Design Name: 3600 NBCert # 93024

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 08/16/2025

Design Type

[Safety Relief Valve] 3600
Capacity Tests: Sec. UV at National Board Testing Lab on March 1, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.970 SCFM/PSIA; (alternate medium): 5.540 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Broady Flow Control Limited {BVL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	84.9 mm ²	10.4 mm	2.5 mm	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	84.9 mm ²	10.4 mm	2.5 mm	15-3625 psi	Air	UV

Design Name: 3600 (Liquid) NBCert # 93035

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/14/2031

Design Type

[Safety Relief Valve] 3600 (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on July 25, 2011
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.690 GPM/SQ. RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Broady Flow Control Limited {BVL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	70.9 mm ²	9.5 mm	2.4 mm	1-250 bar	Water	UV

Design Name: 4000 (API Nozzle -Modulating & Snap Acting Pilot, Air/gas) NBCert # 93068

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/20/2028

Design Type

[Pilot Operated Pressure Relief Valve] 4000 (API Nozzle -Modulating & Snap Acting Pilot, Air/gas)
Capacity Tests: Sec. UV at National Board Testing Lab on April 15, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.821 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Broady Flow Control Limited {BVL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
25-40 DN	50 DN	78.54 mm ²	[D] 10 mm	10 mm	29-6400 psi	Air	UV
25-40 DN	50 DN	136.85 mm ²	[E] 13.25 mm	10 mm	29-6400 psi	Air	UV
25-40 DN	50 DN	216.42 mm ²	[F] 16.6 mm	10 mm	29-6170 psi	Air	UV
40-50 DN	50, 80 DN	354.66 mm ²	[G] 21.25 mm	15 mm	29-6170 psi	Air	UV
40-50 DN	80 DN	551.55 mm ²	[H] 26.5 mm	15 mm	29-6170 psi	Air	UV
50-80 DN	80, 100 DN	913.27 mm ²	[J] 34.1 mm	19 mm	29-4620 psi	Air	UV
80 DN	100 DN	1294.62 mm ²	[K] 40.6 mm	29 mm	29-3705 psi	Air	UV
80-100 DN	100, 150 DN	2010.9 mm ²	[L] 50.6 mm	29 mm	29-3705 psi	Air	UV
100 DN	150 DN	2524.97 mm ²	[M] 56.7 mm	37 mm	29-3705 psi	Air	UV
100 DN	150 DN	3058.15 mm ²	[N] 62.4 mm	37 mm	29-3705 psi	Air	UV
100 DN	150 DN	4417.86 mm ²	[P] 75 mm	37 mm	29-3705 psi	Air	UV
150 DN	200 DN	7791.28 mm ²	[Q] 99.6 mm	53 mm	29-1480 psi	Air	UV
150 DN	200 DN	11122 mm ²	[R] 119 mm	53 mm	29-1020 psi	Air	UV
200 DN	250 DN	18337.3 mm ²	[T] 152.8 mm	71 mm	29-985 psi	Air	UV

Design Name:	4000 (API Nozzle -Modulating & Snap Acting Pilot, Liquid)	NBCert #	93079
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/14/2031

Design Type

[Pilot Operated Pressure Relief Valve] 4000 (API Nozzle -Modulating & Snap Acting Pilot, Liquid)

Capacity Tests: Sec. UV at National Board Testing Lab on October 13, 2015

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.724 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Broady Flow Control Limited {BVL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
25-40 DN	50 DN	78.54 mm ²	[D] 10 mm	10 mm	29-6400 psi	Water	UV
25-40 DN	50 DN	135.85 mm ²	[E] 13.25 mm	10 mm	29-6400 psi	Water	UV
25-40 DN	50 DN	216.42 mm ²	[F] 16.6 mm	10 mm	29-6170 psi	Water	UV
40-50 DN	50, 80 DN	354.66 mm ²	[G] 21.25 mm	15 mm	29-6170 psi	Water	UV
40-50 DN	80 DN	551.55 mm ²	[H] 26.5 mm	15 mm	29-6170 psi	Water	UV
50-80 DN	80, 100 DN	913.27 mm ²	[J] 34.1 mm	19 mm	29-4620 psi	Water	UV
80 DN	100 DN	1294.62 mm ²	[K] 40.6 mm	29 mm	29-3705 psi	Water	UV
80-100 DN	100, 150 DN	2010.9 mm ²	[L] 50.6 mm	29 mm	29-3705 psi	Water	UV
100 DN	150 DN	2524.97 mm ²	[M] 56.7 mm	37 mm	29-3705 psi	Water	UV
100 DN	150 DN	3058.15 mm ²	[N] 62.4 mm	37 mm	29-3705 psi	Water	UV
100 DN	150 DN	4417.86 mm ²	[P] 75 mm	37 mm	29-3705 psi	Water	UV

150 DN	200 DN	7791.28 mm ²	[Q] 99.6 mm	53 mm	29-1480 psi	Water	UV
150 DN	200 DN	11122 mm ²	[R] 119 mm	53 mm	29-1020 psi	Water	UV
200 DN	250 DN	18337.3 mm ²	[T] 152.8 mm	71 mm	29-985 psi	Water	UV

Design Name:	4000 (Full Bore, Modulating & Snap Acting Pilot, Air/gas))	NBCert #	93046
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/23/2028

Design Type

[Pilot Operated Pressure Relief Valve] 4000 (Full Bore, Modulating & Snap Acting Pilot, Air/gas))
Capacity Tests: Sec. UV at National Board Testing Lab on April 15, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.729 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Broady Flow Control Limited {BVL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
25 DN	50 DN	508.7 mm ²	[G1] 25.45 mm	10 mm	29-6400 psi	Air	UV
40 DN	80 DN	1256.6 mm ²	[J1] 40 mm	15 mm	29-6170 psi	Air	UV
50 DN	80 DN	2030.8 mm ²	[L1] 50.85 mm	19 mm	29-6170 psi	Air	UV
80 DN	100 DN	5032.8 mm ²	[P1] 80.05 mm	29 mm	29-3705 psi	Air	UV
100 DN	150 DN	8123.3 mm ²	[Q1] 101.7 mm	37 mm	29-3705 psi	Air	UV
150 DN	200 DN	17695 mm ²	[R1] 150.1 mm	53 mm	29-1480 psi	Air	UV
200 DN	250 DN	32445.2 mm ²	[T1] 203.25 mm	71 mm	29-985 psi	Air	UV

BS & B Safety Systems, LLC (BSB)

Nameplate Abbreviation: BS&B

Tulsa, OK 74145United States

This Company Manufactures or Assembles:

Design Name:	0.5" FRB WFT	NBCert #	77600
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/15/2028

Design Type

[Rupture Disk Device] 0.5" FRB WFT
HolderDesignation: Single use assembly
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on September 7, 2000
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value:35.700 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1 NPS	1 NPS	0.216 in²			85-450 psi	Air	UD
Design Name:		1/2" FRB A-6 M x F & M x M Stakul, W-6 FRB, W-6 FRB F		NBCert #	77217		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UD		08/20/2026		
Design Type							
[Rupture Disk Device] 1/2" FRB A-6 M x F & M x M Stakul, W-6 FRB, W-6 FRB F HolderDesignation: A-6 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 8, 1999 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 2.190 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	0.5 NPS	0.196 in²			35-800 psi		UD
Design Name:		1/2" Welded FRB w. 3/4" Sanitary Connection (air/gas)		NBCert #	77789		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UD		02/10/2031		
Design Type							
[Rupture Disk Device] 1/2" Welded FRB w. 3/4" Sanitary Connection (air/gas) Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on January 13, 2003 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 5.900 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.22 in²			40-500 psi		UD
Design Name:		1/2" Welded FRB with 3/4" Sanitary Clamp Connection (A/G/L)		NBCert #	77442		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UD		04/12/2027		
Design Type							
[Rupture Disk Device] 1/2" Welded FRB with 3/4" Sanitary Clamp Connection (A/G/L) Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on April 11, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl Certified Value:12.000 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	0.75 NPS	0.22 in²	0.62 in		65-300 psi		UD
Design Name: 2" BNBCert # 77497							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			10/03/2025	
Design Type							
[Rupture Disk Device] 2" B HolderDesignation: FA-7R, 1F - 9F, UA-2,3,5,6 Capacity Tests: Sec. UD at National Board Testing Lab on August 11, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 0.230 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		3.33 in²			16-6000 psi		UD
Design Name: 2" BVNBCert # 77486							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			12/20/2025	
Design Type							
[Rupture Disk Device] 2" BV HolderDesignation: FA-7R, FA-1F - 9F, UA-2,3,5,6 Capacity Tests: Sec. UD at National Board Testing Lab on August 11, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 0.550 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		2.24 in²			16-6000 psi		UD
Design Name: 3/4" B assemblyNBCert # 77228							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			03/05/2027	
Design Type							
[Rupture Disk Device] 3/4" B assembly HolderDesignation: Single use Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on February 18, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 3.850 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.44 in²			108-1000 psi		UD
Design Name:			A-10 SK 1" SCD B, A-10 Special		NBCert #	77587	
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			09/13/2028	
Design Type							
[Rupture Disk Device] A-10 SK 1" SCD B, A-10 Special HolderDesignation: Integral Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on September 6, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 0.415 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1 NPS	1 NPS	0.785 in²			150-900 psi		UD
Design Name:			A19 & W19 with Scored B Disk		NBCert #	77644	
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			07/15/2029	
Design Type							
[Rupture Disk Device] A19 & W19 with Scored B Disk Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on April 30, 2001 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 0.503 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.44 in²			108-1000 psi		UD
Design Name:			A-2 SK 0.5 FRB		NBCert #	77598	
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			09/15/2028	
Design Type							
[Rupture Disk Device] A-2 SK 0.5 FRB HolderDesignation: Integral Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on September 1, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 2.200 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	0.5 NPS	0.196 in²			50-650 psi		UD
Design Name: A-6 with B Disk, W-6 with B Disk							

30 NPS	672 in ²	0.5-45 psi	UD
32 NPS	767 in ²	0.35-40 psi	UD
34 NPS	868.3 in ²	0.35-40 psi	UD
36 NPS	975.9 in ²	0.25-40 psi	UD
38 NPS	1090 in ²	0.25-40 psi	UD
4 NPS	12.73 in ²	2-150 psi	UD
40 NPS	1210 in ²	0.25-40 psi	UD
42 NPS	1336 in ²	0.25-40 psi	UD
44 NPS	1469 in ²	0.25-40 psi	UD
46 NPS	1608 in ²	0.25-40 psi	UD
48 NPS	1753 in ²	0.25-40 psi	UD
5 NPS	20 in ²	2-100 psi	UD
6 NPS	28.89 in ²	1-100 psi	UD
8 NPS	50.02 in ²	1-100 psi	UD

Design Name: B, BR, BRR (liquid)

NBCert # 77318

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UD

08/26/2026

Design Type

[Rupture Disk Device] B, BR, BRR (liquid)
 HolderDesignation: FA-7R, FA-1 - FA9, UA-2,3,5,6
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 12, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 1.470 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.189 in ²			80-30000 psi		UD
1 NPS		0.801 in ²			40-12000 psi		UD
1.5 NPS		1.76 in ²			26-6000 psi		UD
10 NPS		78.85 in ²			4-1400 psi		UD
12 NPS		112.5 in ²			4-1000 psi		UD
14 NPS		137.9 in ²			3-750 psi		UD
16 NPS		182.7 in ²			3-500 psi		UD
18 NPS		233.7 in ²			3-475 psi		UD
2 NPS		3.33 in ²			16-6000 psi		UD
20 NPS		291 in ²			2-450 psi		UD
24 NPS		424.6 in ²			2-230 psi		UD
3 NPS		6.514 in ²			12-6000 psi		UD
30 NPS		672 in ²			2-184 psi		UD
32 NPS		767 in ²			2-181 psi		UD
36 NPS		976 in ²			6-160 psi		UD

4 NPS	11.82 in ²	9-6000 psi	UD
40 NPS	1210 in ²	6-145 psi	UD
42 NPS	1336 in ²	3-138 psi	UD
44 NPS	1469 in ²	6-132 psi	UD
6 NPS	28.84 in ²	7-3600 psi	UD
8 NPS	49.89 in ²	5-3600 psi	UD

Design Name:	B, BR, BRR, Welded B	NBCert #	77037
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	08/04/2026

Design Type

[Rupture Disk Device] B, BR, BRR, Welded B
HolderDesignation: FA-7R, FA1,2,3,4,5,6,7,8,9,UA-2,3,5,6
Capacity Tests: Sec. UD at National Board Testing Lab on September 15, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.710 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.189 in ²			80-30000 psi		UD
0.725 in		0.34 in ²			900-20000 psi		UD
1 NPS		0.801 in ²			40-12000 psi		UD
1.5 NPS		1.76 in ²			26-6000 psi	Air	UD
10 NPS		78.85 in ²			4-1400 psi		UD
12 NPS		112.5 in ²			4-1000 psi		UD
14 NPS		137.9 in ²			3-750 psi		UD
16 NPS		182.7 in ²			3-500 psi		UD
18 NPS		233.7 in ²			3-475 psi		UD
2 NPS		3.33 in ²			16-6000 psi		UD
20 NPS		291 in ²			2-450 psi		UD
24 NPS		424.6 in ²			2-230 psi		UD
3 NPS		6.514 in ²			12-6000 psi		UD
30 NPS		672 in ²			2-184 psi		UD
32 NPS		767 in ²			2-181 psi		UD
36 NPS		976 in ²			6-160 psi		UD
4 NPS		11.82 in ²			9-6000 psi		UD
40 NPS		1210 in ²			6-145 psi		UD
42 NPS		1336 in ²			6-138 psi		UD
44 NPS		1469 in ²			6-132 psi		UD
6 NPS		28.84 in ²			7-3600 psi		UD
8 NPS		49.9 in ²			5-3600 psi		UD

Design Name:	B, BR, BRR-LTF	NBCert #	77879
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	11/02/2028

Design Type

[Rupture Disk Device] B, BR, BRR-LTF
HolderDesignation: Lo-to-Flo
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on September 14, 2005
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 8.000 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.189 in ²			80-30000 psi		UD
1 NPS		0.801 in ²			40-12000 psi		UD
1.5 NPS		1.76 in ²			26-6000 psi		UD
10 NPS		78.85 in ²			4-1400 psi		UD
12 NPS		112.5 in ²			4-1000 psi		UD
14 NPS		137.9 in ²			3-750 psi		UD
16 NPS		182.7 in ²			3-500 psi		UD
18 NPS		233.7 in ²			3-475 psi		UD
2 NPS		3.33 in ²			16-6000 psi		UD
20 NPS		291 in ²			2-450 psi		UD
24 NPS		424.6 in ²			2-230 psi		UD
3 NPS		6.514 in ²			12-6000 psi		UD
30 NPS		672 in ²			2-184 psi		UD
32 NPS		767 in ²			2-181 psi		UD
36 NPS		975.9 in ²			6-160 psi		UD
4 NPS		11.82 in ²			9-6000 psi		UD
40 NPS		1210 in ²			6-145 psi		UD
42 NPS		1336 in ²			6-138 psi		UD
44 NPS		1469 in ²			6-132 psi		UD
6 NPS		28.84 in ²			7-3600 psi		UD
8 NPS		49.89 in ²			5-3600 psi		UD

Design Name:	BV, BRV, BSV, BRSV	NBCert #	77026
--------------	--------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	08/04/2026

Design Type

[Rupture Disk Device] BV, BRV, BSV, BRSV
 HolderDesignation: FA-7R, FA-7,FA-1,2,3,4,5,6,7,8,9,UA-2,3,5,6
 Capacity Tests: Sec. UD at National Board Testing Lab on July 13, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.800 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.57 in ²			145-12000 psi	Air	UD
1.5 NPS		1.44 in ²			95-6000 psi	Air	UD
10 NPS		70.88 in ²			14-1400 psi		UD
12 NPS		101.5 in ²			12-1000 psi		UD
14 NPS		130.3 in ²			11-750 psi		UD
16 NPS		176.7 in ²			9-500 psi		UD
18 NPS		202.4 in ²			8-475 psi		UD
2 NPS		2.24 in ²			55-6000 psi	Air	UD
20 NPS		280 in ²			8-450 psi		UD
24 NPS		380.1 in ²			37-230 psi		UD
3 NPS		5.41 in ²			41-6000 psi		UD
30 NPS		615.7 in ²			20-184 psi		UD
32 NPS		728 in ²			31-181 psi		UD
36 NPS		927 in ²			28-160 psi		UD
4 NPS		9.62 in ²			31-6000 psi		UD
40 NPS		1149 in ²			25-145 psi		UD
42 NPS		1269 in ²			24-138 psi		UD
44 NPS		1395 in ²			23-132 psi		UD
6 NPS		23.76 in ²			23-3600 psi		UD
8 NPS		44.18 in ²			18-3600 psi		UD

Design Name: BV, BRV, BSV, BRSV-LTF

NBCert #

77880

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	12/15/2028

Design Type

[Rupture Disk Device] BV, BRV, BSV, BRSV-LTF
 HolderDesignation: Lo-to-Flo
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on September 14, 2005
 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl
 Certified Value: 2.470 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.57 in ²			40-12000 psi		UD

1.5 NPS	1.44 in ²	26-6000 psi	UD
10 NPS	70.88 in ²	4-1400 psi	UD
12 NPS	101.5 in ²	4-1000 psi	UD
14 NPS	130.3 in ²	3-750 psi	UD
16 NPS	176.7 in ²	3-500 psi	UD
18 NPS	202.4 in ²	3-475 psi	UD
2 NPS	2.24 in ²	16-6000 psi	UD
20 NPS	280 in ²	2-450 psi	UD
24 NPS	380.1 in ²	2-230 psi	UD
3 NPS	5.41 in ²	12-6000 psi	UD
30 NPS	615.8 in ²	2-184 psi	UD
32 NPS	728 in ²	6-181 psi	UD
36 NPS	927 in ²	6-160 psi	UD
4 NPS	9.62 in ²	9-6000 psi	UD
40 NPS	1149 in ²	6-145 psi	UD
42 NPS	1269 in ²	6-138 psi	UD
44 NPS	1395 in ²	6-132 psi	UD
6 NPS	23.76 in ²	7-3600 psi	UD
8 NPS	44.18 in ²	5-3600 psi	UD

Design Name:	BV,BRV,BSV,BRSV (liquid)	NBCert #	77273
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 08/06/2026

Design Type

[Rupture Disk Device] BV,BRV,BSV,BRSV (liquid)
HolderDesignation: FA-7R, FA-1 - FA-9,UA-,3,5,6
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 1, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 2.450 Unitless
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.57 in ²			145-12000 psi		UD
1.5 NPS		1.44 in ²			95-6000 psi		UD
10 NPS		70.88 in ²			14-1400 psi		UD
12 NPS		101.5 in ²			12-1000 psi		UD
14 NPS		130.3 in ²			11-750 psi		UD
16 NPS		176.7 in ²			9-500 psi		UD
18 NPS		202.4 in ²			8-475 psi		UD
2 NPS		2.24 in ²			55-6000 psi		UD
20 NPS		280 in ²			8-450 psi		UD
24 NPS		380.1 in ²			37-230 psi		UD

3 NPS	5.41 in ²	41-6000 psi	UD
30 NPS	615.8 in ²	20-184 psi	UD
32 NPS	728 in ²	31-181 psi	UD
36 NPS	927 in ²	28-160 psi	UD
4 NPS	9.62 in ²	31-6000 psi	UD
40 NPS	1149 in ²	25-145 psi	UD
42 NPS	1269 in ²	24-138 psi	UD
44 NPS	1395 in ²	23-132 psi	UD
6 NPS	23.76 in ²	23-3600 psi	UD
8 NPS	44.18 in ²	18-3600 psi	UD

Design Name: CSI		NBCert # 77565
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	09/19/2028

Design Type
[Rupture Disk Device] CSI HolderDesignation: CSR-7RS, CSR-7FS, CSI-7RS Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 30, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.620 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.5 NPS	1.5 NPS	1.89 in ²			50-800 psi		UD
1-1 NPS	1 NPS	0.86 in ²			70-800 psi		UD
2-2 NPS	2 NPS	3.36 in ²			50-800 psi	Air	UD
3-3 NPS	3 NPS	7.29 in ²			45-800 psi		UD
4-4 NPS	4 NPS	11.2 in ²			45-800 psi		UD
6-6 NPS	6 NPS	22.65 in ²			30-800 psi		UD
8-8 NPS	8 NPS	42.72 in ²			30-800 psi		UD
0.75-0.75 NPS	0.75 NPS	0.5 in ²	0 in	0 in	70-800 psi	Air	UD
10-10 NPS	10 NPS	66.3 in ²	0 in	0 in	18-800 psi		UV

Design Name: CSI (liquid)		NBCert #	78162
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	10/14/2027

Design Type

[Rupture Disk Device] CSI (liquid)
HolderDesignation: CSR-7RS, CSR-7FS
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 23, 2015
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 3.090 Unitless
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.5 NPS	1.5 NPS	1.89 in ²			50-800 psi		UD
1-1 NPS	1 NPS	0.86 in ²			70-800 psi		UD
2-2 NPS	2 NPS	3.36 in ²			50-800 psi		UD
3-3 NPS	3 NPS	7.29 in ²			45-800 psi		UD
4-4 NPS	4 NPS	11.2 in ²			45-800 psi		UD
6-6 NPS	6 NPS	22.65 in ²			30-800 psi		UD
8-8 NPS	8 NPS	42.72 in ²			30-800 psi		UD
0.75-0.75 NPS	0.75 NPS	0.5 in ²	0 in	0 in	70-800 psi	Water	UD
10-10 NPS	10 NPS	66.3 in ²	0 in	0 in	18-800 psi		UV

Design Name: CSR

NBCert # 77004

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

10/10/2025

Design Type

[Rupture Disk Device] CSR
HolderDesignation: CSR-7RS, CSR-7FS, CSI-7RS
Capacity Tests: Sec. UD at National Board Testing Lab on July 13, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 1.000 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			120-800 psi		UD
1.5 NPS		2.03 in ²			50-800 psi		UD
2 NPS		3.35 in ²			50-800 psi		UD
3 NPS		7.39 in ²			50-800 psi		UD
4 NPS		12.73 in ²			50-800 psi		UD
6 NPS		28.89 in ²			30-800 psi		UD
8 NPS		50.03 in ²			50-800 psi		UD

Design Name: CSR (liquid)

NBCert # 77093

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

10/03/2025

Design Type

[Rupture Disk Device] CSR (liquid)
 HolderDesignation: CSR-7RS, CRS-7FS, CSI-7RS
 Capacity Tests: Sec. UD at National Board Testing Lab on September 15, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 3.190 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			120-800 psi		UD
1.5 NPS		2.03 in ²			50-800 psi		UD
2 NPS		3.35 in ²			50-800 psi		UD
3 NPS		7.39 in ²			50-800 psi		UD
4 NPS		12.73 in ²			50-800 psi		UD
6 NPS		28.89 in ²			30-800 psi		UD
8 NPS		50.03 in ²			50-800 psi		UD

Design Name: D Series (liquid) DR, DRR NBCert # 77352

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

03/01/2027

Design Type

[Rupture Disk Device] D Series (liquid) DR, DRR
 HolderDesignation: FA-7R, FA-1 - FA-9, UA-2,3,5,6, FF-*
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 28, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 1.300 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.801 in ²			44-2000 psi		UD
1.5 NPS		1.76 in ²			31-1400 psi		UD
10 NPS		78.8 in ²			4-480 psi		UD
12 NPS		112.5 in ²			3-1000 psi		UD
14 NPS		137.9 in ²			3-350 psi		UD
16 NPS		182.7 in ²			3-300 psi		UD
18 NPS		233.7 in ²			3-270 psi		UD
2 NPS		3.33 in ²			15-1100 psi		UD
20 NPS		291 in ²			3-240 psi		UD
24 NPS		424.6 in ²			3-200 psi		UD
28 NPS		584 in ²			3-170 psi	Air	UD
3 NPS		6.51 in ²			11-900 psi		UD
30 NPS		672 in ²			3-170 psi		UD
32 NPS		767 in ²			3-170 psi		UD

36 NPS	976 in ²	3-170 psi	UD
4 NPS	11.8 in ²	8-830 psi	UD
40 NPS	1210 in ²	3-170 psi	UD
42 NPS	1336 in ²	3-170 psi	UD
44 NPS	1465 in ²	3-170 psi	UD
6 NPS	28.84 in ²	6-640 psi	UD
8 NPS	49.9 in ²	5-590 psi	UD

Design Name: DV, D, DR, DRR, DRV NBCert # 77048

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/03/2025

Design Type

[Rupture Disk Device] DV, D, DR, DRR, DRV
HolderDesignation: FA-7R, FA-1F - 9F, UA-2,3,5,6, FF-*
Capacity Tests: Sec. UD at National Board Testing Lab on September 15, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 1.190 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.69 in ²			44-2000 psi		UD
1.5 NPS		1.62 in ²			31-1400 psi		UD
10 NPS		74.6 in ²			4-480 psi		UD
12 NPS		106 in ²			3-400 psi		UD
14 NPS		135 in ²			3-350 psi		UD
16 NPS		176 in ²			3-300 psi		UD
18 NPS		223 in ²			3-270 psi		UD
2 NPS		2.95 in ²			15-1100 psi		UD
20 NPS		277 in ²			3-240 psi		UD
24 NPS		397 in ²			3-200 psi		UD
28 NPS	NPS	584 in ²			3-170 psi	Air	UD
3 NPS		6.49 in ²			11-900 psi		UD
30 NPS		661 in ²			3-170 psi		UD
36 NPS		907 in ²			3-170 psi		UD
4 NPS		11 in ²			8-830 psi		UD
40 NPS		1120 in ²			3-170 psi		UD
42 NPS		1234 in ²			3-170 psi		UD
44 NPS		1355 in ²			3-170 psi		UD
6 NPS		25.9 in ²			6-640 psi		UD
8 NPS		47.1 in ²			5-590 psi		UD

Design Name:	DV, DRV, DSV, DRSV (liquids)	NBCert #	77734
--------------	------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	06/21/2030

Design Type

[Rupture Disk Device] DV, DRV, DSV, DRSV (liquids)
HolderDesignation: FA-7R,FA-1F - FA-9F, UA-2,3,5,6, FF-*
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 11, 2002
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 2.600 Unitless
Media - Test: Air/Gas, Water/Liquid (Krl test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.57 in ²			44-2000 psi		UD
1.5 NPS		1.44 in ²			31-1400 psi		UD
10 NPS		70.88 in ²			4-480 psi		UD
12 NPS		101.5 in ²			3-1000 psi		UD
14 NPS		130.3 in ²			3-350 psi		UD
16 NPS		176.7 in ²			3-300 psi		UD
18 NPS		202.3 in ²			3-270 psi		UD
2 NPS		2.24 in ²			15-1100 psi		UD
20 NPS		280 in ²			3-240 psi		UD
24 NPS		380.1 in ²			3-200 psi		UD
28 NPS		584 in ²			3-170 psi	Air	UD
3 NPS		5.41 in ²			11-900 psi		UD
30 NPS		615.7 in ²			3-170 psi		UD
32 NPS		728 in ²			3-170 psi		UD
36 NPS		927 in ²			3-170 psi		UD
4 NPS		9.62 in ²			8-830 psi		UD
40 NPS		1149 in ²			3-170 psi		UD
42 NPS		1269 in ²			3-170 psi		UD
44 NPS		1395 in ²			3-170 psi		UD
6 NPS		23.76 in ²			6-640 psi		UD
8 NPS		44.18 in ²			5-590 psi		UD

Design Name:	ECR	NBCert #	77071
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	11/25/2025

Design Type

[Rupture Disk Device] ECR
 HolderDesignation: EC-7RS
 Capacity Tests: Sec. UD at National Board Testing Lab on July 2, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.580 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			2-180 psi		UD
1.5 NPS		2.03 in ²			2-80 psi		UD
10 NPS		66.3 in ²			1-15 psi		UD
12 NPS		94.7 in ²			1-15 psi		UD
14 NPS		118 in ²			1-15 psi		UD
16 NPS		154 in ²			1-15 psi		UD
18 NPS		195 in ²			1-15 psi		UD
2 NPS		3.36 in ²			2-80 psi		UD
20 NPS		241 in ²			1-15 psi		UD
24 NPS		348 in ²			1-15 psi		UD
3 NPS		7.3 in ²			1-50 psi		UD
4 NPS		12.1 in ²			1-50 psi		UD
6 NPS		25.4 in ²			1-50 psi		UD
8 NPS		43.6 in ²			1-15 psi		UD

Design Name: ECV

NBCert # 78274

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	03/29/2031

Design Type

[Rupture Disk Device] ECV
 HolderDesignation: EC-7RS, EC-7FS, EC-7R
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on May 19, 2016
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 4.180 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.735 in ²			8-15 psi		UD
1.5 NPS		1.24 in ²			5-15 psi		UD
10 NPS		48.8 in ²			1-15 psi		UD
12 NPS		69.4 in ²			1-15 psi		UD
14 NPS		88 in ²			1-15 psi		UD
16 NPS		115 in ²			1-15 psi		UD
18 NPS		146 in ²			1-15 psi		UD

2 NPS	2.21 in ²	3-15 psi	UD
20 NPS	180 in ²	1-15 psi	UD
24 NPS	261 in ²	1-15 psi	UD
3 NPS	4.76 in ²	2-15 psi	UD
4 NPS	7.9 in ²	1-15 psi	UD
6 NPS	18.1 in ²	1-15 psi	UD
8 NPS	31.4 in ²	1-15 psi	UD

Design Name:	FRB (welded cassette)	NBCert #	77835
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 04/09/2026

Design Type

[Rupture Disk Device] FRB (welded cassette)
HolderDesignation: N/A
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on February 26, 2004
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 6.800 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375 NPS		0.09 in ²			60-400 psi		UD

Design Name:	FRS	NBCert #	77284
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/22/2027

Design Type

[Rupture Disk Device] FRS
HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, S90-7R, S90-7R-TR, SRI-7RS
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 23, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.800 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			13.5-150 psi		UD
1.5 NPS		1.94 in ²			11.5-70 psi		UD
2 NPS		3.36 in ²			11.5-50 psi		UD

Design Name:	FVA	NBCert #	77925
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/02/2025

Design Type

[Rupture Disk Device] FVA
HolderDesignation: FVA
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 7, 2008
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.840 Unitless; Certification Provisions: Kd Certified Rupture Disk (Prev. Code Case 2395)
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS		0.049 in ²			115-1800 psi	Air	UD
0.375 NPS		0.11 in ²			115-1800 psi	Air	UD
0.5 NPS		0.196 in ²			115-1800 psi	Air	UD
0.75 NPS		0.442 in ²			100-1000 psi	Air	UD
1 NPS		0.785 in ²			90-1000 psi	Air	UD
1.5 NPS		1.77 in ²			85-1000 psi	Air	UD

Design Name: GCR-S, SE, SM, SS, SES, SMS, SME,
SMES, SW, N, NS NBCert # 77611

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/04/2029

Design Type

[Rupture Disk Device] GCR-S, SE, SM, SS, SES, SMS, SME, SMES, SW, N, NS
HolderDesignation: GR-C, FM-C, not req'd for -SM
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on November 22, 2000
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 1.950 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		1.5 in ²			10-300 psi	Air	UD
3 NPS		5.29 in ²			10-175 psi		UD
4 NPS		9.78 in ²			10-150 psi		UD
6 NPS		22.5 in ²			10-75 psi		UD
48.3 DN	DN	2.38 in ²	0 in	0 in	10-300 psi		UD
60.3 DN	DN	3.85 in ²	0 in	0 in	10-175 psi		UD
76.1 DN	DN	6.33 in ²	0 in	0 in	10-175 psi		UD

Design Name: GCR-S, SE, SM, SS, SES, SMS, SME,
SMES, SW, N, NS (liquids) NBCert # 78195

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/13/2028

Design Type

[Rupture Disk Device] GCR-S, SE, SM, SS, SES, SMS, SME, SMES, SW, N, NS (liquids)
HolderDesignation: GR-C, FM-C (not req'd for SM)
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 5, 2015
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 2.750 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		1.5 in ²			10-300 psi		UD
3 NPS		5.29 in ²			10-175 psi		UD
4 NPS		9.78 in ²			10-150 psi		UD
6 NPS		22.5 in ²			10-75 psi		UD
48.3 DN	DN	2.38 in ²	0 in	0 in	10-300 psi		UD
60.3 DN	DN	3.85 in ²	0 in	0 in	10-300 psi		UD
76.1 DN	DN	6.33 in ²	0 in	0 in	10-300 psi		UD

Design Name: GCR-S,SE,SM,SS,SES,SMS, SME, SMES, SW, N, NS (2" liquids) NBCert # 78207

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/14/2028

Design Type

[Rupture Disk Device] GCR-S,SE,SM,SS,SES,SMS, SME, SMES, SW, N, NS (2" liquids)
HolderDesignation: GR-C, FM-C, not req'd for -SM
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 25, 2015
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krl
Certified Value: 1.420 Unitless
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		2.7 in ²			10-300 psi	Water	UD

Design Name: GCR-S,SE,SM,SS,SES,SMS, SME, SMES, SW, N, NS (2") NBCert # 77420

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	03/24/2027

Design Type

[Rupture Disk Device] GCR-S,SE,SM,SS,SES,SMS, SME, SMES, SW, N, NS (2")
HolderDesignation: GR-C, FM-C, not req'd for -SM
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on January 10, 2000
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 1.250 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		2.7 in²			10-300 psi	Air	UD
Design Name: GFN, GFA, XN, XN-85NBCert # 77060							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			12/18/2025	
Design Type							
[Rupture Disk Device] GFN, GFA, XN, XN-85 HolderDesignation: NF-7RS, NF-7R, NFI-7RS Capacity Tests: Sec. UD at National Board Testing Lab on December 18, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.550 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			113-1800 psi		UD
1.5 NPS		2.03 in ²			81-1800 psi		UD
10 NPS		78.8 in ²			45-1300 psi		UD
12 NPS		111.9 in ²			41-1100 psi		UD
14 NPS		137.9 in ²			37-750 psi		UD
16 NPS		176.7 in ²			35-270 psi		UD
18 NPS		223.3 in ²			33-240 psi		UD
2 NPS		3.36 in ²			68-1800 psi		UD
20 NPS		277.9 in ²			32-213 psi		UD
24 NPS		402 in ²			30-177 psi		UD
3 NPS		7.39 in ²			54-1600 psi		UD
4 NPS		12.7 in ²			45-1400 psi		UD
6 NPS		28.9 in ²			36-1400 psi		UD
8 NPS		50 in ²			53-1300 psi		UD

Design Name: GFR-S, -SM, -SE, -SS, -SMS, -SES, -SW (1")		NBCert #	77105
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	04/09/2026
Design Type			
[Rupture Disk Device] GFR-S, -SM, -SE, -SS, -SMS, -SES, -SW (1") HolderDesignation: GRC Capacity Tests: Sec. UD at National Board Testing Lab on December 19, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl Certified Value:19.140 Unitless Media - Test: Air/Gas; Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.2 in²			38-175 psi		UD
Design Name:		GFR-S, -SM, -SE, -SS, -SMS, -SES, -SW (1.5")		NBCert #	77116		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UD		04/09/2026		
Design Type							
[Rupture Disk Device] GFR-S, -SM, -SE, -SS, -SMS, -SES, -SW (1.5") HolderDesignation: GRC Capacity Tests: Sec. UD at National Board Testing Lab on December 18, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 9.920 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		0.79 in²			13.5-200 psi		UD
Design Name:		GFR-S, -SM, -SE, -SS, -SMS, -SES, -SW (2")		NBCert #	77127		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UD		12/19/2025		
Design Type							
[Rupture Disk Device] GFR-S, -SM, -SE, -SS, -SMS, -SES, -SW (2") HolderDesignation: GRC-C, FM-C, FT-C Capacity Tests: Sec. UD at National Board Testing Lab on December 19, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl Certified Value: 4.760 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		1.77 in²			11.5-150 psi		UD
Design Name:		GFR-S, -SM, -SE, -SS, -SMS, -SES, -SW 1 1/2" Liquid		NBCert #	77239		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UD		05/12/2026		
Design Type							
[Rupture Disk Device] GFR-S, -SM, -SE, -SS, -SMS, -SES, -SW 1 1/2" Liquid HolderDesignation: GR-C Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on April 26, 1999 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krl Certified Value:11.500 Unitless Media - Test: Air/Gas; Certified: Incompressible (Krl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		0.79 in²			13.5-200 psi		UD
Design Name: GLR-S, GLR-SM, GLR-SE, GLR-SW 1.5 inchNBCert # 77240							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			11/02/2029	
Design Type							
[Rupture Disk Device] GLR-S, GLR-SM, GLR-SE, GLR-SW 1.5 inch HolderDesignation: GR-C, FM-C, FT-C (Not Required for SM or SW) Capacity Tests: Sec. UD at National Board Testing Lab on September 19, 2023 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl Certified Value:13.410 Unitless; (alternate medium): 0.000 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	1.5 NPS	0.79 in²			175-1500 psi		UD
Design Name: JRSNBCert # 77015							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			03/27/2026	
Design Type							
[Rupture Disk Device] JRS HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRI-7RS Capacity Tests: Sec. UD at National Board Testing Lab on July 10, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.310 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in²			22-180 psi		UD
1.5 NPS		1.89 in²			20-150 psi		UD
10 NPS		68.65 in²			12-36 psi		UD
12 NPS		102.28 in²			12-33 psi		UD
14 NPS		121.86 in²			9-30 psi		UD
16 NPS		156 in²			7-28 psi		UD
18 NPS		198 in²			6-26 psi		UD
2 NPS		3.35 in²			18-120 psi		UD
20 NPS		246 in²			5-24 psi		UD
24 NPS		357 in²			5-22 psi		UD
3 NPS		6.53 in²			16-80 psi		UD
30 NPS		592 in²			5-14 psi		UD

32 NPS		706.9 in ²			5-14 psi	UD
36 NPS		868 in ²			5-14 psi	UD
4 NPS		11.86 in ²			14-70 psi	UD
42 NPS		1111 in ²			5-14 psi	UD
6 NPS		25.08 in ²			12-50 psi	UD
8 NPS		42.07 in ²			12-42 psi	UD
28 NPS	NPS	513 in ²	0 in	0 in	5-18 psi	UD

Design Name:	MRB	NBCert #	77824
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 05/20/2026

Design Type

[Rupture Disk Device] MRB
HolderDesignation: N/A
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on May 5, 2004
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 5.300 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.29 in		0.046 in ²			4300-55000 psi		UD
0.3 in		0.05 in ²			4300-55000 psi		UD
0.375 NPS		0.08 in ²			4300-55000 psi		UD
0.5 NPS		0.14 in ²			3800-54000 psi		UD
0.625 NPS		0.22 in ²			3500-52000 psi		UD
0.75 NPS		0.31 in ²			2900-49000 psi		UD
0.875 in		0.52 in ²			2900-49000 psi		UD
1 NPS		0.55 in ²			2500-43000 psi		UD
1.125 in		0.69 in ²			2500-43000 psi		UD
1.25 NPS		0.86 in ²			2500-43000 psi		UD
1.5 NPS		1.24 in ²			1900-35000 psi		UD
10 NPS		55 in ²			400-12000 psi		UD
2 NPS		2.2 in ²			1800-29000 psi		UD
3 NPS		4.5 in ²			1500-21000 psi		UD
3.25 in		5.2 in ²			1500-21000 psi		UD
4 NPS		8.8 in ²			1500-16000 psi		UD
6 NPS		19.8 in ²			1000-14000 psi		UD
8 NPS		35.2 in ²			600-14000 psi		UD

Design Name: PLD	NBCert # 78173
------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/14/2027

Design Type

[Rupture Disk Device] PLD
HolderDesignation: FA-*, FF-*, UA-2, 3, 4, 5, 6
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 20, 2015
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 4.200 Unitless
Media - Test: Air/Gas; Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.69 in ²			44-2000 psi		UD
1.5 NPS		1.62 in ²			31-1400 psi		UD
10 NPS		74.6 in ²			4-480 psi		UD
12 NPS		106 in ²			3-400 psi		UD
14 NPS		135 in ²			3-350 psi		UD
16 NPS		176 in ²			3-300 psi		UD
18 NPS		223 in ²			3-270 psi		UD
2 NPS		2.95 in ²			15-1100 psi		UD
20 NPS		277 in ²			3-240 psi		UD
24 NPS		397 in ²			3-200 psi		UD
28 NPS		584 in ²			3-180 psi		UD
3 NPS		6.49 in ²			11-900 psi		UD
30 NPS		661 in ²			3-170 psi		UD
36 NPS		907 in ²			3-170 psi		UD
4 NPS		11 in ²			8-830 psi		UD
40 NPS		1120 in ²			3-170 psi		UD
42 NPS		1234 in ²			3-170 psi		UD
44 NPS		1355 in ²			3-170 psi		UD
6 NPS		25.9 in ²			6-640 psi		UD
8 NPS		47.1 in ²			5-590 psi		UD

Design Name: RB-90	NBCert # 77138
--------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	05/02/2028

Design Type

[Rupture Disk Device] RB-90
 HolderDesignation: RB-7R, RB-7F, RB-7FF, RB-7FS
 Capacity Tests: Sec. UD at National Board Testing Lab on February 19, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 3.470 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.831 in ²			30-1800 psi		UD
1.5 NPS		1.805 in ²			25-1700 psi		UD
10 NPS		67.62 in ²			15-800 psi		UD
12 NPS		101.8 in ²			15-800 psi		UD
14 NPS		121.7 in ²			15-800 psi		UD
16 NPS		162.8 in ²			15-800 psi		UD
18 NPS		209.99 in ²			13-700 psi		UD
2 NPS		3.153 in ²			22-1600 psi		UD
20 NPS		262.9 in ²			13-700 psi		UD
24 NPS		386.9 in ²			10-700 psi		UD
26 NPS		465 in ²			10-700 psi		UD
28 NPS		530.7 in ²			10-700 psi		UD
3 NPS		6.849 in ²			21-1500 psi		UD
30 NPS		617.7 in ²			10-700 psi		UD
32 NPS		698.4 in ²			10-700 psi		UD
34 NPS		790.1 in ²			10-700 psi		UD
36 NPS		872.8 in ²			10-700 psi		UD
4 NPS		11.84 in ²			20-1500 psi		UD
6 NPS		25.45 in ²			20-850 psi		UD
8 NPS		47.68 in ²			15-800 psi		UD

Design Name: RLS DD

NBCert # 77699

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	06/20/2030

Design Type

[Rupture Disk Device] RLS DD
 HolderDesignation: SRB-7RS DD, SRB-7RS-TR DD, SRB-7FS DD, SRB-7FS-TR DD, S90-7R-TR DD
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 16, 2002
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 1.900 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.842 in ²			125-2000 psi		UD

1.5 NPS	1.77 in ²	85-1800 psi	UD
10 NPS	73.94 in ²	35-250 psi	UD
12 NPS	99.06 in ²	35-150 psi	UD
14 NPS	131.5 in ²	35-130 psi	UD
16 NPS	172.1 in ²	25-110 psi	UD
18 NPS	219.5 in ²	25-90 psi	UD
2 NPS	3.23 in ²	70-1800 psi	UD
20 NPS	270 in ²	20-90 psi	UD
3 NPS	6.44 in ²	70-1600 psi	UD
4 NPS	11.54 in ²	45-1050 psi	UD
6 NPS	26.44 in ²	35-650 psi	UD
8 NPS	47.07 in ²	35-400 psi	UD

Design Name:	RLS DD (liquid)	NBCert #	77688
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	06/21/2030
--------------	----	------------

Design Type

[Rupture Disk Device] RLS DD (liquid)
HolderDesignation: SRB-7RS DD, SRB-7RS-TR DD, SRB-7FS DD, SRB-7FS-TR DD, S90-7R-TR DD
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 24, 2002
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 5.830 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.842 in ²			125-3900 psi		UD
1.5 NPS		1.77 in ²			85-1800 psi		UD
10 NPS		73.94 in ²			35-250 psi		UD
12 NPS		99.06 in ²			35-150 psi		UD
14 NPS		131.5 in ²			35-130 psi		UD
16 NPS		172.1 in ²			25-110 psi		UD
18 NPS		219.5 in ²			25-90 psi		UD
2 NPS		3.23 in ²			70-1800 psi		UD
20 NPS		270 in ²			20-90 psi		UD
3 NPS		6.44 in ²			55-1600 psi		UD
4 NPS		11.54 in ²			45-1050 psi		UD
6 NPS		26.44 in ²			35-650 psi		UD
8 NPS		47.07 in ²			35-900 psi		UD

Design Name:	RLS, RLS Welded Assembly (liquid)	NBCert #	77307
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	08/06/2026

Design Type

[Rupture Disk Device] RLS, RLS Welded Assembly (liquid)
HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, S90-7R, S90-7R-TR, SMR-7R, SRI-7RS, SRB-7RS Special, SRB-QRS
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 16, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 5.830 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.5 in ²			300-6000 psi		UD
1 NPS		0.84 in ²			125-6000 psi		UD
1.5 NPS		1.77 in ²			85-5400 psi		UD
10 NPS		73.9 in ²			35-1200 psi		UD
12 NPS		99 in ²			35-900 psi		UD
14 NPS		131 in ²			35-650 psi		UD
16 NPS		172 in ²			25-550 psi		UD
18 NPS		219 in ²			25-450 psi		UD
2 NPS		3.23 in ²			70-4800 psi		UD
20 NPS		270 in ²			20-350 psi		UD
3 NPS		6.44 in ²			55-3800 psi		UD
4 NPS		11.54 in ²			45-2800 psi		UD
6 NPS		26.4 in ²			35-2000 psi		UD
8 NPS		47 in ²			35-1600 psi		UD

Design Name:	RLS, RLS Welded Assembly	NBCert #	77059
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/16/2025

Design Type

[Rupture Disk Device] RLS, RLS Welded Assembly
HolderDesignation: SRB-7RS, SRB-7RS-TR, S90-7R, S90-7R-TR, SRB-7FS, SRB-7FR-TR, SMR-7R, SRI-7RS, SRB-7RS Special, SRB-QRS
Capacity Tests: Sec. UD at National Board Testing Lab on August 12, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 1.140 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.5 in ²			300-2000 psi		UD
1 NPS		0.84 in ²			125-2200 psi		UD

1.5 NPS	1.77 in ²	85-1800 psi	UD
10 NPS	73.9 in ²	35-250 psi	UD
12 NPS	99 in ²	35-150 psi	UD
14 NPS	131 in ²	35-130 psi	UD
16 NPS	172 in ²	25-110 psi	UD
18 NPS	219 in ²	25-90 psi	UD
2 NPS	3.23 in ²	70-1800 psi	UD
20 NPS	270 in ²	20-90 psi	UD
3 NPS	6.44 in ²	55-1600 psi	UD
4 NPS	11.54 in ²	45-1500 psi	UD
6 NPS	26.4 in ²	35-650 psi	UD
8 NPS	47 in ²	35-400 psi	UD

Design Name:	S-90 (Inconel)	NBCert #	77206
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	05/12/2026
--------------	----	------------

Design Type

[Rupture Disk Device] S-90 (Inconel)
HolderDesignation: S90-7R, S90-7R-TR, SRB-7RS, SRB-7RS-TR, SMR-7R, SRB-7FS, SRB-7FS-TR, SRI-7RS, SRB-QRS
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on April 24, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.230 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			170-1000 psi		UD
1.5 NPS		2.03 in ²			128-1000 psi		UD
10 NPS		78.8 in ²			36-700 psi		UD
12 NPS		111 in ²			33-600 psi		UD
14 NPS		135 in ²			30-500 psi		UD
16 NPS		176 in ²			28-200 psi		UD
18 NPS		223 in ²			26-160 psi		UD
2 NPS		3.36 in ²			96-1000 psi		UD
20 NPS		277 in ²			24-142 psi		UD
24 NPS		402 in ²			22-118 psi		UD
3 NPS		7.39 in ²			72-1000 psi		UD
30 NPS		672 in ²			20-80 psi		UD
4 NPS		12.7 in ²			60-800 psi		UD
6 NPS		28.9 in ²			48-800 psi		UD
8 NPS		50 in ²			42-700 psi		UD
40 NPS	NPS	1195 in ²		0 in	30-250 psi		UD

Design Name:	S90 DD	NBCert #	77712
--------------	--------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	06/21/2030

Design Type
[Rupture Disk Device] S90 DD HolderDesignation: S90-7R DD, S90-7R-TR DD, SRB-7RS DD, SRB-7RS-TR DD,SRB-7FS DD, SRB-7FS-TR DD Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 14, 2002 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 1.130 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			75-1000 psi		UD
1.5 NPS		2.03 in ²			54-1000 psi		UD
10 NPS		79.8 in ²			30-700 psi		UD
12 NPS		111 in ²			27-600 psi		UD
14 NPS		135 in ²			25-500 psi		UD
16 NPS		176 in ²			23-200 psi		UD
18 NPS		223 in ²			22-160 psi		UD
2 NPS		3.35 in ²			45-1000 psi		UD
20 NPS		277 in ²			20-142 psi		UD
24 NPS		402 in ²			20-118 psi		UD
3 NPS		7.39 in ²			36-1000 psi		UD
30 NPS		672 in ²			20-80 psi		UD
4 NPS		12.7 in ²			30-800 psi		UD
6 NPS		28.8 in ²			24-800 psi		UD
8 NPS		50 in ²			35-700 psi		UD

Design Name:	S90, S90 Welded Assembly	NBCert #	77082
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	12/18/2026

Design Type
[Rupture Disk Device] S90, S90 Welded Assembly HolderDesignation: SRB-7RS, SRB-7RS-TR, S90-7R, S90-7R-TR, SMR-7R, SRB-7FS, SRB-7FS-TR, SRI-7RS, SRB-QRS Capacity Tests: Sec. UD at National Board Testing Lab on July 27, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 1.130 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			75-1000 psi		UD

1.5 NPS	2.03 in²	54-1000 psi	UD		
10 NPS	78.8 in²	30-700 psi	UD		
12 NPS	111 in²	27-600 psi	UD		
14 NPS	135 in²	25-500 psi	UD		
16 NPS	176 in²	23-475 psi	UD		
18 NPS	223 in²	22-475 psi	UD		
2 NPS	3.36 in²	45-1000 psi	UD		
20 NPS	277 in²	20-250 psi	UD		
24 NPS	402 in²	18-250 psi	UD		
28 NPS	583 in²	20-250 psi	UD		
3 NPS	7.39 in²	36-1000 psi	UD		
30 NPS	672 in²	20-250 psi	UD		
4 NPS	12.7 in²	30-800 psi	UD		
40 NPS	NPS	1195 in²	20-250 psi	Air	UD
6 NPS	28.8 in²	24-800 psi	UD		
8 NPS	50 in²	35-700 psi	UD		

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	12/15/2027

[Rupture Disk Device] Scored B -LTF, Scd B-LTF, XB-LTF
HolderDesignation: Lo-To-Flo
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 18, 2014
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 4.770 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.8 in²			250-6000 psi		UD
1.5 NPS		1.76 in²			200-4000 psi		UD
10 NPS		78.9 in²			100-1500 psi		UD
12 NPS		112.5 in²			90-1250 psi		UD
14 NPS		137.9 in²			80-1000 psi		UD
16 NPS		182.7 in²			75-800 psi		UD
18 NPS		233.7 in²			70-600 psi		UD
2 NPS		3.33 in²			175-3500 psi		UD
20 NPS		291 in²			65-500 psi		UD
24 NPS		424.6 in²			60-250 psi		UD
3 NPS		6.51 in²			150-3000 psi		UD
4 NPS		11.82 in²			135-2500 psi		UD
6 NPS		28.8 in²			125-2000 psi		UD

8 NPS	49.9 in²	110-1750 psi	UD
-------	----------	--------------	----

Design Name:	Scored B, SCD B, XB	NBCert #	84046
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	03/22/2031
--------------	----	------------

Design Type

[Rupture Disk Device] Scored B, SCD B, XB
HolderDesignation: NF-7R, NF-7RS, NF-7FS, FF-*, FA-
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on February 13, 2013
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.400 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.5 NPS	1.5 NPS	2.04 in²			200-6000 psi	Air	UD
10-10 NPS	10 NPS	78.9 in²			100-3200 psi	Air	UD
1-1 NPS	1 NPS	0.86 in²			250-6000 psi	Air	UD
12-12 NPS	12 NPS	113.1 in²			90-1250 psi	Air	UD
14-14 NPS	14 NPS	137.9 in²			80-1000 psi	Air	UD
16-16 NPS	16 NPS	182.6 in²			75-800 psi	Air	UD
18-18 NPS	18 NPS	233.7 in²			70-600 psi	Air	UD
20-20 NPS	20 NPS	291.1 in²			65-500 psi	Air	UD
2-2 NPS	2 NPS	3.35 in²			175-6000 psi	Air	UD
24-24 NPS	24 NPS	424.6 in²			60-250 psi	Air	UD
3-3 NPS	3 NPS	7.4 in²			150-6000 psi	Air	UD
4-4 NPS	4 NPS	12.73 in²			135-6000 psi	Air	UD
6-6 NPS	6 NPS	28.99 in²			125-6000 psi	Air	UD
8-8 NPS	8 NPS	50 in²			110-4000 psi	Air	UD

Design Name:	SKA	NBCert #	77846
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	11/17/2026
--------------	----	------------

Design Type

[Rupture Disk Device] SKA
HolderDesignation: Integral one piece design
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 13, 2004
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS		0.046 in²	0.25 in		50-750 psi	Air	UD

0.375 NPS	0.085 in ²	0.375 in	50-750 psi	UD
0.5 NPS	0.182 in ²	0.5 in	35-700 psi	UD

Design Name:	SVI Assembly	NBCert #	77723
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 06/20/2030

Design Type

[Rupture Disk Device] SVI Assembly
HolderDesignation: SVI Assembly
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 10, 2002
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 11.350 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		1.37 in ²			125-1000 psi		UD
10 NPS		61 in ²			35-700 psi		UD
2 NPS		2.26 in ²			90-1000 psi		UD
3 NPS		5.11 in ²			75-1000 psi		UD
4 NPS		8.66 in ²			60-800 psi		UD
6 NPS		20.92 in ²			50-700 psi		UD
8 NPS		37 in ²			40-700 psi		UD

Design Name:	W-6 XB	NBCert #	78487
--------------	--------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 12/10/2025

Design Type

[Rupture Disk Device] W-6 XB
HolderDesignation: Integral
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on December 5, 2019
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 2.140 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	0.5 NPS	0.19 in ²			750-5000 psi		UD

Design Name:	Welded 1" FRB, w. 1/2" VCR connections	NBCert #	77778
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/02/2030

Design Type

[Rupture Disk Device] Welded 1" FRB, w. 1/2" VCR connections
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on September 4, 2002
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 16.950 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.5 NPS	0.126 in ²			15-150 psi		UD

Design Name: Welded FRB w/ 3/4" VCR Connections NBCert # 77936

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	11/08/2029

Design Type

[Rupture Disk Device] Welded FRB w/ 3/4" VCR Connections
HolderDesignation: N/A
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on March 16, 2011
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 5.000 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.2 in ²			15-150 psi		UD

Design Name: Welded FRB-Free Outlet NBCert # 78443

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	06/07/2031

Design Type

[Rupture Disk Device] Welded FRB-Free Outlet
HolderDesignation: Integral
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on February 1, 2019
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.820 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125 NPS		0.036 in ²			200-900 psi	Air	UD
0.25 NPS		0.046 in ²			100-850 psi	Air	UD
0.375 NPS		0.096 in ²			50-800 psi	Air	UD
0.5 NPS		0.196 in ²			35-700 psi	Air	UD
0.75 NPS		0.442 in ²			25-405 psi	Air	UD

Design Name:	Welded FRB-Muffled Outlet	NBCert #	78454
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	06/07/2031

Design Type

[Rupture Disk Device] Welded FRB-Muffled Outlet
HolderDesignation: Integral
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on February 1, 2019
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.740 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125 NPS		0.036 in ²			200-900 psi	Air	UD
0.25 NPS		0.046 in ²			100-850 psi	Air	UD
0.375 NPS		0.096 in ²			50-800 psi	Air	UD
0.5 NPS		0.196 in ²			35-700 psi	Air	UD
0.75 NPS		0.442 in ²			25-405 psi	Air	UD

Design Name:	Welded QRB	NBCert #	78375
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/05/2029

Design Type

[Rupture Disk Device] Welded QRB
HolderDesignation: Integral
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 17, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.850 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS		0.049 in ²			800-16000 psi		UD
0.375 NPS		0.11 in ²			800-14000 psi		UD
0.5 NPS		0.19 in ²			500-10500 psi		UD
0.75 NPS		0.44 in ²			350-3000 psi		UD
0.125 NPS		0.024 in ²			800-16000 psi	Air	UD3

Design Name:	X 90 Welded	NBCert #	77868
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	06/30/2027

Design Type

[Rupture Disk Device] X 90 Welded
HolderDesignation: Integral
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 9, 2005
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 6.000 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.34 in ²			500-4000 psi		UD

BS & B Safety Systems, Ltd. (BSI)

Limerick, V94 N4V2Ireland

This Company Manufactures or Assembles:

Design Name: 1.5" SLP-S, SLP-SE, SLP-SM, SLP-N, SLP-SS, SLP-SES, SLP-SMS, SLP-NS NBCert # 78128

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/21/2027

Design Type

[Rupture Disk Device] 1.5" SLP-S, SLP-SE, SLP-SM, SLP-N, SLP-SS, SLP-SES, SLP-SMS, SLP-NS
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on September 12, 2014
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl
Certified Value: 6.700 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		1.08 in ²			15-70 psi		UD

Design Name: 2" BV NBCert # 77486

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	08/09/2028

Design Type

[Rupture Disk Device] 2" BV
HolderDesignation: FA-7R, FA-1F - 9F, UA-2,3,5,6
Capacity Tests: Sec. UD at National Board Testing Lab on August 11, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 0.550 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		2.24 in ²			16-6000 psi		UD

Design Name:	2" SLP-S, SLP-SE, SLP-SM, SLP-N, SLP-SS, SLP-SES, SLP-SMS, SLP-NS	NBCert #	78139
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	01/22/2027
Design Type			
[Rupture Disk Device] 2" SLP-S, SLP-SE, SLP-SM, SLP-N, SLP-SS, SLP-SES, SLP-SMS, SLP-NS Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on September 12, 2014 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl Certified Value: 4.900 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		2.04 in ²			6-55 psi		UD

Design Name:	3" SLP-S, SLP-SE, SLP-SM, SLP-N, SLP-SS, SLP-SES, SLP-SMS, SLP-NS	NBCert #	78140
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	01/22/2027
Design Type			
[Rupture Disk Device] 3" SLP-S, SLP-SE, SLP-SM, SLP-N, SLP-SS, SLP-SES, SLP-SMS, SLP-NS Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on September 12, 2014 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl Certified Value: 9.900 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS		3.55 in ²			5-40 psi		UD

Design Name:	B, BR, BRR (liquid)	NBCert #	77318
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	09/21/2028
Design Type			
[Rupture Disk Device] B, BR, BRR (liquid) HolderDesignation: FA-7R, FA-1 - FA9, UA-2,3,5,6 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 12, 1999 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl Certified Value: 1.470 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.189 in ²			80-30000 psi		UD
1 NPS		0.801 in ²			40-12000 psi		UD
1.5 NPS		1.76 in ²			26-6000 psi		UD

10 NPS	78.85 in ²	4-1400 psi	UD
12 NPS	112.5 in ²	4-1000 psi	UD
14 NPS	137.9 in ²	3-750 psi	UD
16 NPS	182.7 in ²	3-500 psi	UD
18 NPS	233.7 in ²	3-475 psi	UD
2 NPS	3.33 in ²	16-6000 psi	UD
20 NPS	291 in ²	2-450 psi	UD
24 NPS	424.6 in ²	2-230 psi	UD
3 NPS	6.514 in ²	12-6000 psi	UD
30 NPS	672 in ²	2-184 psi	UD
32 NPS	767 in ²	2-181 psi	UD
36 NPS	976 in ²	6-160 psi	UD
4 NPS	11.82 in ²	9-6000 psi	UD
40 NPS	1210 in ²	6-145 psi	UD
42 NPS	1336 in ²	3-138 psi	UD
44 NPS	1469 in ²	6-132 psi	UD
6 NPS	28.84 in ²	7-3600 psi	UD
8 NPS	49.89 in ²	5-3600 psi	UD

Design Name: B, BR, BRR, Welded B NBCert # 77037

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/11/2029

Design Type

[Rupture Disk Device] B, BR, BRR, Welded B
HolderDesignation: FA-7R, FA1,2,3,4,5,6,7,8,9,UA-2,3,5,6
Capacity Tests: Sec. UD at National Board Testing Lab on September 15, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.710 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.189 in ²			80-30000 psi		UD
0.725 in		0.34 in ²			900-20000 psi		UD
1 NPS		0.801 in ²			40-12000 psi		UD
1.5 NPS		1.76 in ²			26-6000 psi	Air	UD
10 NPS		78.85 in ²			4-1400 psi		UD
12 NPS		112.5 in ²			4-1000 psi		UD
14 NPS		137.9 in ²			3-750 psi		UD
16 NPS		182.7 in ²			3-500 psi		UD
18 NPS		233.7 in ²			3-475 psi		UD
2 NPS		3.33 in ²			16-6000 psi		UD
20 NPS		291 in ²			2-450 psi		UD

24 NPS	424.6 in ²	2-230 psi	UD
3 NPS	6.514 in ²	12-6000 psi	UD
30 NPS	672 in ²	2-184 psi	UD
32 NPS	767 in ²	2-181 psi	UD
36 NPS	976 in ²	6-160 psi	UD
4 NPS	11.82 in ²	9-6000 psi	UD
40 NPS	1210 in ²	6-145 psi	UD
42 NPS	1336 in ²	6-138 psi	UD
44 NPS	1469 in ²	6-132 psi	UD
6 NPS	28.84 in ²	7-3600 psi	UD
8 NPS	49.9 in ²	5-3600 psi	UD

Design Name: BV,BRV,BSV,BRSV (liquid) NBCert # 77273

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/05/2028

Design Type

[Rupture Disk Device] BV,BRV,BSV,BRSV (liquid)
 HolderDesignation: FA-7R, FA-1 - FA-9,UA-,3,5,6
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 1, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 2.450 Unitless
 Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.57 in ²			145-12000 psi		UD
1.5 NPS		1.44 in ²			95-6000 psi		UD
10 NPS		70.88 in ²			14-1400 psi		UD
12 NPS		101.5 in ²			12-1000 psi		UD
14 NPS		130.3 in ²			11-750 psi		UD
16 NPS		176.7 in ²			9-500 psi		UD
18 NPS		202.4 in ²			8-475 psi		UD
2 NPS		2.24 in ²			55-6000 psi		UD
20 NPS		280 in ²			8-450 psi		UD
24 NPS		380.1 in ²			37-230 psi		UD
3 NPS		5.41 in ²			41-6000 psi		UD
30 NPS		615.8 in ²			20-184 psi		UD
32 NPS		728 in ²			31-181 psi		UD
36 NPS		927 in ²			28-160 psi		UD
4 NPS		9.62 in ²			31-6000 psi		UD
40 NPS		1149 in ²			25-145 psi		UD
42 NPS		1269 in ²			24-138 psi		UD
44 NPS		1395 in ²			23-132 psi		UD

6 NPS	23.76 in²	23-3600 psi	UD
8 NPS	44.18 in²	18-3600 psi	UD

Design Name:	CSI	NBCert #	77565
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	08/29/2025
--------------	----	------------

Design Type

[Rupture Disk Device] CSI
 HolderDesignation: CSR-7RS, CSR-7FS, CSI-7RS
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 30, 2000
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.620 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.5 NPS	1.5 NPS	1.89 in²			50-800 psi		UD
1-1 NPS	1 NPS	0.86 in²			70-800 psi		UD
2-2 NPS	2 NPS	3.36 in²			50-800 psi	Air	UD
3-3 NPS	3 NPS	7.29 in²			45-800 psi		UD
4-4 NPS	4 NPS	11.2 in²			45-800 psi		UD
6-6 NPS	6 NPS	22.65 in²			30-800 psi		UD
8-8 NPS	8 NPS	42.72 in²			30-800 psi		UD
0.75-0.75 NPS	0.75 NPS	0.5 in²	0 in	0 in	70-800 psi	Air	UD
10-10 NPS	10 NPS	66.3 in²	0 in	0 in	18-800 psi		UV

Design Name:	CSI (liquid)	NBCert #	78162
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	08/17/2028
--------------	----	------------

Design Type

[Rupture Disk Device] CSI (liquid)
 HolderDesignation: CSR-7RS, CSR-7FS
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 23, 2015
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 3.090 Unitless
 Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.5 NPS	1.5 NPS	1.89 in²			50-800 psi		UD
1-1 NPS	1 NPS	0.86 in²			70-800 psi		UD
2-2 NPS	2 NPS	3.36 in²			50-800 psi		UD
3-3 NPS	3 NPS	7.29 in²			45-800 psi		UD
4-4 NPS	4 NPS	11.2 in²			45-800 psi		UD

6-6 NPS	6 NPS	22.65 in ²			30-800 psi		UD
8-8 NPS	8 NPS	42.72 in ²			30-800 psi		UD
0.75-0.75 NPS	0.75 NPS	0.5 in ²	0 in	0 in	70-800 psi	Water	UD
10-10 NPS	10 NPS	66.3 in ²	0 in	0 in	18-800 psi		UV

Design Name: DV, DRV, DSV, DRSV (liquids) NBCert # 77734

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/11/2029

Design Type

[Rupture Disk Device] DV, DRV, DSV, DRSV (liquids)
HolderDesignation: FA-7R,FA-1F - FA-9F, UA-2,3,5,6, FF-*
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 11, 2002
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 2.600 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.57 in ²			44-2000 psi		UD
1.5 NPS		1.44 in ²			31-1400 psi		UD
10 NPS		70.88 in ²			4-480 psi		UD
12 NPS		101.5 in ²			3-1000 psi		UD
14 NPS		130.3 in ²			3-350 psi		UD
16 NPS		176.7 in ²			3-300 psi		UD
18 NPS		202.3 in ²			3-270 psi		UD
2 NPS		2.24 in ²			15-1100 psi		UD
20 NPS		280 in ²			3-240 psi		UD
24 NPS		380.1 in ²			3-200 psi		UD
28 NPS		584 in ²			3-170 psi	Air	UD
3 NPS		5.41 in ²			11-900 psi		UD
30 NPS		615.7 in ²			3-170 psi		UD
32 NPS		728 in ²			3-170 psi		UD
36 NPS		927 in ²			3-170 psi		UD
4 NPS		9.62 in ²			8-830 psi		UD
40 NPS		1149 in ²			3-170 psi		UD
42 NPS		1269 in ²			3-170 psi		UD
44 NPS		1395 in ²			3-170 psi		UD
6 NPS		23.76 in ²			6-640 psi		UD
8 NPS		44.18 in ²			5-590 psi		UD

Design Name: GCR-S, SE, SM, SS, SES, SMS, SME, SMES, SW, N, NS		NBCert #	77611
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	03/16/2026
Design Type			
[Rupture Disk Device] GCR-S, SE, SM, SS, SES, SMS, SME, SMES, SW, N, NS HolderDesignation: GR-C, FM-C, not req'd for -SM Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on November 22, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 1.950 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		1.5 in ²			10-300 psi	Air	UD
3 NPS		5.29 in ²			10-175 psi		UD
4 NPS		9.78 in ²			10-150 psi		UD
6 NPS		22.5 in ²			10-75 psi		UD
48.3 DN	DN	2.38 in ²	0 in	0 in	10-300 psi		UD
60.3 DN	DN	3.85 in ²	0 in	0 in	10-175 psi		UD
76.1 DN	DN	6.33 in ²	0 in	0 in	10-175 psi		UD

Design Name: GCR-S, SE, SM, SS, SES, SMS, SME, SMES, SW, N, NS (liquids)		NBCert #	78195
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	01/12/2029
Design Type			
[Rupture Disk Device] GCR-S, SE, SM, SS, SES, SMS, SME, SMES, SW, N, NS (liquids) HolderDesignation: GR-C, FM-C (not req'd for SM) Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 5, 2015 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl Certified Value: 2.750 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		1.5 in ²			10-300 psi		UD
3 NPS		5.29 in ²			10-175 psi		UD
4 NPS		9.78 in ²			10-150 psi		UD
6 NPS		22.5 in ²			10-75 psi		UD
48.3 DN	DN	2.38 in ²	0 in	0 in	10-300 psi		UD
60.3 DN	DN	3.85 in ²	0 in	0 in	10-300 psi		UD
76.1 DN	DN	6.33 in ²	0 in	0 in	10-300 psi		UD

Design Name: GCR-S,SE,SM,SS,SES,SMS, SME, SMES, SW, N, NS (2" liquids)		NBCert # 78207
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/11/2029
Design Type		
[Rupture Disk Device] GCR-S,SE,SM,SS,SES,SMS, SME, SMES, SW, N, NS (2" liquids) HolderDesignation: GR-C, FM-C, not req'd for -SM Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 25, 2015 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krl Certified Value: 1.420 Unitless Media - Test: Water/Liquid (Krl test on Air/Gas); Certified: Incompressible (Krl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		2.7 in ²			10-300 psi	Water	UD

Design Name: GCR-S,SE,SM,SS,SES,SMS, SME, SMES, SW, N, NS (2")		NBCert # 77420
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	03/12/2026
Design Type		
[Rupture Disk Device] GCR-S,SE,SM,SS,SES,SMS, SME, SMES, SW, N, NS (2") HolderDesignation: GR-C, FM-C , not req'd for -SM Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on January 10, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 1.250 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		2.7 in ²			10-300 psi	Air	UD

Design Name: GFN, GFA, XN, XN-85		NBCert # 77060
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	04/30/2026
Design Type		
[Rupture Disk Device] GFN, GFA, XN, XN-85 HolderDesignation: NF-7RS, NF-7R, NFI-7RS Capacity Tests: Sec. UD at National Board Testing Lab on December 18, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.550 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			113-1800 psi		UD
1.5 NPS		2.03 in ²			81-1800 psi		UD

10 NPS	78.8 in ²	45-1300 psi	UD
12 NPS	111.9 in ²	41-1100 psi	UD
14 NPS	137.9 in ²	37-750 psi	UD
16 NPS	176.7 in ²	35-270 psi	UD
18 NPS	223.3 in ²	33-240 psi	UD
2 NPS	3.36 in ²	68-1800 psi	UD
20 NPS	277.9 in ²	32-213 psi	UD
24 NPS	402 in ²	30-177 psi	UD
3 NPS	7.39 in ²	54-1600 psi	UD
4 NPS	12.7 in ²	45-1400 psi	UD
6 NPS	28.9 in ²	36-1400 psi	UD
8 NPS	50 in ²	53-1300 psi	UD

Design Name:	GLP-S	NBCert #	77790
--------------	-------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 03/06/2031

Design Type

[Rupture Disk Device] GLP-S
HolderDesignation: LP-C
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 30, 2003
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value:10.000 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		0.86 in ²			15-70 psi		UD
2 NPS		1.93 in ²			6-55 psi		UD
3 NPS		3.36 in ²			5-40 psi		UD
4 NPS		7.39 in ²			5-35 psi		UD

Design Name:	JRS	NBCert #	77015
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 05/26/2027

Design Type

[Rupture Disk Device] JRS
HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRI-7RS
Capacity Tests: Sec. UD at National Board Testing Lab on July 10, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.310 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			22-180 psi		UD
1.5 NPS		1.89 in ²			20-150 psi		UD
10 NPS		68.65 in ²			12-36 psi		UD
12 NPS		102.28 in ²			12-33 psi		UD
14 NPS		121.86 in ²			9-30 psi		UD
16 NPS		156 in ²			7-28 psi		UD
18 NPS		198 in ²			6-26 psi		UD
2 NPS		3.35 in ²			18-120 psi		UD
20 NPS		246 in ²			5-24 psi		UD
24 NPS		357 in ²			5-22 psi		UD
3 NPS		6.53 in ²			16-80 psi		UD
30 NPS		592 in ²			5-14 psi		UD
32 NPS		706.9 in ²			5-14 psi		UD
36 NPS		868 in ²			5-14 psi		UD
4 NPS		11.86 in ²			14-70 psi		UD
42 NPS		1111 in ²			5-14 psi		UD
6 NPS		25.08 in ²			12-50 psi		UD
8 NPS		42.07 in ²			12-42 psi		UD
28 NPS	NPS	513 in ²	0 in	0 in	5-18 psi		UD

Design Name: LPS Welded Assembly - 1" Conflat NBCert # 78511

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	08/17/2028

Design Type

[Rupture Disk Device] LPS Welded Assembly - 1" Conflat
HolderDesignation: Integral
Capacity Tests: Sec. UD at National Board Testing Lab on March 2, 2022
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.600 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.302 in ²			15-70 psi		UD

Design Name: LPS, LPS Welded Assembly NBCert # 77745

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/02/2030

Design Type

[Rupture Disk Device] LPS, LPS Welded Assembly
 HolderDesignation: SRB-7RS, SRB-7FS, SR-7R, SMR-7R, SRI-7RS, SRB-QRS, SRB-7RS-TR, SRB-7FS-TR & S90-7R-TR
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 20, 2002
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.790 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.59 in ²			15-70 psi		UD
1 NPS		0.86 in ²			15-70 psi		UD
1.5 NPS		1.93 in ²			6-55 psi		UD
10 NPS		78.86 in ²			5-25 psi		UD
12 NPS		111.87 in ²			5-25 psi	Air	UD
2 NPS		3.36 in ²			5-40 psi		UD
3 NPS		7.39 in ²			5-80 psi		UD
4 NPS		12.74 in ²			5-30 psi		UD
6 NPS		28.89 in ²			5-25 psi		UD
8 NPS		50 in ²			5-25 psi		UD

Design Name: LPS, LPS Welded Assembly (liquid) NBCert # 77756

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

10/01/2030

Design Type

[Rupture Disk Device] LPS, LPS Welded Assembly (liquid)
 HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SR-7R, SMR-7R, SRI-7RS, S90-7R-TR, SRB-QRS
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 20, 2002
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 0.860 Unitless
 Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	0.75 NPS	0.59 in ²			15-70 psi	Water	UD
1 NPS		0.86 in ²			15-70 psi		UD
1.5 NPS		1.93 in ²			6-55 psi		UD
10 NPS		78.86 in ²			5-25 psi		UD
12 NPS		111.87 in ²			5-25 psi	Water	UD
2 NPS		3.36 in ²			5-40 psi		UD
3 NPS		7.39 in ²			5-50 psi		UD
4 NPS		12.74 in ²			5-30 psi		UD
6 NPS		28.89 in ²			5-25 psi		UD
8 NPS		50 in ²			5-25 psi		UD

Design Name: LPS-U 0.5"		NBCert #	78308
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	01/24/2030
Design Type			
[Rupture Disk Device] LPS-U 0.5" HolderDesignation: UR-2, UR-6, LPS-U Welded Assembly Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on February 27, 2017 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 1.060 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 in	0.500 in	0.304 in ²			15-70 psi	Air	UD

Design Name: LPS-U 0.5" (Liquid)		NBCert #	78319
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	01/24/2030
Design Type			
[Rupture Disk Device] LPS-U 0.5" (Liquid) HolderDesignation: UR-2, UR-6, LPS-U Welded Assembly Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on February 27, 2017 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krl Certified Value: 1.220 Unitless Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 in	0.500 in	0.304 in ²			15-70 psi	Water	UD

Design Name: LPS-U 0.75"		NBCert #	78320
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	01/24/2030
Design Type			
[Rupture Disk Device] LPS-U 0.75" HolderDesignation: UR-2, UR-6, LPS-U Welded assembly Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on February 27, 2017 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 0.890 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 in	0.75 in	0.533 in ²			15-70 psi	Air	UD

Design Name: LPS-U 0.75" (Liquid)		NBCert #	78331
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	01/24/2030
Design Type			
[Rupture Disk Device] LPS-U 0.75" (Liquid) HolderDesignation: UR-2, UR-6, LPS-U Welded Assembly Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on February 27, 2017 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krl Certified Value: 0.930 Unitless Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 in	0.750 in	0.533 in ²			15-70 psi	Water	UD

Design Name: LPS-U 1.0"		NBCert #	78342
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	12/14/2029
Design Type			
[Rupture Disk Device] LPS-U 1.0" HolderDesignation: UR-2, UR-6, LPS-U Welded Assembly Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on February 27, 2017 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl Certified Value: 1.700 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 in	1.0 in	0.608 in ²			15-70 psi	Air	UD

Design Name: LSR & LSR Welded Assembly		NBCert #	77150
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	05/17/2029
Design Type			
[Rupture Disk Device] LSR & LSR Welded Assembly HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, S90-7R, S90-7R-TR, SR-7R, SPR-7R, SMR-7R, SR-7R, SPR-7R, SRI-7RS, SRB-QRS Capacity Tests: Sec. UD at National Board Testing Lab on February 7, 2023 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 0.590 Unitless; (alternate medium): 0.000 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			9-300 psi		UD

1.5 NPS	2.03 in ²	4-300 psi	UD
2 NPS	3.36 in ²	3-300 psi	UD
3 NPS	7.39 in ²	2.5-300 psi	UD
4 NPS	12.74 in ²	2-250 psi	UD
6 NPS	28.89 in ²	2-200 psi	UD

Design Name:	MVB Cassette	NBCert #	77655
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/27/2029

Design Type

[Rupture Disk Device] MVB Cassette
HolderDesignation: N/A
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 11, 2001
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 0.232 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS		7.39 in ²			80-400 psi	Air	UD

Design Name:	RB-90	NBCert #	77138
--------------	-------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/11/2029

Design Type

[Rupture Disk Device] RB-90
HolderDesignation: RB-7R, RB-7F, RB-7FF, RB-7FS
Capacity Tests: Sec. UD at National Board Testing Lab on February 19, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 3.470 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.831 in ²			30-1800 psi		UD
1.5 NPS		1.805 in ²			25-1700 psi		UD
10 NPS		67.62 in ²			15-800 psi		UD
12 NPS		101.8 in ²			15-800 psi		UD
14 NPS		121.7 in ²			15-800 psi		UD
16 NPS		162.8 in ²			15-800 psi		UD
18 NPS		209.99 in ²			13-700 psi		UD
2 NPS		3.153 in ²			22-1600 psi		UD
20 NPS		262.9 in ²			13-700 psi		UD
24 NPS		386.9 in ²			10-700 psi		UD

26 NPS	465 in ²	10-700 psi	UD
28 NPS	530.7 in ²	10-700 psi	UD
3 NPS	6.849 in ²	21-1500 psi	UD
30 NPS	617.7 in ²	10-700 psi	UD
32 NPS	698.4 in ²	10-700 psi	UD
34 NPS	790.1 in ²	10-700 psi	UD
36 NPS	872.8 in ²	10-700 psi	UD
4 NPS	11.84 in ²	20-1500 psi	UD
6 NPS	25.45 in ²	20-850 psi	UD
8 NPS	47.68 in ²	15-800 psi	UD

Design Name: RLS, RLS Welded Assembly (liquid) NBCert # 77307

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/27/2029

Design Type

[Rupture Disk Device] RLS, RLS Welded Assembly (liquid)
 HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, S90-7R, S90-7R-TR, SMR-7R, SRI-7RS, SRB-7RS Special, SRB-QRS
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 16, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 5.830 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.5 in ²			300-6000 psi		UD
1 NPS		0.84 in ²			125-6000 psi		UD
1.5 NPS		1.77 in ²			85-5400 psi		UD
10 NPS		73.9 in ²			35-1200 psi		UD
12 NPS		99 in ²			35-900 psi		UD
14 NPS		131 in ²			35-650 psi		UD
16 NPS		172 in ²			25-550 psi		UD
18 NPS		219 in ²			25-450 psi		UD
2 NPS		3.23 in ²			70-4800 psi		UD
20 NPS		270 in ²			20-350 psi		UD
3 NPS		6.44 in ²			55-3800 psi		UD
4 NPS		11.54 in ²			45-2800 psi		UD
6 NPS		26.4 in ²			35-2000 psi		UD
8 NPS		47 in ²			35-1600 psi		UD

Design Name: RLS, RLS Welded Assembly NBCert # 77059

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	05/26/2027

Design Type

[Rupture Disk Device] RLS, RLS Welded Assembly
 HolderDesignation: SRB-7RS, SRB-7RS-TR, S90-7R, S90-7R-TR, SRB-7FS, SRB-7FR-TR, SMR-7R, SRI-7RS, SRB-7RS Special, SRB-QRS
 Capacity Tests: Sec. UD at National Board Testing Lab on August 12, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 1.140 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.5 in ²			300-2000 psi		UD
1 NPS		0.84 in ²			125-2200 psi		UD
1.5 NPS		1.77 in ²			85-1800 psi		UD
10 NPS		73.9 in ²			35-250 psi		UD
12 NPS		99 in ²			35-150 psi		UD
14 NPS		131 in ²			35-130 psi		UD
16 NPS		172 in ²			25-110 psi		UD
18 NPS		219 in ²			25-90 psi		UD
2 NPS		3.23 in ²			70-1800 psi		UD
20 NPS		270 in ²			20-90 psi		UD
3 NPS		6.44 in ²			55-1600 psi		UD
4 NPS		11.54 in ²			45-1500 psi		UD
6 NPS		26.4 in ²			35-650 psi		UD
8 NPS		47 in ²			35-400 psi		UD

Design Name: S-90 (Inconel)

NBCert #

77206

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UD

10/27/2029

Design Type

[Rupture Disk Device] S-90 (Inconel)
 HolderDesignation: S90-7R, S90-7R-TR, SRB-7RS, SRB-7RS-TR, SMR-7R, SRB-7FS, SRB-7FS-TR, SRI-7RS, SRB-QRS
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on April 24, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.230 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			170-1000 psi		UD
1.5 NPS		2.03 in ²			128-1000 psi		UD
10 NPS		78.8 in ²			36-700 psi		UD
12 NPS		111 in ²			33-600 psi		UD
14 NPS		135 in ²			30-500 psi		UD
16 NPS		176 in ²			28-200 psi		UD
18 NPS		223 in ²			26-160 psi		UD

2 NPS		3.36 in ²		96-1000 psi	UD
20 NPS		277 in ²		24-142 psi	UD
24 NPS		402 in ²		22-118 psi	UD
3 NPS		7.39 in ²		72-1000 psi	UD
30 NPS		672 in ²		20-80 psi	UD
4 NPS		12.7 in ²		60-800 psi	UD
6 NPS		28.9 in ²		48-800 psi	UD
8 NPS		50 in ²		42-700 psi	UD
40 NPS	NPS	1195 in ²	0 in	30-250 psi	UD

Design Name: S90, S90 Welded Assembly NBCert # 77082

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/27/2029

Design Type

[Rupture Disk Device] S90, S90 Welded Assembly
HolderDesignation: SRB-7RS, SRB-7RS-TR, S90-7R, S90-7R-TR, SMR-7R, SRB-7FS, SRB-7FS-TR, SRI-7RS, SRB-QRS
Capacity Tests: Sec. UD at National Board Testing Lab on July 27, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 1.130 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			75-1000 psi		UD
1.5 NPS		2.03 in ²			54-1000 psi		UD
10 NPS		78.8 in ²			30-700 psi		UD
12 NPS		111 in ²			27-600 psi		UD
14 NPS		135 in ²			25-500 psi		UD
16 NPS		176 in ²			23-475 psi		UD
18 NPS		223 in ²			22-475 psi		UD
2 NPS		3.36 in ²			45-1000 psi		UD
20 NPS		277 in ²			20-250 psi		UD
24 NPS		402 in ²			18-250 psi		UD
28 NPS		583 in ²			20-250 psi		UD
3 NPS		7.39 in ²			36-1000 psi		UD
30 NPS		672 in ²			20-250 psi		UD
4 NPS		12.7 in ²			30-800 psi		UD
40 NPS	NPS	1195 in ²			20-250 psi	Air	UD
6 NPS		28.8 in ²			24-800 psi		UD
8 NPS		50 in ²			35-700 psi		UD

Design Name:	S90-HP, S90-HP Welded Assembly	NBCert #	78432
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	11/05/2025

Design Type

[Rupture Disk Device] S90-HP, S90-HP Welded Assembly
HolderDesignation: SRB-7HP, S90-7HP
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on April 9, 2019
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 8.000 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.71 in ²			1000-6005 psi		UD
1.5 NPS		1.62 in ²			1000-6005 psi		UD
2 NPS		2.68 in ²			1000-6005 psi		UD
3 NPS		5.92 in ²			1000-6005 psi		UD
4 NPS		10.2 in ²			800-6005 psi		UD
6 NPS		23 in ²			800-6005 psi		UD

Design Name:	SIGMA, SIGMA EXL, UBR	NBCert #	77464
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	09/19/2028

Design Type

[Rupture Disk Device] SIGMA, SIGMA EXL, UBR
HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SR-7R, SRI-7RS, S90-7R-TR, SRB-QRS
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 28, 2000
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.380 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
	10 NPS	78.86 in ²			15-100 psi	Air	UD
1.5-1.5 NPS	1.5 NPS	1.93 in ²			25-450 psi	Air	UD
1-1 NPS	1 NPS	0.86 in ²			30-500 psi		UD
2-2 NPS	2 NPS	3.36 in ²			25-400 psi	Air	UD
3-3 NPS	3 NPS	7.39 in ²			20-400 psi	Air	UD
4-4 NPS	4 NPS	12.74 in ²			16-400 psi	Air	UD
6-6 NPS	6 NPS	28.89 in ²			15-225 psi	Air	UD
8-8 NPS	8 NPS	50 in ²			15-125 psi	Air	UD

Design Name: SIGMA, SIGMA EXL, UBR (liquid)		NBCert #	77475
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	09/19/2028
Design Type			
[Rupture Disk Device] SIGMA, SIGMA EXL, UBR (liquid) HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SRB-7R, SRI-7RS, S90-7R-TR, SRB-QRS Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 28, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl Certified Value: 1.250 Unitless Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.5 NPS	1.5 NPS	1.93 in ²			25-750 psi	Water	UD
10-10 NPS	10 NPS	78.86 in ²			15-100 psi	Water	UD
1-1 NPS	1 NPS	0.86 in ²			30-500 psi		UD
2-2 NPS	2 NPS	3.36 in ²			25-400 psi	Water	UD
3-3 NPS	3 NPS	7.39 in ²			20-400 psi	Water	UD
4-4 NPS	4 NPS	12.74 in ²			16-400 psi	Water	UD
6-6 NPS	6 NPS	28.89 in ²			15-225 psi	Water	UD
8-8 NPS	8 NPS	50 in ²			15-125 psi	Water	UD

Design Name: SKI, SKI-TN		NBCert #	78410
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	10/18/2030
Design Type			
[Rupture Disk Device] SKI, SKI-TN HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SRI-7RS, SRB-QRS Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 4, 2018 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 0.470 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 in	1.0 in	0.86 in ²			60-500 psi	Air	UD
1.5 in	1.5 in	1.93 in ²			45-500 psi	Air	UD
2 in	2.0 in	3.36 in ²			30-500 psi	Air	UD
3 in	3.0 in	7.39 in ²			25-500 psi	Air	UD
4 in	4.0 in	12.74 in ²			20-500 psi	Air	UD
6 in	6.0 in	28.89 in ²			20-261 psi	Air	UD
8 in	8.0 in	50 in ²			20-200 psi	Air	UD

Design Name:	SKI, SKI-TN (Liquid)	NBCert #	78421
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/18/2030

Design Type

[Rupture Disk Device] SKI, SKI-TN (Liquid)
 HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SRI-7RS, SRB-QRS
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 4, 2018
 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krl
 Certified Value: 1.030 Unitless
 Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 in	1.0 in	0.86 in ²			60-500 psi	Water	UD
1.5 in	1.5 in	1.93 in ²			45-500 psi	Water	UD
2 in	2.0 in	3.36 in ²			30-500 psi	Water	UD
3 in	3.0 in	7.39 in ²			25-500 psi	Water	UD
4 in	4.0 in	12.74 in ²			20-500 psi	Water	UD
6 in	6.0 in	28.89 in ²			20-261 psi	Water	UD
8 in	8.0 in	50 in ²			20-200 psi	Water	UD

Design Name:	SKI-TK	NBCert #	78465
--------------	--------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 11/21/2025

Design Type

[Rupture Disk Device] SKI-TK
 HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SRI-7RS
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on May 13, 2019
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.680 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			60-500 psi		UD
1.5 NPS		1.93 in ²			45-500 psi		UD
2 NPS		3.36 in ²			30-500 psi		UD
3 NPS		7.39 in ²			25-500 psi		UD
4 NPS		12.74 in ²			20-500 psi		UD
6 NPS		28.89 in ²			20-261 psi		UD
8 NPS		50 in ²			20-200 psi		UD

Design Name:	SKI-TK (Liquid)	NBCert #	78476
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 11/21/2025

Design Type

[Rupture Disk Device] SKI-TK (Liquid)
HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SRI-7RS
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on May 13, 2019
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 1.300 Unitless
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			60-500 psi		UD
1.5 NPS		1.93 in ²			45-500 psi		UD
2 NPS		3.36 in ²			30-500 psi		UD
3 NPS		7.39 in ²			25-500 psi		UD
4 NPS		12.74 in ²			20-500 psi		UD
6 NPS		28.89 in ²			20-261 psi		UD
8 NPS		50 in ²			20-200 psi		UD

Design Name:	SKr DD	NBCert #	78106
--------------	--------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 05/17/2029

Design Type

[Rupture Disk Device] SKr DD
HolderDesignation: S90-7R DD, S90-7R-TR DD, SRB-7RS DD, SRB-7RS-TR DD, SRB-7FS DD, SRB-7FS-TR DD
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on September 26, 2013
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.630 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.59 in ²			55-500 psi	Air	UD
1 NPS		0.86 in ²			55-500 psi	Air	UD
1.5 NPS		2.04 in ²			40-500 psi	Air	UD
10 NPS		78.86 in ²			11-150 psi	Air	UD
12 NPS		117.87 in ²			9-110 psi	Air	UD
2 NPS		3.36 in ²			25-500 psi	Air	UD
3 NPS		7.39 in ²			20-500 psi	Air	UD
4 NPS		12.74 in ²			16-500 psi	Air	UD
6 NPS		28.89 in ²			15-261 psi	Air	UD

8 NPS	50 in ²	15-200 psi	Air	UD
-------	--------------------	------------	-----	----

Design Name: SKr DD (Liquid)		NBCert #	78117
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	12/20/2025
Design Type			
[Rupture Disk Device] SKr DD (Liquid) HolderDesignation: S90-7R DD, S90-7R-TR DD, SRB-7RS DD, SRB-7RS-TR DD, SRB-7FS DD, SRB-7FS-TR DD Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on September 26, 2013 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl Certified Value: 1.600 Unitless Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.59 in ²			55-500 psi	Water	UD
1 NPS		0.86 in ²			55-500 psi	Water	UD
1.5 NPS		2.04 in ²			40-500 psi	Water	UD
10 NPS		78.86 in ²			11-150 psi	Water	UD
12 NPS		117.87 in ²			9-110 psi	Water	UD
2 NPS		3.36 in ²			25-500 psi	Water	UD
3 NPS		7.39 in ²			20-500 psi	Water	UD
4 NPS		12.74 in ²			16-500 psi	Water	UD
6 NPS		28.89 in ²			15-261 psi	Water	UD
8 NPS		50 in ²			15-200 psi	Water	UD

Design Name: SKR, SKR Welded Assembly		NBCert #	77161
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	04/30/2026
Design Type			
[Rupture Disk Device] SKR, SKR Welded Assembly HolderDesignation: SRB-7RS, SRB-7RS-TR, S90-7R, S90-7R-TR SRB-7FS, SRB-7FS-TR, SRI-7RS, SRB-QRS Capacity Tests: Sec. UD at National Board Testing Lab on April 24, 1999 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.370 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.59 in ²			55-500 psi	Air	UD
1 NPS		0.86 in ²			55-500 psi		UD
1.5 NPS		2.04 in ²			40-500 psi		UD
10 NPS		78.86 in ²			11-150 psi		UD
12 NPS		117.87 in ²			9-110 psi		UD

2 NPS	3.36 in ²	25-550 psi	UD
3 NPS	7.39 in ²	20-500 psi	UD
4 NPS	12.74 in ²	16-500 psi	UD
6 NPS	28.89 in ²	15-261 psi	UD
8 NPS	50 in ²	15-200 psi	UD

Design Name: SKR, SKR Welded Assembly (Liquids) NBCert # 77329

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/22/2026

Design Type

[Rupture Disk Device] SKR, SKR Welded Assembly (Liquids)
 HolderDesignation: S90-7R, S90-7R-TR, SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SRI-7RS, SRB-QRS
 Capacity Tests: Sec. UD at National Board Testing Lab on April 30, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 1.900 Unitless
 Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.59 in ²			55-500 psi	Water	UD
1 NPS		0.86 in ²			55-500 psi		UD
1.5 NPS		2.04 in ²			40-500 psi		UD
10 NPS		78.86 in ²			11-150 psi		UD
12 NPS		117.87 in ²			9-110 psi		UD
2 NPS		3.36 in ²			25-550 psi		UD
3 NPS		7.39 in ²			20-500 psi		UD
4 NPS		12.74 in ²			16-500 psi		UD
6 NPS		28.89 in ²			15-261 psi		UD
8 NPS		50 in ²			15-200 psi		UD

Design Name: SKr-U 1" NBCert # 77521

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/18/2028

Design Type

[Rupture Disk Device] SKr-U 1"
 HolderDesignation: UR-2, UR-6, Welded Assembly
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 24, 2000
 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
 Certified Value: 1.250 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.608 in ²			55-500 psi		UD

Design Name: Skr-U 1/2"		NBCert # 77509
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	09/18/2028
Design Type		
[Rupture Disk Device] Skr-U 1/2" HolderDesignation: UR-2, UR-6, Welded Assembly Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on September 15, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 0.850 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.5 NPS	.5 NPS	0.304 in ²			55-500 psi		UD

Design Name: SKr-U 3/4" Liquid		NBCert # 77543
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	09/11/2028
Design Type		
[Rupture Disk Device] SKr-U 3/4" Liquid HolderDesignation: UR-2, UR-6, Welded Assembly Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 26, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krl Certified Value: 1.100 Unitless Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-0.75 NPS	.75 NPS	0.533 in ²			55-775 psi		UD

Design Name: SKr-U 1" Liquid		NBCert # 77554
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	09/14/2028
Design Type		
[Rupture Disk Device] SKr-U 1" Liquid HolderDesignation: UR-2, UR-6, Welded Assembly Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 24, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krl Certified Value: 2.200 Unitless Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.608 in ²			55-500 psi		UD

Design Name: SKr-U 3/4"		NBCert #	77510
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	09/11/2028
Design Type			
[Rupture Disk Device] SKr-U 3/4" HolderDesignation: UR-2, UR-6, Welded Assembly Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 26, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 0.730 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-0.75 NPS	.75 NPS	0.533 in ²			55-775 psi		UD

Design Name: SRC		NBCert #	77767
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	03/06/2031
Design Type			
[Rupture Disk Device] SRC HolderDesignation: None Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 26, 2002 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 1.100 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		3.35 in ²			75-400 psi		UD
3 NPS		7.39 in ²			60-400 psi		UD
4 NPS		12.7 in ²			50-400 psi		UD
5 NPS		20 in ²			50-350 psi		UD
6 NPS		28.8 in ²			50-350 psi		UD
8 NPS		50 in ²			50-350 psi		UD
		22.85 in ²	[SPL] 141.5 mm		92-350 psi		UD

Design Name: SRD & CCS		NBCert #	78229
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	08/15/2028

Design Type

[Rupture Disk Device] SRD & CCS

HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SMR-7R, SR-7R, SPR-7R, S90-7R, S90-7R-TR, SRI-7RS, SRB-QRS

Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on May 19, 2016

Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg

Certified Value: 0.590 Unitless

Media - Test: Air/Gas; Certified: Compressible (Krg)

Set Pressure Definition: Burst Pressure

Flow Area Configuration: MNFA

Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.84 in ²			481-750 psi		UD
1.5 NPS		1.77 in ²			421-600 psi		UD
2 NPS		3.23 in ²			421-500 psi		UD
3 NPS		6.44 in ²			281-500 psi		UD
4 NPS		11.54 in ²			271-500 psi		UD
6 NPS		26.44 in ²			101-200 psi		UD
8 NPS		47.07 in ²			76-150 psi		UD
10 NPS		73.94 in ²		0 in	60-125 psi		UD
12 NPS		99.1 in ²		0 in	45-90 psi		UD
24 NPS		334 in ²		0 in	32-60 psi		UD

Design Name: SRD & CCS (Liquid)

NBCert #

78230

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	08/16/2028

Design Type

[Rupture Disk Device] SRD & CCS (Liquid)

HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SMR-7R, SR-7R, SPR-7R, S90-7R, S90-7R-TR, SRI-7RS, SRB-QRS

Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on May 19, 2016

Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krl

Certified Value: 4.000 Unitless

Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)

Set Pressure Definition: Burst Pressure

Flow Area Configuration: MNFA

Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.84 in ²			481-750 psi		UD
1.5 NPS		1.77 in ²			421-600 psi		UD
2 NPS		3.23 in ²			421-500 psi		UD
3 NPS		6.44 in ²			281-500 psi		UD
4 NPS		11.54 in ²			271-500 psi		UD
6 NPS		26.44 in ²			101-200 psi		UD
8 NPS		47.07 in ²			76-150 psi		UD
10 NPS		73.94 in ²		0 in	60-125 psi		UD
12 NPS		99.1 in ²		0 in	45-90 psi		UD
24 NPS		334 in ²		0 in	32-60 psi		UD

Design Name:	SRD-L & CCS-L	NBCert #	78241
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 08/16/2028

Design Type

[Rupture Disk Device] SRD-L & CCS-L
HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SMR-7R, SR-7R, SPR-7R, S90-7R, S90-7R-TR, SRI-7RS, SRB-QRS
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on May 19, 2016
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 3.400 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.84 in ²			75-480 psi		UD
1.5 NPS		1.77 in ²			75-420 psi		UD
2 NPS		3.23 in ²			75-420 psi		UD
3 NPS		6.44 in ²			45-280 psi		UD
4 NPS		11.54 in ²			20-270 psi		UD
6 NPS		26.44 in ²			20-100 psi		UD
8 NPS		47.07 in ²			15-75 psi		UD
10 NPS		73.94 in ²		0 in	13-60 psi		UD
12 NPS		99 in ²		0 in	13-45 psi		UD
14 NPS		131 in ²		0 in	12-40 psi		UD
16 NPS		172 in ²		0 in	12-38 psi		UD
18 NPS		219 in ²		0 in	10-36 psi		UD
20 NPS		270 in ²		0 in	10-34 psi		UD
24 NPS		334 in ²		0 in	10-32 psi		UD

Design Name:	SRD-L & CCS-L (Liquid)	NBCert #	78252
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/11/2029

Design Type

[Rupture Disk Device] SRD-L & CCS-L (Liquid)
HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SMR-7R, SR-7R, SPR-7R, S90-7R, S90-7R-TR, SRI-7RS, SRB-QRS
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on May 19, 2016
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 4.500 Unitless
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.84 in ²			75-480 psi		UD
1.5 NPS		1.77 in ²			75-420 psi		UD

2 NPS	3.23 in ²		75-420 psi	UD
3 NPS	6.44 in ²		45-280 psi	UD
4 NPS	11.54 in ²		20-270 psi	UD
6 NPS	26.44 in ²		20-100 psi	UD
8 NPS	47.07 in ²		15-75 psi	UD
10 NPS	73.94 in ²	0 in	13-60 psi	UD
12 NPS	99 in ²	0 in	13-45 psi	UD
14 NPS	131 in ²	0 in	12-40 psi	UD
16 NPS	172 in ²	0 in	12-38 psi	UD
18 NPS	219 in ²	0 in	10-36 psi	UD
20 NPS	270 in ²	0 in	10-36 psi	UD
24 NPS	334 in ²	0 in	10-32 psi	UD

Design Name: SSR NBCert # 77969

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/27/2029

Design Type

[Rupture Disk Device] SSR
 HolderDesignation: SRB-7RS, SRB-7RS-TR, SPR-7R, SMR-7R, S90-7R, S90-7R-TR, SRB-7FS, SRB-7FS-TR, SR-7R, SRI-7RS, SRB-QRS
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on March 28, 2006
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.520 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			55-350 psi		UD
1.5 NPS		1.93 in ²			40-350 psi		UD
10 NPS		78.8 in ²			15-150 psi		UD
2 NPS		3.36 in ²			25-300 psi		UD
3 NPS		7.39 in ²			20-250 psi		UD
4 NPS		12.74 in ²			16-250 psi		UD
6 NPS		28.89 in ²			15-250 psi		UD
8 NPS		50 in ²			15-200 psi		UD
12 NPS	NPS	111.8 in ²	0 in	0 in	13-70 psi		UD

Design Name: SSR (liquid) NBCert # 77958

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/27/2029

Design Type

[Rupture Disk Device] SSR (liquid)

HolderDesignation: SRB-7RS, SRB-7RS-TR, SMR-7R, SPR-7R, S90-7R, S90-7R-TR, SRB-7FS, SRB-7FS-TR, SR-7R, SRI-7RS, SRB-QRS

Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on March 28, 2006

Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl

Certified Value: 0.520 Unitless

Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)

Set Pressure Definition: Burst Pressure

Flow Area Configuration: MNFA

Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			55-350 psi		UD
1.5 NPS		1.93 in ²			40-350 psi		UD
10 NPS		78.8 in ²			15-150 psi		UD
2 NPS		3.36 in ²			25-350 psi		UD
3 NPS		7.39 in ²			20-350 psi		UD
4 NPS		12.74 in ²			16-375 psi		UD
6 NPS		28.89 in ²			15-350 psi		UD
8 NPS		50 in ²			15-350 psi		UD
12 NPS	NPS	111.8 in ²	0 in	0 in	13-250 psi		UD

Design Name: VSP-SH, RCS

NBCert #

77947

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

05/17/2029

Design Type

[Rupture Disk Device] VSP-SH, RCS

HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, S90-7R, S90-7R-TR, SMR-7R, SR-7R, SPR-7R, SRI-7RS, SHO-7R

Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on March 1, 2011

Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl

Certified Value: 1.770 Unitless

Media - Test: Air/Gas; Certified: Compressible (Krg)

Set Pressure Definition: Burst Pressure

Flow Area Configuration: MNFA

Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS		68.65 in ²			5.8-50 psi	Air	UD
12 NPS		102.28 in ²			2.9-50 psi	Air	UD
14 NPS		121.86 in ²			2.9-50 psi	Air	UD
16 NPS		156 in ²			2.9-50 psi	Air	UD
18 NPS		198 in ²			1.5-50 psi	Air	UD
20 NPS		246 in ²			1.5-50 psi	Air	UD
22 NPS		313 in ²			1.5-50 psi	Air	UD
24 NPS		357 in ²			0.7-50 psi	Air	UD
26 NPS		441 in ²			0.7-50 psi	Air	UD
28 NPS		514 in ²			0.7-50 psi	Air	UD
30 NPS		592 in ²			0.7-50 psi	Air	UD
32 NPS		706.9 in ²			0.7-50 psi	Air	UD

36 NPS		868 in ²		0.7-50 psi	Air	UD
38 NPS		959 in ²		0.7-50 psi	Air	UD
40 NPS		1065 in ²		0.7-50 psi	Air	UD
42 NPS		1176 in ²		0.7-50 psi	Air	UD
44 NPS		1292 in ²		0.7-50 psi	Air	UD
46 NPS		1415 in ²		0.7-50 psi	Air	UD
48 NPS		1548 in ²		0.7-50 psi	Air	UD
52 NPS		1815 in ²		0.7-50 psi	Air	UD
56 NPS		2110 in ²		0.7-50 psi	Air	UD
6 NPS		25.08 in ²		7.3-140 psi	Air	UD
60 NPS		2426 in ²		0.7-50 psi	Air	UD
8 NPS		42.07 in ²		7.3-100 psi	Air	UD
1.5 NPS	NPS	1.89 in ²	0 in	60-150 psi		UD
2 NPS	NPS	3.35 in ²	0 in	45-150 psi		UD
3 NPS	NPS	6.53 in ²	0 in	22-150 psi		UD
4 NPS	NPS	11.86 in ²	0 in	8.7-150 psi		UD

Design Name: XT (Liquid) NBCert # 78094

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	08/17/2028

Design Type

[Rupture Disk Device] XT (Liquid)
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on February 13, 2013
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 0.500 Unitless
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			250-1450 psi	Water	UD
1.5 NPS		2.03 in ²			150-1450 psi	Water	UD
10 NPS		78.8 in ²			60-840 psi	Water	UD
12 NPS		111 in ²			60-720 psi	Water	UD
2 NPS		3.36 in ²			150-1450 psi	Water	UD
3 NPS		7.39 in ²			150-1300 psi	Water	UD
4 NPS		12.7 in ²			80-1150 psi	Water	UD
6 NPS		28.8 in ²			70-1040 psi	Water	UD
8 NPS		50 in ²			60-960 psi	Water	UD

Design Name: XT, XT Welded Assembly NBCert # 77149

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/27/2029

Design Type

[Rupture Disk Device] XT, XT Welded Assembly
 HolderDesignation: NX-7R, NF-7R, NF-7RS, TL-7R, TLP-7R
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 1, 2006
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.500 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 in	in	0.86 in ²			80-1450 psi		UD
1.5 in	in	2.03 in ²			55-1450 psi		UD
10 in	in	78.8 in ²			60-840 psi		UD
12 in	in	111 in ²			60-720 psi		UD
2 in	in	3.36 in ²			45-1450 psi		UD
3 in	in	7.39 in ²			45-1300 psi		UD
4 in	in	12.7 in ²			40-1150 psi		UD
6 in	in	28.8 in ²			40-1040 psi		UD
8 in	in	50 in ²			40-960 psi		UD

BS&B Premco Latinoamerica S.A. De C.V. (BSP)

Santa Catarina, Nuevo Leon, 66360Mexico

This Company Manufactures or Assembles:

Design Name: AV		NBCert # 77341
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	08/25/2027

Design Type

[Rupture Disk Device] AV
 HolderDesignation: AV7R, AV-7RS, AV-7FS, AV-1, -2, -3, -4, -5, -6, -7, -8, -9
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on November 4, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 4.350 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS		78.85 in ²			0.6-60 psi		UD
12 NPS		113.1 in ²			0.6-60 psi		UD
14 NPS		137.9 in ²			0.6-60 psi		UD
16 NPS		182.7 in ²			0.6-60 psi		UD
18 NPS		233.7 in ²			0.5-60 psi		UD
2 NPS		3.356 in ²			5-150 psi		UD

2.5 NPS	4.787 in ²	5-150 psi	UD
20 NPS	291 in ²	0.5-60 psi	UD
22 NPS	354.7 in ²	0.5-60 psi	UD
24 NPS	424.6 in ²	0.5-60 psi	UD
26 NPS	500.7 in ²	0.5-45 psi	UD
28 NPS	583.2 in ²	0.5-45 psi	UD
3 NPS	7.392 in ²	4-150 psi	UD
30 NPS	672 in ²	0.5-45 psi	UD
32 NPS	767 in ²	0.35-40 psi	UD
34 NPS	868.3 in ²	0.35-40 psi	UD
36 NPS	975.9 in ²	0.25-40 psi	UD
38 NPS	1090 in ²	0.25-40 psi	UD
4 NPS	12.73 in ²	2-150 psi	UD
40 NPS	1210 in ²	0.25-40 psi	UD
42 NPS	1336 in ²	0.25-40 psi	UD
44 NPS	1469 in ²	0.25-40 psi	UD
46 NPS	1608 in ²	0.25-40 psi	UD
48 NPS	1753 in ²	0.25-40 psi	UD
5 NPS	20 in ²	2-100 psi	UD
6 NPS	28.89 in ²	1-100 psi	UD
8 NPS	50.02 in ²	1-100 psi	UD

Design Name: AVV	NBCert # 78364
------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	04/15/2027

Design Type

[Rupture Disk Device] AVV
HolderDesignation: AV-75 (optional)
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on March 17, 2017
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value:10.500 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 in		0.4 in ²			10-150 psi		UD
1.5 in		0.95 in ²			7-150 psi		UD
10 in		45.5 in ²			0.6-60 psi		UD
12 in		62.75 in ²			0.6-60 psi		UD
14 in		74.5 in ²			0.6-60 psi		UD
16 in		111 in ²			0.6-60 psi		UD
18 in		158 in ²			0.5-60 psi		UD
2 in		1.6 in ²			5-150 psi		UD

20 in	195 in ²	0.5-60 psi	UD
24 in	280 in ²	0.5-60 psi	UD
28 in	382 in ²	0.5-60 psi	UD
3 in	4 in ²	4-150 psi	UD
30 in	425 in ²	0.5-60 psi	UD
32 in	500 in ²	0.35-40 psi	UD
36 in	630 in ²	0.25-40 psi	UD
4 in	8 in ²	2-150 psi	UD
40 in	780 in ²	0.25-40 psi	UD
44 in	945 in ²	0.25-40 psi	UD
48 in	1125 in ²	0.25-40 psi	UD
6 in	16.5 in ²	1-100 psi	UD
8 in	35.75 in ²	1-100 psi	UD

Design Name: BPAV (air/gas) NBCert # 77981

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 04/10/2029

Design Type

[Buckling Pin Non-reclosing Device] BPAV (air/gas)
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 27, 2011
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.800 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: Nozzle/Full Lift & MNFA
Designed by: BS&B Premco LLC {PRL}
Comments: Lifts listed are required total travel.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5 NPS	0.72 in ²	0.957 in	0.912 in	2100-3500 psi	Air	UD
1 NPS	1.5 NPS	0.86 in ²	1.046 in	0.912 in	15-2100 psi	Air	UD
1.5 NPS	2 NPS	2.04 in ²	1.612 in	1.051 in	15-1440 psi	Air	UD
2 NPS	3 NPS	3.36 in ²	2.067 in	1.257 in	15-720 psi	Air	UD
3 NPS	4 NPS	7.39 in ²	3.067 in	1.755 in	15-720 psi	Air	UD
4 NPS	6 NPS	12.73 in ²	4.026 in	2.084 in	15-720 psi	Air	UD
6 NPS	8, 10 NPS	28.89 in ²	6.065 in	2.61 in	15-275 psi	Air	UD
8 NPS	10 NPS	50.03 in ²	7.981 in	3.304 in	15-275 psi	Air	UD

Design Name: BPAV (Liquid) NBCert # 77970

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 04/10/2029

Design Type

[Buckling Pin Non-reclosing Device] BPAV (Liquid)
 Capacity Tests: Sec. UD at National Board Testing Lab on May 3, 2012
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.686 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: Buckling Pressure
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: BS&B Premco LLC {PRL}
 Comments: Lifts listed are required total travel.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5 NPS	0.72 in ²	0.957 in	0.912 in	2100-3500 psi	Water	UD
1 NPS	1.5 NPS	0.86 in ²	1.046 in	0.912 in	50-2100 psi	Water	UD
1.5 NPS	2 NPS	2.04 in ²	1.612 in	1.051 in	15-1440 psi	Water	UD
2 NPS	3 NPS	3.36 in ²	2.067 in	1.257 in	15-720 psi	Water	UD
3 NPS	4 NPS	7.39 in ²	3.067 in	1.755 in	15-720 psi	Water	UD
4 NPS	6 NPS	12.73 in ²	4.026 in	2.084 in	15-720 psi	Water	UD
6 NPS	8, 10 NPS	28.89 in ²	6.065 in	2.61 in	15-275 psi	Water	UD
8 NPS	10 NPS	50.03 in ²	7.981 in	3.304 in	15-275 psi	Water	UD

Design Name: BPPV NBCert # 77992

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	11/02/2029

Design Type

[Buckling Pin Non-reclosing Device] BPPV
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on December 20, 2011
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 2.200 Unitless; Certification Provisions: Exceeds Lab Limits (Prev. CC 2397)
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Buckling Pressure
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: BS&B Premco LLC {PRL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
6-6 NPS	6 NPS	28.27 in ²	6 in	3 in	15-275 psi	Air	UD
8-8 NPS	8 NPS	49.02 in ²	7.9 in	3.95 in	15-275 psi	Air	UD
10-10 NPS	10 NPS	77.32 in ²	9.92 in	4.96 in	15-275 psi	Air	UD
12-12 NPS	12 NPS	110.85 in ²	11.88 in	5.94 in	15-275 psi	Air	UD
14-14 NPS	14 NPS	135.1 in ²	13.12 in	6.56 in	15-275 psi	Air	UD
16-16 NPS	16 NPS	179 in ²	15.1 in	7.55 in	15-275 psi	Air	UD
18-18 NPS	18 NPS	229 in ²	17.08 in	8.54 in	15-275 psi	Air	UD
20-20 NPS	20 NPS	285.2 in ²	19.06 in	9.53 in	15-275 psi	Air	UD
22-22 NPS	22 NPS	347.5 in ²	21.04 in	10.52 in	15-275 psi	Air	UD
24-24 NPS	24 NPS	416.1 in ²	23.02 in	11.51 in	15-275 psi	Air	UD
26-26 NPS	26 NPS	490.6 in ²	25 in	12.5 in	15-275 psi	Air	UD
28-28 NPS	28 NPS	571.5 in ²	26.98 in	13.49 in	15-275 psi	Air	UD
30-30 NPS	30 NPS	658.4 in ²	28.96 in	14.48 in	15-275 psi	Air	UD

32-32 NPS	32 NPS	751.5 in ²	30.94 in	15.47 in	15-100 psi	Air	UD
34-34 NPS	34 NPS	850.8 in ²	32.92 in	16.46 in	15-100 psi	Air	UD
36-36 NPS	36 NPS	956.2 in ²	34.9 in	17.45 in	15-100 psi	Air	UD
38-38 NPS	38 NPS	1067.8 in ²	36.88 in	18.44 in	15-100 psi	Air	UD
40-40 NPS	40 NPS	1185.6 in ²	38.86 in	19.43 in	15-100 psi	Air	UD
42-42 NPS	42 NPS	1309.5 in ²	40.84 in	20.42 in	15-100 psi	Air	UD
44-44 NPS	44 NPS	1439.5 in ²	42.82 in	21.41 in	15-100 psi	Air	UD
46-46 NPS	46 NPS	1575.7 in ²	44.8 in	22.4 in	15-100 psi	Air	UD
48-48 NPS	48 NPS	1718.1 in ²	46.78 in	23.39 in	15-100 psi	Air	UD
50-50 NPS	50 NPS	1866.6 in ²	48.76 in	24.38 in	15-100 psi	Air	UD
52-52 NPS	52 NPS	2021.3 in ²	50.74 in	25.37 in	15-100 psi	Air	UD
54-54 NPS	54 NPS	2182.1 in ²	52.72 in	26.36 in	15-100 psi	Air	UD
56-56 NPS	56 NPS	2349.1 in ²	54.7 in	27.35 in	15-100 psi	Air	UD
58-58 NPS	58 NPS	2522.3 in ²	56.68 in	28.34 in	15-100 psi	Air	UD
60-60 NPS	60 NPS	2701.6 in ²	58.66 in	29.33 in	15-100 psi	Air	UD
62-62 NPS	62 NPS	2887.1 in ²	60.64 in	30.32 in	15-100 psi	Air	UD
64-64 NPS	64 NPS	3078.7 in ²	62.63 in	31.31 in	15-100 psi	Air	UD
66-66 NPS	66 NPS	3276.5 in ²	64.61 in	32.3 in	15-100 psi	Air	UD
68-68 NPS	68 NPS	3480.4 in ²	66.59 in	33.29 in	15-100 psi	Air	UD
70-70 NPS	70 NPS	3690.5 in ²	68.57 in	34.28 in	15-100 psi	Air	UD
72-72 NPS	72 NPS	3906.7 in ²	70.55 in	35.27 in	15-100 psi	Air	UD
74-74 NPS	74 NPS	4129.1 in ²	72.53 in	36.26 in	15-100 psi	Air	UD
76-76 NPS	76 NPS	4357.7 in ²	74.51 in	37.25 in	15-100 psi	Air	UD
78-78 NPS	78 NPS	4592.4 in ²	76.49 in	38.24 in	15-100 psi	Air	UD
80-80 NPS	80 NPS	4833.3 in ²	78.47 in	39.23 in	15-100 psi	Air	UD
82-82 NPS	82 NPS	5080.3 in ²	80.45 in	40.22 in	15-100 psi	Air	UD
84-84 NPS	84 NPS	5333.5 in ²	82.43 in	41.41 in	15-100 psi	Air	UD
86-86 NPS	86 NPS	5592.9 in ²	84.41 in	42.2 in	15-100 psi	Air	UD
88-88 NPS	88 NPS	5858.4 in ²	86.39 in	43.19 in	15-100 psi	Air	UD
90-90 NPS	90 NPS	6130 in ²	88.37 in	44.18 in	15-100 psi	Air	UD
92-92 NPS	92 NPS	6407.8 in ²	90.35 in	45.17 in	15-100 psi	Air	UD
94-94 NPS	94 NPS	6691.8 in ²	92.33 in	46.16 in	15-100 psi	Air	UD
96-96 NPS	96 NPS	6981.9 in ²	94.31 in	47.15 in	15-100 psi	Air	UD

Design Name: BPRV, BPIV, TOV			NBCert # 77813	
Manufacturer/Assembler		Designators		Expiration Date
Manufacturer		UD		12/14/2029

Design Type

[Buckling Pin Non-reclosing Device] BPRV, BPIV, TOV

Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on April 12, 2004

Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl

Certified Value: 1.220 Unitless

Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)

Set Pressure Definition: Buckling Pressure

Flow Area Configuration: MNFA

Designed by: BS&B Premco LLC {PRL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS		62.48 in ²			1-2250 psi		UD
12 NPS		90.5 in ²			1-2250 psi		UD
14 NPS		109 in ²			1-1440 psi		UD
16 NPS		149 in ²			1-1440 psi		UD
18 NPS		196.2 in ²			1-1440 psi		UD
2 NPS		2.75 in ²			15-3700 psi		UD
20 NPS		239.1 in ²			1-720 psi		UD
24 NPS		367.6 in ²			1-720 psi		UD
26 NPS		400.6 in ²			1-720 psi		UD
28 NPS		466.8 in ²			1-720 psi		UD
3 NPS		6 in ²			15-3700 psi		UD
30 NPS		601 in ²			1-720 psi		UD
32 NPS		614 in ²			1-720 psi		UD
34 NPS		695 in ²			1-720 psi		UD
36 NPS		781 in ²			1-720 psi		UD
38 NPS		872 in ²			1-720 psi		UD
4 NPS		10 in ²			15-2250 psi		UD
40 NPS		968 in ²			1-720 psi		UD
42 NPS		1069 in ²			1-720 psi		UD
44 NPS		1175 in ²			1-720 psi		UD
46 NPS		1286 in ²			1-160 psi		UD
48 NPS		1403 in ²			1-160 psi		UD
50 NPS		1524 in ²			1-160 psi		UD
52 NPS		1650 in ²			1-160 psi		UD
54 NPS		1784 in ²			1-160 psi		UD
56 NPS		1918 in ²			1-160 psi		UD
58 NPS		2059.4 in ²			1-160 psi		UD
6 NPS		23.5 in ²			1-2250 psi		UD
60 NPS		2206 in ²			1-160 psi		UD
62 NPS		2357 in ²			1-160 psi		UD
64 NPS		2514 in ²			1-160 psi		UD
66 NPS		2675 in ²			1-160 psi		UD
68 NPS		2842 in ²			1-160 psi		UD
70 NPS		3013 in ²			1-160 psi		UD

72 NPS		3190 in²			1-160 psi	UD
74 NPS		3371 in²			1-160 psi	UD
76 NPS		3558 in²			1-160 psi	UD
78 NPS		3750 in²			1-160 psi	UD
8 NPS		39.65 in²			1-2250 psi	UD
80 NPS	NPS	3946 in²	0 in	0 in	1-160 psi	UD
82 NPS	NPS	4148 in²	0 in	0 in	1-160 psi	UD
84 NPS	NPS	4355 in²	0 in	0 in	1-160 psi	UD
86 NPS	NPS	4566 in²	0 in	0 in	1-160 psi	UD
88 NPS	NPS	4783 in²	0 in	0 in	1-160 psi	UD
90 NPS	NPS	5005 in²	0 in	0 in	1-160 psi	UD
92 NPS	NPS	5232 in²	0 in	0 in	1-160 psi	UD
94 NPS	NPS	5464 in²	0 in	0 in	1-160 psi	UD
96 NPS	NPS	5700 in²	0 in	0 in	1-160 psi	UD

Design Name: RB-90 NBCert # 77138

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 06/12/2031

Design Type

[Rupture Disk Device] RB-90
HolderDesignation: RB-7R, RB-7F, RB-7FF, RB-7FS
Capacity Tests: Sec. UD at National Board Testing Lab on February 19, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 3.470 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.831 in²			30-1800 psi		UD
1.5 NPS		1.805 in²			25-1700 psi		UD
10 NPS		67.62 in²			15-800 psi		UD
12 NPS		101.8 in²			15-800 psi		UD
14 NPS		121.7 in²			15-800 psi		UD
16 NPS		162.8 in²			15-800 psi		UD
18 NPS		209.99 in²			13-700 psi		UD
2 NPS		3.153 in²			22-1600 psi		UD
20 NPS		262.9 in²			13-700 psi		UD
24 NPS		386.9 in²			10-700 psi		UD
26 NPS		465 in²			10-700 psi		UD
28 NPS		530.7 in²			10-700 psi		UD
3 NPS		6.849 in²			21-1500 psi		UD
30 NPS		617.7 in²			10-700 psi		UD
32 NPS		698.4 in²			10-700 psi		UD

34 NPS	790.1 in ²	10-700 psi	UD
36 NPS	872.8 in ²	10-700 psi	UD
4 NPS	11.84 in ²	20-1500 psi	UD
6 NPS	25.45 in ²	20-850 psi	UD
8 NPS	47.68 in ²	15-800 psi	UD

Design Name:	RDV-HP	NBCert #	79017
--------------	--------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/11/2030

Design Type

[Safety Relief Valve] RDV-HP
Capacity Tests: Sec. UV at National Board Testing Lab on March 20, 2014
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:3261.0 SCFM
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: BS&B Premco LLC {PRL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS	3 NPS	4.345 in ²	2.352 in	0.384 in	50-50 psi	Air	UV

Design Name:	VSP-SH, RCS	NBCert #	77947
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/23/2030

Design Type

[Rupture Disk Device] VSP-SH, RCS
HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, S90-7R, S90-7R-TR, SMR-7R, SR-7R, SPR-7R, SRI-7RS, SHO-7R
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on March 1, 2011
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 1.770 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS		68.65 in ²			5.8-50 psi	Air	UD
12 NPS		102.28 in ²			2.9-50 psi	Air	UD
14 NPS		121.86 in ²			2.9-50 psi	Air	UD
16 NPS		156 in ²			2.9-50 psi	Air	UD
18 NPS		198 in ²			1.5-50 psi	Air	UD
20 NPS		246 in ²			1.5-50 psi	Air	UD
22 NPS		313 in ²			1.5-50 psi	Air	UD
24 NPS		357 in ²			0.7-50 psi	Air	UD
26 NPS		441 in ²			0.7-50 psi	Air	UD
28 NPS		514 in ²			0.7-50 psi	Air	UD

30 NPS		592 in ²		0.7-50 psi	Air	UD
32 NPS		706.9 in ²		0.7-50 psi	Air	UD
36 NPS		868 in ²		0.7-50 psi	Air	UD
38 NPS		959 in ²		0.7-50 psi	Air	UD
40 NPS		1065 in ²		0.7-50 psi	Air	UD
42 NPS		1176 in ²		0.7-50 psi	Air	UD
44 NPS		1292 in ²		0.7-50 psi	Air	UD
46 NPS		1415 in ²		0.7-50 psi	Air	UD
48 NPS		1548 in ²		0.7-50 psi	Air	UD
52 NPS		1815 in ²		0.7-50 psi	Air	UD
56 NPS		2110 in ²		0.7-50 psi	Air	UD
6 NPS		25.08 in ²		7.3-140 psi	Air	UD
60 NPS		2426 in ²		0.7-50 psi	Air	UD
8 NPS		42.07 in ²		7.3-100 psi	Air	UD
1.5 NPS	NPS	1.89 in ²	0 in	60-150 psi		UD
2 NPS	NPS	3.35 in ²	0 in	45-150 psi		UD
3 NPS	NPS	6.53 in ²	0 in	22-150 psi		UD
4 NPS	NPS	11.86 in ²	0 in	8.7-150 psi		UD

BS&B PREMCO LATINOAMERICA S.A. DE C.V. (PLS)

Guadalupe, Nuevo Leon, 67180Mexico

This Company Manufactures or Assembles:

Design Name:	AMBV, MBV, MBV+, & AMBV+ W/Bar Type Vacuum Support	NBCert #	13037
Manufacturer/Assembler	Designators	Expiration Date	

Manufacturer

UD

02/05/2030

Design Type

[Rupture Disk Device] AMBV, MBV, MBV+, & AMBV+ W/Bar Type Vacuum Support

HolderDesignation: N/A

Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 10, 2001

Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl

Certified Value: 1.900 Unitless

Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)

Set Pressure Definition: Burst Pressure

Flow Area Configuration: MNFA

Designed by: BS&B PREMCO LATINOAMERICA S.A. DE C.V. {PLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.63 in ²			10-150 psi		UD
1.5 NPS		1.66 in ²			10-150 psi		UD
10 NPS		63.73 in ²			10-125 psi		UD
12 NPS		91.55 in ²			10-125 psi		UD
14 NPS		110.3 in ²			10-100 psi		UD

16 NPS	146.1 in ²	10-100 psi	UD
18 NPS	187 in ²	10-100 psi	UD
2 NPS	2.693 in ²	10-150 psi	UD
2.5 NPS	4.33 in ²	10-150 psi	UD
20 NPS	232.9 in ²	10-50 psi	UD
24 NPS	339.7 in ²	10-50 psi	UD
3 NPS	5.923 in ²	10-150 psi	UD
4 NPS	10.41 in ²	10-150 psi	UD
5 NPS	16.15 in ²	10-150 psi	UD
6 NPS	23.15 in ²	10-150 psi	HV, UV, V
8 NPS	40.92 in ²	10-150 psi	UD

Design Name: IMB, AIMB, IMBL, AIMBL, FSM, AFSM NBCert # 13048

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 04/27/2030

Design Type

[Rupture Disk Device] IMB, AIMB, IMBL, AIMBL, FSM, AFSM
HolderDesignation: N/A
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 10, 2001
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.310 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS&B PREMCO LATINOAMERICA S.A. DE C.V. {PLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			10-1000 psi		UD
1.5 NPS		2.036 in ²			7-1000 psi		UD
10 NPS		78.85 in ²			0.25-150 psi		UD
12 NPS		113.1 in ²			0.25-150 psi		UD
14 NPS		137.9 in ²			0.25-150 psi		UD
16 NPS		182.7 in ²			0.25-150 psi		UD
18 NPS		233.7 in ²			0.25-150 psi		UD
2 NPS		3.36 in ²			3-500 psi		UD
2.5 NPS		4.79 in ²			2-500 psi		UD
20 NPS		291 in ²			0.25-150 psi		UD
24 NPS		424.6 in ²			0.25-150 psi		UD
3 NPS		7.39 in ²			2-500 psi		UD
4 NPS		12.73 in ²			1.5-500 psi		UD
5 NPS		20.01 in ²			1-450 psi		UD
6 NPS		28.89 in ²			1-450 psi		UD
8 NPS		50.03 in ²			0.5-450 psi		UD

Design Name: MB, AMB, MB+, & AMB+		NBCert #	13059
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	04/27/2030
Design Type			
[Rupture Disk Device] MB, AMB, MB+, & AMB+ HolderDesignation: N/A Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 10, 2001 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 0.193 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS&B PREMCO LATINOAMERICA S.A. DE C.V. {PLS}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			10-150 psi		UD
1.5 NPS		2.035 in ²			7-150 psi		UD
10 NPS		78.85 in ²			0.25-125 psi		UD
12 NPS		113.1 in ²			0.25-125 psi		UD
14 NPS		137.9 in ²			0.25-100 psi		UD
16 NPS		182.7 in ²			0.25-100 psi		UD
18 NPS		233.7 in ²			0.25-100 psi		UD
2 NPS		3.36 in ²			2-150 psi		UD
2.5 NPS		4.79 in ²			2-150 psi		UD
20 NPS		291 in ²			0.25-50 psi		UD
24 NPS		424.6 in ²			0.25-50 psi		UD
3 NPS		7.39 in ²			1-150 psi		UD
4 NPS		12.73 in ²			1-150 psi		UD
5 NPS		20 in ²			1-150 psi		UD
6 NPS		28.89 in ²			1-150 psi		UD
8 NPS		50.03 in ²			0.5-150 psi		UD

Design Name: MBV, AMBV w. Dial Vac. Support		NBCert #	13060
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	12/15/2027
Design Type			
[Rupture Disk Device] MBV, AMBV w. Dial Vac. Support HolderDesignation: N/A Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on September 21, 2001 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 5.400 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS&B PREMCO LATINOAMERICA S.A. DE C.V. {PLS}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		1.02 in ²			7-150 psi		UD
10 NPS		41.1 in ²			0.25-125 psi		UD
12 NPS		59.1 in ²			0.25-125 psi		UD
14 NPS		88.4 in ²			0.25-100 psi		UD
16 NPS		95.7 in ²			0.25-100 psi		UD
18 NPS		124.3 in ²			0.25-100 psi		UD
2 NPS		1.75 in ²			2-150 psi		UD
2.5 NPS		3.05 in ²			2-150 psi		UD
20 NPS		153.9 in ²			0.25-50 psi		UD
24 NPS		226.1 in ²			0.25-50 psi		UD
3 NPS		4.2 in ²			1-150 psi		UD
4 NPS		7.61 in ²			1-150 psi		UD
5 NPS		11.61 in ²			1-150 psi		UD
6 NPS		15.82 in ²			1-150 psi		UD
8 NPS		25.87 in ²			0.5-150 psi		UD

Design Name: RE	NBCert # 13026
-----------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	02/16/2030

Design Type

[Rupture Disk Device] RE
HolderDesignation: RETR, RETF
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 23, 2001
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.150 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS&B PREMCO LATINOAMERICA S.A. DE C.V. {PLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			10-435 psi		UD
1.5 NPS		2.036 in ²			7-290 psi		UD
10 NPS		78.85 in ²			1-43 psi		UD
12 NPS		113.1 in ²			1-36 psi		UD
14 NPS		137.9 in ²			1-29 psi		UD
16 NPS		182.6 in ²			1-21 psi		UD
18 NPS		233.7 in ²			1-21 psi		UD
2 NPS		3.36 in ²			3-217 psi		UD
2.5 NPS		4.79 in ²			3-174 psi		UD
20 NPS		291 in ²			1-17 psi		UD
24 NPS		424.6 in ²			1-17 psi		UD
3 NPS		7.39 in ²			2.2-145 psi		UD

4 NPS	12.73 in ²	2.2-116 psi	UD
5 NPS	20.01 in ²	1.5-87 psi	UD
6 NPS	28.89 in ²	1-72 psi	UD
8 NPS	50.03 in ²	1-58 psi	UD

Design Name: REL	NBCert # 13004
------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/24/2030

Design Type

[Rupture Disk Device] REL
HolderDesignation: REL-7R, REL-7F
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 28, 2001
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.160 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS&B PREMCO LATINOAMERICA S.A. DE C.V. {PLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			10-435 psi		UD
1.5 NPS		2.036 in ²			7-290 psi		UD
10 NPS		78.85 in ²			1-43 psi		UD
12 NPS		113.1 in ²			1-36 psi		UD
14 NPS		137.9 in ²			1-29 psi		UD
16 NPS		182.7 in ²			1-21 psi		UD
18 NPS		233.7 in ²			1-21 psi		UD
2 NPS		3.36 in ²			3-217 psi		UD
2.5 NPS		4.78 in ²			3-174 psi		UD
20 NPS		291.4 in ²			1-17 psi		UD
24 NPS		424.6 in ²			1-17 psi		UD
3 NPS		7.39 in ²			2.2-145 psi		UD
4 NPS		12.73 in ²			2.2-116 psi		UD
5 NPS		20.01 in ²			1.5-87 psi		UD
6 NPS		28.89 in ²			1-72 psi		UD
8 NPS		50.03 in ²			1-58 psi		UD

Design Name: REV	NBCert # 13015
------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	02/05/2030

Design Type

[Rupture Disk Device] REV
HolderDesignation: REV-7R
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 21, 2001
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 3.150 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS&B PREMCO LATINOAMERICA S.A. DE C.V. {PLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.691 in ²			10-435 psi		UD
1.5 NPS		1.767 in ²			7-290 psi		UD
10 NPS		56.54 in ²			1-43 psi		UD
12 NPS		77.6 in ²			1-36 psi		UD
14 NPS		99.2 in ²			1-29 psi		UD
16 NPS		125.3 in ²			1-21 psi		UD
18 NPS		158.7 in ²			1-21 psi		UD
2 NPS		3.092 in ²			3-217 psi		UD
2.5 NPS		4.79 in ²			3-174 psi		UD
20 NPS		190 in ²			1-17 psi		UD
24 NPS		269.4 in ²			1-17 psi		UD
3 NPS		6.29 in ²			2.2-145 psi		UD
4 NPS		10.27 in ²			2.2-116 psi		UD
5 NPS		14.71 in ²			1.5-87 psi		UD
6 NPS		20.95 in ²			1-72 psi		UD
8 NPS		37.12 in ²			1-58 psi		UD

BS&B Premco LLC (PRL)

Tulsa, OK 74145United States

This Company Manufactures or Assembles:

Design Name:	BPAV (air/gas)	NBCert #	77981
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UD	02/08/2029	

Design Type

[Buckling Pin Non-reclosing Device] BPAV (air/gas)
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 27, 2011
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.800 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: Nozzle/Full Lift & MNFA
Designed by: BS&B Premco LLC {PRL}
Comments: Lifts listed are required total travel.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5 NPS	0.72 in ²	0.957 in	0.912 in	2100-3500 psi	Air	UD
1 NPS	1.5 NPS	0.86 in ²	1.046 in	0.912 in	15-2100 psi	Air	UD
1.5 NPS	2 NPS	2.04 in ²	1.612 in	1.051 in	15-1440 psi	Air	UD
2 NPS	3 NPS	3.36 in ²	2.067 in	1.257 in	15-720 psi	Air	UD
3 NPS	4 NPS	7.39 in ²	3.067 in	1.755 in	15-720 psi	Air	UD
4 NPS	6 NPS	12.73 in ²	4.026 in	2.084 in	15-720 psi	Air	UD
6 NPS	8, 10 NPS	28.89 in ²	6.065 in	2.61 in	15-275 psi	Air	UD
8 NPS	10 NPS	50.03 in ²	7.981 in	3.304 in	15-275 psi	Air	UD

Design Name:	BPAV (Liquid)	NBCert #	77970
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/19/2029

Design Type

[Buckling Pin Non-reclosing Device] BPAV (Liquid)
Capacity Tests: Sec. UD at National Board Testing Lab on May 3, 2012
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.686 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: Nozzle/Full Lift
Designed by: BS&B Premco LLC {PRL}
Comments: Lifts listed are required total travel.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5 NPS	0.72 in ²	0.957 in	0.912 in	2100-3500 psi	Water	UD
1 NPS	1.5 NPS	0.86 in ²	1.046 in	0.912 in	50-2100 psi	Water	UD
1.5 NPS	2 NPS	2.04 in ²	1.612 in	1.051 in	15-1440 psi	Water	UD
2 NPS	3 NPS	3.36 in ²	2.067 in	1.257 in	15-720 psi	Water	UD
3 NPS	4 NPS	7.39 in ²	3.067 in	1.755 in	15-720 psi	Water	UD
4 NPS	6 NPS	12.73 in ²	4.026 in	2.084 in	15-720 psi	Water	UD
6 NPS	8, 10 NPS	28.89 in ²	6.065 in	2.61 in	15-275 psi	Water	UD
8 NPS	10 NPS	50.03 in ²	7.981 in	3.304 in	15-275 psi	Water	UD

Design Name:	BPCV (Air/Gas)	NBCert #	78386
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/27/2030

Design Type

[Buckling Pin Non-reclosing Device] BPCV (Air/Gas)
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 12, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.706 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: Nozzle/Full Lift
Designed by: BS&B Premco LLC {PRL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1 NPS	0.72 in ²	0.957 in	0.371 in	2101-3500 psi	Air	UD
1 NPS	1 NPS	0.86 in ²	1.05 in	0.371 in	15-2100 psi	Air	UD
1.5 NPS	1.5 NPS	2.04 in ²	1.61 in	0.547 in	15-1440 psi	Air	UD
2 NPS	2 NPS	3.36 in ²	2.07 in	0.703 in	15-720 psi	Air	UD
3 NPS	3 NPS	7.39 in ²	3.07 in	1.016 in	15-720 psi	Air	UD
4 NPS	4 NPS	12.73 in ²	4.03 in	1.328 in	15-720 psi	Air	UD
6 NPS	6 NPS	28.89 in ²	6.07 in	1.953 in	15-275 psi	Air	UD
8 NPS	8 NPS	50.03 in ²	7.981 in	2.656 in	15-275 psi	Air	UD
10 NPS	10 NPS	78.81 in ²	10.02 in	3.281 in	15-275 psi	Air	UD
12 NPS	12 NPS	113.04 in ²	12 in	3.906 in	15-275 psi	Air	UD
14 NPS	14 NPS	137.81 in ²	13.25 in	4.297 in	15-275 psi	Air	UD

Design Name: BPCV (Liquid) NBCert # 78397

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/16/2030

Design Type

[Buckling Pin Non-reclosing Device] BPCV (Liquid)
Capacity Tests: Sec. UD at National Board Testing Lab on June 4, 2018
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.617 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: Nozzle/Full Lift
Designed by: BS&B Premco LLC {PRL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1 NPS	0.72 in ²	0.957 in	0.371 in	2101-3500 psi	Water	UD
1 NPS	1 NPS	0.86 in ²	1.05 in	0.371 in	15-2100 psi	Water	UD
1.5 NPS	1.5 NPS	2.04 in ²	1.61 in	0.547 in	15-1440 psi	Water	UD
2 NPS	2 NPS	3.36 in ²	2.07 in	0.703 in	15-720 psi	Water	UD
3 NPS	3 NPS	7.39 in ²	3.07 in	1.016 in	15-720 psi	Water	UD
4 NPS	4 NPS	12.73 in ²	4.03 in	1.328 in	15-720 psi	Water	UD
6 NPS	6 NPS	28.89 in ²	6.07 in	1.953 in	15-275 psi	Water	UD
8 NPS	8 NPS	50.03 in ²	7.981 in	2.656 in	15-275 psi	Water	UD
10 NPS	10 NPS	78.81 in ²	10.02 in	3.281 in	15-275 psi	Water	UD
12 NPS	12 NPS	113.04 in ²	12 in	3.906 in	15-275 psi	Water	UD
14 NPS	14 NPS	137.81 in ²	13.25 in	4.297 in	15-275 psi	Water	UD

Design Name: BPCV LP (Air) NBCert # 78498

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	11/17/2026

Design Type

[Buckling Pin Non-reclosing Device] BPCV LP (Air)
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 21, 2020
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 2.310 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: MNFA
Designed by: BS&B Premco LLC {PRL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
6 NPS	6 NPS	28.89 in ²	6.067 in	3.5 in	1-15 psi	Air	UD
8 NPS	8 NPS	50 in ²	7.981 in	4.62 in	1-15 psi	Air	UD
10 NPS	10 NPS	78.81 in ²	10.02 in	5.833 in	1-15 psi	Air	UD
12 in	12 in	113.04 in ²	12 in	6.986 in	1-15 psi	Air	UD
14 NPS	14 NPS	137.82 in ²	13.25 in	7.714 in	1-15 psi	Air	UD
16 NPS	16 NPS	182.56 in ²	15.25 in	8.878 in	1-15 psi	Air	UD
18 NPS	18 NPS	233.59 in ²	17.25 in	10.042 in	1-15 psi	Air	UD
20 NPS	20 NPS	290.89 in ²	19.25 in	11.207 in	1-15 psi	Air	UD
24 NPS	24 NPS	424.34 in ²	23.25 in	13.536 in	1-15 psi	Air	UD
30 NPS	30 NPS	617.62 in ²	29.25 in	17.029 in	1-15 psi	Air	UD

Design Name: BPPV

NBCert # 77992

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

06/19/2030

Design Type

[Buckling Pin Non-reclosing Device] BPPV
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on December 20, 2011
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 2.200 Unitless; Certification Provisions: Exceeds Lab Limits (Prev. CC 2397)
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: Nozzle/Full Lift
Designed by: BS&B Premco LLC {PRL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
6-6 NPS	6 NPS	28.27 in ²	6 in	3 in	15-275 psi	Air	UD
8-8 NPS	8 NPS	49.02 in ²	7.9 in	3.95 in	15-275 psi	Air	UD
10-10 NPS	10 NPS	77.32 in ²	9.92 in	4.96 in	15-275 psi	Air	UD
12-12 NPS	12 NPS	110.85 in ²	11.88 in	5.94 in	15-275 psi	Air	UD
14-14 NPS	14 NPS	135.1 in ²	13.12 in	6.56 in	15-275 psi	Air	UD
16-16 NPS	16 NPS	179 in ²	15.1 in	7.55 in	15-275 psi	Air	UD
18-18 NPS	18 NPS	229 in ²	17.08 in	8.54 in	15-275 psi	Air	UD
20-20 NPS	20 NPS	285.2 in ²	19.06 in	9.53 in	15-275 psi	Air	UD
22-22 NPS	22 NPS	347.5 in ²	21.04 in	10.52 in	15-275 psi	Air	UD
24-24 NPS	24 NPS	416.1 in ²	23.02 in	11.51 in	15-275 psi	Air	UD
26-26 NPS	26 NPS	490.6 in ²	25 in	12.5 in	15-275 psi	Air	UD
28-28 NPS	28 NPS	571.5 in ²	26.98 in	13.49 in	15-275 psi	Air	UD

30-30 NPS	30 NPS	658.4 in ²	28.96 in	14.48 in	15-275 psi	Air	UD
32-32 NPS	32 NPS	751.5 in ²	30.94 in	15.47 in	15-100 psi	Air	UD
34-34 NPS	34 NPS	850.8 in ²	32.92 in	16.46 in	15-100 psi	Air	UD
36-36 NPS	36 NPS	956.2 in ²	34.9 in	17.45 in	15-100 psi	Air	UD
38-38 NPS	38 NPS	1067.8 in ²	36.88 in	18.44 in	15-100 psi	Air	UD
40-40 NPS	40 NPS	1185.6 in ²	38.86 in	19.43 in	15-100 psi	Air	UD
42-42 NPS	42 NPS	1309.5 in ²	40.84 in	20.42 in	15-100 psi	Air	UD
44-44 NPS	44 NPS	1439.5 in ²	42.82 in	21.41 in	15-100 psi	Air	UD
46-46 NPS	46 NPS	1575.7 in ²	44.8 in	22.4 in	15-100 psi	Air	UD
48-48 NPS	48 NPS	1718.1 in ²	46.78 in	23.39 in	15-100 psi	Air	UD
50-50 NPS	50 NPS	1866.6 in ²	48.76 in	24.38 in	15-100 psi	Air	UD
52-52 NPS	52 NPS	2021.3 in ²	50.74 in	25.37 in	15-100 psi	Air	UD
54-54 NPS	54 NPS	2182.1 in ²	52.72 in	26.36 in	15-100 psi	Air	UD
56-56 NPS	56 NPS	2349.1 in ²	54.7 in	27.35 in	15-100 psi	Air	UD
58-58 NPS	58 NPS	2522.3 in ²	56.68 in	28.34 in	15-100 psi	Air	UD
60-60 NPS	60 NPS	2701.6 in ²	58.66 in	29.33 in	15-100 psi	Air	UD
62-62 NPS	62 NPS	2887.1 in ²	60.64 in	30.32 in	15-100 psi	Air	UD
64-64 NPS	64 NPS	3078.7 in ²	62.63 in	31.31 in	15-100 psi	Air	UD
66-66 NPS	66 NPS	3276.5 in ²	64.61 in	32.3 in	15-100 psi	Air	UD
68-68 NPS	68 NPS	3480.4 in ²	66.59 in	33.29 in	15-100 psi	Air	UD
70-70 NPS	70 NPS	3690.5 in ²	68.57 in	34.28 in	15-100 psi	Air	UD
72-72 NPS	72 NPS	3906.7 in ²	70.55 in	35.27 in	15-100 psi	Air	UD
74-74 NPS	74 NPS	4129.1 in ²	72.53 in	36.26 in	15-100 psi	Air	UD
76-76 NPS	76 NPS	4357.7 in ²	74.51 in	37.25 in	15-100 psi	Air	UD
78-78 NPS	78 NPS	4592.4 in ²	76.49 in	38.24 in	15-100 psi	Air	UD
80-80 NPS	80 NPS	4833.3 in ²	78.47 in	39.23 in	15-100 psi	Air	UD
82-82 NPS	82 NPS	5080.3 in ²	80.45 in	40.22 in	15-100 psi	Air	UD
84-84 NPS	84 NPS	5333.5 in ²	82.43 in	41.41 in	15-100 psi	Air	UD
86-86 NPS	86 NPS	5592.9 in ²	84.41 in	42.2 in	15-100 psi	Air	UD
88-88 NPS	88 NPS	5858.4 in ²	86.39 in	43.19 in	15-100 psi	Air	UD
90-90 NPS	90 NPS	6130 in ²	88.37 in	44.18 in	15-100 psi	Air	UD
92-92 NPS	92 NPS	6407.8 in ²	90.35 in	45.17 in	15-100 psi	Air	UD
94-94 NPS	94 NPS	6691.8 in ²	92.33 in	46.16 in	15-100 psi	Air	UD
96-96 NPS	96 NPS	6981.9 in ²	94.31 in	47.15 in	15-100 psi	Air	UD

Design Name: BPRV, BPIV, TOV

NBCert # 77813

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	04/24/2030

Design Type

[Buckling Pin Non-reclosing Device] BPRV, BPIV, TOV

Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on April 12, 2004

Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl

Certified Value: 1.220 Unitless

Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)

Set Pressure Definition: Buckling Pressure

Flow Area Configuration: MNFA

Designed by: BS&B Premco LLC {PRL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS		62.48 in ²			1-2250 psi		UD
12 NPS		90.5 in ²			1-2250 psi		UD
14 NPS		109 in ²			1-1440 psi		UD
16 NPS		149 in ²			1-1440 psi		UD
18 NPS		196.2 in ²			1-1440 psi		UD
2 NPS		2.75 in ²			15-3700 psi		UD
20 NPS		239.1 in ²			1-720 psi		UD
24 NPS		367.6 in ²			1-720 psi		UD
26 NPS		400.6 in ²			1-720 psi		UD
28 NPS		466.8 in ²			1-720 psi		UD
3 NPS		6 in ²			15-3700 psi		UD
30 NPS		601 in ²			1-720 psi		UD
32 NPS		614 in ²			1-720 psi		UD
34 NPS		695 in ²			1-720 psi		UD
36 NPS		781 in ²			1-720 psi		UD
38 NPS		872 in ²			1-720 psi		UD
4 NPS		10 in ²			15-2250 psi		UD
40 NPS		968 in ²			1-720 psi		UD
42 NPS		1069 in ²			1-720 psi		UD
44 NPS		1175 in ²			1-720 psi		UD
46 NPS		1286 in ²			1-160 psi		UD
48 NPS		1403 in ²			1-160 psi		UD
50 NPS		1524 in ²			1-160 psi		UD
52 NPS		1650 in ²			1-160 psi		UD
54 NPS		1784 in ²			1-160 psi		UD
56 NPS		1918 in ²			1-160 psi		UD
58 NPS		2059.4 in ²			1-160 psi		UD
6 NPS		23.5 in ²			1-2250 psi		UD
60 NPS		2206 in ²			1-160 psi		UD
62 NPS		2357 in ²			1-160 psi		UD
64 NPS		2514 in ²			1-160 psi		UD
66 NPS		2675 in ²			1-160 psi		UD
68 NPS		2842 in ²			1-160 psi		UD
70 NPS		3013 in ²			1-160 psi		UD

72 NPS		3190 in ²			1-160 psi	UD
74 NPS		3371 in ²			1-160 psi	UD
76 NPS		3558 in ²			1-160 psi	UD
78 NPS		3750 in ²			1-160 psi	UD
8 NPS		39.65 in ²			1-2250 psi	UD
80 NPS	NPS	3946 in ²	0 in	0 in	1-160 psi	UD
82 NPS	NPS	4148 in ²	0 in	0 in	1-160 psi	UD
84 NPS	NPS	4355 in ²	0 in	0 in	1-160 psi	UD
86 NPS	NPS	4566 in ²	0 in	0 in	1-160 psi	UD
88 NPS	NPS	4783 in ²	0 in	0 in	1-160 psi	UD
90 NPS	NPS	5005 in ²	0 in	0 in	1-160 psi	UD
92 NPS	NPS	5232 in ²	0 in	0 in	1-160 psi	UD
94 NPS	NPS	5464 in ²	0 in	0 in	1-160 psi	UD
96 NPS	NPS	5700 in ²	0 in	0 in	1-160 psi	UD

Design Name:	EORV	NBCert #	78218
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/27/2030

Design Type

[Buckling Pin Non-reclosing Device] EORV
Capacity Tests: Sec. UD at National Board Testing Lab on June 4, 2018
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.164 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: Nozzle/Full Lift
Designed by: BS&B Premco LLC {PRL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.8125 in	.8125 in	0.049 in ²	0.25 in	0.9 in	5000-20000 psi	Water	UD

Design Name:	IDV	NBCert #	78409
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/26/2030

Design Type

[Safety Relief Valve] IDV
Capacity Tests: Sec. UV at BS & B Safety Systems, LLC on August 31, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.700 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: BS&B Premco LLC {PRL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1 NPS	0.66 in ²			15-500 psi	Air	UV
1.5 NPS	1.5 NPS	1.59 in ²			15-500 psi	Air	UV

10 NPS	10 NPS	64.78 in ²	15-500 psi	Air	UV
2 NPS	2 NPS	2.69 in ²	15-500 psi	Air	UV
3 NPS	3 NPS	5.95 in ²	15-500 psi	Air	UV
4 NPS	4 NPS	10.4 in ²	15-500 psi	Air	UV
6 NPS	6 NPS	23.52 in ²	15-500 psi	Air	UV
8 NPS	8 NPS	41.27 in ²	15-500 psi	Air	UV

Design Name:	MRB	NBCert #	77824
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	03/28/2031

Design Type

[Rupture Disk Device] MRB
HolderDesignation: N/A
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on May 5, 2004
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 5.300 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.29 in		0.046 in ²			4300-55000 psi		UD
0.3 in		0.05 in ²			4300-55000 psi		UD
0.375 NPS		0.08 in ²			4300-55000 psi		UD
0.5 NPS		0.14 in ²			3800-54000 psi		UD
0.625 NPS		0.22 in ²			3500-52000 psi		UD
0.75 NPS		0.31 in ²			2900-49000 psi		UD
0.875 in		0.52 in ²			2900-49000 psi		UD
1 NPS		0.55 in ²			2500-43000 psi		UD
1.125 in		0.69 in ²			2500-43000 psi		UD
1.25 NPS		0.86 in ²			2500-43000 psi		UD
1.5 NPS		1.24 in ²			1900-35000 psi		UD
10 NPS		55 in ²			400-12000 psi		UD
2 NPS		2.2 in ²			1800-29000 psi		UD
3 NPS		4.5 in ²			1500-21000 psi		UD
3.25 in		5.2 in ²			1500-21000 psi		UD
4 NPS		8.8 in ²			1500-16000 psi		UD
6 NPS		19.8 in ²			1000-14000 psi		UD
8 NPS		35.2 in ²			600-14000 psi		UD

Design Name:	RDV-HP	NBCert #	79017
--------------	--------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	06/09/2026

Design Type

[Safety Relief Valve] RDV-HP
Capacity Tests: Sec. UV at National Board Testing Lab on March 20, 2014
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:3261.0 SCFM
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: BS&B Premco LLC {PRL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS	3 NPS	4.345 in ²	2.352 in	0.384 in	50-50 psi	Air	UV

BS&B SAFETY SYSTEMS (INDIA) LIMITED (BIN)

Chennai, Tamil Nadu, 600097India

This Company Manufactures or Assembles:

Design Name: B, BR, BRR (liquid) NBCert # 77318

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	08/26/2027

Design Type

[Rupture Disk Device] B, BR, BRR (liquid)
HolderDesignation: FA-7R, FA-1 - FA9, UA-2,3,5,6
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 12, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 1.470 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.189 in ²			80-30000 psi		UD
1 NPS		0.801 in ²			40-12000 psi		UD
1.5 NPS		1.76 in ²			26-6000 psi		UD
10 NPS		78.85 in ²			4-1400 psi		UD
12 NPS		112.5 in ²			4-1000 psi		UD
14 NPS		137.9 in ²			3-750 psi		UD
16 NPS		182.7 in ²			3-500 psi		UD
18 NPS		233.7 in ²			3-475 psi		UD
2 NPS		3.33 in ²			16-6000 psi		UD
20 NPS		291 in ²			2-450 psi		UD
24 NPS		424.6 in ²			2-230 psi		UD
3 NPS		6.514 in ²			12-6000 psi		UD
30 NPS		672 in ²			2-184 psi		UD
32 NPS		767 in ²			2-181 psi		UD

36 NPS	976 in ²	6-160 psi	UD
4 NPS	11.82 in ²	9-6000 psi	UD
40 NPS	1210 in ²	6-145 psi	UD
42 NPS	1336 in ²	3-138 psi	UD
44 NPS	1469 in ²	6-132 psi	UD
6 NPS	28.84 in ²	7-3600 psi	UD
8 NPS	49.89 in ²	5-3600 psi	UD

Design Name:	B, BR, BRR, Welded B	NBCert #	77037
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/14/2028

Design Type

[Rupture Disk Device] B, BR, BRR, Welded B
 HolderDesignation: FA-7R, FA1,2,3,4,5,6,7,8,9,UA-2,3,5,6
 Capacity Tests: Sec. UD at National Board Testing Lab on September 15, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.710 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.189 in ²			80-30000 psi		UD
0.725 in		0.34 in ²			900-20000 psi		UD
1 NPS		0.801 in ²			40-12000 psi		UD
1.5 NPS		1.76 in ²			26-6000 psi	Air	UD
10 NPS		78.85 in ²			4-1400 psi		UD
12 NPS		112.5 in ²			4-1000 psi		UD
14 NPS		137.9 in ²			3-750 psi		UD
16 NPS		182.7 in ²			3-500 psi		UD
18 NPS		233.7 in ²			3-475 psi		UD
2 NPS		3.33 in ²			16-6000 psi		UD
20 NPS		291 in ²			2-450 psi		UD
24 NPS		424.6 in ²			2-230 psi		UD
3 NPS		6.514 in ²			12-6000 psi		UD
30 NPS		672 in ²			2-184 psi		UD
32 NPS		767 in ²			2-181 psi		UD
36 NPS		976 in ²			6-160 psi		UD
4 NPS		11.82 in ²			9-6000 psi		UD
40 NPS		1210 in ²			6-145 psi		UD
42 NPS		1336 in ²			6-138 psi		UD
44 NPS		1469 in ²			6-132 psi		UD
6 NPS		28.84 in ²			7-3600 psi		UD
8 NPS		49.9 in ²			5-3600 psi		UD

Design Name:	BV, BRV, BSV, BRSV	NBCert #	77026
--------------	--------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/14/2028

Design Type

[Rupture Disk Device] BV, BRV, BSV, BRSV
HolderDesignation: FA-7R, FA-7,FA-1,2,3,4,5,6,7,8,9,UA-2,3,5,6
Capacity Tests: Sec. UD at National Board Testing Lab on July 13, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.800 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.57 in ²			145-12000 psi	Air	UD
1.5 NPS		1.44 in ²			95-6000 psi	Air	UD
10 NPS		70.88 in ²			14-1400 psi		UD
12 NPS		101.5 in ²			12-1000 psi		UD
14 NPS		130.3 in ²			11-750 psi		UD
16 NPS		176.7 in ²			9-500 psi		UD
18 NPS		202.4 in ²			8-475 psi		UD
2 NPS		2.24 in ²			55-6000 psi	Air	UD
20 NPS		280 in ²			8-450 psi		UD
24 NPS		380.1 in ²			37-230 psi		UD
3 NPS		5.41 in ²			41-6000 psi		UD
30 NPS		615.7 in ²			20-184 psi		UD
32 NPS		728 in ²			31-181 psi		UD
36 NPS		927 in ²			28-160 psi		UD
4 NPS		9.62 in ²			31-6000 psi		UD
40 NPS		1149 in ²			25-145 psi		UD
42 NPS		1269 in ²			24-138 psi		UD
44 NPS		1395 in ²			23-132 psi		UD
6 NPS		23.76 in ²			23-3600 psi		UD
8 NPS		44.18 in ²			18-3600 psi		UD

Design Name:	BV,BRV,BSV,BRSV (liquid)	NBCert #	77273
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	08/26/2027

Design Type

[Rupture Disk Device] BV,BRV,BSV,BRSV (liquid)
 HolderDesignation: FA-7R, FA-1 - FA-9,UA-,3,5,6
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 1, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 2.450 Unitless
 Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.57 in ²			145-12000 psi		UD
1.5 NPS		1.44 in ²			95-6000 psi		UD
10 NPS		70.88 in ²			14-1400 psi		UD
12 NPS		101.5 in ²			12-1000 psi		UD
14 NPS		130.3 in ²			11-750 psi		UD
16 NPS		176.7 in ²			9-500 psi		UD
18 NPS		202.4 in ²			8-475 psi		UD
2 NPS		2.24 in ²			55-6000 psi		UD
20 NPS		280 in ²			8-450 psi		UD
24 NPS		380.1 in ²			37-230 psi		UD
3 NPS		5.41 in ²			41-6000 psi		UD
30 NPS		615.8 in ²			20-184 psi		UD
32 NPS		728 in ²			31-181 psi		UD
36 NPS		927 in ²			28-160 psi		UD
4 NPS		9.62 in ²			31-6000 psi		UD
40 NPS		1149 in ²			25-145 psi		UD
42 NPS		1269 in ²			24-138 psi		UD
44 NPS		1395 in ²			23-132 psi		UD
6 NPS		23.76 in ²			23-3600 psi		UD
8 NPS		44.18 in ²			18-3600 psi		UD

Design Name: DV, DRV, DSV, DRSV (liquids) NBCert # 77734

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	09/07/2025

Design Type

[Rupture Disk Device] DV, DRV, DSV, DRSV (liquids)
 HolderDesignation: FA-7R,FA-1F - FA-9F, UA-2,3,5,6, FF-*
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 11, 2002
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 2.600 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.57 in ²			44-2000 psi		UD

1.5 NPS	1.44 in ²	31-1400 psi	UD
10 NPS	70.88 in ²	4-480 psi	UD
12 NPS	101.5 in ²	3-1000 psi	UD
14 NPS	130.3 in ²	3-350 psi	UD
16 NPS	176.7 in ²	3-300 psi	UD
18 NPS	202.3 in ²	3-270 psi	UD
2 NPS	2.24 in ²	15-1100 psi	UD
20 NPS	280 in ²	3-240 psi	UD
24 NPS	380.1 in ²	3-200 psi	UD
28 NPS	584 in ²	3-170 psi	Air UD
3 NPS	5.41 in ²	11-900 psi	UD
30 NPS	615.7 in ²	3-170 psi	UD
32 NPS	728 in ²	3-170 psi	UD
36 NPS	927 in ²	3-170 psi	UD
4 NPS	9.62 in ²	8-830 psi	UD
40 NPS	1149 in ²	3-170 psi	UD
42 NPS	1269 in ²	3-170 psi	UD
44 NPS	1395 in ²	3-170 psi	UD
6 NPS	23.76 in ²	6-640 psi	UD
8 NPS	44.18 in ²	5-590 psi	UD

Design Name: GFN, GFA, XN, XN-85

NBCert # 77060

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UD

05/15/2029

Design Type

[Rupture Disk Device] GFN, GFA, XN, XN-85
 HolderDesignation: NF-7RS, NF-7R, NFI-7RS
 Capacity Tests: Sec. UD at National Board Testing Lab on December 18, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.550 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			113-1800 psi		UD
1.5 NPS		2.03 in ²			81-1800 psi		UD
10 NPS		78.8 in ²			45-1300 psi		UD
12 NPS		111.9 in ²			41-1100 psi		UD
14 NPS		137.9 in ²			37-750 psi		UD
16 NPS		176.7 in ²			35-270 psi		UD
18 NPS		223.3 in ²			33-240 psi		UD
2 NPS		3.36 in ²			68-1800 psi		UD
20 NPS		277.9 in ²			32-213 psi		UD

24 NPS	402 in ²	30-177 psi	UD
3 NPS	7.39 in ²	54-1600 psi	UD
4 NPS	12.7 in ²	45-1400 psi	UD
6 NPS	28.9 in ²	36-1400 psi	UD
8 NPS	50 in ²	53-1300 psi	UD

Design Name:	JRS	NBCert #	77015
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/26/2030

Design Type

[Rupture Disk Device] JRS
HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRI-7RS
Capacity Tests: Sec. UD at National Board Testing Lab on July 10, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.310 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			22-180 psi		UD
1.5 NPS		1.89 in ²			20-150 psi		UD
10 NPS		68.65 in ²			12-36 psi		UD
12 NPS		102.28 in ²			12-33 psi		UD
14 NPS		121.86 in ²			9-30 psi		UD
16 NPS		156 in ²			7-28 psi		UD
18 NPS		198 in ²			6-26 psi		UD
2 NPS		3.35 in ²			18-120 psi		UD
20 NPS		246 in ²			5-24 psi		UD
24 NPS		357 in ²			5-22 psi		UD
3 NPS		6.53 in ²			16-80 psi		UD
30 NPS		592 in ²			5-14 psi		UD
32 NPS		706.9 in ²			5-14 psi		UD
36 NPS		868 in ²			5-14 psi		UD
4 NPS		11.86 in ²			14-70 psi		UD
42 NPS		1111 in ²			5-14 psi		UD
6 NPS		25.08 in ²			12-50 psi		UD
8 NPS		42.07 in ²			12-42 psi		UD
28 NPS	NPS	513 in ²	0 in	0 in	5-18 psi		UD

Design Name:	RLS, RLS Welded Assembly (liquid)	NBCert #	77307
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/13/2028

Design Type

[Rupture Disk Device] RLS, RLS Welded Assembly (liquid)
 HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, S90-7R, S90-7R-TR, SMR-7R, SRI-7RS, SRB-7RS Special, SRB-QRS
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 16, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 5.830 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.5 in ²			300-6000 psi		UD
1 NPS		0.84 in ²			125-6000 psi		UD
1.5 NPS		1.77 in ²			85-5400 psi		UD
10 NPS		73.9 in ²			35-1200 psi		UD
12 NPS		99 in ²			35-900 psi		UD
14 NPS		131 in ²			35-650 psi		UD
16 NPS		172 in ²			25-550 psi		UD
18 NPS		219 in ²			25-450 psi		UD
2 NPS		3.23 in ²			70-4800 psi		UD
20 NPS		270 in ²			20-350 psi		UD
3 NPS		6.44 in ²			55-3800 psi		UD
4 NPS		11.54 in ²			45-2800 psi		UD
6 NPS		26.4 in ²			35-2000 psi		UD
8 NPS		47 in ²			35-1600 psi		UD

Design Name: RLS, RLS Welded Assembly NBCert # 77059

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	05/19/2026

Design Type

[Rupture Disk Device] RLS, RLS Welded Assembly
 HolderDesignation: SRB-7RS, SRB-7RS-TR, S90-7R, S90-7R-TR, SRB-7FS, SRB-7FR-TR, SMR-7R, SRI-7RS, SRB-7RS Special, SRB-QRS
 Capacity Tests: Sec. UD at National Board Testing Lab on August 12, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 1.140 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.5 in ²			300-2000 psi		UD
1 NPS		0.84 in ²			125-2200 psi		UD
1.5 NPS		1.77 in ²			85-1800 psi		UD
10 NPS		73.9 in ²			35-250 psi		UD
12 NPS		99 in ²			35-150 psi		UD
14 NPS		131 in ²			35-130 psi		UD
16 NPS		172 in ²			25-110 psi		UD

18 NPS	219 in ²	25-90 psi	UD
2 NPS	3.23 in ²	70-1800 psi	UD
20 NPS	270 in ²	20-90 psi	UD
3 NPS	6.44 in ²	55-1600 psi	UD
4 NPS	11.54 in ²	45-1500 psi	UD
6 NPS	26.4 in ²	35-650 psi	UD
8 NPS	47 in ²	35-400 psi	UD

Design Name:	S90, S90 Welded Assembly	NBCert #	77082
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 05/23/2029

Design Type

[Rupture Disk Device] S90, S90 Welded Assembly
 HolderDesignation: SRB-7RS, SRB-7RS-TR, S90-7R, S90-7R-TR, SMR-7R, SRB-7FS, SRB-7FS-TR, SRI-7RS, SRB-QRS
 Capacity Tests: Sec. UD at National Board Testing Lab on July 27, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 1.130 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			75-1000 psi		UD
1.5 NPS		2.03 in ²			54-1000 psi		UD
10 NPS		78.8 in ²			30-700 psi		UD
12 NPS		111 in ²			27-600 psi		UD
14 NPS		135 in ²			25-500 psi		UD
16 NPS		176 in ²			23-475 psi		UD
18 NPS		223 in ²			22-475 psi		UD
2 NPS		3.36 in ²			45-1000 psi		UD
20 NPS		277 in ²			20-250 psi		UD
24 NPS		402 in ²			18-250 psi		UD
28 NPS		583 in ²			20-250 psi		UD
3 NPS		7.39 in ²			36-1000 psi		UD
30 NPS		672 in ²			20-250 psi		UD
4 NPS		12.7 in ²			30-800 psi		UD
40 NPS	NPS	1195 in ²			20-250 psi	Air	UD
6 NPS		28.8 in ²			24-800 psi		UD
8 NPS		50 in ²			35-700 psi		UD

BS&B SAFETY SYSTEMS LTDA (BDD)

Nameplate Abbreviation: BS&B

Sao Paulo, 13350-000Brazil

This Company Manufactures or Assembles:

Design Name: BPAV (air/gas)		NBCert # 77981
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	07/09/2030

Design Type

[Buckling Pin Non-reclosing Device] BPAV (air/gas)
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 27, 2011
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.800 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: Nozzle/Full Lift & MNFA
Designed by: BS&B Premco LLC {PRL}
Comments: Lifts listed are required total travel.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5 NPS	0.72 in ²	0.957 in	0.912 in	2100-3500 psi	Air	UD
1 NPS	1.5 NPS	0.86 in ²	1.046 in	0.912 in	15-2100 psi	Air	UD
1.5 NPS	2 NPS	2.04 in ²	1.612 in	1.051 in	15-1440 psi	Air	UD
2 NPS	3 NPS	3.36 in ²	2.067 in	1.257 in	15-720 psi	Air	UD
3 NPS	4 NPS	7.39 in ²	3.067 in	1.755 in	15-720 psi	Air	UD
4 NPS	6 NPS	12.73 in ²	4.026 in	2.084 in	15-720 psi	Air	UD
6 NPS	8, 10 NPS	28.89 in ²	6.065 in	2.61 in	15-275 psi	Air	UD
8 NPS	10 NPS	50.03 in ²	7.981 in	3.304 in	15-275 psi	Air	UD

Design Name: BPAV (Liquid)		NBCert # 77970
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	07/09/2030

Design Type

[Buckling Pin Non-reclosing Device] BPAV (Liquid)
Capacity Tests: Sec. UD at National Board Testing Lab on May 3, 2012
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.686 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: Nozzle/Full Lift
Designed by: BS&B Premco LLC {PRL}
Comments: Lifts listed are required total travel.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5 NPS	0.72 in ²	0.957 in	0.912 in	2100-3500 psi	Water	UD
1 NPS	1.5 NPS	0.86 in ²	1.046 in	0.912 in	50-2100 psi	Water	UD

1.5 NPS	2 NPS	2.04 in ²	1.612 in	1.051 in	15-1440 psi	Water	UD
2 NPS	3 NPS	3.36 in ²	2.067 in	1.257 in	15-720 psi	Water	UD
3 NPS	4 NPS	7.39 in ²	3.067 in	1.755 in	15-720 psi	Water	UD
4 NPS	6 NPS	12.73 in ²	4.026 in	2.084 in	15-720 psi	Water	UD
6 NPS	8, 10 NPS	28.89 in ²	6.065 in	2.61 in	15-275 psi	Water	UD
8 NPS	10 NPS	50.03 in ²	7.981 in	3.304 in	15-275 psi	Water	UD

Design Name: BPCV (Air/Gas) NBCert # 78386

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/10/2030

Design Type

[Buckling Pin Non-reclosing Device] BPCV (Air/Gas)
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 12, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.706 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: Nozzle/Full Lift
Designed by: BS&B Premco LLC {PRL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1 NPS	0.72 in ²	0.957 in	0.371 in	2101-3500 psi	Air	UD
1 NPS	1 NPS	0.86 in ²	1.05 in	0.371 in	15-2100 psi	Air	UD
1.5 NPS	1.5 NPS	2.04 in ²	1.61 in	0.547 in	15-1440 psi	Air	UD
2 NPS	2 NPS	3.36 in ²	2.07 in	0.703 in	15-720 psi	Air	UD
3 NPS	3 NPS	7.39 in ²	3.07 in	1.016 in	15-720 psi	Air	UD
4 NPS	4 NPS	12.73 in ²	4.03 in	1.328 in	15-720 psi	Air	UD
6 NPS	6 NPS	28.89 in ²	6.07 in	1.953 in	15-275 psi	Air	UD
8 NPS	8 NPS	50.03 in ²	7.981 in	2.656 in	15-275 psi	Air	UD
10 NPS	10 NPS	78.81 in ²	10.02 in	3.281 in	15-275 psi	Air	UD
12 NPS	12 NPS	113.04 in ²	12 in	3.906 in	15-275 psi	Air	UD
14 NPS	14 NPS	137.81 in ²	13.25 in	4.297 in	15-275 psi	Air	UD

Design Name: BPCV (Liquid) NBCert # 78397

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/10/2030

Design Type

[Buckling Pin Non-reclosing Device] BPCV (Liquid)
Capacity Tests: Sec. UD at National Board Testing Lab on June 4, 2018
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.617 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: Nozzle/Full Lift
Designed by: BS&B Premco LLC {PRL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1 NPS	0.72 in ²	0.957 in	0.371 in	2101-3500 psi	Water	UD
1 NPS	1 NPS	0.86 in ²	1.05 in	0.371 in	15-2100 psi	Water	UD
1.5 NPS	1.5 NPS	2.04 in ²	1.61 in	0.547 in	15-1440 psi	Water	UD
2 NPS	2 NPS	3.36 in ²	2.07 in	0.703 in	15-720 psi	Water	UD
3 NPS	3 NPS	7.39 in ²	3.07 in	1.016 in	15-720 psi	Water	UD
4 NPS	4 NPS	12.73 in ²	4.03 in	1.328 in	15-720 psi	Water	UD
6 NPS	6 NPS	28.89 in ²	6.07 in	1.953 in	15-275 psi	Water	UD
8 NPS	8 NPS	50.03 in ²	7.981 in	2.656 in	15-275 psi	Water	UD
10 NPS	10 NPS	78.81 in ²	10.02 in	3.281 in	15-275 psi	Water	UD
12 NPS	12 NPS	113.04 in ²	12 in	3.906 in	15-275 psi	Water	UD
14 NPS	14 NPS	137.81 in ²	13.25 in	4.297 in	15-275 psi	Water	UD

Design Name:	BPRV, BPIV, TOV	NBCert #	77813
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	09/10/2030

Design Type

[Buckling Pin Non-reclosing Device] BPRV, BPIV, TOV
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on April 12, 2004
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 1.220 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: MNFA
Designed by: BS&B Premco LLC {PRL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS		62.48 in ²			1-2250 psi		UD
12 NPS		90.5 in ²			1-2250 psi		UD
14 NPS		109 in ²			1-1440 psi		UD
16 NPS		149 in ²			1-1440 psi		UD
18 NPS		196.2 in ²			1-1440 psi		UD
2 NPS		2.75 in ²			15-3700 psi		UD
20 NPS		239.1 in ²			1-720 psi		UD
24 NPS		367.6 in ²			1-720 psi		UD
26 NPS		400.6 in ²			1-720 psi		UD
28 NPS		466.8 in ²			1-720 psi		UD
3 NPS		6 in ²			15-3700 psi		UD
30 NPS		601 in ²			1-720 psi		UD
32 NPS		614 in ²			1-720 psi		UD
34 NPS		695 in ²			1-720 psi		UD
36 NPS		781 in ²			1-720 psi		UD
38 NPS		872 in ²			1-720 psi		UD

4 NPS		10 in ²			15-2250 psi	UD
40 NPS		968 in ²			1-720 psi	UD
42 NPS		1069 in ²			1-720 psi	UD
44 NPS		1175 in ²			1-720 psi	UD
46 NPS		1286 in ²			1-160 psi	UD
48 NPS		1403 in ²			1-160 psi	UD
50 NPS		1524 in ²			1-160 psi	UD
52 NPS		1650 in ²			1-160 psi	UD
54 NPS		1784 in ²			1-160 psi	UD
56 NPS		1918 in ²			1-160 psi	UD
58 NPS		2059.4 in ²			1-160 psi	UD
6 NPS		23.5 in ²			1-2250 psi	UD
60 NPS		2206 in ²			1-160 psi	UD
62 NPS		2357 in ²			1-160 psi	UD
64 NPS		2514 in ²			1-160 psi	UD
66 NPS		2675 in ²			1-160 psi	UD
68 NPS		2842 in ²			1-160 psi	UD
70 NPS		3013 in ²			1-160 psi	UD
72 NPS		3190 in ²			1-160 psi	UD
74 NPS		3371 in ²			1-160 psi	UD
76 NPS		3558 in ²			1-160 psi	UD
78 NPS		3750 in ²			1-160 psi	UD
8 NPS		39.65 in ²			1-2250 psi	UD
80 NPS	NPS	3946 in ²	0 in	0 in	1-160 psi	UD
82 NPS	NPS	4148 in ²	0 in	0 in	1-160 psi	UD
84 NPS	NPS	4355 in ²	0 in	0 in	1-160 psi	UD
86 NPS	NPS	4566 in ²	0 in	0 in	1-160 psi	UD
88 NPS	NPS	4783 in ²	0 in	0 in	1-160 psi	UD
90 NPS	NPS	5005 in ²	0 in	0 in	1-160 psi	UD
92 NPS	NPS	5232 in ²	0 in	0 in	1-160 psi	UD
94 NPS	NPS	5464 in ²	0 in	0 in	1-160 psi	UD
96 NPS	NPS	5700 in ²	0 in	0 in	1-160 psi	UD

Design Name:	GCR-S, SE, SM, SS, SES, SMS, SME, SMES, SW, N, NS			NBCert #	77611
Manufacturer/Assembler		Designators			Expiration Date
Manufacturer		UD			08/15/2028

Design Type

[Rupture Disk Device] GCR-S, SE, SM, SS, SES, SMS, SME, SMES, SW, N, NS
HolderDesignation: GR-C, FM-C, not req'd for -SM
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on November 22, 2000
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 1.950 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		1.5 in ²			10-300 psi	Air	UD
3 NPS		5.29 in ²			10-175 psi		UD
4 NPS		9.78 in ²			10-150 psi		UD
6 NPS		22.5 in ²			10-75 psi		UD
48.3 DN	DN	2.38 in ²	0 in	0 in	10-300 psi		UD
60.3 DN	DN	3.85 in ²	0 in	0 in	10-175 psi		UD
76.1 DN	DN	6.33 in ²	0 in	0 in	10-175 psi		UD

Design Name: GCR-S, SE, SM, SS, SES, SMS, SME, SMES, SW, N, NS (liquids) NBCert # 78195

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	08/16/2028

Design Type

[Rupture Disk Device] GCR-S, SE, SM, SS, SES, SMS, SME, SMES, SW, N, NS (liquids)
HolderDesignation: GR-C, FM-C (not req'd for SM)
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 5, 2015
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 2.750 Unitless
Media - Test: Air/Gas, Water/Liquid (Krl test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		1.5 in ²			10-300 psi		UD
3 NPS		5.29 in ²			10-175 psi		UD
4 NPS		9.78 in ²			10-150 psi		UD
6 NPS		22.5 in ²			10-75 psi		UD
48.3 DN	DN	2.38 in ²	0 in	0 in	10-300 psi		UD
60.3 DN	DN	3.85 in ²	0 in	0 in	10-300 psi		UD
76.1 DN	DN	6.33 in ²	0 in	0 in	10-300 psi		UD

Design Name: GCR-S,SE,SM,SS,SES,SMS, SME, SMES, SW, N, NS (2" liquids) NBCert # 78207

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	08/16/2028

Design Type

[Rupture Disk Device] GCR-S,SE,SM,SS,SES,SMS, SME, SMES, SW, N, NS (2" liquids)
HolderDesignation: GR-C, FM-C, not req'd for -SM
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 25, 2015
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krl
Certified Value: 1.420 Unitless
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		2.7 in ²			10-300 psi	Water	UD

Design Name: GCR-S,SE,SM,SS,SES,SMS, SME, SMES, SW, N, NS (2") NBCert # 77420

Manufacturer/Assembler

Manufacturer

Designators

UD

Expiration Date

08/17/2028

Design Type

[Rupture Disk Device] GCR-S,SE,SM,SS,SES,SMS, SME, SMES, SW, N, NS (2")
HolderDesignation: GR-C, FM-C, not req'd for -SM
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on January 10, 2000
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 1.250 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		2.7 in ²			10-300 psi	Air	UD

Design Name: GFN, GFA, XN, XN-85 NBCert # 77060

Manufacturer/Assembler

Manufacturer

Designators

UD

Expiration Date

10/06/2028

Design Type

[Rupture Disk Device] GFN, GFA, XN, XN-85
HolderDesignation: NF-7RS, NF-7R, NFI-7RS
Capacity Tests: Sec. UD at National Board Testing Lab on December 18, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.550 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			113-1800 psi		UD
1.5 NPS		2.03 in ²			81-1800 psi		UD
10 NPS		78.8 in ²			45-1300 psi		UD
12 NPS		111.9 in ²			41-1100 psi		UD
14 NPS		137.9 in ²			37-750 psi		UD
16 NPS		176.7 in ²			35-270 psi		UD

18 NPS	223.3 in ²	33-240 psi	UD
2 NPS	3.36 in ²	68-1800 psi	UD
20 NPS	277.9 in ²	32-213 psi	UD
24 NPS	402 in ²	30-177 psi	UD
3 NPS	7.39 in ²	54-1600 psi	UD
4 NPS	12.7 in ²	45-1400 psi	UD
6 NPS	28.9 in ²	36-1400 psi	UD
8 NPS	50 in ²	53-1300 psi	UD

Design Name: JRS

NBCert # 77015

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	05/23/2030

Design Type

[Rupture Disk Device] JRS
 HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRI-7RS
 Capacity Tests: Sec. UD at National Board Testing Lab on July 10, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.310 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			22-180 psi		UD
1.5 NPS		1.89 in ²			20-150 psi		UD
10 NPS		68.65 in ²			12-36 psi		UD
12 NPS		102.28 in ²			12-33 psi		UD
14 NPS		121.86 in ²			9-30 psi		UD
16 NPS		156 in ²			7-28 psi		UD
18 NPS		198 in ²			6-26 psi		UD
2 NPS		3.35 in ²			18-120 psi		UD
20 NPS		246 in ²			5-24 psi		UD
24 NPS		357 in ²			5-22 psi		UD
3 NPS		6.53 in ²			16-80 psi		UD
30 NPS		592 in ²			5-14 psi		UD
32 NPS		706.9 in ²			5-14 psi		UD
36 NPS		868 in ²			5-14 psi		UD
4 NPS		11.86 in ²			14-70 psi		UD
42 NPS		1111 in ²			5-14 psi		UD
6 NPS		25.08 in ²			12-50 psi		UD
8 NPS		42.07 in ²			12-42 psi		UD
28 NPS	NPS	513 in ²	0 in	0 in	5-18 psi		UD

Design Name: LPS, LPS Welded Assembly		NBCert #	77745
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	08/15/2028
Design Type			
[Rupture Disk Device] LPS, LPS Welded Assembly HolderDesignation: SRB-7RS, SRB-7FS, SR-7R, SMR-7R, SRI-7RS, SRB-QRS, SRB-7RS-TR, SRB-7FS-TR & S90-7R-TR Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 20, 2002 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.790 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.59 in ²			15-70 psi		UD
1 NPS		0.86 in ²			15-70 psi		UD
1.5 NPS		1.93 in ²			6-55 psi		UD
10 NPS		78.86 in ²			5-25 psi		UD
12 NPS		111.87 in ²			5-25 psi	Air	UD
2 NPS		3.36 in ²			5-40 psi		UD
3 NPS		7.39 in ²			5-80 psi		UD
4 NPS		12.74 in ²			5-30 psi		UD
6 NPS		28.89 in ²			5-25 psi		UD
8 NPS		50 in ²			5-25 psi		UD

Design Name: LPS, LPS Welded Assembly (liquid)		NBCert #	77756
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	05/23/2030
Design Type			
[Rupture Disk Device] LPS, LPS Welded Assembly (liquid) HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SR-7R, SMR-7R, SRI-7RS, S90-7R-TR, SRB-QRS Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 20, 2002 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl Certified Value: 0.860 Unitless Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, Ltd. {BSI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	0.75 NPS	0.59 in ²			15-70 psi	Water	UD
1 NPS		0.86 in ²			15-70 psi		UD
1.5 NPS		1.93 in ²			6-55 psi		UD
10 NPS		78.86 in ²			5-25 psi		UD
12 NPS		111.87 in ²			5-25 psi	Water	UD
2 NPS		3.36 in ²			5-40 psi		UD

3 NPS	7.39 in ²	5-50 psi	UD
4 NPS	12.74 in ²	5-30 psi	UD
6 NPS	28.89 in ²	5-25 psi	UD
8 NPS	50 in ²	5-25 psi	UD

Design Name: RLS, RLS Welded Assembly (liquid) NBCert # 77307

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 08/16/2028

Design Type

[Rupture Disk Device] RLS, RLS Welded Assembly (liquid)
 HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, S90-7R, S90-7R-TR, SMR-7R, SRI-7RS, SRB-7RS Special, SRB-QRS
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 16, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 5.830 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.5 in ²			300-6000 psi		UD
1 NPS		0.84 in ²			125-6000 psi		UD
1.5 NPS		1.77 in ²			85-5400 psi		UD
10 NPS		73.9 in ²			35-1200 psi		UD
12 NPS		99 in ²			35-900 psi		UD
14 NPS		131 in ²			35-650 psi		UD
16 NPS		172 in ²			25-550 psi		UD
18 NPS		219 in ²			25-450 psi		UD
2 NPS		3.23 in ²			70-4800 psi		UD
20 NPS		270 in ²			20-350 psi		UD
3 NPS		6.44 in ²			55-3800 psi		UD
4 NPS		11.54 in ²			45-2800 psi		UD
6 NPS		26.4 in ²			35-2000 psi		UD
8 NPS		47 in ²			35-1600 psi		UD

Design Name: RLS, RLS Welded Assembly NBCert # 77059

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 08/15/2028

Design Type

[Rupture Disk Device] RLS, RLS Welded Assembly
 HolderDesignation: SRB-7RS, SRB-7RS-TR, S90-7R, S90-7R-TR, SRB-7FS, SRB-7FR-TR, SMR-7R, SRI-7RS, SRB-7RS Special, SRB-QRS
 Capacity Tests: Sec. UD at National Board Testing Lab on August 12, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 1.140 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.5 in ²			300-2000 psi		UD
1 NPS		0.84 in ²			125-2200 psi		UD
1.5 NPS		1.77 in ²			85-1800 psi		UD
10 NPS		73.9 in ²			35-250 psi		UD
12 NPS		99 in ²			35-150 psi		UD
14 NPS		131 in ²			35-130 psi		UD
16 NPS		172 in ²			25-110 psi		UD
18 NPS		219 in ²			25-90 psi		UD
2 NPS		3.23 in ²			70-1800 psi		UD
20 NPS		270 in ²			20-90 psi		UD
3 NPS		6.44 in ²			55-1600 psi		UD
4 NPS		11.54 in ²			45-1500 psi		UD
6 NPS		26.4 in ²			35-650 psi		UD
8 NPS		47 in ²			35-400 psi		UD

Design Name: S90, S90 Welded Assembly NBCert # 77082

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	08/16/2028

Design Type

[Rupture Disk Device] S90, S90 Welded Assembly
 HolderDesignation: SRB-7RS, SRB-7RS-TR, S90-7R, S90-7R-TR, SMR-7R, SRB-7FS, SRB-7FS-TR, SRI-7RS, SRB-QRS
 Capacity Tests: Sec. UD at National Board Testing Lab on July 27, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 1.130 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			75-1000 psi		UD
1.5 NPS		2.03 in ²			54-1000 psi		UD
10 NPS		78.8 in ²			30-700 psi		UD
12 NPS		111 in ²			27-600 psi		UD
14 NPS		135 in ²			25-500 psi		UD
16 NPS		176 in ²			23-475 psi		UD
18 NPS		223 in ²			22-475 psi		UD
2 NPS		3.36 in ²			45-1000 psi		UD
20 NPS		277 in ²			20-250 psi		UD
24 NPS		402 in ²			18-250 psi		UD
28 NPS		583 in ²			20-250 psi		UD
3 NPS		7.39 in ²			36-1000 psi		UD
30 NPS		672 in ²			20-250 psi		UD

4 NPS		12.7 in ²	30-800 psi		UD
40 NPS	NPS	1195 in ²	20-250 psi	Air	UD
6 NPS		28.8 in ²	24-800 psi		UD
8 NPS		50 in ²	35-700 psi		UD

Design Name:	SKR, SKR Welded Assembly	NBCert #	77161
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 08/29/2025

Design Type

[Rupture Disk Device] SKR, SKR Welded Assembly
HolderDesignation: SRB-7RS, SRB-7RS-TR, S90-7R, S90-7R-TR SRB-7FS, SRB-7FS-TR, SRI-7RS, SRB-QRS
Capacity Tests: Sec. UD at National Board Testing Lab on April 24, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.370 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.59 in ²			55-500 psi	Air	UD
1 NPS		0.86 in ²			55-500 psi		UD
1.5 NPS		2.04 in ²			40-500 psi		UD
10 NPS		78.86 in ²			11-150 psi		UD
12 NPS		117.87 in ²			9-110 psi		UD
2 NPS		3.36 in ²			25-550 psi		UD
3 NPS		7.39 in ²			20-500 psi		UD
4 NPS		12.74 in ²			16-500 psi		UD
6 NPS		28.89 in ²			15-261 psi		UD
8 NPS		50 in ²			15-200 psi		UD

Design Name:	SKR, SKR Welded Assmly (Liquids)	NBCert #	77329
--------------	----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 08/16/2028

Design Type

[Rupture Disk Device] SKR, SKR Welded Assmly (Liquids)
HolderDesignation: S90-7R, S90-7R-TR, SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SRI-7RS, SRB-QRS
Capacity Tests: Sec. UD at National Board Testing Lab on April 30, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 1.900 Unitless
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.59 in ²			55-500 psi	Water	UD
1 NPS		0.86 in ²			55-500 psi		UD

1.5 NPS	2.04 in²	40-500 psi	UD
10 NPS	78.86 in²	11-150 psi	UD
12 NPS	117.87 in²	9-110 psi	UD
2 NPS	3.36 in²	25-550 psi	UD
3 NPS	7.39 in²	20-500 psi	UD
4 NPS	12.74 in²	16-500 psi	UD
6 NPS	28.89 in²	15-261 psi	UD
8 NPS	50 in²	15-200 psi	UD

Caliber Valve and Controls LLC (CLV)

Nameplate Abbreviation: Caliber Valve & Controls

Lake Charles, LA 70615United States

This Company Manufactures or Assembles:

Design Name: 78 (Pilot Operated)		NBCert #	44053
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	01/08/2027
Design Type			
[Pilot Operated Pressure Relief Valve] 78 (Pilot Operated)			
Capacity Tests: Sec. UV at National Board Testing Lab on August 5, 1999			
Method of Establishing Relieving Capacity: Flow Capacity, K			
Certified Value: 0.878 Unitless			
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam			
Set Pressure Definition: Initial Audible Discharge			
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot			
Flow Area Configuration: Nozzle/Full Lift			
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.124 in²	[D] 0.398 in	0.53 in	26.1-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.124 in²	[D] 0.398 in	0.53 in	29-740 psi	Steam	UV
1-1.5 NPS	2 NPS	0.222 in²	[E] 0.531 in	0.53 in	26.1-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.222 in²	[E] 0.531 in	0.53 in	29-740 psi	Steam	UV
1-1.5 NPS	2 NPS	0.352 in²	[F] 0.669 in	0.53 in	26.1-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.352 in²	[F] 0.669 in	0.53 in	29-740 psi	Steam	UV
1.5-2 NPS	3 NPS	0.568 in²	[G] 0.85 in	0.7 in	26.1-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.568 in²	[G] 0.85 in	0.7 in	29-740 psi	Steam	UV
1.5-2 NPS	3 NPS	0.887 in²	[H] 1.063 in	0.7 in	26.1-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.887 in²	[H] 1.063 in	0.7 in	29-740 psi	Steam	UV
2-3 NPS	3,4 NPS	1.457 in²	[J] 1.362 in	0.8 in	26.1-6250 psi	Air	UV
2-3 NPS	3,4 NPS	1.457 in²	[J] 1.362 in	0.8 in	29-740 psi	Steam	UV
3 NPS	4 NPS	2.097 in²	[K] 1.634 in	1.18 in	26.1-3750 psi	Air	UV
3 NPS	4 NPS	2.097 in²	[K] 1.634 in	1.18 in	29-740 psi	Steam	UV
3-4 NPS	4,6 NPS	3.229 in²	[L] 2.028 in	1.18 in	26.1-3750 psi	Air	UV

3-4 NPS	4,6 NPS	3.229 in ²	[L] 2.028 in	1.18 in	29-740 psi	Steam	UV
4 NPS	6 NPS	4.095 in ²	[M] 2.284 in	1.57 in	26.1-3750 psi	Air	UV
4 NPS	6 NPS	4.095 in ²	[M] 2.284 in	1.57 in	29-740 psi	Steam	UV
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	1.57 in	26.1-3750 psi	Air	UV
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	1.57 in	29-740 psi	Steam	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.57 in	26.1-3750 psi	Air	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.57 in	29-740 psi	Steam	UV
6 NPS	8 NPS	12.915 in ²	[Q] 4.055 in	2.16 in	26.1-3750 psi	Air	UV
6 NPS	8 NPS	12.915 in ²	[Q] 4.055 in	2.16 in	29-740 psi	Steam	UV
6 NPS	8 NPS	15.904 in ²	[R] 4.5 in	2.16 in	26.1-1500 psi	Air	UV
6 NPS	8 NPS	15.904 in ²	[R] 4.5 in	2.16 in	29-740 psi	Steam	UV
8-8 NPS	10 NPS	28.274 in ²	[T] 6 in	2.99 in	26.1-1500 psi	Air	UV
8-8 NPS	10 NPS	28.274 in ²	[T] 6 in	2.99 in	29-740 psi	Steam	UV

Design Name:	9 Series	NBCert #	44019
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 05/18/2027

Design Type

[Safety Relief Valve] 9 Series
Capacity Tests: Sec. UV at National Board Testing Lab on July 24, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.823 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	0.236 in	0.07 in	15-4700 psi	Air	UV
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	0.236 in	0.07 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.124 in ²	0.398 in	0.1 in	14.5-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.124 in ²	0.398 in	0.1 in	14.5-4700 psi	Air	UV
0.75-1 NPS	1 NPS	0.222 in ²	0.531 in	0.13 in	14.5-2220 psi	Air	UV
0.75-1 NPS	1 NPS	0.222 in ²	0.531 in	0.13 in	14.5-2220 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.669 in	0.17 in	14.5-740 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.669 in	0.17 in	14.5-740 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	0.85 in	0.21 in	14.5-285 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	0.85 in	0.21 in	14.5-285 psi	Steam	UV

Design Name:	P3, P4 (liquids)	NBCert #	92012
--------------	------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/08/2027

Design Type

[Relief Valve] P3, P4 (liquids)
Capacity Tests: Sec. UV, V at National Board Testing Lab on December 7, 1993
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.631 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Water	UV, V
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Water	UV, V
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Water	UV, V
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Water	UV, V
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Water	UV, V
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Water	UV, V
4 NPS	6 NPS	7.032 in ²	[P] 2.992 in	0.94 in	15-1300 psi	Water	UV, V
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Water	UV, V
6 NPS	8-10 NPS	15.267 in ²	[R] 4.409 in	1.477 in	15-500 psi	Water	UV, V
8 NPS	10 NPS	28.126 in ²	[T] 5.984 in	1.88 in	15-500 psi	Water	UV, V

Design Name: P3, P4, P5

NBCert # 92001

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/08/2027

Design Type

[Safety Relief Valve] P3, P4, P5
Capacity Tests: Sec. UV at unknown lab on June 5, 1986
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Air	UV
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Air	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-2900 psi	Steam	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-2900 psi	Steam	UV

1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Air	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-2900 psi	Steam	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Air	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-2900 psi	Steam	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Air	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Steam	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Air	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Steam	UV
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Air	UV
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Steam	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Air	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Steam	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Air	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Steam	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Air	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Steam	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Air	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Steam	UV

Design Name: STARFLOW-V NBCert # 44110

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler V 01/08/2027

Design Type

[Safety Valve] STARFLOW-V
Capacity Tests: Sec. UV, V at National Board Testing Lab on April 26, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}
Comments: org. date added and V orif. area corrected from 38.548 to 38.485 JB 8-10-20
corrected H inlet to add 1.5" JB -8-2-21

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5-3 NPS	0.373 in ²	[F] 0.689 in	0.172 in	30-2250 psi	Steam	UV, V
1.25-2 NPS	1.5-3 NPS	0.589 in ²	[G] 0.866 in	0.217 in	30-2250 psi	Steam	UV, V
1.5-2 NPS	2.5, 3 NPS	0.996 in ²	[H] 1.126 in	0.281 in	30-2250 psi	Steam	UV, V

1.5-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.3622 in	0.341 in	30-2250 psi	Steam	UV, V
2-3 NPS	3-6 NPS	1.667 in ²	[K] 1.457 in	0.364 in	30-2250 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.758 in ²	[L] 1.874 in	0.469 in	30-2250 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.983 in ²	[M] 2.252 in	0.563 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	5.303 in ²	[N] 2.5984 in	0.65 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	0.75 in	30-2250 psi	Steam	UV, V
6 NPS	8 NPS	10.148 in ²	[Q] 3.594 in	0.902 in	30-1494 psi	Steam	UV, V
6 NPS	8, 10 NPS	14.173 in ²	[R] 4.248 in	1.062 in	30-1494 psi	Steam	UV, V
8 NPS	10 NPS	23.997 in ²	[T] 5.528 in	1.382 in	30-740 psi	Steam	UV, V
10 NPS	14 NPS	38.485 in ²	[V] 7 in	1.75 in	30-740 psi	Steam	UV, V
12 NPS	2x12 NPS	55.438 in ²	[W] 8.402 in	2.1 in	30-740 psi	Steam	UV, V

Design Name: STARFLOW-V (Restricted Lift) NBCert # 44121

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler V 05/18/2027

Design Type

[Safety Valve] STARFLOW-V (Restricted Lift)
Capacity Tests: Sec. UV, V at National Board Testing Lab on April 27, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Restricted Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}
Comments: Org. date added and "V" orif. area corrected from 34.485 to 38.485 JB 8-10-20
corrected H by adding 1.5" inlet JB 8-2-21

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5-3 NPS	0.373 in ²	[F] 0.689 in	0.095 in	30-2250 psi	Steam	UV, V
1.25-2 NPS	1.5-3 NPS	0.589 in ²	[G] 0.8661 in	0.119 in	30-2250 psi	Steam	UV, V
1.5-2 NPS	2.5, 3 NPS	0.996 in ²	[H] 1.126 in	0.156 in	30-2250 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.3622 in	0.188 in	30-2250 psi	Steam	UV, V
2-3 NPS	3-6 NPS	1.667 in ²	[K] 1.457 in	0.201 in	30-2250 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.758 in ²	[L] 1.874 in	0.258 in	30-2250 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.983 in ²	[M] 2.252 in	0.31 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	5.303 in ²	[N] 2.5984 in	0.357 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	0.414 in	30-2250 psi	Steam	UV, V
6 NPS	8 NPS	10.148 in ²	[Q] 3.594 in	0.496 in	30-1494 psi	Steam	UV, V
6 NPS	8, 10 NPS	14.173 in ²	[R] 4.248 in	0.584 in	30-1494 psi	Steam	UV, V
8 NPS	10 NPS	23.997 in ²	[T] 5.528 in	0.76 in	30-740 psi	Steam	UV, V
10 NPS	14 NPS	38.485 in ²	[V] 7 in	0.963 in	30-740 psi	Steam	UV, V
12 NPS	2x12 NPS	55.438 in ²	[W] 8.402 in	1.155 in	30-740 psi	Steam	UV, V

Design Name:	Starsteam V Series (Res. Lift)	NBCert #	92045
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	V	05/18/2027	

Design Type

[Safety Valve] Starsteam V Series (Res. Lift)
Capacity Tests: Sec. UV, V at National Board Testing Lab on August 6, 2012
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Restricted Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	3 NPS	0.996 in ²	[1] 1.125 in	0.156 in	15-6525 psi	Steam	UV, V
2 NPS	3 NPS	1.667 in ²	[2] 1.456 in	0.201 in	15-6525 psi	Steam	UV, V
2.5 NPS	6 NPS	2.758 in ²	[3] 1.874 in	0.258 in	15-6525 psi	Steam	UV, V
3 NPS	6 NPS	3.983 in ²	[4] 2.251 in	0.309 in	15-6525 psi	Steam	UV, V
4 NPS	6 NPS	5.303 in ²	[5] 2.598 in	0.357 in	15-6525 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[6] 3 in	0.414 in	15-3280 psi	Steam	UV, V
6 NPS	8 NPS	11.056 in ²	[Q] 3.571 in	0.517 in	15-2798 psi	Steam	UV, V
6 NPS	10 NPS	15.904 in ²	[R] 4.5 in	0.619 in	15-1580 psi	Steam	UV, V
6 NPS	10 NPS	19.299 in ²	[RR] 4.957 in	0.681 in	15-1580 psi	Steam	UV, V
8 NPS	10 NPS	27.391 in ²	[T] 5.905 in	0.812 in	15-1190 psi	Steam	UV, V

Caltrol, Inc. (CAT)

Benicia, CA 94510 United States

This Company Manufactures or Assembles:

Design Name:	243/249/443/449/546/843/849/943/5046/5049/8043/8049	NBCert #	01292
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	10/13/2027	

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
Capacity Tests: Sec. UV at unknown lab on August 8, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name:	253/259/453/459/853/859/953/959/5059/8053/8059	NBCert #	01304
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	10/13/2027
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
Capacity Tests: Sec. UV at unknown lab on July 31, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.627 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/26/2028

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.491 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 81, 81P, 83, 84 NBCert # 01089

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/26/2028

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
 Capacity Tests: Sec. UV at unknown lab on July 8, 1965
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.816 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}
 Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 81P (Liquids)

NBCert # 01102

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/26/2028

Design Type

[Relief Valve] 81P (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.720 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: 93% of pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V

Design Name: 900 Series (Liquid), 7700, SNC		NBCert #	15499
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	10/13/2027
Design Type			
[Relief Valve] 900 Series (Liquid), 7700, SNC Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.661 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name: 900 Series, 7700, SNC		NBCert #	15411
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	10/13/2027
Design Type			
[Safety Relief Valve] 900 Series, 7700, SNC Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - ; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV

0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: H Series (HCI, HSJ, HCA, HA, HB, HC, HCB, HCP, HJO, HN, HNA, HNB, HNP, HS, NBCert # 15006 HSA, HSB, HSC, HSP)

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 10/13/2027

Design Type

[Safety Valve] H Series (HCI, HSJ, HCA, HA, HB, HC, HCB, HCP, HJO, HN, HNA, HNB, HNP, HS, HSA, HSB, HSC, HSP)
Capacity Tests: Sec. UV, V at unknown lab on September 1, 1939
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1.5 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-500 psi	Steam	UV, V
0.75 NPS	1.5 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-500 psi	Steam	UV, V
1-1.5 NPS	2 - 3 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-3100 psi	Steam	UV, V
1-2 NPS	2.5, 3 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-3100 psi	Steam	UV, V
1.5-2 NPS	3, 4, 6 NPS	0.785 in ²	[H] 1 in	0.25 in	15-5000 psi	Steam	UV, V
1.5 NPS	3 NPS	0.865 in ²	1.05 in	0.262 in	15-3100 psi	Steam	UV, V
1.5 NPS	3 NPS	0.994 in ²	[H2] 1.125 in	0.281 in	15-3100 psi	Steam	UV, V
2-3 NPS	3, 4, 6 NPS	1.288 in ²	[J] 1.281 in	0.32 in	15-5000 psi	Steam	UV, V
2 NPS	4 NPS	1.431 in ²	[J2] 1.35 in	0.338 in	15-3100 psi	Steam	UV, V
2.5-3 NPS	4, 6 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-6000 psi	Steam	UV, V
2.5 NPS	6 NPS	2.545 in ²	[K2] 1.8 in	0.45 in	15-6800 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.476 in	15-3100 psi	Steam	UV, V
3 NPS	6 NPS	3.341 in ²	[L2] 2.062 in	0.516 in	15-3100 psi	Steam	UV, V
3-4 NPS	6, 8 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-6000 psi	Steam	UV, V
3 NPS	6, 8 NPS	3.976 in ²	[M2] 2.25 in	0.563 in	15-6000 psi	Steam	UV, V
4 NPS	6 NPS	4.341 in ²	[N] 2.351 in	0.588 in	15-3100 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.712 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	7.07 in ²	[P2] 3 in	0.75 in	15-3100 psi	Steam	UV, V

6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.937 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	12.25 in ²	[Q2] 3.95 in	0.988 in	15-3100 psi	Steam	UV, V
6 NPS	8, 10 NPS	16 in ²	[R] 4.513 in	1.128 in	15-3100 psi	Steam	UV, V
6 NPS	10 NPS	19.29 in ²	[RR] 4.956 in	1.239 in	15-3100 psi	Steam	UV, V
8 NPS	10, 12 NPS	26 in ²	[T] 5.75 in	1.437 in	15-500 psi	Steam	UV, V
8 NPS	12, 14 NPS	28.274 in ²	6 in	1.5 in	15-2000 psi	Steam	UV, V
10 NPS	14 NPS	44.18 in ²	7.5 in	1.875 in	15-500 psi	Steam	UV, V
12 NPS	16 NPS	63.62 in ²	9 in	2.25 in	15-500 psi	Steam	UV, V
14 NPS	18 NPS	86.59 in ²	10.5 in	2.625 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	95.21 in ²	11.01 in	2.753 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	114.04 in ²	12.05 in	3.02 in	15-500 psi	Steam	UV, V
18 NPS	24 NPS	143.14 in ²	13.5 in	3.375 in	15-500 psi	Steam	UV, V
20 NPS	24 NPS	176.71 in ²	15 in	3.75 in	15-500 psi	Steam	UV, V

Design Name: HL, HSL NBCert # 15589

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler V 09/09/2028

Design Type

[Safety Valve] HL, HSL
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on November 3, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.869 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	1.5 NPS	0.339 in ²	[F] 0.657 in	0.164 in	15-725 psi	Steam	UV, V
1.25-2 NPS	1.5 NPS	0.553 in ²	[G] 0.839 in	0.21 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.868 in ²	[H] 1.051 in	0.263 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.327 in ²	[J] 1.3 in	0.325 in	15-725 psi	Steam	UV, V
2-3 NPS	3-4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-725 psi	Steam	UV, V
2.5-4 NPS	4-6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-725 psi	Steam	UV, V
3 NPS	4-6 NPS	3.955 in ²	[M] 2.244 in	0.561 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	4.831 in ²	[N] 2.48 in	0.62 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	7.031 in ²	[P] 2.992 in	0.748 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[QQ] 3.75 in	0.937 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	0.984 in	15-725 psi	Steam	UV, V

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/13/2027

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.656 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/26/2028

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
 Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.870 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name: JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Liquids) (Restricted lift version of Certification 15095) NBCert # 01393

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/13/2027

Design Type

[Safety Relief Valve] JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Liquids) (Restricted lift version of Certification 15095)
 Capacity Tests: Sec. NV, UV, V at unknown lab on October 14, 2015
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.656 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Restricted Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Water	UV, V

1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.137 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.137 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	0.493 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.616 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Water	UV, V

Design Name:	JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Restricted Lift version of Certification 15512)	NBCert #	01382
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	01/26/2028
-----------	----	------------

Design Type

[Safety Relief Valve] JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Restricted Lift version of Certification 15512)
Capacity Tests: Sec. UV at unknown lab on October 13, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.6949 in ²	0.892 in	0.137 in	15-2500 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	0.493 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.616 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/13/2027

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV

1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Design Name:	JOS-E-RL/JBS-E-RL/JDS-E-RL (Restricted Lift version of cert 15208)	NBCert #	01045
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	10/13/2027
-----------	----	------------

Design Type

[Safety Relief Valve] JOS-E-RL/JBS-E-RL/JDS-E-RL (Restricted Lift version of cert 15208)

Capacity Tests: Sec. UV at unknown lab on May 26, 2015

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.865 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable (Single Ring)

Flow Area Configuration: Restricted Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-15000 psi	Air	UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.08 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.08 in	15-15000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.08 in	15-15000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.08 in	15-2000 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.08 in	15-15000 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.08 in	15-2000 psi	Steam	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.099 in	15-15000 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.099 in	15-2000 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.127 in	15-10000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.127 in	15-2000 psi	Steam	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.152 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.152 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.18 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.18 in	15-3000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.189 in	15-2000 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.189 in	15-5000 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.213 in	15-2000 psi	Steam	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.213 in	15-5000 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.234 in	15-1480 psi	Steam	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.234 in	15-3000 psi	Air	UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.255 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.255 in	15-2250 psi	Steam	UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.284 in	15-1480 psi	Steam	UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.284 in	15-3000 psi	Air	UV
6 NPS	8 NPS	11.045 in ²	3.75 in	0.373 in	15-1000 psi	Steam	UV

6 NPS	8 NPS	11.045 in ²	3.75 in	0.373 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.174 in ²	3.937 in	0.373 in	15-2250 psi	Air	UV
6 NPS	8 NPS	12.174 in ²	3.937 in	0.373 in	15-2250 psi	Steam	UV
6 NPS	10 NPS	12.236 in ²	3.947 in	0.449 in	15-2250 psi	Air	UV
6 NPS	10 NPS	12.236 in ²	3.947 in	0.449 in	15-2250 psi	Steam	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.373 in	15-1480 psi	Steam	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.373 in	15-3000 psi	Air	UV
6 NPS	8 NPS	15.288 in ²	4.412 in	0.424 in	15-2250 psi	Air	UV
6 NPS	8 NPS	15.288 in ²	4.412 in	0.424 in	15-2250 psi	Steam	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.449 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.449 in	15-1480 psi	Steam	UV
8 NPS	10 NPS	18.254 in ²	4.821 in	0.572 in	15-2250 psi	Air	UV
8 NPS	10 NPS	18.254 in ²	4.821 in	0.572 in	15-2250 psi	Steam	UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	0.572 in	15-740 psi	Air	UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	0.572 in	15-740 psi	Steam	UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	0.592 in	15-740 psi	Air	UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	0.592 in	15-740 psi	Steam	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	0.731 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	0.731 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	0.933 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	0.933 in	15-325 psi	Steam	UV

Caltrol, Inc. (THI)

Paramount, CA 90723United States

This Company Manufactures or Assembles:

Design Name: 243/249/443/449/546/843/849/943/5046/5049/8043/8049 NBCert # 01292

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/23/2030

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049

Capacity Tests: Sec. UV at unknown lab on August 8, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV

1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name: 253/259/453/459/853/859/953/959/5059/8053/8059 NBCert # 01304

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/23/2030

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
Capacity Tests: Sec. UV at unknown lab on July 31, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.627 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/25/2030

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.767 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/23/2030

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV

4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 81, 81P, 83, 84 NBCert # 01089

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/23/2030

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 81P (Liquids) NBCert # 01102

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/23/2030

Design Type

[Relief Valve] 81P (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.720 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: 93% of pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name: 900 Series (Liquid), 7700, SNC NBCert # 15499

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

04/23/2030

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.661 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV

1.5 NPS 2.5 NPS 0.5674 in² [#9] 0.85 in 0.274 in 15-5000 psi Water UV, V

Design Name: 900 Series, 7700, SNC		NBCert # 15411
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/23/2030
Design Type		
<div>[Safety Relief Valve] 900 Series, 7700, SNC</div> <div>Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990</div> <div>Method of Establishing Relieving Capacity: Flow Capacity, K</div> <div>Certified Value: 0.878 Unitless</div> <div>Media - ; Certified: Air, Gas, Steam</div> <div>Set Pressure Definition: Pop</div> <div>Blowdown Characteristics: Fixed</div> <div>Flow Area Configuration: Nozzle/Full Lift</div> <div>Designed by: Emerson Automation Solutions Final Control US LP {AGC}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: HL, HSL		NBCert #	15589
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV, V	03/11/2031	
Design Type			
[Safety Valve] HL, HSL Capacity Tests: Sec. UV, V at Crosby Valve, LLC on November 3, 1999 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.869 Unitless Media - Test: Steam; Certified: Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	1.5 NPS	0.339 in ²	[F] 0.657 in	0.164 in	15-725 psi	Steam	UV, V
1.25-2 NPS	1.5 NPS	0.553 in ²	[G] 0.839 in	0.21 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.868 in ²	[H] 1.051 in	0.263 in	15-725 psi	Steam	UV, V

1.5-2.5 NPS	2.5 NPS	1.327 in ²	[J] 1.3 in	0.325 in	15-725 psi	Steam	UV, V
2-3 NPS	3-4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-725 psi	Steam	UV, V
2.5-4 NPS	4-6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-725 psi	Steam	UV, V
3 NPS	4-6 NPS	3.955 in ²	[M] 2.244 in	0.561 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	4.831 in ²	[N] 2.48 in	0.62 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	7.031 in ²	[P] 2.992 in	0.748 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[QQ] 3.75 in	0.937 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	0.984 in	15-725 psi	Steam	UV, V

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/23/2030

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V

4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/23/2030

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/23/2030

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.865 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV

6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

CARRARO S.R.L. (CAO)

Nameplate Abbreviation: CARRARO

Segrate (MI), 20054Italy

This Company Manufactures or Assembles:

Design Name: CS 35 / G		NBCert #	95408
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	08/12/2027	
Design Type			
<p>[Safety Relief Valve] CS 35 / G Capacity Tests: Sec. UV at National Board Testing Lab on April 10, 2014 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:22.250 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: CARRARO S.R.L. {CAO}</p>			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	706.5 mm ²	[G] 30 mm	11.5 mm	1-29 bar	Water	UV

Design Name: CS 35 / J		NBCert #	95419
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	02/02/2027
Design Type			
[Safety Relief Valve] CS 35 / J Capacity Tests: Sec. UV at National Board Testing Lab on April 10, 2014 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 42.030 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: CARRARO S.R.L. {CAO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	3 NPS	1256 mm ²	[J] 40 mm	17 mm	1-30 bar	Water	UV

Design Name: CS80-SA, CS91-SA		NBCert #	95420
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	08/02/2027
Design Type			
[Safety Relief Valve] CS80-SA, CS91-SA Capacity Tests: Sec. UV at National Board Testing Lab on May 13, 2021 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: CARRARO S.R.L. {CAO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.25 NPS	86.5 mm ²	[D] 10.5 mm	3.5 mm	1-97.2 bar	Air	UV
1 NPS	1.25 NPS	143 mm ²	[E] 13.5 mm	4.5 mm	1-83.8 bar	Air	UV
1.25 NPS	1.5 NPS	226.8 mm ²	[F] 17 mm	5.7 mm	1-62.4 bar	Air	UV
1.25 NPS	1.5 NPS	362.8 mm ²	[G] 21.5 mm	7.2 mm	1-52.9 bar	Air	UV
1.5 NPS	2.5 NPS	551.2 mm ²	[H] 26.5 mm	8.8 mm	1-70 bar	Air	UV
1.5 NPS	2.5 NPS	907.4 mm ²	[J] 34 mm	11.3 mm	1-80.2 bar	Air	UV
2 NPS	3 NPS	1319.6 mm ²	[K] 41 mm	13.7 mm	1-77 bar	Air	UV
2.5 NPS	4 NPS	2041.8 mm ²	[L] 51 mm	17 mm	1-65 bar	Air	UV
3 NPS	4 NPS	2050.5 mm ²	[M] 57 mm	19 mm	1-50.2 bar	Air	UV
4 NPS	6 NPS	3017.5 mm ²	[N] 62 mm	20.7 mm	1-45.1 bar	Air	UV
4 NPS	6 NPS	4534.2 mm ²	[P] 76 mm	25.3 mm	1-45.8 bar	Air	UV
6 NPS	8 NPS	7850 mm ²	[Q] 100 mm	33.3 mm	1-37.3 bar	Air	UV
6 NPS	8 NPS	11798 mm ²	[R] 123 mm	40.9 mm	1-26.3 bar	Air	UV
8 NPS	10 NPS	18496 mm ²	[T] 153.5 mm	51.2 mm	1-22.4 bar	Air	UV

Cash Acme (The Trade Name of Reliance Worldwide Corporation) (CSH)

Cullman, AL 35055United States

This Company Manufactures or Assembles:

Design Name: (1-1/2")FVX-4 (2") FVMX-3 (T&P)		NBCert #	09098
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	HV	10/04/2030	
Design Type			
[Temperature Actuated Pressure Relief Valve] (1-1/2")FVX-4 (2") FVMX-3 (T&P) Capacity Tests: Sec. HV at National Board Testing Lab (Picaway) on November 19, 1981 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:33.690 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Cash Acme (The Trade Name of Reliance Worldwide Corporation) {CSH}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	1.5 NPS	1.23 in ²	1.25 in	0.4 in	75-150 psi	Steam	HV

Design Name: 1 FVX, FVMX3-5C, 3LS-6LS Ser. 4 (T&P)			NBCert #	09122
Manufacturer/Assembler		Designators		Expiration Date
Manufacturer		HV		06/15/2030
Design Type				
[Temperature Actuated Pressure Relief Valve] 1 FVX, FVMX3-5C, 3LS-6LS Ser. 4 (T&P) Capacity Tests: Sec. HV at National Board Testing Lab (Picaway) on May 29, 1980 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:11.990 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Cash Acme (The Trade Name of Reliance Worldwide Corporation) {CSH}				

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1 NPS	0.558 in ²	0.843 in	0.148 in	75-150 psi	Steam	HV

Design Name: 1 FVX-5L/Series 15, 1-1/4 FVMX4L, FVX-8L		NBCert #	09100
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	HV	05/21/2030	

Design Type

[Temperature Actuated Pressure Relief Valve] 1 FVX-5L/Series 15, 1-1/4 FVMX4L, FVX-8L
Capacity Tests: Sec. HV at National Board Testing Lab (Picaway) on April 4, 1979
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:20.170 PPH/PSIA
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: 40 CC Method
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Cash Acme (The Trade Name of Reliance Worldwide Corporation) {CSH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.25 NPS	1 NPS	0.785 in ²	1 in	0.3 in	75-150 psi	Steam	HV

Design Name:	F-30 (3/4")	NBCert #	09009
--------------	-------------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

HV

07/10/2030

Design Type

[Safety Relief Valve] F-30 (3/4")
Capacity Tests: Sec. HV at unknown lab on July 18, 1983
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:510.00 PPH
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: 40 CC Method
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Cash Acme (The Trade Name of Reliance Worldwide Corporation) {CSH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.307 in ²	0.625 in	0.156 in	30-30 psi	Steam	HV

Design Name:	F-30F (3/4")	NBCert #	09166
--------------	--------------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

HV

08/21/2029

Design Type

[Safety Relief Valve] F-30F (3/4")
HolderDesignation:
Capacity Tests: Sec. HV at National Board Testing Lab on March 9, 2023
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:423600 BTU/HR; (alternate medium): 0.000
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: 40 CC Method
Blowdown Characteristics: Fixed
Flow Area Configuration:
Designed by: Cash Acme (The Trade Name of Reliance Worldwide Corporation) {CSH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	0.75 NPS	0.307 in ²	0.625 in	0.156 in	30-30 psi	Steam	HV

Design Name:	F-82, P3000BR (1-1/2")	NBCert #	09043
--------------	------------------------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

HV

09/16/2030

Design Type

[Safety Relief Valve] F-82, P3000BR (1-1/2")
Capacity Tests: Sec. HV at National Board Testing Lab on November 11, 1981
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:43.740 PPH/PSIA
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: 40 CC Method
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Cash Acme (The Trade Name of Reliance Worldwide Corporation) {CSH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	1.5 NPS	1.77 in ²	1.5 in	0.421 in	30-150 psi	Steam	HV

Design Name: F-82, P3000BR (2") NBCert # 09054

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer HV 07/10/2030

Design Type

[Safety Relief Valve] F-82, P3000BR (2")
Capacity Tests: Sec. HV at unknown lab on November 19, 1981
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:81.800 PPH/PSIA
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: 40 CC Method
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Cash Acme (The Trade Name of Reliance Worldwide Corporation) {CSH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	3.142 in ²	2 in	0.562 in	30-150 psi	Steam	HV

Design Name: F-82, P3000BR (3/4") NBCert # 09010

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer HV 02/20/2031

Design Type

[Safety Relief Valve] F-82, P3000BR (3/4")
Capacity Tests: Sec. HV at unknown lab on August 6, 1972
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:15.050 PPH/PSIA
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: 40 CC Method
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Cash Acme (The Trade Name of Reliance Worldwide Corporation) {CSH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.442 in ²	0.75 in	0.3 in	30-150 psi	Steam	HV

Design Name: F-82, P3000BR (1") NBCert # 09021

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer HV 05/12/2030

Design Type

[Safety Relief Valve] F-82, P3000BR (1")
Capacity Tests: Sec. HV at unknown lab on May 16, 1980
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:21.490 PPH/PSIA
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: 40 CC Method
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Cash Acme (The Trade Name of Reliance Worldwide Corporation) {CSH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1 NPS	0.785 in ²	1 in	0.3 in	30-150 psi	Steam	HV

Design Name: F-82, P3000BR (1-1/4") NBCert # 09032

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

HV

06/17/2030

Design Type

[Safety Relief Valve] F-82, P3000BR (1-1/4")
Capacity Tests: Sec. HV at unknown lab on November 19, 1981
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:35.720 PPH/PSIA
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: 40 CC Method
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Cash Acme (The Trade Name of Reliance Worldwide Corporation) {CSH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.25 NPS	1.23 in ²	1.25 in	0.4 in	30-150 psi	Steam	HV

Design Name: F-95, P3000CI NBCert # 09199

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

HV

09/16/2030

Design Type

[Safety Relief Valve] F-95, P3000CI
Capacity Tests: Sec. HV at National Board Testing Lab on November 8, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.694 Unitless
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Cash Acme (The Trade Name of Reliance Worldwide Corporation) {CSH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.559 in ²	0.844 in	0.323 in	30-75 psi	Steam	HV
1 NPS	1.25 NPS	0.785 in ²	1 in	0.294 in	30-75 psi	Steam	HV
1.25 NPS	1.5 NPS	1.227 in ²	1.25 in	0.383 in	30-75 psi	Steam	HV
1.5 NPS	2 NPS	1.767 in ²	1.5 in	0.437 in	30-75 psi	Steam	HV
2 NPS	2.5 NPS	3.142 in ²	2 in	0.59 in	30-75 psi	Steam	HV

Design Name: FVX, FVMX-1-3-5-8, FVMX-5LS-SST Ser. 4 (3/4")		NBCert #	09111
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	11/05/2030
Design Type			
[Temperature Actuated Pressure Relief Valve] FVX, FVMX-1-3-5-8, FVMX-5LS-SST Ser. 4 (3/4") Capacity Tests: Sec. HV at National Board Testing Lab (Picaway) on June 20, 1984 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:10.640 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Cash Acme (The Trade Name of Reliance Worldwide Corporation) {CSH}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.442 in ²	0.75 in	0.17 in	75-150 psi	Steam	HV

Design Name: FWL-2F, PRV-R2X (3/4"), FWL-2, PRV-R (3/4")		NBCert #	09087
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	08/21/2029
Design Type			
[Safety Relief Valve] FWL-2F, PRV-R2X (3/4"), FWL-2, PRV-R (3/4") HolderDesignation: Capacity Tests: Sec. HV at National Board Testing Lab on March 9, 2023 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:6476.0 BTU/HR/PSIA; (alternate medium): 0.000 Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Cash Acme (The Trade Name of Reliance Worldwide Corporation) {CSH}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	0.75 NPS	0.173 in ²	0.47 in	0.118 in	75-150 psi	Steam	HV

Design Name: NCLX-1, -5, -8; NCLX-5L, -5LX, -5S, -LS, -A;S-14,-6,A4,4,A2		NBCert #	09155
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	06/21/2030
Design Type			
[Temperature Actuated Pressure Relief Valve] NCLX-1, -5, -8; NCLX-5L, -5LX, -5S, -LS, -A;S-14,-6,A4,4,A2 Capacity Tests: Sec. HV at National Board Testing Lab on November 1, 1994 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.600 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Cash Acme (The Trade Name of Reliance Worldwide Corporation) {CSH}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.173 in ²	0.469 in	0.08 in	75-150 psi	Steam	HV

Castel s.r.l. (CAS)

Milano, 20042Italy

This Company Manufactures or Assembles:

Design Name:	3030/44 - 3030/66	NBCert #	02394
--------------	-------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/16/2029

Design Type

[Safety Relief Valve] 3030/44 - 3030/66
Capacity Tests: Sec. UV at National Board Testing Lab on September 2, 2021
Certified Value: 2.380 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Castel s.r.l. {CAS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.75 NPS	113 mm ²	12 mm	4.2 mm	9-50 bar	Air	UV

Design Name:	3030E/410 - 3030E/610 (HP)	NBCert #	02956
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/05/2031

Design Type

[Safety Relief Valve] 3030E/410 - 3030E/610 (HP)
HolderDesignation:
Capacity Tests: Sec. UV at National Board Testing Lab on September 12, 2024
Certified Value: 2.370 SCFM/PSIA; (alternate medium): 0.000
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Castel s.r.l. {CAS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1.25 NPS	95 mm ²	11 mm	4.7 mm	95.1-150 bar	Air	UV

Design Name:	3030E/410 - 3030E/610 (LP)	NBCert #	02428
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/05/2031

Design Type

[Safety Relief Valve] 3030E/410 - 3030E/610 (LP)
Capacity Tests: Sec. UV at National Board Testing Lab on September 12, 2024
Certified Value: 2.370 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Castel s.r.l. {CAS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1.25 NPS	95 mm ²	11 mm	4.7 mm	60-75 bar	Air	UV

Design Name: 3030E/410 - 3030E/610 (MP) NBCert # 02945

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

03/05/2031

Design Type

[Safety Relief Valve] 3030E/410 - 3030E/610 (MP)
HolderDesignation:
Capacity Tests: Sec. UV at National Board Testing Lab on December 12, 2024
Certified Value: 2.370 SCFM/PSIA; (alternate medium): 0.000
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Castel s.r.l. {CAS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1.25 NPS	95 mm ²	11 mm	4.7 mm	75.1-95 bar	Air	UV

Cavagna Group Spa (CAV)

Nameplate Abbreviation: OMECA

Brescia, OTH, 25011Italy

This Company Manufactures or Assembles:

Design Name: 1064 NBCert # 69252

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

03/01/2028

Design Type

[Safety Relief Valve] 1064
Capacity Tests: Sec. UV at National Board Testing Lab on January 14, 2020
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:1356.0 SCFM; Certification Provisions: Cert. @ 20% OP
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Cavagna Group Spa {CAV}
Comments: 90% test value = 1356.5 SCFM

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.368 in²	0.685 in	0.197 in	250-250 psi	Air	UV
Design Name: 1128BNBCert # 69128							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			03/01/2028	
Design Type							
[Safety Relief Valve] 1128B Capacity Tests: Sec. UV at National Board Testing Lab on July 12, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:1732.0 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Cavagna Group Spa {CAV}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		268.2 mm²	0.787 in	10 mm	250-0 psi	Air	UV
Design Name: 1129NBCert # 69139							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			01/03/2029	
Design Type							
[Safety Relief Valve] 1129 Capacity Tests: Sec. UV at National Board Testing Lab on June 25, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:2396.0 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Cavagna Group Spa {CAV}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		483.6 mm²	1 in	12 mm	250-0 psi	Air	UV
Design Name: 1130NBCert # 69140							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			12/12/2030	
Design Type							
[Safety Relief Valve] 1130 Capacity Tests: Sec. UV at National Board Testing Lab on June 25, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:3934.0 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Cavagna Group Spa {CAV}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	Top mm	716.3 mm²	1.224 in	10 mm	250-0 psi	Air	UV
Design Name: 1135NBCert # 69151							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			12/05/2030	
Design Type							
[Safety Relief Valve] 1135 Capacity Tests: Sec. UV at National Board Testing Lab on June 25, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:967.00 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Cavagna Group Spa {CAV}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		157 mm²	14.7 mm	10 mm	250-0 psi	Air	UV
Design Name: 1162BNBCert # 69218							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			03/01/2028	
Design Type							
[Safety Relief Valve] 1162B Capacity Tests: Sec. UV at National Board Testing Lab on June 13, 2007 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:657.00 SCFM Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Cavagna Group Spa {CAV}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS					312-312 psi	Air	UV
Design Name: 700073NBCert # 69083							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			06/26/2030	
Design Type							
[Safety Relief Valve] 700073 Capacity Tests: Sec. UV at National Board Testing Lab on July 12, 2001 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:1808.0 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Cavagna Group Spa {CAV}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		283.4 mm²	19 mm	9 mm	250-250 psi	Air	UV
Design Name: PV19 (700214)NBCert # 69230							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			07/02/2030	
Design Type							
[Safety Relief Valve] PV19 (700214) Capacity Tests: Sec. UV at National Board Testing Lab on September 29, 2011 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:2051.0 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Cavagna Group Spa {CAV}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	Top NPS	283.4 mm²	0.748 in	10 mm	250-250 psi	Air	UV
Design Name: PV24 (700216)NBCert # 69241							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			07/03/2030	
Design Type							
[Safety Relief Valve] PV24 (700216) Capacity Tests: Sec. UV at National Board Testing Lab on September 29, 2011 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:3158.0 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Cavagna Group Spa {CAV}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	Top NPS	471.2 mm²	0.965 in	10 mm	250-250 psi	Air	UV
Design Name: PV29 (700217)NBCert # 69229							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			07/16/2030	
Design Type							
[Safety Relief Valve] PV29 (700217) Capacity Tests: Sec. UV at National Board Testing Lab on June 1, 2012 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:4746.0 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Cavagna Group Spa {CAV}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	Top NPS	683.5 mm²	1.16 in	12 mm	250-250 psi	Air	UV
Design Name: PV60			NBCert #		69195		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		04/07/2029		
Design Type							
<div>[Safety Relief Valve] PV60 Capacity Tests: Sec. UV at National Board Testing Lab on September 28, 2016 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value: 11433 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Cavagna Group Spa {CAV}</div>							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		1590.4 mm ²	45 mm	20 mm	250 psi	Air	UV

Centrix Control Solutions L.P. (BRB)

Edmonton, AB T6E 5X1Canada

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3		NBCert #	18032
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV, V	07/25/2028
Design Type			
[Safety Valve] 1541, 1543, 1541-3, 1543-3 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV

0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1811, 1511

NBCert #

18122

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV, V

06/29/2028

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V

2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA (Liquids) NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 07/25/2028

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	07/26/2028
-----------	----	------------

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV

8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/25/2028

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/25/2028

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2

NBCert #

18144

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/26/2028

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert #

18751

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	07/25/2028

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 3.256 GPM/SQ. RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM

NBCert # 19066

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

11/23/2027

Design Type

[Safety Relief Valve] 1900-DM
 Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
 Set Pressure Definition(1): Pop; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name:	1900-DM-D	NBCert #	19088
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/23/2027

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name:	1900-DM-E	NBCert #	19099
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 05/02/2028

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/26/2028

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name:	1900E-2, 1900-30E-2 LA & DALA (Liquids)	NBCert #	18762
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	07/25/2028

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name:	2900-TM (39PV & 39MV pilots)	NBCert #	01427
--------------	------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/17/2031

Design Type

[Pilot Operated Pressure Relief Valve] 2900-TM (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV

1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Water	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Water	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Water	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2000 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Water	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Water	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-300 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Water	UV

8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Water	UV

Design Name:	3900-TM (39PV, 39MV pilots)	NBCert #	01438
--------------	-----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/26/2028

Design Type

[Pilot Operated Pressure Relief Valve] 3900-TM (39PV, 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; (alternate medium): 0.743 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV

1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV

10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Chalmers & Kubeck, Inc. (BRU)

Metuchen, NJ 08840United States

This Company Manufactures or Assembles:

Design Name: 1900, 1900-30, 1900-35		NBCert # 18201
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/09/2025
Design Type		
[Safety Relief Valve] 1900, 1900-30, 1900-35 Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.855 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV

4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/09/2025

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV

1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Chalmers & Kubeck, Inc. (CKB)

Beaver Falls, PA 15010United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3		NBCert # 18032
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/11/2026
Design Type		
[Safety Valve] 1541, 1543, 1541-3, 1543-3 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V

1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1811, 1511

NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV, V

02/13/2026

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	02/19/2026

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/10/2026

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/18/2026

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/19/2026

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV

0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/18/2026

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 02/18/2026

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name:	1900-DM	NBCert #	19066
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/16/2029

Design Type

[Safety Relief Valve] 1900-DM

Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D		NBCert # 19088
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/16/2029
Design Type		
[Safety Relief Valve] 1900-DM-D Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787) Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid Set Pressure Definition(1): Pop; (2): First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E		NBCert # 19099
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/16/2029
Design Type		
[Safety Relief Valve] 1900-DM-E Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787) Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid Set Pressure Definition(1): Pop; (2): First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2		NBCert # 18166
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/18/2026
Design Type		
[Safety Relief Valve] 1900E-2, 1900-30E-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	02/18/2026

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids) NBCert # 19077

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/19/2026

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 2900-TM (39PV & 39MV pilots) NBCert # 01427

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/09/2030

Design Type

[Pilot Operated Pressure Relief Valve] 2900-TM (39PV & 39MV pilots)

Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Water	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Water	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Water	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2000 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Water	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Water	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Water	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-300 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Water	UV

Design Name: 3900-TM (39PV, 39MV pilots) NBCert # 01438

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/04/2031

Design Type

[Pilot Operated Pressure Relief Valve] 3900-TM (39PV, 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; (alternate medium): 0.743 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Water	UV

1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV

6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Chalmers & Kubeck, Inc. (CKI)

Aston, PA 19014United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3 NBCert # 18032

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 02/02/2031

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V

1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1700 & 2700

NBCert #

18100

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

V

11/14/2028

Design Type

[Safety Valve] 1700 & 2700
Capacity Tests: Sec. UV, V at Dresser, Inc. on August 1, 1957
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	50-5800 psi	Steam	V
4 NPS	4 dual NPS	1.84 in ²	[K] 1.531 in	0.383 in	50-5800 psi	Steam	V
2-3 NPS	4, 6 NPS	2.545 in ²	[#3] 1.8 in	0.45 in	50-5800 psi	Steam	UV, V
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-2575 psi	Steam	UV
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	50-5800 psi	Steam	V
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	15-3100 psi	Steam	UV
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	50-5800 psi	Steam	V

4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	15-3100 psi	Steam	UV
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	15-1800 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	1.24 in	50-2200 psi	Steam	UV, V
8-10 NPS	10,12 NPS	28.3 in ²	[T] 6 in	1.5 in	50-1500 psi	Steam	UV, V

Design Name: 1700 & 2700 (Restricted Lift version of Cert. # 18100) NBCert # 18111

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler V 09/27/2028

Design Type

[Safety Valve] 1700 & 2700 (Restricted Lift version of Cert. # 18100)
Capacity Tests: Sec. UV, V at unknown lab on October 13, 1981
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	50-5800 psi	Steam	V
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	15-3100 psi	Steam	UV
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	50-5800 psi	Steam	V
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-2575 psi	Steam	UV
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	50-5800 psi	Steam	V
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	15-3100 psi	Steam	UV
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	50-5800 psi	Steam	V
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	15-3100 psi	Steam	UV
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	15-2093 psi	Steam	UV

6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.946 in	0.296 in	15-2000 psi	Steam	UV, V
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	0.372 in	50-2200 psi	Steam	V
8-10 NPS	10, 12 NPS	28.3 in ²	[T] 6 in	0.45 in	50-1500 psi	Steam	UV, V

Design Name: 1811, 1511

NBCert #

18122

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	02/02/2031

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	08/18/2029

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/02/2031

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/23/2029

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/14/2029

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV

0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/02/2031

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 09/18/2029

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ. RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name:	1900-DM	NBCert #	19066
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/04/2029

Design Type

[Safety Relief Valve] 1900-DM

Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D		NBCert # 19088
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/04/2029
Design Type		
[Safety Relief Valve] 1900-DM-D Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787) Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid Set Pressure Definition(1): Pop; (2): First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E		NBCert # 19099
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/04/2029
Design Type		
[Safety Relief Valve] 1900-DM-E Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787) Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid Set Pressure Definition(1): Pop; (2): First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2		NBCert # 18166
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/02/2031
Design Type		
[Safety Relief Valve] 1900E-2, 1900-30E-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	09/18/2029

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids) NBCert # 19077

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/13/2029

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 1982 NBCert # 18379

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/02/2031

Design Type

[Safety Relief Valve] 1982
 Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at unknown lab on May 6, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Air	NV, UV
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Steam	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Air	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Steam	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Air	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Steam	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Air	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Air	NV, UV

Design Name: 1982 LS, 820000LS

NBCert #

18380

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/15/2028

Design Type

[Relief Valve] 1982 LS, 820000LS
 Capacity Tests: Sec. UV at Dresser, Inc. on December 19, 1984
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.758 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	NV
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	UV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	NV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	NV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	UV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	NV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	NV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	UV

Design Name: 2900-TM (39PV & 39MV pilots)

NBCert #

01427

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/14/2030

Design Type

[Pilot Operated Pressure Relief Valve] 2900-TM (39PV & 39MV pilots)

Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Water	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Water	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Water	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2000 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Water	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Water	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-300 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Water	UV

Design Name:	3900 (39PV, 39MV pilots)	NBCert #	18447
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/23/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV

1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV

6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid) NBCert # 18458

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/23/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV

3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

CIRCOR Aerospace, Inc. (CSC)

Nameplate Abbreviation: Circle Seal

Corona, CA 92878United States

This Company Manufactures or Assembles:

Design Name: D-500-2M		NBCert #	10001
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	04/29/2026
Design Type			
[Safety Relief Valve] D-500-2M Capacity Tests: Sec. UV at Phillips Petroleum on November 16, 1966 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.359 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Designed by: CIRCOR Aerospace, Inc. {CSC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.25 NPS		0.059 in ²	0.275 in	0.069 in	15-150 psi	Air	UV

Design Name:	M5100-1M	NBCert #	10012
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 04/29/2026

Design Type

[Safety Relief Valve] M5100-1M
Capacity Tests: Sec. UV at Phillips Petroleum on November 6, 1966
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.286 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Designed by: CIRCOR Aerospace, Inc. {CSC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.125 NPS	Side NPS	0.049 in ²	0.25 in	0.06 in	100-1200 psi	Air	UV

Design Name:	M5100-2M & 3M	NBCert #	10023
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 04/29/2026

Design Type

[Safety Relief Valve] M5100-2M & 3M
Capacity Tests: Sec. UV at Phillips Petroleum on November 16, 1966
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.667 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Designed by: CIRCOR Aerospace, Inc. {CSC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.375 NPS		0.1 in ²	0.358 in	0.08 in	15-1200 psi	Air	UV

Design Name:	M5100-4M	NBCert #	10034
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 04/29/2026

Design Type

[Safety Relief Valve] M5100-4M
Capacity Tests: Sec. UV at Phillips Petroleum on November 16, 1966
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.310 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Designed by: CIRCOR Aerospace, Inc. {CSC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.5 NPS		0.209 in ²	0.516 in	0.1 in	15-1200 psi	Air	UV

Design Name: M5100-6M & 8M 100 - 1200			NBCert # 10056				
Manufacturer/Assembler		Designators		Expiration Date			
Manufacturer		UV		04/29/2026			
Design Type							
[Safety Relief Valve] M5100-6M & 8M 100 - 1200 Capacity Tests: Sec. UV at Phillips Petroleum on November 16, 1966 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.453 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Designed by: CIRCOR Aerospace, Inc. {CSC}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS		0.428 in²	0.738 in	0.25 in	100-1200 psi	Air	UV

Cleveland Valve and Gauge, Co. (CVG)					Nameplate Abbreviation: Cleveland Valve & Gauge Co.
Cleveland, OH 44135United States					

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3				NBCert # 18032			
Manufacturer/Assembler			Designators		Expiration Date		
Assembler			UV, V		07/13/2026		
Design Type							
[Safety Valve] 1541, 1543, 1541-3, 1543-3 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV

1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1811, 1511

NBCert #

18122

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV, V

07/24/2026

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V

4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/01/2026

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/24/2026

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV

10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/01/2026

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/30/2026

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/22/2026

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/22/2026

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/22/2026

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name:	1900E-2, 1900-30E-2 LA & DALA (Liquids)	NBCert #	18762
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/22/2026

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name:	19110M & 19110H (Liquids)	NBCert #	19077
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/22/2026

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name:	3900 (39PV, 39MV pilots)	NBCert #	18447
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	06/01/2026
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV

3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid) NBCert # 18458

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/11/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.743 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV

8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Continental Disc Corporation, LLC (CDC)

Nameplate Abbreviation: CDC

Liberty, MO 64068-3385United States

This Company Manufactures or Assembles:

Design Name: APX (DD) (Gas) NBCert # 75776

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/18/2030

Design Type

[Rupture Disk Device] APX (DD) (Gas)
HolderDesignation: APX Double Disc Insert
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on August 14, 2023
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.440 Unitless; (alternate medium): 0.000
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			30-600 psi		UD
1.5 NPS		2.04 in ²			25-485 psi		UD
10 NPS		78.8 in ²			10-200 psi		UD
12 NPS		113 in ²			10-150 psi		UD
2 NPS		3.36 in ²			20-475 psi		UD
3 NPS		7.39 in ²			20-475 psi		UD
4 NPS		12.7 in ²			20-300 psi		UD
6 NPS		28.8 in ²			10-250 psi		UD
8 NPS		50 in ²			10-200 psi		UD

Design Name: APX (DD) (Liquid) NBCert # 75787

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/18/2030

Design Type

[Rupture Disk Device] APX (DD) (Liquid)
HolderDesignation: APX Double Disc Insert
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on August 14, 2023
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.540 Unitless; (alternate medium): 0.000
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			30-600 psi		UD
1.5 NPS		2.04 in ²			25-485 psi		UD
10 NPS		78.8 in ²			10-200 psi		UD
12 NPS		12.7 in ²			10-150 psi		UD
2 NPS		3.36 in ²			20-475 psi		UD
3 NPS		7.39 in ²			20-475 psi		UD
4 NPS		12.7 in ²			20-300 psi		UD
6 NPS		28.8 in ²			10-250 psi		UD
8 NPS		50 in ²			10-200 psi		UD

Design Name:	APX (FS) (Gas)	NBCert #	75754
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/18/2030

Design Type

[Rupture Disk Device] APX (FS) (Gas)
HolderDesignation: APX Insert, APX RH
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on May 15, 2023
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.370 Unitless; (alternate medium): 0.000
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			25-600 psi		UD
1.5 NPS		2.04 in ²			20-485 psi		UD
10 NPS		78.8 in ²			10-200 psi		UD
12 NPS		113 in ²			10-150 psi		UD
2 NPS		3.36 in ²			20-475 psi		UD
3 NPS		7.39 in ²			20-475 psi		UD
4 NPS		12.7 in ²			20-300 psi		UD
6 NPS		28.8 in ²			10-250 psi		UD
8 NPS		50 in ²			10-200 psi		UD

Design Name:	APX (FS) (Liquid)	NBCert #	75765
--------------	-------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/18/2030

Design Type

[Rupture Disk Device] APX (FS) (Liquid)
HolderDesignation: APX Insert, APX RH
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on August 14, 2023
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.410 Unitless; (alternate medium): 0.000
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			25-600 psi		UD
1.5 NPS		2.04 in ²			20-485 psi		UD
10 NPS		78.8 in ²			10-200 psi		UD
12 NPS		113 in ²			10-200 psi		UD
2 NPS		3.36 in ²			20-475 psi		UD
3 NPS		7.39 in ²			20-475 psi		UD
4 NPS		12.7 in ²			20-300 psi		UD
6 NPS		28.8 in ²			10-250 psi		UD
8 NPS		50 in ²			10-200 psi		UD

Design Name: CD 31074

NBCert # 75484

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

01/17/2031

Design Type

[Rupture Disk Device] CD 31074
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on January 14, 2003
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value:10.000 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.3125 NPS		0.037 in ²			250-1200 psi		UD
0.5 NPS		0.117 in ²			250-1200 psi		UD
0.75 NPS		0.29 in ²			150-1000 psi		UD
1 NPS		0.462 in ²			100-1000 psi		UD
1.25 NPS		0.688 in ²			50-1000 psi		UD

Design Name: CD 31327

NBCert # 75653

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

09/01/2028

Design Type

[Rupture Disk Device] CD 31327
HolderDesignation: CD 31327
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on August 12, 2010
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl
Certified Value:18.000 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.13 in ²			22-175 psi		UD

Design Name:	CD30935	NBCert #	75259
--------------	---------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer	UD	05/09/2031
--------------	----	------------

Design Type

[Rupture Disk Device] CD30935
HolderDesignation: N/A
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on January 9, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl
Certified Value: 1.000 Unitless
Media - Test: Air/Gas; Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.5 NPS	0.26 in ²	0.58 in		140-1000 psi		UD

Design Name:	CD30936	NBCert #	75260
--------------	---------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer	UD	05/09/2031
--------------	----	------------

Design Type

[Rupture Disk Device] CD30936
HolderDesignation: N/A
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on January 14, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl
Certified Value: 1.000 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.44 in ²	0.75 in		140-1000 psi		UD

Design Name:	CD31159	NBCert #	75732
--------------	---------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer	UD	06/15/2029
--------------	----	------------

Design Type

[Rupture Disk Device] CD31159
HolderDesignation: N/A
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on May 9, 2017
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl
Certified Value:20.000 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		1.13 in ²			15-500 psi		UD

Design Name: CDC (CF) NBCert # 75361

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

08/02/2028

Design Type

[Rupture Disk Device] CDC (CF)
HolderDesignation: Clean-Sweep CU8, CU9. CR8, CR9
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on July 19, 2000
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 1.570 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			25-2160 psi		UD
1.5 NPS		2.04 in ²			22-2160 psi		UD
10 NPS		78.85 in ²			2-720 psi		UD
12 NPS		113.1 in ²			2-720 psi		UD
14 NPS		137.9 in ²			2-720 psi		UD
16 NPS		182.7 in ²			2-720 psi		UD
18 NPS		233.7 in ²			2-720 psi		UD
2 NPS		3.36 in ²			7-2160 psi		UD
20 NPS		291 in ²			2-275 psi		UD
24 NPS		424.6 in ²			2-275 psi		UD
3 NPS		7.39 in ²			6-1440 psi		UD
30 NPS		672 in ²			2-275 psi		UD
32 NPS		767 in ²			2-275 psi		UD
36 NPS		975.9 in ²			2-275 psi		UD
4 NPS		12.73 in ²			5-1440 psi		UD
6 NPS		28.89 in ²			3-1440 psi		UD
8 NPS		50.03 in ²			2-720 psi		UD

Design Name:	CDC (FS)	NBCert #	75002
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	03/24/2031

Design Type

[Rupture Disk Device] CDC (FS)
 HolderDesignation: RHI, UNISERT, FLAT SEAT
 Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on February 13, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 0.340 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			25-2160 psi		UD
1.5 NPS		2.04 in ²			22-2160 psi		UD
10 NPS		78.85 in ²			2-720 psi		UD
12 NPS		113.1 in ²			2-720 psi		UD
14 NPS		137.89 in ²			2-720 psi		UD
16 NPS		182.65 in ²			2-720 psi		UD
18 NPS		233.71 in ²			2-720 psi		UD
2 NPS		3.36 in ²			7-2160 psi		UD
20 NPS		291.04 in ²			2-275 psi		UD
24 NPS		424.56 in ²			2-275 psi		UD
3 NPS		7.39 in ²			6-1440 psi		UD
30 NPS		671.96 in ²			2-275 psi		UD
32 NPS		766.99 in ²			2-275 psi		UD
36 NPS		975.91 in ²			2-275 psi		UD
4 NPS		12.73 in ²			5-1440 psi		UD
6 NPS		28.89 in ²			3-1440 psi		UD
8 NPS		50.03 in ²			2-720 psi		UD

Design Name:	CDC, CDCV (DD)	NBCert #	75642
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	09/02/2028

Design Type

[Rupture Disk Device] CDC, CDCV (DD)
 HolderDesignation: Unisert double disk
 Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on August 13, 2010
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 1.810 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in²			30-2160 psi		UD
1.5 NPS		2.04 in²			27-2160 psi		UD
10 NPS		78.8 in²			5-720 psi		UD
12 NPS		113 in²			4-720 psi		UD
14 NPS		137 in²			3-720 psi		UD
16 NPS		182 in²			1.3-720 psi		UD
18 NPS		233 in²			4-720 psi		UD
2 NPS		3.36 in²			15-2160 psi		UD
20 NPS		291 in²			4-275 psi		UD
24 NPS		424 in²			4-275 psi		UD
28 NPS		583 in²			4-275 psi		UD
3 NPS		7.39 in²			6.5-1440 psi		UD
30 NPS		671 in²			4-275 psi		UD
32 NPS		766 in²			4-275 psi		UD
36 NPS		975 in²			4-275 psi		UD
38 NPS		1089 in²			4-275 psi		UD
4 NPS		12.7 in²			7-1440 psi		UD
40 NPS		1209 in²			4-275 psi		UD
42 NPS		1336 in²			4-275 psi		UD
44 NPS		1469 in²			4-275 psi		UD
46 NPS		1608 in²			4-275 psi		UD
48 NPS		1753 in²			4-275 psi		UD
6 NPS		28.8 in²			5-1440 psi		UD
8 NPS		50 in²			5-720 psi		UD

Design Name:	CDC/LD/ (LL)	NBCert #	75057
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	02/13/2031
--------------	----	------------

Design Type

[Rupture Disk Device] CDC/LD/ (LL)
HolderDesignation: Insert, Full Bolted #1 thru #9, Union 2U, 3U, 5U, 6U
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on February 13, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 1.810 Unitless
Media - Test: Air/Gas; Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.72 in²			25-2160 psi		UD
1.5 NPS		1.77 in²			22-2160 psi		UD
10 NPS		78.85 in²			2-720 psi		UD

12 NPS	113.1 in ²	2-720 psi	UD
14 NPS	137.89 in ²	2-720 psi	UD
16 NPS	182.65 in ²	2-720 psi	UD
18 NPS	233.71 in ²	2-720 psi	UD
2 NPS	3.36 in ²	7-2160 psi	UD
20 NPS	291.04 in ²	2-720 psi	UD
24 NPS	424.56 in ²	2-275 psi	UD
3 NPS	7.39 in ²	6-1440 psi	UD
30 NPS	671.96 in ²	2-275 psi	UD
4 NPS	12.73 in ²	5-1440 psi	UD
6 NPS	28.89 in ²	3-1440 psi	UD
8 NPS	50.03 in ²	2-1440 psi	UD

Design Name: CDCV (CF) NBCert # 75372

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	08/02/2028

Design Type

[Rupture Disk Device] CDCV (CF)
 HolderDesignation: Clean-sweep CU8, CU9, CR8, CR9
 Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on July 14, 2000
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 2.540 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			30-2160 psi		UD
1.5 NPS		2.04 in ²			18-2160 psi		UD
10 NPS		78.85 in ²			5-720 psi		UD
12 NPS		113.1 in ²			4-720 psi		UD
14 NPS		137.89 in ²			4-720 psi		UD
16 NPS		182.65 in ²			4-720 psi		UD
18 NPS		233.71 in ²			4-720 psi		UD
2 NPS		3.36 in ²			10-2160 psi		UD
20 NPS		291.04 in ²			4-275 psi		UD
24 NPS		424.56 in ²			4-275 psi		UD
28 NPS		583.21 in ²			4-275 psi		UD
3 NPS		7.39 in ²			6.5-1440 psi		UD
30 NPS		671.96 in ²			4-275 psi		UD
32 NPS		766.99 in ²			4-275 psi		UD
36 NPS		975.91 in ²			4-275 psi		UD
4 NPS		12.73 in ²			7-1440 psi		UD
6 NPS		28.89 in ²			5-1440 psi		UD

8 NPS	50.03 in ²	5-720 psi	UD
-------	-----------------------	-----------	----

Design Name: CDCV (FS threaded)		NBCert #	75338
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	04/30/2026
Design Type			
[Rupture Disk Device] CDCV (FS threaded) HolderDesignation: Tite-seal, screw type, throwaway Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on April 26, 1999 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 5.730 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Continental Disc Corporation, LLC {CDC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125 NPS		0.01 in ²			30-3000 psi		UD
0.25 NPS		0.04 in ²			30-3000 psi		UD
0.375 NPS		0.1 in ²			30-3000 psi		UD
0.5 NPS		0.17 in ²			30-3000 psi		UD
0.75 NPS		0.29 in ²			30-3000 psi		UD
1 NPS		0.52 in ²			30-3000 psi		UD
1.25 NPS		1.05 in ²			25-3000 psi		UD

Design Name: CDCV (FS)		NBCert #	75046
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	03/24/2031
Design Type			
[Rupture Disk Device] CDCV (FS) HolderDesignation: RHI, UNISERT, Flat Seat Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on February 13, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 1.040 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Continental Disc Corporation, LLC {CDC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			30-2160 psi		UD
1.5 NPS		2.04 in ²			18-2160 psi		UD
10 NPS		78.85 in ²			5-720 psi		UD
12 NPS		113.1 in ²			4-720 psi		UD
14 NPS		137.9 in ²			4-720 psi		UD
16 NPS		182.7 in ²			4-720 psi		UD
18 NPS		233.7 in ²			4-720 psi		UD
2 NPS		3.36 in ²			10-2160 psi		UD

20 NPS	291 in ²	4-275 psi	UD
24 NPS	424.6 in ²	4-275 psi	UD
28 NPS	583.2 in ²	4-275 psi	UD
3 NPS	7.39 in ²	6.5-1440 psi	UD
30 NPS	672 in ²	4-275 psi	UD
32 NPS	767 in ²	4-275 psi	UD
36 NPS	975.9 in ²	4-275 psi	UD
38 NPS	1090 in ²	4-275 psi	UD
4 NPS	12.73 in ²	7-1440 psi	UD
40 NPS	1210 in ²	4-275 psi	UD
42 NPS	1336 in ²	4-275 psi	UD
44 NPS	1469 in ²	4-275 psi	UD
46 NPS	1608 in ²	4-275 psi	UD
48 NPS	1753 in ²	4-275 psi	UD
6 NPS	28.89 in ²	5-1440 psi	UD
8 NPS	50.03 in ²	5-720 psi	UD

Design Name: CDCV (FS) (No Options) NBCert # 75215

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/27/2025

Design Type

[Rupture Disk Device] CDCV (FS) (No Options)
 HolderDesignation: RHI, UNISERT
 Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on October 27, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 0.530 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			30-2160 psi		UD
1.5 NPS		2.04 in ²			18-2160 psi		UD
10 NPS		78.85 in ²			5-720 psi		UD
12 NPS		113.1 in ²			4-720 psi		UD
14 NPS		137.89 in ²			4-720 psi		UD
16 NPS		182.65 in ²			4-720 psi		UD
18 NPS		233.71 in ²			4-720 psi		UD
2 NPS		3.36 in ²			10-2160 psi		UD
20 NPS		291.04 in ²			4-275 psi		UD
24 NPS		424.56 in ²			4-275 psi		UD
28 NPS		583.21 in ²			4-40 psi		UD
3 NPS		7.39 in ²			6.5-1440 psi		UD
30 NPS		671.96 in ²			4-40 psi		UD

32 NPS	766.99 in ²	4-40 psi	UD
36 NPS	975.91 in ²	4-275 psi	UD
38 NPS	1090 in ²	4-275 psi	UD
4 NPS	12.73 in ²	7-1440 psi	UD
40 NPS	1210 in ²	4-275 psi	UD
42 NPS	1336 in ²	4-275 psi	UD
44 NPS	1469 in ²	4-275 psi	UD
46 NPS	1608 in ²	4-275 psi	UD
48 NPS	1753 in ²	4-275 psi	UD
6 NPS	28.89 in ²	5-1440 psi	UD
8 NPS	50.03 in ²	5-720 psi	UD

Design Name:	CDCV , LDV (LL)	NBCert #	75507
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	10/03/2025
--------------	----	------------

Design Type

[Rupture Disk Device] CDCV , LDV (LL)
HolderDesignation: Insert, Full bolted #1 - #9, Union 2U, 3U, 5U, 6U
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on June 10, 2003
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 2.800 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.72 in ²			30-2160 psi		UD
1.5 NPS		1.77 in ²			25-2160 psi		UD
10 NPS		78.85 in ²			5-720 psi		UD
12 NPS		113.1 in ²			4-720 psi		UD
14 NPS		137.9 in ²			4-720 psi		UD
16 NPS		182.7 in ²			4-720 psi		UD
18 NPS		233.7 in ²			4-720 psi		UD
2 NPS		3.36 in ²			10-2160 psi		UD
20 NPS		291 in ²			4-720 psi		UD
24 NPS		425.6 in ²			4-275 psi		UD
3 NPS		7.39 in ²			7-1440 psi		UD
30 NPS		672 in ²			4-275 psi		UD
4 NPS		12.73 in ²			7-1440 psi		UD
6 NPS		28.89 in ²			5-1440 psi		UD
8 NPS		50.03 in ²			5-1440 psi		UD

Design Name:	ENVIRO-SEAL, Isolation Seal	NBCert #	75013
--------------	-----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	03/24/2031

Design Type

[Rupture Disk Device] ENVIRO-SEAL, Isolation Seal
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on February 13, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 2.000 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			15-275 psi		UD
1.5 NPS		2.04 in ²			10-275 psi		UD
10 NPS		78.85 in ²			1.2-275 psi		UD
12 NPS		113.1 in ²			1-275 psi		UD
14 NPS		137.89 in ²			1-275 psi		UD
16 NPS		182.65 in ²			1-275 psi		UD
18 NPS		233.71 in ²			1-275 psi		UD
2 NPS		3.36 in ²			6-275 psi		UD
20 NPS		291.04 in ²			1-275 psi		UD
24 NPS		424.56 in ²			1-275 psi		UD
3 NPS		7.39 in ²			4-275 psi		UD
30 NPS		671.96 in ²			1-275 psi		UD
32 NPS		766.99 in ²			1-275 psi		UD
36 NPS		975.91 in ²			1-275 psi		UD
4 NPS		12.73 in ²			2.9-275 psi		UD
6 NPS		28.89 in ²			2-275 psi		UD
8 NPS		50.03 in ²			1.6-275 psi		UD

Design Name:	HPX (DD)	NBCert #	75664
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/27/2029

Design Type

[Rupture Disk Device] HPX (DD)
HolderDesignation: HPX (DD), ULTRX
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on June 22, 2011
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.970 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			15-2160 psi		UD
1.5 NPS		2.04 in ²			10-2160 psi		UD
10 NPS		78.8 in ²			9-720 psi		UD
12 NPS		113.1 in ²			9-720 psi		UD
2 NPS		3.36 in ²			10-1440 psi		UD
3 NPS		7.39 in ²			9-1440 psi		UD
3.5 NPS		9.89 in ²			9-1440 psi		UD
4 NPS		12.7 in ²			9-1440 psi		UD
6 NPS		28.8 in ²			9-720 psi		UD
8 NPS		50 in ²			9-720 psi		UD

Design Name:	HPX (FS)(GAS)	NBCert #	75585
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	12/03/2026

Design Type

[Rupture Disk Device] HPX (FS)(GAS)
HolderDesignation: Star-X, HPX, HPX-RH, HPX-PT, HPX-PT-RH, VRD, ULTRX, HPX-CTG, HPX-CTG-RH
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on October 21, 2009
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.290 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			15-2160 psi		UD
1.5 NPS		2.04 in ²			10-2160 psi		UD
10 NPS		78.8 in ²			9-720 psi		UD
12 NPS		113.1 in ²			9-720 psi		UD
2 NPS		3.36 in ²			10-1440 psi		UD
3 NPS		7.39 in ²			9-1440 psi		UD
3.5 NPS		9.89 in ²			9-1440 psi		UD
4 NPS		12.73 in ²			9-1440 psi		UD
6 NPS		28.89 in ²			9-720 psi		UD
8 NPS		50.03 in ²			9-720 psi		UD

Design Name:	HPX (FS)(Liquid)	NBCert #	75596
--------------	------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	12/03/2026

Design Type

[Rupture Disk Device] HPX (FS)(Liquid)
 HolderDesignation: Star-X, HPX, HPX-RH, HPX-PT, HPX-PT-RH, VRD, ULTRX, HPX-CTG, HPX-CTG-RH
 Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on October 21, 2009
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 0.380 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			15-2160 psi		UD
1.5 NPS		2.04 in ²			10-2160 psi		UD
10 NPS		78.8 in ²			9-720 psi		UD
12 NPS		113.1 in ²			9-720 psi		UD
2 NPS		3.36 in ²			10-1440 psi		UD
3 NPS		7.39 in ²			9-1440 psi		UD
3.5 NPS		9.89 in ²			9-1440 psi		UD
4 NPS		12.73 in ²			9-1440 psi		UD
6 NPS		28.89 in ²			9-720 psi		UD
8 NPS		50.03 in ²			9-720 psi		UD

Design Name: HPX Sanitary, Sanitrx HPX, Sanitrx LPX (SF,NA,IS)(Gas) NBCert # 75608

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	12/02/2026

Design Type

[Rupture Disk Device] HPX Sanitary, Sanitrx HPX, Sanitrx LPX (SF,NA,IS)(Gas)
 Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on October 29, 2009
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 1.130 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.265 in ²			40-400 psi		UD
1 NPS		0.493 in ²			25-300 psi		UD
1.5 NPS		1.18 in ²			4-200 psi		UD
2 NPS		2.25 in ²			4-150 psi		UD
3 NPS		5.49 in ²			4-100 psi		UD

Design Name: HPX Sanitary, Sanitrx HPX, Sanitrx LPX (SF,NA,IS)(Liquid) NBCert # 75619

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	12/03/2026

Design Type

[Rupture Disk Device] HPX Sanitary, Sanitrx HPX, Sanitrx LPX (SF,NA,IS)(Liquid)
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on October 29, 2009
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 1.600 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.265 in ²			40-400 psi		UD
1 NPS		0.493 in ²			25-300 psi		UD
1.5 NPS		1.18 in ²			4-200 psi		UD
2 NPS		2.25 in ²			4-150 psi		UD
3 NPS		5.49 in ²			4-100 psi		UD

Design Name: IntegrX-HPX NBCert # 75743

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

07/28/2027

Design Type

[Rupture Disk Device] IntegrX-HPX
HolderDesignation: N/A
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on April 23, 2021
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 1.880 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.265 in ²			100-250 psi		UD
1 NPS		0.493 in ²			30-250 psi		UD
1.5 NPS		1.18 in ²			20-500 psi		UD
2 NPS		2.25 in ²			20-450 psi		UD
3 NPS		5.49 in ²			15-175 psi		UD
4 NPS		9.77 in ²			15-100 psi		UD

Design Name: KBA NBCert # 75035

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

02/13/2030

Design Type

[Rupture Disk Device] KBA
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on February 12, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 3.620 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.72 in ²			35-2160 psi		UD
1.5 NPS		1.77 in ²			30-2160 psi		UD
10 NPS		71.81 in ²			18-720 psi		UD
12 NPS		101.6 in ²			18-275 psi		UD
14 NPS		122.7 in ²			17-275 psi		UD
16 NPS		160.9 in ²			16-275 psi		UD
18 NPS		204.2 in ²			15-275 psi		UD
2 NPS		2.95 in ²			26-2160 psi		UD
20 NPS		252.7 in ²			12-275 psi		UD
24 NPS		365.2 in ²			12-275 psi		UD
28 NPS		498.2 in ²			11-275 psi		UD
3 NPS		6.61 in ²			24-1440 psi		UD
30 NPS		572.5 in ²			10-275 psi		UD
32 NPS		651.9 in ²			9-275 psi		UD
4 NPS		11.5 in ²			23-1440 psi		UD
6 NPS		26.07 in ²			20-1440 psi		UD
8 NPS		45.66 in ²			15-720 psi		UD

Design Name:	LOTRX (Gas)	NBCert #	75620
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	04/21/2027
--------------	----	------------

Design Type

[Rupture Disk Device] LOTRX (Gas)
HolderDesignation: LOTRX
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on January 28, 2010
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.420 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			2-40 psi		UD
1.5 NPS		2.04 in ²			2-30 psi		UD
2 NPS		3.36 in ²			2-25 psi		UD
3 NPS		7.39 in ²			1-22 psi		UD
4 NPS		12.73 in ²			1-22 psi		UD
6 NPS		28.89 in ²			1-20 psi		UD
8 NPS		50.03 in ²			1-35 psi		UD

Design Name:	LOTRX (Liquid)	NBCert #	75631
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	04/22/2027

Design Type

[Rupture Disk Device] LOTRX (Liquid)
HolderDesignation: LOTRX
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on February 11, 2010
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 0.420 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			2-40 psi		UD
1.5 NPS		2.04 in ²			2-30 psi		UD
2 NPS		3.36 in ²			2-25 psi		UD
3 NPS		7.39 in ²			1-22 psi		UD
4 NPS		12.73 in ²			1-22 psi		UD
6 NPS		28.89 in ²			1-20 psi		UD
8 NPS		50.03 in ²			1-35 psi		UD

Design Name:	MICRO X, MX-9T & SCORED FLAT SEAT	NBCert #	75079
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	03/24/2031

Design Type

[Rupture Disk Device] MICRO X, MX-9T & SCORED FLAT SEAT
HolderDesignation: RHI, UNISERT, FLAT SEAT, MX-9T, MX-9T-RH
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on February 12, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.290 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			140-6000 psi		UD
1.5 NPS		2.04 in ²			120-6000 psi		UD
10 NPS		78.85 in ²			40-720 psi		UD
12 NPS		113.1 in ²			35-720 psi		UD
14 NPS		137.89 in ²			21-720 psi		UD
16 NPS		182.65 in ²			18-720 psi		UD
18 NPS		233.71 in ²			16-720 psi		UD
2 NPS		3.36 in ²			55-6000 psi		UD
20 NPS		291.04 in ²			15-720 psi		UD

24 NPS	424.56 in ²	15-720 psi	UD
28 NPS	583.21 in ²	15-720 psi	UD
3 NPS	7.39 in ²	50-6000 psi	UD
30 NPS	671.96 in ²	15-720 psi	UD
32 NPS	766.99 in ²	15-720 psi	UD
36 NPS	975.91 in ²	15-275 psi	UD
4 NPS	12.73 in ²	50-6000 psi	UD
6 NPS	28.89 in ²	45-6000 psi	UD
8 NPS	50.03 in ²	40-6000 psi	UD

Design Name:	MICRO X, MX-9T (CF)	NBCert #	75383
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 08/02/2028

Design Type

[Rupture Disk Device] MICRO X, MX-9T (CF)
 HolderDesignation: CU8, CU9, CR8, CR9
 Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on July 12, 2000
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 1.520 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			140-6000 psi		UD
1.5 NPS		2.04 in ²			120-6000 psi		UD
10 NPS		78.85 in ²			40-720 psi		UD
12 NPS		113.1 in ²			35-720 psi		UD
14 NPS		137.9 in ²			21-720 psi		UD
16 NPS		182.7 in ²			18-720 psi		UD
18 NPS		233.7 in ²			16-720 psi		UD
2 NPS		3.36 in ²			55-6000 psi		UD
20 NPS		291 in ²			15-720 psi		UD
24 NPS		424.6 in ²			15-720 psi		UD
28 NPS		583.2 in ²			15-720 psi		UD
3 NPS		7.39 in ²			50-6000 psi		UD
30 NPS		672 in ²			15-720 psi		UD
32 NPS		767 in ²			15-720 psi		UD
36 NPS		975.9 in ²			15-275 psi		UD
4 NPS		12.73 in ²			50-6000 psi		UD
6 NPS		28.89 in ²			45-6000 psi		UD
8 NPS		50.03 in ²			40-6000 psi		UD

Design Name:	MICRO X-V(DD), MICRO X, MX-9T-V, MX-9T	NBCert #	75473
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UD	01/17/2031	
Design Type			
[Rupture Disk Device] MICRO X-V(DD), MICRO X, MX-9T-V, MX-9T HolderDesignation: UNISERT (DD), MX-9T (DD) Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on January 2, 2003 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 5.590 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Continental Disc Corporation, LLC {CDC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			140-6000 psi		UD
1.5 NPS		2.04 in ²			120-6000 psi		UD
10 NPS		78.85 in ²			40-720 psi		UD
12 NPS		113.1 in ²			35-720 psi		UD
14 NPS		137.9 in ²			21-720 psi		UD
16 NPS		182.6 in ²			18-720 psi		UD
18 NPS		233.7 in ²			16-720 psi		UD
2 NPS		3.36 in ²			55-3600 psi		UD
20 NPS		291 in ²			15-720 psi		UD
24 NPS		424.6 in ²			15-720 psi		UD
28 NPS		583.2 in ²			15-720 psi		UD
3 NPS		7.39 in ²			50-3600 psi		UD
30 NPS		672 in ²			15-720 psi		UD
32 NPS		767 in ²			15-720 psi		UD
36 NPS		975.9 in ²			15-275 psi		UD
4 NPS		12.73 in ²			50-3600 psi		UD
6 NPS		28.89 in ²			45-1440 psi		UD
8 NPS		50.03 in ²			40-1440 psi		UD

Design Name:	MICRO X-V, MX-9T-V & SCORED FLAT SEAT	NBCert #	75080
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UD	03/24/2031	
Design Type			
[Rupture Disk Device] MICRO X-V, MX-9T-V & SCORED FLAT SEAT HolderDesignation: RHI, UNISERT, FLAT SEAT, MX-9T, MX-9T-RH Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on February 13, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.290 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Continental Disc Corporation, LLC {CDC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			140-6000 psi		UD
1.5 NPS		2.04 in ²			120-6000 psi		UD
10 NPS		78.85 in ²			40-720 psi		UD
12 NPS		113.1 in ²			35-720 psi		UD
14 NPS		137.89 in ²			21-720 psi		UD
16 NPS		182.65 in ²			18-720 psi		UD
18 NPS		233.71 in ²			16-720 psi		UD
2 NPS		3.36 in ²			55-3600 psi		UD
20 NPS		291.04 in ²			15-720 psi		UD
24 NPS		424.56 in ²			15-720 psi		UD
28 NPS		583.21 in ²			15-720 psi		UD
3 NPS		7.39 in ²			50-3600 psi		UD
30 NPS		671.96 in ²			15-720 psi		UD
32 NPS		766.99 in ²			15-720 psi		UD
36 NPS		975.91 in ²			15-275 psi		UD
4 NPS		12.73 in ²			50-3600 psi		UD
6 NPS		28.89 in ²			45-1440 psi		UD
8 NPS		50.03 in ²			40-1440 psi		UD

Design Name: MICRO-X-V, MX-9T-V Flat Seat (liquid) NBCert # 75181

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 05/13/2031

Design Type

[Rupture Disk Device] MICRO-X-V, MX-9T-V Flat Seat (liquid)
HolderDesignation: RHI, Unisert and Flat Seat, MX-9T, MX-9T-RH
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on May 13, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 1.100 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			140-6000 psi		UD
1.5 NPS		2.04 in ²			120-6000 psi		UD
10 NPS		78.85 in ²			40-720 psi		UD
12 NPS		113.1 in ²			35-720 psi		UD
14 NPS		137.9 in ²			21-720 psi		UD
16 NPS		182.7 in ²			18-720 psi		UD
18 NPS		233.7 in ²			15-720 psi		UD
2 NPS		3.36 in ²			55-3600 psi		UD
20 NPS		291 in ²			15-720 psi		UD

24 NPS	424.6 in ²	75-720 psi	UD
28 NPS	583.2 in ²	64-720 psi	UD
3 NPS	7.39 in ²	50-3600 psi	UD
30 NPS	672 in ²	60-720 psi	UD
32 NPS	767 in ²	56-720 psi	UD
36 NPS	975.9 in ²	50-275 psi	UD
4 NPS	12.73 in ²	50-3600 psi	UD
6 NPS	28.89 in ²	45-1440 psi	UD
8 NPS	50.03 in ²	40-1440 psi	UD

Design Name:	Micro-X-V, MX-9T-V (CF)	NBCert #	75394
--------------	-------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 03/17/2027

Design Type

[Rupture Disk Device] Micro-X-V, MX-9T-V (CF)
HolderDesignation: Clean-sweep, CU8, CU9, CR8, CR9
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on July 18, 2000
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 1.740 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			140-6000 psi		UD
1.5 NPS		2.04 in ²			120-6000 psi		UD
10 NPS		78.85 in ²			40-720 psi		UD
12 NPS		113.1 in ²			35-720 psi		UD
14 NPS		137.9 in ²			21-720 psi		UD
16 NPS		182.7 in ²			18-720 psi		UD
18 NPS		233.7 in ²			16-720 psi		UD
2 NPS		3.36 in ²			55-3600 psi		UD
20 NPS		291 in ²			15-720 psi		UD
24 NPS		424.6 in ²			15-720 psi		UD
28 NPS		583.2 in ²			15-720 psi		UD
3 NPS		7.39 in ²			50-3600 psi		UD
30 NPS		672 in ²			15-720 psi		UD
32 NPS		767 in ²			15-720 psi		UD
36 NPS		975.9 in ²			15-275 psi		UD
4 NPS		12.73 in ²			50-3600 psi		UD
6 NPS		28.89 in ²			45-1440 psi		UD
8 NPS		50.03 in ²			40-1440 psi		UD

Design Name:	MINTRX (gas)	NBCert #	75552
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/18/2025

Design Type

[Rupture Disk Device] MINTRX (gas)
HolderDesignation: MINTRX
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on July 21, 2008
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.450 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			50-275 psi		UD
1.5 NPS		2.04 in ²			45-275 psi		UD
2 NPS		3.36 in ²			35-275 psi		UD
3 NPS		7.39 in ²			25-275 psi		UD
4 NPS		12.73 in ²			20-275 psi		UD
6 NPS		28.89 in ²			15-275 psi		UD
8 NPS		50.03 in ²			15-275 psi		UD

Design Name:	MINTRX (liquid)	NBCert #	75541
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/18/2025

Design Type

[Rupture Disk Device] MINTRX (liquid)
HolderDesignation: MINTRX
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on July 21, 2008
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 0.500 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			50-275 psi		UD
1.5 NPS		2.04 in ²			45-275 psi		UD
2 NPS		3.36 in ²			35-275 psi		UD
3 NPS		7.39 in ²			25-275 psi		UD
4 NPS		12.73 in ²			20-275 psi		UD
6 NPS		28.89 in ²			15-275 psi		UD
8 NPS		50.03 in ²			15-275 psi		UD

Design Name:	MINTRX (No Options)	NBCert #	75237
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 05/13/2031

Design Type

[Rupture Disk Device] MINTRX (No Options)
HolderDesignation: MINTRX
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on May 13, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.460 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			50-275 psi		UD
1.5 NPS		2.04 in ²			45-275 psi		UD
2 NPS		3.36 in ²			35-275 psi		UD
3 NPS		7.39 in ²			25-275 psi		UD
4 NPS		12.73 in ²			20-275 psi		UD
6 NPS		28.89 in ²			15-275 psi		UD
8 NPS		50.03 in ²			15-275 psi		UD

Design Name:	MRD	NBCert #	75798
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/18/2030

Design Type

[Rupture Disk Device] MRD
HolderDesignation: MRD
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on December 29, 2023
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 15.000 Unitless; (alternate medium): 0.000
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125 NPS		0.01 in ²			7000-10000 psi		UD
0.5 NPS		0.17 in ²			5000-6000 psi		UD
0.75 NPS		0.29 in ²			4000-6000 psi		UD
1 NPS		0.52 in ²			4000-6000 psi		UD

Design Name:	PL (CF)	NBCert #	75349
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 08/02/2028

Design Type

[Rupture Disk Device] PL (CF)
 HolderDesignation: Clean Sweep CU8, CU9, CR8, CR9
 Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on July 19, 2000
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 1.570 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			35-2160 psi		UD
1.5 NPS		2.04 in ²			32-2160 psi		UD
10 NPS		78.85 in ²			5-720 psi		UD
12 NPS		113.1 in ²			5-720 psi		UD
14 NPS		137.9 in ²			5-720 psi		UD
16 NPS		182.7 in ²			5-720 psi		UD
18 NPS		233.7 in ²			5-720 psi		UD
2 NPS		3.36 in ²			15-2160 psi		UD
20 NPS		291 in ²			5-275 psi		UD
24 NPS		424.6 in ²			5-275 psi		UD
28 NPS		583.2 in ²			5-275 psi		UD
3 NPS		7.39 in ²			11-1440 psi		UD
30 NPS		672 in ²			5-275 psi		UD
32 NPS		767 in ²			5-275 psi		UD
36 NPS		975.9 in ²			5-275 psi		UD
4 NPS		12.73 in ²			6-1440 psi		UD
6 NPS		28.89 in ²			5-1440 psi		UD
8 NPS		50.03 in ²			4-720 psi		UD

Design Name: PL, PLV, LPL, LPLV (Flat Seat) NBCert # 75169

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	05/13/2031

Design Type

[Rupture Disk Device] PL, PLV, LPL, LPLV (Flat Seat)
 HolderDesignation: RHI, Unisert, Flat Seat
 Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on May 14, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 1.600 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			35-2160 psi		UD
1.5 NPS		2.04 in ²			32-2160 psi		UD
10 NPS		78.85 in ²			5-720 psi		UD

12 NPS	113.1 in ²	5-720 psi	UD
14 NPS	137.9 in ²	5-720 psi	UD
16 NPS	182.7 in ²	5-720 psi	UD
18 NPS	233.7 in ²	5-720 psi	UD
2 NPS	3.36 in ²	15-2160 psi	UD
20 NPS	291 in ²	5-275 psi	UD
24 NPS	424.6 in ²	5-275 psi	UD
28 NPS	583.2 in ²	5-275 psi	UD
3 NPS	7.39 in ²	8-1440 psi	UD
30 NPS	672 in ²	5-275 psi	UD
32 NPS	767 in ²	5-275 psi	UD
36 NPS	975.9 in ²	5-275 psi	UD
4 NPS	12.73 in ²	6-1440 psi	UD
6 NPS	28.89 in ²	5-1440 psi	UD
8 NPS	50.03 in ²	4-720 psi	UD

Design Name: PL, PLV, LPL, LPLV (Angular seat) NBCert # 75170

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 08/14/2025

Design Type

[Rupture Disk Device] PL, PLV, LPL, LPLV (Angular seat)
 HolderDesignation: Insert, Full bolted #1 thru #9, Union 2U, 3U, 5U,6U
 Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on May 14, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 5.000 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.52 in ²			35-2160 psi		UD
1.5 NPS		1.4 in ²			32-2160 psi		UD
10 NPS		78.85 in ²			5-720 psi		UD
12 NPS		113.1 in ²			5-720 psi		UD
14 NPS		137.9 in ²			5-720 psi		UD
16 NPS		182.7 in ²			5-720 psi		UD
18 NPS		233.7 in ²			5-720 psi		UD
2 NPS		3.36 in ²			15-2160 psi		UD
20 NPS		291 in ²			5-720 psi		UD
24 NPS		424.6 in ²			5-275 psi		UD
3 NPS		7.39 in ²			11-1440 psi		UD
30 NPS		672 in ²			5-275 psi		UD
4 NPS		12.73 in ²			6-1440 psi		UD
6 NPS		28.89 in ²			5-1440 psi		UD

Design Name: PLV (CF)		NBCert #	75350
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	08/02/2028
Design Type			
[Rupture Disk Device] PLV (CF) HolderDesignation: Clean Sweep CU8, CU9, CR8, CR9 Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on July 18, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 2.640 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Continental Disc Corporation, LLC {CDC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in²			60-2160 psi		UD
1.5 NPS		2.04 in²			60-2160 psi		UD
10 NPS		78.85 in²			8-720 psi		UD
12 NPS		113.1 in²			8-720 psi		UD
14 NPS		137.9 in²			8-720 psi		UD
16 NPS		182.7 in²			8-720 psi		UD
18 NPS		233.7 in²			8-720 psi		UD
2 NPS		3.36 in²			28-2160 psi		UD
20 NPS		291 in²			8-275 psi		UD
24 NPS		424.6 in²			8-275 psi		UD
28 NPS		583.2 in²			8-275 psi		UD
3 NPS		7.39 in²			8-1440 psi		UD
30 NPS		275 in²			8-275 psi		UD
32 NPS		767 in²			8-275 psi		UD
36 NPS		975.9 in²			8-275 psi		UD
4 NPS		12.73 in²			15-1440 psi		UD
6 NPS		28.89 in²			12-1440 psi		UD
8 NPS		50.03 in²			11-720 psi		UD

Design Name: RCS		NBCert #	75147
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	02/13/2031
Design Type			
[Rupture Disk Device] RCS Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on February 13, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.590 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Continental Disc Corporation, LLC {CDC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			115-2160 psi		UD
1.5 NPS		2.04 in ²			83-2160 psi		UD
2 NPS		3.36 in ²			70-1440 psi		UD
3 NPS		7.39 in ²			65-1440 psi		UD
4 NPS		12.73 in ²			55-1440 psi		UD
6 NPS		28.89 in ²			40-1440 psi		UD
8 NPS		50.03 in ²			35-1440 psi		UD
10 NPS	NPS	78.85 in ²	0 in	0 in	30-1440 psi		UD
12 NPS	NPS	113.1 in ²	0 in	0 in	25-1440 psi		UD
14 NPS	NPS	137.9 in ²	0 in	0 in	20-720 psi		UD
16 NPS	NPS	182.7 in ²	0 in	0 in	20-720 psi		UD
18 NPS	NPS	233.7 in ²	0 in	0 in	20-720 psi		UD
20 NPS	NPS	291 in ²	0 in	0 in	20-720 psi		UD
24 NPS	NPS	424.6 in ²	0 in	0 in	20-275 psi		UD
30 NPS	NPS	672 in ²	0 in	0 in	20-275 psi		UD
32 NPS	NPS	767 in ²	0 in	0 in	20-275 psi		UD

Design Name: RCS (DD)		NBCert # 75518	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	10/03/2025
Design Type			
[Rupture Disk Device] RCS (DD) HolderDesignation: RCS (DD) Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on September 23, 2003 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.600 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Continental Disc Corporation, LLC {CDC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			115-2160 psi		UD
1.5 NPS		2.04 in ²			83-2160 psi		UD
10 NPS		78.85 in ²			30-1440 psi		UD
12 NPS		113.1 in ²			25-1440 psi		UD
14 NPS		137.9 in ²			20-720 psi		UD
16 NPS		182.7 in ²			20-720 psi		UD
18 NPS		233.7 in ²			20-720 psi		UD
2 NPS		3.36 in ²			70-1440 psi		UD
20 NPS		291 in ²			20-720 psi		UD
24 NPS		424.6 in ²			20-275 psi		UD
3 NPS		7.39 in ²			65-1440 psi		UD

30 NPS	672 in ²	20-275 psi	UD
32 NPS	767 in ²	20-275 psi	UD
4 NPS	12.73 in ²	55-1440 psi	UD
6 NPS	28.89 in ²	40-1440 psi	UD
8 NPS	50.03 in ²	35-1440 psi	UD

Design Name:	RCS (No Options)	NBCert #	75226
--------------	------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 05/14/2031

Design Type

[Rupture Disk Device] RCS (No Options)
HolderDesignation: RCS
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on May 14, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.350 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			115-2160 psi		UD
1.5 NPS		2.04 in ²			83-2160 psi		UD
10 NPS		78.85 in ²			30-1440 psi		UD
12 NPS		113.1 in ²			25-1440 psi		UD
14 NPS		137.9 in ²			20-720 psi		UD
16 NPS		182.7 in ²			20-720 psi		UD
18 NPS		233.7 in ²			20-720 psi		UD
2 NPS		3.36 in ²			70-1440 psi		UD
20 NPS		291 in ²			20-720 psi		UD
24 NPS		424.6 in ²			20-275 psi		UD
3 NPS		7.39 in ²			65-1440 psi		UD
30 NPS		672 in ²			20-275 psi		UD
32 NPS		767 in ²			20-275 psi		UD
4 NPS		12.73 in ²			55-1440 psi		UD
6 NPS		28.89 in ²			40-1440 psi		UD
8 NPS		50.03 in ²			35-1440 psi		UD

Design Name:	Sanitrx , Sanitrx NA (liquid)	NBCert #	75451
--------------	-------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/17/2031

Design Type

[Rupture Disk Device] Sanitrx , Sanitrx NA (liquid)
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on January 7, 2003
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 1.600 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.493 in ²			25-1500 psi		UD
1.5 NPS		1.18 in ²			14-1500 psi		UD
2 NPS		2.25 in ²			11-1000 psi		UD
3 NPS		5.49 in ²			10-1000 psi		UD
4 NPS		9.77 in ²			10-1000 psi		UD

Design Name: Sanitrx , Sanitrx-NA(Air/Gas) NBCert # 75462

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

01/17/2031

Design Type

[Rupture Disk Device] Sanitrx , Sanitrx-NA(Air/Gas)
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on January 7, 2003
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 1.130 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.493 in ²			25-1500 psi		UD
1.5 NPS		1.18 in ²			14-1500 psi		UD
2 NPS		2.25 in ²			11-1000 psi		UD
3 NPS		5.49 in ²			10-1000 psi		UD
4 NPS		9.77 in ²			10-1000 psi		UD

Design Name: SANITRX HPX II (SF, NA, IS)(GAS) NBCert # 75675

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

10/27/2029

Design Type

[Rupture Disk Device] SANITRX HPX II (SF, NA, IS)(GAS)
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on June 17, 2011
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 1.600 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.49 in ²			300-1500 psi		UD
1.5 NPS		1.18 in ²			200-1500 psi		UD
2 NPS		2.25 in ²			150-1000 psi		UD
3 NPS		5.49 in ²			100-1000 psi		UD
4 NPS		9.77 in ²			10-1000 psi		UD

Design Name: SANITRX HPX II (SF, NA, IS)(Liquid) NBCert # 75686

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/26/2029

Design Type

[Rupture Disk Device] SANITRX HPX II (SF, NA, IS)(Liquid)
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on June 17, 2011
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 1.880 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.49 in ²			300-1500 psi		UD
1.5 NPS		1.18 in ²			200-1500 psi		UD
2 NPS		2.25 in ²			150-1000 psi		UD
3 NPS		5.49 in ²			100-1000 psi		UD
4 NPS		9.77 in ²			10-1000 psi		UD

Design Name: Sanitrx LP, Sanitrx LP-NA NBCert # 75440

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/17/2031

Design Type

[Rupture Disk Device] Sanitrx LP, Sanitrx LP-NA
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on December 17, 2002
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.290 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.493 in ²			25-250 psi		UD
1.5 NPS		1.18 in ²			10-60 psi		UD
2 NPS		2.25 in ²			10-60 psi		UD
3 NPS		5.49 in ²			10-60 psi		UD
4 NPS		9.77 in ²			10-60 psi		UD

Design Name:	SANITRX MP (SF, NA, IS) (gas)	NBCert #	75574
--------------	-------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	03/11/2026

Design Type

[Rupture Disk Device] SANITRX MP (SF, NA, IS) (gas)
HolderDesignation: N/A
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on November 20, 2008
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 1.130 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.493 in ²			35-100 psi		UD
1.5 NPS		1.18 in ²			15-100 psi		UD
2 NPS		2.25 in ²			15-100 psi		UD
3 NPS		5.49 in ²			10-60 psi		UD

Design Name:	SANITRX MP (SF, NA, IS) (liquid)	NBCert #	75563
--------------	----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	03/11/2026

Design Type

[Rupture Disk Device] SANITRX MP (SF, NA, IS) (liquid)
HolderDesignation: N/A
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on November 3, 2008
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 1.600 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.493 in ²			35-100 psi		UD
1.5 NPS		1.18 in ²			15-100 psi		UD
2 NPS		2.25 in ²			15-100 psi		UD
3 NPS		5.49 in ²			10-60 psi		UD

Design Name:	Sanitrx, Sanitrx LP-NA (liquid)	NBCert #	75439
--------------	---------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/17/2031

Design Type

[Rupture Disk Device] Sanitrx, Sanitrx LP-NA (liquid)
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on December 17, 2002
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 0.320 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.493 in ²			25-250 psi		UD
1.5 NPS		1.18 in ²			10-60 psi		UD
2 NPS		2.25 in ²			10-60 psi		UD
3 NPS		5.49 in ²			10-60 psi		UD
4 NPS		9.77 in ²			10-60 psi		UD

Design Name: SRA (FS) NBCert # 75282

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	04/30/2026

Design Type

[Rupture Disk Device] SRA (FS)
HolderDesignation: SRA Tite seal, SRA screw type, SRA Insert, WSRA, SRA Union
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on April 15, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 3.590 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125 NPS		0.04 in ²			35-3600 psi		UD
0.25 NPS		0.07 in ²			35-3600 psi		UD
0.375 NPS		0.14 in ²			35-3600 psi		UD
0.5 NPS		0.23 in ²			35-3600 psi		UD
0.75 NPS		0.43 in ²			15-2000 psi		UD
1 NPS		0.72 in ²			10-2000 psi		UD
1.25 NPS		1.28 in ²			10-1000 psi		UD

Design Name: SRA (Gas) NBCert # 75697

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	12/05/2030

Design Type

[Rupture Disk Device] SRA (Gas)
HolderDesignation: Screw Type Tite-Seal
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on October 13, 2012
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.850 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.25 NPS		0.049 in ²			35-1000 psi	Air	UD
0.375-0.375 NPS		0.11 in ²			35-1000 psi	Air	UD
0.5-0.5 NPS		0.169 in ²			35-1000 psi	Air	UD

Design Name: SRA (Liquid) NBCert # 75709

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	12/05/2030

Design Type

[Rupture Disk Device] SRA (Liquid)
HolderDesignation: Screw Type Tite-Seal
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on October 13, 2012
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.650 Unitless
Media - ; Certified: Liquid
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.25 NPS		0.049 in ²			35-1000 psi	Water	UD
0.375-0.375 NPS		0.11 in ²			35-1000 psi	Water	UD
0.5-0.5 NPS		0.169 in ²			35-1000 psi	Water	UD

Design Name: SRA RVI (FS) NBCert # 75406

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	03/17/2027

Design Type

[Rupture Disk Device] SRA RVI (FS)
HolderDesignation: RVI, RVI Tite-Seal, RVI Screw Type
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on July 28, 2000
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 4.710 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125 NPS	1/8 - 1-1/4 NPS	0.03 in ²			35-1000 psi		UD
0.25 NPS	1/4 - 1 1/4 NPS	0.05 in ²			35-2000 psi		UD

0.375 NPS	3/8 - 1 1/4 NPS	0.1 in ²	35-2000 psi	UD
0.5 NPS	1/2 - 1 1/4 NPS	0.17 in ²	20-2000 psi	UD
0.75 NPS	3/4 - 1 1/4 NPS	0.29 in ²	15-2000 psi	UD
1 NPS	1, 1 1/4 NPS	0.52 in ²	10-2000 psi	UD
1.25 NPS	1 1/4 NPS	1.06 in ²	10-1000 psi	UD

Design Name:	STANDARD	NBCert #	75091
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 03/24/2031

Design Type

[Rupture Disk Device] STANDARD
HolderDesignation: Insert, Full Bolted #1 thru #9, Union 2U, 3U, 5U, 6U
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on February 13, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 1.130 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.23 in ²			65-6000 psi		UD
0.75 NPS		0.43 in ²			50-6000 psi		UD
1 NPS		0.72 in ²			29-6000 psi		UD
1.5 NPS		1.77 in ²			22-6000 psi		UD
10 NPS		78.85 in ²			4-3600 psi		UD
12 NPS		113.1 in ²			3-3600 psi		UD
14 NPS		137.89 in ²			3-2160 psi		UD
16 NPS		182.65 in ²			3-2160 psi		UD
18 NPS		233.71 in ²			3-1440 psi		UD
2 NPS		3.36 in ²			10-6000 psi		UD
20 NPS		291.04 in ²			3-1400 psi		UD
24 NPS		424.56 in ²			3-1400 psi		UD
3 NPS		7.39 in ²			9-6000 psi		UD
30 NPS		671.96 in ²			3-1440 psi		UD
4 NPS		12.73 in ²			7-6000 psi		UD
6 NPS		28.89 in ²			5-6000 psi		UD
8 NPS		50.03 in ²			4-3600 psi		UD

Design Name:	Standard (angle seat threaded)	NBCert #	75305
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 04/30/2026

Design Type

[Rupture Disk Device] Standard (angle seat threaded)
HolderDesignation: Screw type
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on April 14, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 6.090 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125 NPS		0.01 in ²			65-3000 psi		UD
0.25 NPS		0.04 in ²			65-3000 psi		UD
0.375 NPS		0.1 in ²			65-3000 psi		UD
0.5 NPS		0.17 in ²			65-3000 psi		UD
0.75 NPS		0.29 in ²			50-3000 psi		UD
1 NPS		0.52 in ²			29-3000 psi		UD
1.25 NPS		1.05 in ²			22-3000 psi		UD

Design Name: Standard (flat seat threaded) NBCert # 75327

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

04/30/2026

Design Type

[Rupture Disk Device] Standard (flat seat threaded)
HolderDesignation: Tite-seal, screw type, Throw-away
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on April 14, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 9.590 Unitless
Media - Test: Air/Gas; Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125 NPS		0.01 in ²			65-15000 psi		UD
0.25 NPS		0.04 in ²			65-15000 psi		UD
0.375 NPS		0.1 in ²			65-15000 psi		UD
0.5 NPS		0.17 in ²			65-15000 psi		UD
0.75 NPS		0.29 in ²			29-5000 psi		UD
1 NPS		0.52 in ²			29-5000 psi		UD
1.25 NPS		1.05 in ²			22-5000 psi		UD

Design Name: Standard V (LL) NBCert # 75495

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

10/03/2025

Design Type

[Rupture Disk Device] Standard V (LL)
 HolderDesignation: Insert (LL, HL), Full bolted #1 through #9 (LL, HL), Union 2U, 3U, 5U, 6U(UL)
 Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on June 10, 2003
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 1.880 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.72 in ²			30-6000 psi		UD
1.5 NPS		1.77 in ²			23-6000 psi		UD
10 NPS		78.85 in ²			5-720 psi		UD
12 NPS		113 in ²			4-720 psi		UD
14 NPS		137 in ²			4-720 psi		UD
16 NPS		182 in ²			4-720 psi		UD
18 NPS		233 in ²			4-720 psi		UD
2 NPS		3.36 in ²			10-4000 psi		UD
2 NPS		2.95 in ²	[HL]		10-6000 psi		UD
20 NPS		291 in ²			4-720 psi		UD
24 NPS		424 in ²			4-275 psi		UD
3 NPS		7.39 in ²			9-6000 psi		UD
30 NPS		671 in ²			4-275 psi		UD
4 NPS		12.7 in ²			7-1440 psi		UD
4 NPS		11.4 in ²	[HL]		7-6000 psi		UD
6 NPS		28.8 in ²			5-1440 psi		UD
8 NPS		50 in ²			5-1440 psi		UD

Design Name: Standard-V (Angle seat threaded) NBCert # 75316

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	04/30/2026

Design Type

[Rupture Disk Device] Standard-V (Angle seat threaded)
 HolderDesignation: Screw type
 Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on April 14, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value:13.300 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125 NPS		0.01 in ²			85-3000 psi		UD
0.25 NPS		0.04 in ²			85-3000 psi		UD
0.375 NPS		0.1 in ²			85-3000 psi		UD
0.5 NPS		0.17 in ²			85-3000 psi		UD

0.75 NPS	0.29 in ²	50-3000 psi	UD
1 NPS	0.52 in ²	29-3000 psi	UD
1.25 NPS	1.05 in ²	29-3000 psi	UD

Design Name: Standard-V (flat seat threaded) NBCert # 75293

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 04/30/2026

Design Type

[Rupture Disk Device] Standard-V (flat seat threaded)
HolderDesignation: Tite-seal, screw type, throw-away
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on April 26, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value:10.500 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125 NPS		0.01 in ²			85-15000 psi		UD
0.25 NPS		0.04 in ²			85-15000 psi		UD
0.375 NPS		0.1 in ²			85-15000 psi		UD
0.5 NPS		0.17 in ²			85-15000 psi		UD
0.75 NPS		0.29 in ²			29-5000 psi		UD
1 NPS		0.52 in ²			29-5000 psi		UD
1.25 NPS		1.05 in ²			29-5000 psi		UD

Design Name: STAR X, STAR X HP (gas) NBCert # 75529

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 02/20/2031

Design Type

[Rupture Disk Device] STAR X, STAR X HP (gas)
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on July 21, 2008
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.290 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			18-275 psi		UD
1.5 NPS		2.04 in ²			16-275 psi		UD
2 NPS		3.36 in ²			14-275 psi		UD
3 NPS		7.39 in ²			14-275 psi		UD
4 NPS		12.73 in ²			13-275 psi		UD
6 NPS		28.89 in ²			12-275 psi		UD

Design Name:	STAR X, STAR X HP (liquid)	NBCert #	75530
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	02/20/2031

Design Type

[Rupture Disk Device] STAR X, STAR X HP (liquid)
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on July 21, 2008
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 0.380 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			18-275 psi		UD
1.5 NPS		2.04 in ²			16-275 psi		UD
2 NPS		3.36 in ²			14-275 psi		UD
3 NPS		7.39 in ²			14-275 psi		UD
4 NPS		12.73 in ²			13-275 psi		UD
6 NPS		28.89 in ²			12-275 psi		UD

Design Name:	ULTRX (DD)	NBCert #	75271
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/27/2025

Design Type

[Rupture Disk Device] ULTRX (DD)
HolderDesignation: ULTRX Double Disk
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on October 17, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.970 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			100-2160 psi		UD
1.5 NPS		2.04 in ²			85-2160 psi		UD
10 NPS		78.85 in ²			15-720 psi		UD
12 NPS		113.1 in ²			10-720 psi		UD
2 NPS		3.36 in ²			65-1440 psi		UD
3 NPS		7.39 in ²			50-1440 psi		UD
4 NPS		12.73 in ²			45-1440 psi		UD
6 NPS		28.89 in ²			40-720 psi		UD
8 NPS		50.03 in ²			35-720 psi		UD

Design Name: ULTRX, ULTRX HP		NBCert #	75125
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	03/24/2031
Design Type			
[Rupture Disk Device] ULTRX, ULTRX HP HolderDesignation: ULTRX, ULTRX-T Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on February 13, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 0.620 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Continental Disc Corporation, LLC {CDC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			95-2160 psi		UD
1.5 NPS		2.04 in ²			85-2160 psi		UD
10 NPS		78.85 in ²			14-720 psi		UD
12 NPS		113.1 in ²			10-720 psi		UD
2 NPS		3.36 in ²			65-1440 psi		UD
3 NPS		7.39 in ²			50-1440 psi		UD
4 NPS		12.73 in ²			45-1440 psi		UD
6 NPS		28.89 in ²			40-720 psi		UD
8 NPS		50.03 in ²			35-720 psi		UD

Design Name: ULTRX, ULTRX HP (No Options)		NBCert #	75248
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	05/14/2031
Design Type			
[Rupture Disk Device] ULTRX, ULTRX HP (No Options) HolderDesignation: ULTRX, ULTRX-T Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on May 14, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.360 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Continental Disc Corporation, LLC {CDC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			100-2160 psi		UD
1.5 NPS		2.04 in ²			85-2160 psi		UD
10 NPS		78.85 in ²			15-720 psi		UD
12 NPS		113.1 in ²			10-720 psi		UD
2 NPS		3.36 in ²			65-1440 psi		UD
3 NPS		7.39 in ²			50-1440 psi		UD
4 NPS		12.73 in ²			45-1440 psi		UD

6 NPS	28.89 in ²	40-720 psi	UD
8 NPS	50.03 in ²	35-720 psi	UD

Design Name:	VRD	NBCert #	75428
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 02/22/2030

Design Type

[Rupture Disk Device] VRD
HolderDesignation: VRD
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on July 2, 2002
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.480 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			13-1000 psi		UD
1.5 NPS		2.04 in ²			10-1000 psi		UD
2 NPS		3.36 in ²			9-1000 psi		UD
3 NPS		7.39 in ²			9-1000 psi		UD
4 NPS		12.73 in ²			9-800 psi		UD
6 NPS		28.89 in ²			8-500 psi		UD
8 NPS		50.03 in ²			19-350 psi		UD

Design Name:	WMP (Gas)	NBCert #	75710
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 12/05/2030

Design Type

[Rupture Disk Device] WMP (Gas)
HolderDesignation: N/A
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on October 31, 2012
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.800 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.125 NPS		0.006 in ²			1200-15000 psi	Air	UD
0.25-0.25 NPS		0.026 in ²			800-15000 psi	Air	UD
0.375-0.375 NPS		0.059 in ²			500-15000 psi	Air	UD
0.5-0.5 NPS		0.082 in ²			450-15000 psi	Air	UD
0.75-0.75 NPS		0.168 in ²			350-7500 psi	Air	UD
1-1 NPS		0.332 in ²			300-6000 psi	Air	UD

Design Name:	WMP (Liquid)	NBCert #	75721
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	12/05/2030

Design Type

[Rupture Disk Device] WMP (Liquid)
HolderDesignation: N/A
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on October 31, 2012
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.590 Unitless
Media - ; Certified: Liquid
Set Pressure Definition: Burst Pressure
Flow Area Configuration: Nozzle/Full Lift
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.125 NPS		0.006 in ²			1200-15000 psi	Water	UD
0.25-0.25 NPS		0.026 in ²			800-15000 psi	Water	UD
0.375-0.375 NPS		0.059 in ²			500-15000 psi	Water	UD
0.5-0.5 NPS		0.082 in ²			450-15000 psi	Water	UD
0.75-0.75 NPS		0.168 in ²			350-7500 psi	Water	UD
1-1 NPS		0.332 in ²			300-6000 psi	Water	UD

Design Name:	ZAP	NBCert #	75024
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	03/24/2031

Design Type

[Rupture Disk Device] ZAP
Capacity Tests: Sec. UD at Continental Disc Corporation, LLC on February 13, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 5.880 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Continental Disc Corporation, LLC {CDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.56 in ²			50-1440 psi		UD
1.5 NPS		1.45 in ²			45-1440 psi		UD
2 NPS		2.36 in ²			35-1440 psi		UD
3 NPS		4.85 in ²			30-1440 psi		UD
4 NPS		7.99 in ²			25-1440 psi		UD
6 NPS		17.27 in ²			20-1440 psi		UD
8 NPS		30.1 in ²			15-720 psi		UD

Continental NH3 Products Co., Inc. (CNT)

Dallas, TX 75208United States

This Company Manufactures or Assembles:

Design Name: AA-402VA		NBCert #	12003
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	07/12/2029	
Design Type			
[Safety Relief Valve] AA-402VA Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on March 2, 1987 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:2057.0 SCFM Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Continental NH3 Products Co., Inc. {CNT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.44 in²	0.75 in		250-250 psi	Air	UV

Design Name: AA-402VA (265 psig)		NBCert #	12025
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	07/12/2029	
Design Type			
[Safety Relief Valve] AA-402VA (265 psig) Capacity Tests: Sec. UV at National Board Testing Lab on May 20, 1996 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:2130.0 SCFM Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Continental NH3 Products Co., Inc. {CNT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.44 in²	0.75 in		265-265 psi	Air	UV

Design Name: AA-417-AB		NBCert #	12036
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	01/11/2026	

Design Type

[Safety Relief Valve] AA-417-AB
Capacity Tests: Sec. UV at National Board Testing Lab on October 14, 1998
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:5886.0 SCFM
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Designed by: Continental NH3 Products Co., Inc. {CNT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS		1.22 in²	1.25 in		250-250 psi	Air	UV

Contro Valve Equipment Inc. (CBU)

Nameplate Abbreviation: Contro Valve
Inc

Burlington, ON L7N 3G2Canada

This Company Manufactures or Assembles:

Design Name: 119 Series NBCert # 11361

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	03/19/2030

Design Type

[Safety Valve] 119 Series
Capacity Tests: Sec. UV, V at National Board Testing Lab on March 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5 NPS	1.358 in²	[J] 1.315 in	0.329 in	15-250 psi	Air	UV
1.5 NPS	2.5 NPS	1.358 in²	[J] 1.315 in	0.329 in	15-250 psi	Steam	UV
1.5 NPS	2.5 NPS	1.358 in²	[J] 1.315 in	0.329 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	1.926 in²	[K] 1.566 in	0.392 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	1.926 in²	[K] 1.566 in	0.392 in	15-250 psi	Steam	UV
2-3 NPS	3 NPS	1.926 in²	[K] 1.566 in	0.392 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	2.99 in²	[L] 1.951 in	0.488 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	2.99 in²	[L] 1.951 in	0.488 in	15-250 psi	Steam	NV
2.5-4 NPS	4 NPS	2.99 in²	[L] 1.951 in	0.488 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.774 in²	[M] 2.192 in	0.548 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.774 in²	[M] 2.192 in	0.548 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.774 in²	[M] 2.192 in	0.548 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.55 in²	[N] 2.407 in	0.602 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.55 in²	[N] 2.407 in	0.602 in	15-250 psi	Steam	UV

4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Steam	V
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Air	UV
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Steam	UV
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Steam	V
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Air	UV
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Steam	UV
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Steam	V
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Air	UV
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Steam	UV
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Steam	V

Design Name: 1541, 1543, 1541-3, 1543-3 NBCert # 18032

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	03/05/2031

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V

1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1811, 1511

NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV, V

03/05/2031

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	19 Series	NBCert #	11282
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 03/19/2030

Design Type

[Safety Valve] 19 Series
Capacity Tests: Sec. UV, V at unknown lab on March 27, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.826 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.129 in ²	[D] 0.406 in	0.101 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.129 in ²	[D] 0.406 in	0.101 in	15-300 psi	Steam	UV, V
0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Air	UV
0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Steam	UV, V
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Air	UV
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Steam	UV, V
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Air	UV
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Steam	UV, V

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/04/2031

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V

1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

03/06/2031

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV

3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/19/2029

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV

1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/04/2031

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2 NBCert # 18144

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/06/2031

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV

1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV
-----------	---------	------------------------	--------------	----------	-------------	-----	----

Design Name:	1900-DM	NBCert #	19066
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	06/25/2030
-----------	----	------------

Design Type

[Safety Relief Valve] 1900-DM
Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV

10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D NBCert # 19088

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/25/2030

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E NBCert # 19099

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/25/2030

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2 NBCert # 18166

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/06/2031

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

03/04/2031

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 1982 LS, 820000LS NBCert # 18380

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

01/29/2026

Design Type

[Relief Valve] 1982 LS, 820000LS
Capacity Tests: Sec. UV at Dresser, Inc. on December 19, 1984
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.758 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	NV
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	UV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	NV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	NV

1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	UV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	NV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	NV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	UV

Design Name: 500 Series (Liquids)

NBCert #

11473

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

03/19/2030

Design Type

[Safety Relief Valve] 500 Series (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on February 25, 2000
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.689 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.129 in ²	[D] 0.406 in	0.102 in	15-1000 psi	Water	UV
0.75-1 NPS	1.25 NPS	0.229 in ²	[E] 0.539 in	0.135 in	15-1000 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-1000 psi	Water	UV
1.25-1.5 NPS	2 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-1000 psi	Water	UV
1.5-2 NPS	2.5 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-1000 psi	Water	UV
2 NPS	3 NPS	1.504 in ²	[J] 1.384 in	0.346 in	15-1000 psi	Water	UV

Contro Valve Equipment Inc. (CTR)

Nameplate Abbreviation: Contro Valve Inc.

Sarnia, ON N7S 5N5Canada

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3

NBCert #

18032

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

05/20/2031

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	02/18/2030
-----------	----	------------

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V

1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

02/18/2030

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV

3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/07/2027

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV

0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/02/2027

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/18/2030

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert # 18751

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/18/2030

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM NBCert # 19066

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/18/2029

Design Type

[Safety Relief Valve] 1900-DM
Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV

3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D

NBCert #

19088

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/18/2029

Design Type

[Safety Relief Valve] 1900-DM-D

Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Curtain Area

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E

NBCert #

19099

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/18/2029

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2 NBCert # 18166

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

04/08/2031

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

02/18/2030

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name:	19110M & 19110H (Liquids)	NBCert #	19077
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 05/20/2031

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name:	2900-TM (39PV & 39MV pilots)	NBCert #	01427
--------------	------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/07/2030

Design Type

[Pilot Operated Pressure Relief Valve] 2900-TM (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Water	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV

1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Water	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Water	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2000 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Water	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Water	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-300 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Water	UV

Design Name: 3900-TM (39PV, 39MV pilots)	NBCert # 01438
--	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	11/07/2030
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 3900-TM (39PV, 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; (alternate medium): 0.743 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV

3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Contro Valve Equipment Inc. (VAL)

Nameplate Abbreviation: Contro Valve Inc.

Brossard, QC J4Y 2R4Canada

This Company Manufactures or Assembles:

Design Name:	119 Series	NBCert #	11361
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/25/2029

Design Type

[Safety Valve] 119 Series
 Capacity Tests: Sec. UV, V at National Board Testing Lab on March 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Air	UV
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Steam	UV
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Steam	UV
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Steam	NV
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Steam	V
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Air	UV
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Steam	UV
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Steam	V
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Air	UV
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Steam	UV
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Steam	V
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Air	UV
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Steam	UV

6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Steam	V
-------	-------	------------------------	--------------	----------	------------	-------	---

Design Name:	1541, 1543, 1541-3, 1543-3	NBCert #	18032
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 02/04/2026

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name:	1811, 1511	NBCert #	18122
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/16/2029

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	19 Series	NBCert #	11282
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/25/2029

Design Type

[Safety Valve] 19 Series
Capacity Tests: Sec. UV, V at unknown lab on March 27, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.826 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.129 in ²	[D] 0.406 in	0.101 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.129 in ²	[D] 0.406 in	0.101 in	15-300 psi	Steam	UV, V
0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Air	UV
0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Steam	UV, V
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Air	UV
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Steam	UV, V
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Air	UV
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Steam	UV, V

Design Name: 1900, 1900-30 1900-35 LA & DALA (Liquids) NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/05/2026

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V

4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

02/13/2026

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV

4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series

NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

01/22/2029

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV

2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV
---------	---------	-----------------------	---------	----------	-------------	-------	----------------------------

Design Name: 19000 Series, Liquid NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/23/2030

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2 NBCert # 18144

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/05/2026

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert # 18751

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/23/2030

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 3.256 GPM/SQ. RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM

NBCert # 19066

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

09/20/2029

Design Type

[Safety Relief Valve] 1900-DM
 Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
 Set Pressure Definition(1): Pop; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D NBCert # 19088

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/20/2029

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E NBCert # 19099

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/20/2029

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2		NBCert # 18166
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/05/2026
Design Type		
[Safety Relief Valve] 1900E-2, 1900-30E-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids)		NBCert # 18762
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/23/2030
Design Type		
[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids) Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.798 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids)		NBCert # 19077
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/18/2029
Design Type		
[Relief Valve] 19110M & 19110H (Liquids) Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.264 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 2900-TM (39PV & 39MV pilots) NBCert # 01427

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/07/2030

Design Type

[Pilot Operated Pressure Relief Valve] 2900-TM (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Water	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Water	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Water	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2000 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Water	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Water	UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Water	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-300 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Water	UV

Design Name: 3900 (39PV, 39MV pilots) NBCert # 18447

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/05/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV

1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV

6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid)

NBCert #

18458

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

02/08/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)

Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.743 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV

3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Design Name: 500 Series

NBCert #

11462

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

01/18/2029

Design Type

[Safety Valve] 500 Series
Capacity Tests: Sec. UV at National Board Testing Lab on June 12, 2000
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.861 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.129 in ²	[D] 0.406 in	0.102 in	15-2000 psi	Air	UV
0.5-0.75 NPS	.75, 1 NPS	0.129 in ²	[D] 0.406 in	0.102 in	15-2000 psi	Steam	UV
0.75-1 NPS	1.25 NPS	0.229 in ²	[E] 0.539 in	0.135 in	15-2000 psi	Air	UV
0.75-1 NPS	1.25 NPS	0.229 in ²	[E] 0.539 in	0.135 in	15-2000 psi	Steam	UV
1-1.25 NPS	1.5 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-2000 psi	Air	UV
1-1.25 NPS	1.5 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-2000 psi	Steam	UV

1.25-1.5 NPS	2 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-2000 psi	Air	UV
1.25-1.5 NPS	2 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-2000 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-2000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-2000 psi	Steam	UV
2 NPS	3 NPS	1.504 in ²	[J] 1.384 in	0.346 in	15-2000 psi	Air	UV
2 NPS	3 NPS	1.504 in ²	[J] 1.384 in	0.346 in	15-2000 psi	Steam	UV

Design Name: 500 Series (Liquids) NBCert # 11473

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/25/2029

Design Type

[Safety Relief Valve] 500 Series (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on February 25, 2000
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.689 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.129 in ²	[D] 0.406 in	0.102 in	15-1000 psi	Water	UV
0.75-1 NPS	1.25 NPS	0.229 in ²	[E] 0.539 in	0.135 in	15-1000 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-1000 psi	Water	UV
1.25-1.5 NPS	2 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-1000 psi	Water	UV
1.5-2 NPS	2.5 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-1000 psi	Water	UV
2 NPS	3 NPS	1.504 in ²	[J] 1.384 in	0.346 in	15-1000 psi	Water	UV

Control Devices, LLC (CDV)

Nameplate Abbreviation: CD

Fenton, MO 63026 United States

This Company Manufactures or Assembles:

Design Name: SA NBCert # 14038

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	06/03/2029

Design Type

[Safety Relief Valve] SA
Capacity Tests: Sec. UV at National Board Testing Lab on April 1, 1996
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.716 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Control Devices, LLC {CDV}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.375 NPS		0.049 in²	0.25 in	0.088 in	50-350 psi	Air	UV
Design Name: SB		NBCert #			14061		
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			03/20/2029	
Design Type							
[Safety Relief Valve] SB Capacity Tests: Sec. UV at National Board Testing Lab on July 26, 1996 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.310 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Control Devices, LLC {CDV}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS		0.221 in²	0.531 in	0.267 in	25-300 psi	Air	UV
Design Name: SCB		NBCert #			14083		
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			09/22/2029	
Design Type							
[Safety Relief Valve] SCB Capacity Tests: Sec. UV at National Board Testing Lab on April 14, 1997 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.260 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Control Devices, LLC {CDV}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.2206 in²	0.53 in	0.254 in	25-300 psi	Air	UV
Design Name: SF		NBCert #			14050		
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			05/29/2031	
Design Type							
[Safety Relief Valve] SF Capacity Tests: Sec. UV at National Board Testing Lab on January 27, 1993 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.526 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Control Devices, LLC {CDV}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.11 in²	0.375 in	0.17 in	50-250 psi	Air	UV
Design Name: SNNBCert #14094							
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		04/07/2031		
Design Type							
[Safety Relief Valve] SN Capacity Tests: Sec. UV at National Board Testing Lab on February 6, 1998 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.750 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Control Devices, LLC {CDV}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.11 in²	0.375 in	0.15 in	50-350 psi	Air	UV
Design Name: SPNBCert #14049							
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		03/22/2030		
Design Type							
[Safety Relief Valve] SP Capacity Tests: Sec. UV at National Board Testing Lab on February 12, 1992 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.276 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Control Devices, LLC {CDV}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.25 NPS		0.0191 in²	0.156 in	0.11 in	75-250 psi	Air	UV
Design Name: STNBCert #14016							
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		09/13/2029		
Design Type							
[Safety Relief Valve] ST Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on May 12, 1988 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.759 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Control Devices, LLC {CDV}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.375 NPS		0.049 in ²	0.25 in	0.138 in	25-350 psi	Air	UV

Design Name: SW NBCert # 14072

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/20/2029

Design Type
[Safety Relief Valve] SW Capacity Tests: Sec. UV at National Board Testing Lab on September 16, 1996 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 6.920 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Control Devices, LLC {CDV}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.25 NPS		0.46 in ²	0.765 in	0.314 in	25-300 psi	Air	UV

Control Southern Inc. (CSM)

Macon, GA 31217 United States

This Company Manufactures or Assembles:

Design Name: 243/249/443/449/546/843/849/943/5046/5049/8043/8049			NBCert #	01292
Manufacturer/Assembler		Designators	Expiration Date	
Assembler		UV	08/29/2029	

Design Type
[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049 Capacity Tests: Sec. UV at unknown lab on August 8, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Air/Gas; Certified: Air, Gas, Steam Set Pressure Definition(1): Pop; (2): Initial Audible Discharge Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV

3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name: 253/259/453/459/853/859/953/959/5059/8053/8059 NBCert # 01304

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/29/2029

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
Capacity Tests: Sec. UV at unknown lab on July 31, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.627 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 263/269/463/469/566/863/869/963/969/5066/5069 NBCert # 01315

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/29/2029

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069
 Capacity Tests: Sec. UV at unknown lab on July 30, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.860 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/29/2029

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.767 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V

1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/19/2029

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.491 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids)		NBCert #	01348
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	10/19/2029
Design Type			
[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids) Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.712 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name: 63B (.437", #7 orifice)		NBCert #	01067
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	08/29/2029
Design Type			
[Safety Relief Valve] 63B (.437", #7 orifice) Capacity Tests: Sec. UV at Crosby Valve, LLC on December 3, 1975 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.370 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.15 in ²	[#7] 0.437 in	0.16 in	45-374 psi	Air	UV

Design Name: 81, 81P, 83, 84		NBCert #	01089
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	08/29/2029

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
 Capacity Tests: Sec. UV at unknown lab on July 8, 1965
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.816 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}
 Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 81P (Liquids)

NBCert #

01102

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/29/2029

Design Type

[Relief Valve] 81P (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.720 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: 93% of pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V

Design Name: 900 Series (Liquid), 7700, SNC		NBCert #	15499
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	08/29/2029
Design Type			
[Relief Valve] 900 Series (Liquid), 7700, SNC Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.661 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name: 900 Series, 7700, SNC		NBCert #	15411
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	08/29/2029
Design Type			
[Safety Relief Valve] 900 Series, 7700, SNC Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - ; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV

0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: H Series (HCI, HSJ, HCA, HA, HB, HC, HCB, HCP, HJO, HN, HNA, HNB, HNP, HS, NBCert # 15006 HSA, HSB, HSC, HSP)

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler V 07/08/2026

Design Type

[Safety Valve] H Series (HCI, HSJ, HCA, HA, HB, HC, HCB, HCP, HJO, HN, HNA, HNB, HNP, HS, HSA, HSB, HSC, HSP)
Capacity Tests: Sec. UV, V at unknown lab on September 1, 1939
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1.5 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-500 psi	Steam	UV, V
0.75 NPS	1.5 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-500 psi	Steam	UV, V
1-1.5 NPS	2 - 3 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-3100 psi	Steam	UV, V
1-2 NPS	2.5, 3 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-3100 psi	Steam	UV, V
1.5-2 NPS	3, 4, 6 NPS	0.785 in ²	[H] 1 in	0.25 in	15-5000 psi	Steam	UV, V
1.5 NPS	3 NPS	0.865 in ²	1.05 in	0.262 in	15-3100 psi	Steam	UV, V
1.5 NPS	3 NPS	0.994 in ²	[H2] 1.125 in	0.281 in	15-3100 psi	Steam	UV, V
2-3 NPS	3, 4, 6 NPS	1.288 in ²	[J] 1.281 in	0.32 in	15-5000 psi	Steam	UV, V
2 NPS	4 NPS	1.431 in ²	[J2] 1.35 in	0.338 in	15-3100 psi	Steam	UV, V
2.5-3 NPS	4, 6 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-6000 psi	Steam	UV, V
2.5 NPS	6 NPS	2.545 in ²	[K2] 1.8 in	0.45 in	15-6800 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.476 in	15-3100 psi	Steam	UV, V
3 NPS	6 NPS	3.341 in ²	[L2] 2.062 in	0.516 in	15-3100 psi	Steam	UV, V
3-4 NPS	6, 8 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-6000 psi	Steam	UV, V
3 NPS	6, 8 NPS	3.976 in ²	[M2] 2.25 in	0.563 in	15-6000 psi	Steam	UV, V
4 NPS	6 NPS	4.341 in ²	[N] 2.351 in	0.588 in	15-3100 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.712 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	7.07 in ²	[P2] 3 in	0.75 in	15-3100 psi	Steam	UV, V

6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.937 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	12.25 in ²	[Q2] 3.95 in	0.988 in	15-3100 psi	Steam	UV, V
6 NPS	8, 10 NPS	16 in ²	[R] 4.513 in	1.128 in	15-3100 psi	Steam	UV, V
6 NPS	10 NPS	19.29 in ²	[RR] 4.956 in	1.239 in	15-3100 psi	Steam	UV, V
8 NPS	10, 12 NPS	26 in ²	[T] 5.75 in	1.437 in	15-500 psi	Steam	UV, V
8 NPS	12, 14 NPS	28.274 in ²	6 in	1.5 in	15-2000 psi	Steam	UV, V
10 NPS	14 NPS	44.18 in ²	7.5 in	1.875 in	15-500 psi	Steam	UV, V
12 NPS	16 NPS	63.62 in ²	9 in	2.25 in	15-500 psi	Steam	UV, V
14 NPS	18 NPS	86.59 in ²	10.5 in	2.625 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	95.21 in ²	11.01 in	2.753 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	114.04 in ²	12.05 in	3.02 in	15-500 psi	Steam	UV, V
18 NPS	24 NPS	143.14 in ²	13.5 in	3.375 in	15-500 psi	Steam	UV, V
20 NPS	24 NPS	176.71 in ²	15 in	3.75 in	15-500 psi	Steam	UV, V

Design Name: HL, HSL NBCert # 15589

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 10/04/2028

Design Type

[Safety Valve] HL, HSL
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on November 3, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.869 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	1.5 NPS	0.339 in ²	[F] 0.657 in	0.164 in	15-725 psi	Steam	UV, V
1.25-2 NPS	1.5 NPS	0.553 in ²	[G] 0.839 in	0.21 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.868 in ²	[H] 1.051 in	0.263 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.327 in ²	[J] 1.3 in	0.325 in	15-725 psi	Steam	UV, V
2-3 NPS	3-4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-725 psi	Steam	UV, V
2.5-4 NPS	4-6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-725 psi	Steam	UV, V
3 NPS	4-6 NPS	3.955 in ²	[M] 2.244 in	0.561 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	4.831 in ²	[N] 2.48 in	0.62 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	7.031 in ²	[P] 2.992 in	0.748 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[QQ] 3.75 in	0.937 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	0.984 in	15-725 psi	Steam	UV, V

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/29/2029

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.656 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/29/2029

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV

6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Design Name:	Kunkle 300,600	NBCert #	36076
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	07/08/2026

Design Type
[Safety Valve] Kunkle 300,600 Capacity Tests: Sec. UV, V at unknown lab on February 10, 1961 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	UV
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	V

1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	V
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Air	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	V
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Air	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	V
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Air	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	V
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	V
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Air	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	UV

Design Name: Kunkle 6000, 6252 Series NBCert # 36324

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	10/19/2029

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV

1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

ControlWorx, LLC (GEG)

Nameplate Abbreviation:
CONTROLWORX

Geismar, LA 70734United States

This Company Manufactures or Assembles:

Design Name:	243/249/443/449/546/843/849/943/5046/5049/8043/8049	NBCert #	01292
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 12/07/2029

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
Capacity Tests: Sec. UV at unknown lab on August 8, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name:	253/259/453/459/853/859/953/959/5059/8053/8059	NBCert #	01304
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/17/2029

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
Capacity Tests: Sec. UV at unknown lab on July 31, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.627 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV

1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 263/269/463/469/566/863/869/963/969/506
6/5069 NBCert # 01315

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 12/07/2029

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069

Capacity Tests: Sec. UV at unknown lab on July 30, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.860 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name:	443/449/546/843/849/943/949/5046/5049 (Liquids)	NBCert #	01337
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/17/2029

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.767 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name:	453/459/853/859/953/959/5059 (Liquids)	NBCert #	01326
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/17/2029

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.491 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV

2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids) NBCert # 01348

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 12/07/2029

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids)
Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.712 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name: 63B (.312", #5 orifice) NBCert # 01056

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/17/2029

Design Type

[Safety Relief Valve] 63B (.312", #5 orifice)
Capacity Tests: Sec. UV at Crosby Valve, LLC on December 3, 1975
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.180 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1 NPS	0.077 in ²	[#5] 0.312 in	0.15 in	37-531 psi	Air	UV

Design Name: 63B (.437", #7 orifice) NBCert # 01067

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 08/17/2029

Design Type

[Safety Relief Valve] 63B (.437", #7 orifice)
Capacity Tests: Sec. UV at Crosby Valve, LLC on December 3, 1975
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.370 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.15 in ²	[#7] 0.437 in	0.16 in	45-374 psi	Air	UV

Design Name: 81, 81P, 83, 84 NBCert # 01089

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 08/17/2029

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV

0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 81P (Liquids) NBCert # 01102

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/17/2029

Design Type

[Relief Valve] 81P (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: 93% of pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name: 900 Series, 7700, SNC NBCert # 15411

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/17/2029

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV

0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: HL, HSL

NBCert #

15589

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

V

01/10/2029

Design Type

[Safety Valve] HL, HSL

Capacity Tests: Sec. UV, V at Crosby Valve, LLC on November 3, 1999

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.869 Unitless

Media - Test: Steam; Certified: Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable (Dual Ring)

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	1.5 NPS	0.339 in ²	[F] 0.657 in	0.164 in	15-725 psi	Steam	UV, V
1.25-2 NPS	1.5 NPS	0.553 in ²	[G] 0.839 in	0.21 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.868 in ²	[H] 1.051 in	0.263 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.327 in ²	[J] 1.3 in	0.325 in	15-725 psi	Steam	UV, V
2-3 NPS	3-4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-725 psi	Steam	UV, V
2.5-4 NPS	4-6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-725 psi	Steam	UV, V
3 NPS	4-6 NPS	3.955 in ²	[M] 2.244 in	0.561 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	4.831 in ²	[N] 2.48 in	0.62 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	7.031 in ²	[P] 2.992 in	0.748 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[QQ] 3.75 in	0.937 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	0.984 in	15-725 psi	Steam	UV, V

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids)

NBCert #

15095

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

08/17/2029

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.656 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/17/2029

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
 Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.870 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name: JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Liquids) (Restricted lift version of Certification 15095) NBCert # 01393

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/17/2029

Design Type

[Safety Relief Valve] JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Liquids) (Restricted lift version of Certification 15095)
 Capacity Tests: Sec. NV, UV, V at unknown lab on October 14, 2015
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.656 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Restricted Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Water	UV, V

1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.137 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.137 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	0.493 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.616 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Water	UV, V

Design Name:	JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Restricted Lift version of Certification 15512)	NBCert #	01382
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	08/17/2029
-----------	----	------------

Design Type

[Safety Relief Valve] JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Restricted Lift version of Certification 15512)
Capacity Tests: Sec. UV at unknown lab on October 13, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.6949 in ²	0.892 in	0.137 in	15-2500 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	0.493 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.616 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/17/2029

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV

1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Design Name: JOS-E-RL/JBS-E-RL/JDS-E-RL (Restricted Lift version of cert 15208) NBCert # 01045

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/17/2029

Design Type

[Safety Relief Valve] JOS-E-RL/JBS-E-RL/JDS-E-RL (Restricted Lift version of cert 15208)

Capacity Tests: Sec. UV at unknown lab on May 26, 2015

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.865 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable (Single Ring)

Flow Area Configuration: Restricted Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-15000 psi	Air	UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.08 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.08 in	15-15000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.08 in	15-15000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.08 in	15-2000 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.08 in	15-15000 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.08 in	15-2000 psi	Steam	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.099 in	15-15000 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.099 in	15-2000 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.127 in	15-10000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.127 in	15-2000 psi	Steam	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.152 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.152 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.18 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.18 in	15-3000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.189 in	15-2000 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.189 in	15-5000 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.213 in	15-2000 psi	Steam	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.213 in	15-5000 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.234 in	15-1480 psi	Steam	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.234 in	15-3000 psi	Air	UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.255 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.255 in	15-2250 psi	Steam	UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.284 in	15-1480 psi	Steam	UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.284 in	15-3000 psi	Air	UV
6 NPS	8 NPS	11.045 in ²	3.75 in	0.373 in	15-1000 psi	Steam	UV

6 NPS	8 NPS	11.045 in ²	3.75 in	0.373 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.174 in ²	3.937 in	0.373 in	15-2250 psi	Air	UV
6 NPS	8 NPS	12.174 in ²	3.937 in	0.373 in	15-2250 psi	Steam	UV
6 NPS	10 NPS	12.236 in ²	3.947 in	0.449 in	15-2250 psi	Air	UV
6 NPS	10 NPS	12.236 in ²	3.947 in	0.449 in	15-2250 psi	Steam	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.373 in	15-1480 psi	Steam	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.373 in	15-3000 psi	Air	UV
6 NPS	8 NPS	15.288 in ²	4.412 in	0.424 in	15-2250 psi	Air	UV
6 NPS	8 NPS	15.288 in ²	4.412 in	0.424 in	15-2250 psi	Steam	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.449 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.449 in	15-1480 psi	Steam	UV
8 NPS	10 NPS	18.254 in ²	4.821 in	0.572 in	15-2250 psi	Air	UV
8 NPS	10 NPS	18.254 in ²	4.821 in	0.572 in	15-2250 psi	Steam	UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	0.572 in	15-740 psi	Air	UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	0.572 in	15-740 psi	Steam	UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	0.592 in	15-740 psi	Air	UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	0.592 in	15-740 psi	Steam	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	0.731 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	0.731 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	0.933 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	0.933 in	15-325 psi	Steam	UV

ControlWorx, LLC (WTM)

Nameplate Abbreviation: ControlWorx

Mobile, AL 36615United States

This Company Manufactures or Assembles:

Design Name: 243/249/443/449/546/843/849/943/5046/5049/8043/8049 NBCert # 01292

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 12/18/2025

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049

Capacity Tests: Sec. UV at unknown lab on August 8, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV

1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name: 81, 81P, 83, 84 NBCert # 01089

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/10/2026

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 81P (Liquids) NBCert # 01102

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/10/2026

Design Type

[Relief Valve] 81P (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: 93% of pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name: 900 Series (Liquid), 7700, SNC NBCert # 15499

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/18/2025

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV

1.5 NPS 2.5 NPS 0.5674 in² [#9] 0.85 in 0.274 in 15-5000 psi Water UV, V

Design Name: 900 Series, 7700, SNC			NBCert #	15411
Manufacturer/Assembler		Designators		Expiration Date

Assembler UV 12/18/2025

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids)			NBCert #	15095
Manufacturer/Assembler		Designators		Expiration Date

Assembler UV 12/18/2025

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.656 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV

1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name:	JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB	NBCert #	15208
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/18/2025

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV

6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

CORNERSTONE CONTROLS (DPL)

Dayton, OH 45417 United States

This Company Manufactures or Assembles:

Design Name:	243/249/443/449/546/843/849/943/5046/5049/8043/8049	NBCert #	01292
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/05/2028

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049

Capacity Tests: Sec. UV at unknown lab on August 8, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV

8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name:	253/259/453/459/853/859/953/959/5059/8053/8059	NBCert #	01304
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	10/05/2028
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
 Capacity Tests: Sec. UV at unknown lab on July 31, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.627 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name:	263/269/463/469/566/863/869/963/969/5066/5069	NBCert #	01315
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	10/05/2028
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069
 Capacity Tests: Sec. UV at unknown lab on July 30, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.860 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV

2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/05/2028

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.767 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/05/2028

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids) NBCert # 01348

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/05/2028

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids)
 Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.712 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name:	81, 81P, 83, 84	NBCert #	01089
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/05/2028

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name:	81P (Liquids)	NBCert #	01102
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/06/2029

Design Type

[Relief Valve] 81P (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.720 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: 93% of pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name: 900 Series (Liquid), 7700, SNC NBCert # 15499

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/05/2028

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.661 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV

1.5 NPS 2.5 NPS 0.5674 in² [#9] 0.85 in 0.274 in 15-5000 psi Water UV, V

Design Name: 900 Series, 7700, SNC		NBCert # 15411
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/05/2028
Design Type		
<div>[Safety Relief Valve] 900 Series, 7700, SNC</div> <div>Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990</div> <div>Method of Establishing Relieving Capacity: Flow Capacity, K</div> <div>Certified Value: 0.878 Unitless</div> <div>Media - ; Certified: Air, Gas, Steam</div> <div>Set Pressure Definition: Pop</div> <div>Blowdown Characteristics: Fixed</div> <div>Flow Area Configuration: Nozzle/Full Lift</div> <div>Designed by: Emerson Automation Solutions Final Control US LP {AGC}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: HL, HSL		NBCert #	15589
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	V	08/16/2030	
Design Type			
[Safety Valve] HL, HSL Capacity Tests: Sec. UV, V at Crosby Valve, LLC on November 3, 1999 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.869 Unitless Media - Test: Steam; Certified: Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	1.5 NPS	0.339 in ²	[F] 0.657 in	0.164 in	15-725 psi	Steam	UV, V
1.25-2 NPS	1.5 NPS	0.553 in ²	[G] 0.839 in	0.21 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.868 in ²	[H] 1.051 in	0.263 in	15-725 psi	Steam	UV, V

1.5-2.5 NPS	2.5 NPS	1.327 in ²	[J] 1.3 in	0.325 in	15-725 psi	Steam	UV, V
2-3 NPS	3-4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-725 psi	Steam	UV, V
2.5-4 NPS	4-6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-725 psi	Steam	UV, V
3 NPS	4-6 NPS	3.955 in ²	[M] 2.244 in	0.561 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	4.831 in ²	[N] 2.48 in	0.62 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	7.031 in ²	[P] 2.992 in	0.748 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[QQ] 3.75 in	0.937 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	0.984 in	15-725 psi	Steam	UV, V

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/05/2028

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V

4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/05/2028

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/05/2028

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.865 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV

6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Crosby Valve, LLC (CVM)

Mansfield, MA 02048United States

This Company Manufactures or Assembles:

Design Name: 800			NBCert # 15466				
Manufacturer/Assembler		Designators		Expiration Date			
Manufacturer		NV, UV		12/06/2028			
Design Type							
[Safety Relief Valve] 800 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on August 8, 1991 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.877 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Crosby Valve, LLC {CVM}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.1244 in²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.75-1 NPS	1 NPS	0.1244 in²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV

0.75-1 NPS	1 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	UV
1-2 NPS	1 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV
1-2 NPS	1 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	UV
1-2 NPS	1 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1-2 NPS	1.5, 2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5, 2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name:	81, 81P, 83, 84	NBCert #	01089
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV, UV 10/21/2027

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name:	81P (Liquids)	NBCert #	01102
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV 08/24/2028

Design Type

[Relief Valve] 81P (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: 93% of pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name: 900 Series (Liquid), 7700, SNC NBCert # 15499

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, UV	03/17/2029

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV

1.5 NPS 2.5 NPS 0.5674 in² [#9] 0.85 in 0.274 in 15-5000 psi Water UV, V

Design Name: 900 Series, 7700, SNC		NBCert # 15411
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, UV	06/07/2029
Design Type		
<div>[Safety Relief Valve] 900 Series, 7700, SNC</div> <div>Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990</div> <div>Method of Establishing Relieving Capacity: Flow Capacity, K</div> <div>Certified Value: 0.878 Unitless</div> <div>Media - ; Certified: Air, Gas, Steam</div> <div>Set Pressure Definition: Pop</div> <div>Blowdown Characteristics: Fixed</div> <div>Flow Area Configuration: Nozzle/Full Lift</div> <div>Designed by: Emerson Automation Solutions Final Control US LP {AGC}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: BP		NBCert #	15501
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		NV, UV	03/29/2029
Design Type			
[Safety Relief Valve] BP Capacity Tests: Sec. UV at Crosby Valve, LLC on August 24, 1995 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.841 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.0539 in ²	[#4] 0.262 in	0.06 in	50-3000 psi	Air	UV
0.75-1 NPS	1 NPS	0.0929 in ²	[#5] 0.344 in	0.085 in	50-3000 psi	Air	UV
0.75-1 NPS	1 NPS	0.114 in ²	[#5A] 0.381 in	0.098 in	50-3000 psi	Air	UV

0.75-1 NPS	1 NPS	0.1364 in²	[#6] 0.417 in	0.112 in	50-3000 psi	Air	UV
------------	-------	------------	---------------	----------	-------------	-----	----

Design Name:	BP (Liquids)	NBCert #	15534
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	03/29/2029
--------------	----	------------

Design Type

[Relief Valve] BP (Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on September 15, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.631 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.0539 in²	[#4] 0.262 in	0.06 in	50-3000 psi	Water	UV, V
0.75-1 NPS	1 NPS	0.0929 in²	[#5] 0.344 in	0.085 in	50-3000 psi	Water	UV, V
0.75-1 NPS	1 NPS	0.114 in²	[#5A] 0.381 in	0.098 in	50-3000 psi	Water	UV, V
0.75-1 NPS	1 NPS	0.1364 in²	[#6] 0.417 in	0.112 in	50-3000 psi	Water	UV, V

Design Name:	CV1B	NBCert #	15398
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	NV	12/11/2025
--------------	----	------------

Design Type

[Vacuum Relief Valve] CV1B
Capacity Tests: Sec. NV, -Class 2, -Class 3 at Anderson Greenwood Crosby on December 11, 2013
Method of Establishing Relieving Capacity: Flow Capacity, Single Valve Method
Certified Value:1652.0 SCFM
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Start-to-Leak
Flow Area Configuration: Nozzle/Full Lift
Designed by: Crosby Valve, LLC {CVM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
6-8 NPS	6, 8 NPS	16.98 in²	4.65 in		-0.2 psi	Air	NV

Design Name:	ES-657	NBCert #	15613
--------------	--------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	NV, -Class 1	11/30/2028
--------------	--------------	------------

Design Type

[Power Actuated Relief Valve] ES-657
Capacity Tests: Sec. NV, -Class 1 at Anderson Greenwood Crosby on July 26, 2022
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.612 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Heavy Flow
Blowdown Characteristics: Adjustable (Other)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Crosby Valve, LLC {CVM}
Comments: Capacity at 159.5 psid (10% above set), Report TR5778 Rev. 0 saved to support files, Test report TR5778 Rev. 1 includes DOF

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 NPS	4 NPS	2.761 in²	1.875 in	0.75 in	1370-1370 psi	Water	NV, -Class 1
Design Name: HA-HAANBCert # 15017							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			NV			03/01/2029	
Design Type							
[Safety Valve] HA-HAA Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3 at Crosby Valve, LLC on February 17, 1968 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Steam; Certified: Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Crosby Valve, LLC {CVM}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
6-8 NPS	8, 8 dual NPS	12.174 in²	[Q] 3.937 in	0.984 in	15-3000 psi	Steam	NV
6-8 NPS	8,10,8 dual NPS	16 in²	[R] 4.513 in	1.128 in	15-3000 psi	Steam	NV
6 NPS	10, Dual 8 NPS	16.5 in²	[R4] 4.5835 in	1.146 in	15-3000 psi	Steam	NV
8 NPS	10 NPS	17.72 in²	[R2] 4.75 in	1.188 in	15-3000 psi	Steam	NV
8 NPS	12,10 dual, 12 dual NPS	28.27 in²	[T] 6 in	1.5 in	15-3000 psi	Steam	NV
Design Name: HB (Class 1)NBCert # 15028							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			NV			03/01/2029	
Design Type							
[Safety Valve] HB (Class 1) Capacity Tests: Sec. NV at Crosby Valve, LLC on November 25, 1968 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.869 Unitless Media - Test: Steam; Certified: Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Crosby Valve, LLC {CVM}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2, 2-1/2 NPS	0.196 in²	[E] 0.5 in	0.125 in	15-3000 psi	Steam	NV
1.5 NPS	2, 2-1/2 NPS	0.249 in²	0.563 in	0.14 in	15-3000 psi	Steam	NV
1.5 NPS	2 - 3 NPS	0.307 in²	[F] 0.625 in	0.156 in	15-3000 psi	Steam	NV
1.5 NPS	2-1/2 - 4 NPS	0.503 in²	[G] 0.8 in	0.2 in	15-3000 psi	Steam	NV
1.5 NPS	2 1/2 - 4 NPS	0.65 in²	0.909 in	0.227 in	15-3000 psi	Steam	NV
1.5-3 NPS	3, 4 NPS	0.785 in²	[H] 1 in	0.25 in	15-3000 psi	Steam	NV
2-3 NPS	4, 6 NPS	1.288 in²	[J] 1.281 in	0.32 in	15-3000 psi	Steam	NV
2.5-4 NPS	4, 6 NPS	1.84 in²	[K] 1.531 in	0.382 in	15-3000 psi	Steam	NV

3-6 NPS	6 NPS	2.545 in ²	[K2] 1.8 in	0.45 in	15-3000 psi	Steam	NV
3-6 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.476 in	15-3000 psi	Steam	NV
3-6 NPS	6 NPS	2.993 in ²	[M1] 1.952 in	0.488 in	15-3000 psi	Steam	NV
3-6 NPS	6 NPS	3.644 in ²	[M] 2.154 in	0.538 in	15-3000 psi	Steam	NV
4-6 NPS	6, 8 NPS	4.382 in ²	[N] 2.362 in	0.591 in	15-3000 psi	Steam	NV
4-6 NPS	6, 8 NPS	6.38 in ²	[P] 2.85 in	0.712 in	15-3000 psi	Steam	NV
6 NPS	8 NPS	7.917 in ²	[P3] 3.175 in	0.794 in	15-3000 psi	Steam	NV
6 NPS	10 NPS	16.12 in ²	[R] 4.531 in	1.133 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	16.474 in ²	[R] 4.58 in	1.145 in	15-1500 psi	Steam	NV

Design Name:	HE	NBCert #	15039
--------------	----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV 10/24/2030

Design Type

[Safety Valve] HE
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 15, 1970
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5 NPS	0.307 in ²	0.625 in	0.156 in	15-3100 psi	Steam	NV, V
1.5 NPS	2.5 NPS	0.503 in ²	0.8 in	0.2 in	15-3100 psi	Steam	NV, V
1.5 NPS	3 NPS	0.785 in ²	[H] 1 in	0.25 in	15-3100 psi	Steam	NV, V
2 NPS	4 NPS	1.288 in ²	[J] 1.281 in	0.32 in	15-3100 psi	Steam	NV, V
2.5 NPS	6 NPS	1.84 in ²	[K] 1.531 in	0.382 in	15-3100 psi	Steam	NV, V
2.5 NPS	6 NPS	2.545 in ²	[K2] 1.8 in	0.45 in	15-3100 psi	Steam	NV, V
3 NPS	6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-3100 psi	Steam	NV, V
3 NPS	6 NPS	3.976 in ²	[M2] 2.25 in	0.562 in	15-3100 psi	Steam	NV, V
4 NPS	6 NPS	6.38 in ²	2.85 in	0.712 in	15-3100 psi	Steam	NV, V
4 NPS	6, 8 NPS	7.069 in ²	[P2] 3 in	0.75 in	15-3100 psi	Steam	NV, V
6 NPS	8 NPS	11.045 in ²	3.75 in	0.937 in	15-3100 psi	Steam	NV, V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.513 in	1.128 in	15-1500 psi	Steam	NV, V
8 NPS	10, 12, 14 NPS	19.369 in ²	[R3] 4.966 in	1.242 in	15-3100 psi	Steam	NV, V
8 NPS	10, 12, 14 NPS	21.1 in ²	[R5] 5.183 in	1.295 in	15-3100 psi	Steam	NV, V
8 NPS	14 NPS	22 in ²	[R6] 5.295 in	1.324 in	15-3100 psi	Steam	NV, V
10 NPS	16 NPS	36.4 in ²	[T2] 6.808 in	1.707 in	15-3100 psi	Steam	NV, V

Design Name: JB	NBCert # 15073
-----------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, UV	10/23/2027

Design Type

[Safety Relief Valve] JB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on August 8, 1957
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.856 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Crosby Valve, LLC {CVM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	1-2 NPS	0.1244 in ²	[D] 0.398 in	0.099 in	15-2900 psi	Steam	NV, UV
0.75-1.5 NPS	1-2 NPS	0.1244 in ²	[D] 0.398 in	0.099 in	15-6000 psi	Air	NV, UV
0.75-1.5 NPS	1-2.5 NPS	0.2223 in ²	[E] 0.532 in	0.133 in	15-2900 psi	Steam	NV, UV
0.75-1.5 NPS	1-2.5 NPS	0.2223 in ²	[E] 0.532 in	0.133 in	15-6000 psi	Air	NV, UV
1-1.5 NPS	2 NPS	0.3484 in ²	[F] 0.666 in	0.167 in	15-2900 psi	Steam	NV, UV
1-1.5 NPS	2 NPS	0.3484 in ²	[F] 0.666 in	0.167 in	15-5000 psi	Air	NV, UV
1.5-2 NPS	2-3 NPS	0.57 in ²	[G] 0.852 in	0.213 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2-3 NPS	0.57 in ²	[G] 0.852 in	0.213 in	15-3705 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.891 in ²	[H] 1.065 in	0.266 in	15-2900 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.891 in ²	[H] 1.065 in	0.266 in	15-2900 psi	Steam	NV, UV
2 NPS	3 NPS	1.459 in ²	[J] 1.363 in	0.34 in	15-2900 psi	Air	NV, UV
2 NPS	3 NPS	1.459 in ²	[J] 1.363 in	0.34 in	15-2900 psi	Steam	NV, UV
3 NPS	4 NPS	2.087 in ²	[K] 1.63 in	0.408 in	15-2900 psi	Steam	NV, UV
3 NPS	4 NPS	2.087 in ²	[K] 1.63 in	0.408 in	15-2900 psi	Air	NV, UV
3 NPS	4 NPS	3.237 in ²	[L] 2.03 in	0.508 in	15-1500 psi	Steam	NV, UV
3 NPS	4 NPS	3.237 in ²	[L] 2.03 in	0.508 in	15-1500 psi	Air	NV, UV
4 NPS	6 NPS	4.083 in ²	[M] 2.28 in	0.57 in	15-1100 psi	Steam	NV, UV
4 NPS	6 NPS	4.083 in ²	[M] 2.28 in	0.57 in	15-1100 psi	Air	NV, UV
4 NPS	6 NPS	4.924 in ²	[N] 2.504 in	0.626 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	4.924 in ²	[N] 2.504 in	0.626 in	15-1000 psi	Air	NV, UV
4 NPS	6 NPS	7.234 in ²	[P] 3.035 in	0.759 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	7.234 in ²	[P] 3.035 in	0.759 in	15-1000 psi	Air	NV, UV
6 NPS	8 NPS	12.53 in ²	[Q] 3.994 in	0.999 in	15-600 psi	Steam	NV, UV
6 NPS	8 NPS	12.53 in ²	[Q] 3.994 in	0.999 in	15-600 psi	Air	NV, UV
6 NPS	8-10 NPS	18.148 in ²	[R] 4.807 in	1.2 in	15-500 psi	Steam	NV, UV
6 NPS	8-10 NPS	18.148 in ²	[R] 4.807 in	1.2 in	15-500 psi	Air	NV, UV
8 NPS	10 NPS	29.494 in ²	[T] 6.128 in	1.532 in	15-500 psi	Steam	NV, UV
8 NPS	10 NPS	29.494 in ²	[T] 6.128 in	1.532 in	15-500 psi	Air	NV, UV
10-12 NPS	14 NPS	38.485 in ²	7 in	1.75 in	15-600 psi	Steam	NV, UV

10-12 NPS	14 NPS	38.485 in ²	7 in	1.75 in	15-600 psi	Air	NV, UV
10-12 NPS	14 NPS	47.85 in ²	[V] 7.805 in	1.951 in	15-500 psi	Steam	NV, UV
10-12 NPS	14 NPS	47.85 in ²	[V] 7.805 in	1.951 in	15-500 psi	Air	NV, UV
12 NPS	16 NPS	68.9 in ²	[W] 9.366 in	2.341 in	15-500 psi	Steam	NV, UV
12 NPS	16 NPS	68.9 in ²	[W] 9.366 in	2.341 in	15-500 psi	Air	NV, UV
12 NPS	16 NPS	72 in ²	[W1] 9.575 in	2.394 in	15-400 psi	Steam	NV, UV
12 NPS	16 NPS	72 in ²	[W1] 9.575 in	2.394 in	15-400 psi	Air	NV, UV
14 NPS	18 NPS	93.78 in ²	[Y] 10.927 in	2.732 in	15-400 psi	Air	NV, UV
14 NPS	18 NPS	93.78 in ²	[Y] 10.927 in	2.732 in	15-400 psi	Steam	NV, UV
16 NPS	18 NPS	103.15 in ²	[Z] 11.46 in	2.865 in	15-400 psi	Air	NV, UV
16 NPS	18 NPS	103.15 in ²	[Z] 11.46 in	2.865 in	15-400 psi	Steam	NV, UV
18-20 NPS	24 NPS	108.434 in ²	11.75 in	2.938 in	15-600 psi	Air	NV, UV
18-20 NPS	24 NPS	108.434 in ²	11.75 in	2.938 in	15-600 psi	Steam	NV, UV
16 NPS	18 NPS	110 in ²	[Z1] 11.835 in	2.959 in	15-400 psi	Air	NV, UV
16 NPS	18 NPS	110 in ²	[Z1] 11.835 in	2.959 in	15-400 psi	Steam	NV, UV
16 NPS	20-22 NPS	123.47 in ²	[Z2] 12.538 in	3.135 in	15-400 psi	Air	NV, UV
16 NPS	20-22 NPS	123.47 in ²	[Z2] 12.538 in	3.135 in	15-400 psi	Steam	NV, UV
18-20 NPS	24 NPS	155.04 in ²	[AA] 14.05 in	3.513 in	15-400 psi	Steam	NV, UV
18-20 NPS	24 NPS	155.04 in ²	[AA] 14.05 in	3.513 in	15-400 psi	Air	NV, UV
20 NPS	24 NPS	191.38 in ²	[BB] 15.61 in	3.902 in	15-400 psi	Air	NV, UV
20 NPS	24 NPS	191.38 in ²	[BB] 15.61 in	3.902 in	15-400 psi	Steam	NV, UV
20 NPS	24 NPS	213.82 in ²	[BB2] 16.5 in	4.125 in	15-300 psi	Air	NV, UV
20 NPS	24 NPS	213.82 in ²	[BB2] 16.5 in	4.125 in	15-300 psi	Steam	NV, UV

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Liquids)	NBCert #	15095
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	NV, UV	01/09/2029
--------------	--------	------------

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V

1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JMBL (Liquids) NBCert # 15129

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV, UV 02/15/2028

Design Type

[Relief Valve] JMBL (Liquids)
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on October 5, 1984
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.657 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Crosby Valve, LLC {CVM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.0552 in ²	[2] 0.265 in	0.07 in	15-5000 psi	Water	NV
0.5-1 NPS	1 NPS	0.0552 in ²	[2] 0.265 in	0.07 in	15-5000 psi	Water	UV

0.5-1 NPS	1 NPS	0.0845 in ²	[4] 0.328 in	0.095 in	15-5000 psi	Water	NV
0.5-1 NPS	1 NPS	0.0845 in ²	[4] 0.328 in	0.095 in	15-5000 psi	Water	UV
0.5-1.5 NPS	1, 1.5 NPS	0.1244 in ²	[6] 0.398 in	0.125 in	15-5000 psi	Water	NV
0.5-1.5 NPS	1, 1.5 NPS	0.1244 in ²	[6] 0.398 in	0.125 in	15-5000 psi	Water	UV
0.75-1.5 NPS	1, 1.5 NPS	0.2214 in ²	[8] 0.531 in	0.2 in	15-5000 psi	Water	NV
0.75-1.5 NPS	1, 1.5 NPS	0.2214 in ²	[8] 0.531 in	0.2 in	15-5000 psi	Water	UV

Design Name:	JMB-WR	NBCert #	15174
--------------	--------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV, -Class 1, -Class 2, -Class 3, UV 07/11/2026

Design Type

[Safety Relief Valve] JMB-WR
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 10, 1981
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.563 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Crosby Valve, LLC {CVM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	1, 1.5 NPS	0.012 in ²	0.124 in	0.012 in	5-2750 psi	Water	NV
0.75-1.5 NPS	1, 1.5 NPS	0.012 in ²	0.124 in	0.012 in	5-2750 psi	Water	UV
0.75-1.5 NPS	1, 1.5 NPS	0.0274 in ²	0.187 in	0.015 in	5-2750 psi	Water	NV
0.75-1.5 NPS	1, 1.5 NPS	0.0274 in ²	0.187 in	0.015 in	5-2750 psi	Water	UV
0.75-1.5 NPS	1, 1.5 NPS	0.0486 in ²	0.249 in	0.021 in	5-2750 psi	Water	NV
0.75-1.5 NPS	1, 1.5 NPS	0.0486 in ²	0.249 in	0.021 in	5-2750 psi	Water	UV
0.75-1.5 NPS	1, 1.5 NPS	0.1098 in ²	0.374 in	0.04 in	5-2750 psi	Water	NV
0.75-1.5 NPS	1, 1.5 NPS	0.1098 in ²	0.374 in	0.04 in	5-2750 psi	Water	UV

Design Name:	JO/HSU (Class 2 and 3)	NBCert #	15196
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV, -Class 1, -Class 2, -Class 3, UV 07/11/2026

Design Type

[Safety Relief Valve] JO/HSU (Class 2 and 3)
Capacity Tests: Sec. NV, UV at unknown lab on October 19, 1955
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Crosby Valve, LLC {CVM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 2.5 NPS	0.1244 in ²	[D] 0.398 in	0.099 in	15-10000 psi	Air	NV, UV
1-1.5 NPS	2, 2.5 NPS	0.1244 in ²	[D] 0.398 in	0.099 in	15-2900 psi	Steam	NV, UV

1-1.5 NPS	2, 2.5 NPS	0.2223 in ²	[E] 0.532 in	0.133 in	15-2900 psi	Steam	NV, UV
1-1.5 NPS	2, 2.5 NPS	0.2223 in ²	[E] 0.532 in	0.133 in	15-7500 psi	Air	NV, UV
1.5 NPS	2 NPS	0.3484 in ²	[F] 0.666 in	0.167 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2 NPS	0.3484 in ²	[F] 0.666 in	0.167 in	15-5000 psi	Air	NV, UV
1.5 NPS	2.5 NPS	0.57 in ²	[G] 0.852 in	0.213 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.57 in ²	[G] 0.852 in	0.213 in	15-3705 psi	Air	NV, UV
1.5 NPS	3 NPS	0.891 in ²	[H] 1.065 in	0.266 in	15-2900 psi	Air	NV, UV
1.5 NPS	3 NPS	0.891 in ²	[H] 1.065 in	0.266 in	15-2900 psi	Steam	NV, UV
2 NPS	3 NPS	1.459 in ²	[J] 1.363 in	0.34 in	15-2900 psi	Air	NV, UV
2 NPS	3 NPS	1.459 in ²	[J] 1.363 in	0.34 in	15-2900 psi	Steam	NV, UV
3 NPS	4 NPS	2.087 in ²	[K] 1.63 in	0.408 in	15-2900 psi	Air	NV, UV
3 NPS	4 NPS	2.087 in ²	[K] 1.63 in	0.408 in	15-2900 psi	Steam	NV, UV
3 NPS	4 NPS	3.237 in ²	[L] 2.03 in	0.508 in	15-1500 psi	Air	NV, UV
3 NPS	4 NPS	3.237 in ²	[L] 2.03 in	0.508 in	15-1500 psi	Steam	NV, UV
4 NPS	6 NPS	4.083 in ²	[M] 2.28 in	0.57 in	15-1100 psi	Air	NV, UV
4 NPS	6 NPS	4.083 in ²	[M] 2.28 in	0.57 in	15-1100 psi	Steam	NV, UV
4 NPS	6 NPS	4.924 in ²	[N] 2.504 in	0.626 in	15-1000 psi	Air	NV, UV
4 NPS	6 NPS	4.924 in ²	[N] 2.504 in	0.626 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	7.234 in ²	[P] 3.035 in	0.759 in	15-1000 psi	Air	NV, UV
4 NPS	6 NPS	7.234 in ²	[P] 3.035 in	0.759 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	12.53 in ²	[Q] 3.994 in	0.999 in	15-600 psi	Air	NV, UV
6 NPS	8 NPS	12.53 in ²	[Q] 3.994 in	0.999 in	15-600 psi	Steam	NV, UV
6 NPS	8 NPS	18.148 in ²	[R] 4.807 in	1.2 in	15-500 psi	Air	NV, UV
6 NPS	8 NPS	18.148 in ²	[R] 4.807 in	1.2 in	15-500 psi	Steam	NV, UV
8 NPS	10 NPS	29.494 in ²	[T] 6.128 in	1.532 in	15-500 psi	Air	NV, UV
8 NPS	10 NPS	29.494 in ²	[T] 6.128 in	1.532 in	15-500 psi	Steam	NV, UV
10 NPS	14 NPS	47.85 in ²	[V] 7.805 in	1.951 in	15-500 psi	Air	NV, UV
10 NPS	14 NPS	47.85 in ²	[V] 7.805 in	1.951 in	15-500 psi	Steam	NV, UV
12 NPS	14 NPS	68.9 in ²	[W] 9.366 in	2.341 in	15-500 psi	Air	NV, UV
12 NPS	14 NPS	68.9 in ²	[W] 9.366 in	2.341 in	15-500 psi	Steam	NV, UV
14 NPS	18 NPS	93.78 in ²	[Y] 10.927 in	2.732 in	15-400 psi	Air	NV, UV
14 NPS	18 NPS	93.78 in ²	[Y] 10.927 in	2.732 in	15-400 psi	Steam	NV, UV
16 NPS	18 NPS	103.15 in ²	[Z] 11.46 in	2.865 in	15-400 psi	Air	NV, UV
16 NPS	18 NPS	103.15 in ²	[Z] 11.46 in	2.865 in	15-400 psi	Steam	NV, UV
16 NPS	20 NPS	123.47 in ²	[Z2] 12.538 in	3.135 in	15-400 psi	Air	NV, UV
16 NPS	20 NPS	123.47 in ²	[Z2] 12.538 in	3.135 in	15-400 psi	Steam	NV, UV
18 NPS	24 NPS	155.04 in ²	[AA] 14.05 in	3.513 in	15-400 psi	Air	NV, UV
18 NPS	24 NPS	155.04 in ²	[AA] 14.05 in	3.513 in	15-400 psi	Steam	NV, UV
20 NPS	24 NPS	191.38 in ²	[BB] 15.61 in	3.902 in	15-400 psi	Air	NV, UV
20 NPS	24 NPS	191.38 in ²	[BB] 15.61 in	3.902 in	15-400 psi	Steam	NV, UV
20 NPS	24 NPS	213.82 in ²	[BB2] 16.5 in	4.125 in	15-300 psi	Air	NV, UV

20 NPS 24 NPS 213.82 in² [BB2] 16.5 in 4.125 in 15-300 psi Steam NV, UV

Design Name: JO/JB-WR (Class 1, 2, 3 Liquids) NBCert # 15343

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, UV	03/01/2029
Design Type		

[Relief Valve] JO/JB-WR (Class 1, 2, 3 Liquids)
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on October 3, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.564 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Crosby Valve, LLC {CVM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2, 2.5 NPS	0.114 in²	[D] 0.455 in	0.08 in	5-6000 psi	Water	NV
0.75-1.5 NPS	2, 2.5 NPS	0.205 in²	[E] 0.61 in	0.107 in	5-6000 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.316 in²	[F] 0.751 in	0.134 in	5-5000 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5 in²	[G] 0.93 in	0.171 in	5-3600 psi	Water	NV
1.5-2 NPS	3,4 NPS	0.778 in²	[H] 1.163 in	0.213 in	5-2480 psi	Water	NV
2-3 NPS	3 - 6 NPS	1.281 in²	[J] 1.494 in	0.273 in	5-2440 psi	Water	NV
3 NPS	4, 6 NPS	1.831 in²	[K] 1.782 in	0.327 in	5-1950 psi	Water	NV
3-4 NPS	4,6 NPS	2.827 in²	[L] 2.211 in	0.407 in	5-1500 psi	Water	NV
4 NPS	6 NPS	3.562 in²	[M] 2.481 in	0.457 in	5-1100 psi	Water	NV
4 NPS	6,8 NPS	4.312 in²	[N] 2.734 in	0.502 in	5-1000 psi	Water	NV
4 NPS	6,8 NPS	6.315 in²	[P] 3.306 in	0.608 in	5-1000 psi	Water	NV
6 NPS	8 NPS	10.998 in²	[Q] 4.376 in	0.8 in	5-600 psi	Water	NV
6 NPS	8-10 NPS	15.8 in²	[R] 4.811 in	0.96 in	15-600 psi	Water	NV

Design Name: JPV-A NBCert # 15231

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 2, -Class 3, UV	11/18/2030
Design Type		

[Safety Relief Valve] JPV-A
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Crosby Valve, LLC on April 29, 1968
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Crosby Valve, LLC {CVM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS	14 NPS	44.18 in²	[V] 7.5 in	1.875 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
10 NPS	14 NPS	44.18 in²	[V] 7.5 in	1.875 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV

12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.25 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.25 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
14 NPS	18 NPS	86.59 in ²	[Y] 10.5 in	2.625 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
14 NPS	18 NPS	86.59 in ²	[Y] 10.5 in	2.625 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
16 NPS	18 NPS	95.21 in ²	[Z] 11.01 in	2.753 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
16 NPS	18 NPS	95.21 in ²	[Z] 11.01 in	2.753 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
16 NPS	20 NPS	114.04 in ²	[Z2] 12.05 in	3.012 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
16 NPS	20 NPS	114.04 in ²	[Z2] 12.05 in	3.012 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
18 NPS	22, 24 NPS	143.14 in ²	[AA] 13.5 in	3.375 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
18 NPS	22, 24 NPS	143.14 in ²	[AA] 13.5 in	3.375 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
20 NPS	24 NPS	176.71 in ²	[BB] 15 in	3.75 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
20 NPS	24 NPS	176.71 in ²	[BB] 15 in	3.75 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: JRAK-BS (Class 1, 2, 3 Liquids) NBCert # 15309

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV, UV 08/30/2028

Design Type

[Relief Valve] JRAK-BS (Class 1, 2, 3 Liquids)
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 19, 1981
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.646 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Crosby Valve, LLC {CVM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.012 in ²	0.124 in	0.008 in	15-3600 psi	Water	UV
0.5-1 NPS	1 NPS	0.012 in ²	0.124 in	0.008 in	5-3600 psi	Water	NV
0.5-1 NPS	1 NPS	0.0274 in ²	0.187 in	0.019 in	15-3600 psi	Water	UV
0.5-1 NPS	1 NPS	0.0274 in ²	0.187 in	0.019 in	5-3600 psi	Water	NV
0.5-1 NPS	1 NPS	0.0486 in ²	0.249 in	0.029 in	15-3600 psi	Water	UV
0.5-1 NPS	1 NPS	0.0486 in ²	0.249 in	0.029 in	5-3600 psi	Water	NV
0.5-1 NPS	1 NPS	0.0674 in ²	0.293 in	0.04 in	15-3600 psi	Water	UV
0.5-1 NPS	1 NPS	0.0674 in ²	0.293 in	0.04 in	5-3600 psi	Water	NV
0.5-1 NPS	1 NPS	0.1098 in ²	0.374 in	0.061 in	15-3600 psi	Water	UV
0.5-1 NPS	1 NPS	0.1098 in ²	0.374 in	0.061 in	5-3600 psi	Water	NV

Design Name: JRL (Liquids) NBCert # 15310

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV, UV 08/30/2028

Design Type

[Relief Valve] JRL (Liquids)
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on October 3, 1984
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.145 GPM/SQ. RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Crosby Valve, LLC {CVM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.084 in ²	0.328 in	0.125 in	15-2000 psi	Water	NV
0.5-1 NPS	1 NPS	0.084 in ²	0.328 in	0.125 in	15-2000 psi	Water	UV

Design Name: SS-114-657 NBCert # 15602

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

NV, -Class 1

09/26/2026

Design Type

[Power Actuated Relief Valve] SS-114-657
Capacity Tests: Sec. NV, -Class 1 at Anderson Greenwood Crosby on August 31, 2020
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.777 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Heavy Flow
Blowdown Characteristics: Adjustable (Other)
Flow Area Configuration: Curtain Area
Designed by: Crosby Valve, LLC {CVM}
Comments: Rated capacity calculated at 44 PSID

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4-4 NPS	4 NPS	3.356 in ²	3.438 in	0.75 in	1415-1415 psi	Water	NV, -Class 1

Design Name: VR (1") NBCert # 15488

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

NV

03/01/2029

Design Type

[Vacuum Relief Valve] VR (1")
Capacity Tests: Sec. NV at Crosby Valve, LLC on December 20, 1991
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.600 SCFM/F(P*(P-Po))^{0.5}
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Cage
Designed by: Crosby Valve, LLC {CVM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1 NPS	0.442 in ²			0.1-7 psi	Air	NV

Design Name:	VR (2")	NBCert #	15578
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV	03/01/2029

Design Type

[Vacuum Relief Valve] VR (2")
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3 at Crosby Valve, LLC on January 23, 1992
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:38.300 SCFM/F(P*(P-Po))^.5
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Cage
Designed by: Crosby Valve, LLC {CVM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	1.841 in ²			0.1-7 psi	Air	NV

Design Name:	VR (3")	NBCert #	15556
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV	08/15/2029

Design Type

[Vacuum Relief Valve] VR (3")
Capacity Tests: Sec. NV at Crosby Valve, LLC on November 7, 1996
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:87.110 SCFM/F(P*(P-Po))^.5
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Designed by: Crosby Valve, LLC {CVM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS	3 NPS	4.146 in ²			0.1-7 psi	Air	NV

Curtiss Wright (Tianjin) Flow Control Co., Ltd. (FTC)

Tianjin, 301700People's Republic of China

This Company Manufactures or Assembles:

Design Name:	2400	NBCert #	57451
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/02/2030

Design Type

[Safety Relief Valve] 2400

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on August 28, 2019

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.817 Unitless

Media - Test: Air/Gas; Certified: Air, Gas

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75-1 NPS	0.049 in ²	[B] 0.25 in	0.08 in	20-2000 psi	Air	UV
0.5-1 NPS	1-2 NPS	0.11 in ²	[D] 0.375 in	0.12 in	20-1410 psi	Air	UV
0.75-1 NPS	1-2 NPS	0.196 in ²	[E] 0.5 in	0.175 in	20-600 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.295 in	20-4000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.365 in	20-3000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.435 in	20-2500 psi	Air	UV

Design Name: 2600 & 2600S

NBCert # 57057

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

06/21/2030

Design Type

[Safety Relief Valve] 2600 & 2600S

Capacity Tests: Sec. UV at unknown lab on June 11, 1972

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable (Single Ring)

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV

3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

09/21/2027

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV

1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids)	NBCert # 57068
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	09/21/2027
--------------	----	------------

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V

1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S

NBCert #

57237

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

09/22/2027

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV

2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/23/2027

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name:	3800	NBCert #	57024
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/22/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3800
Capacity Tests: Sec. UV at unknown lab on May 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV

1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name:	3800FP	NBCert #	57035
--------------	--------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	09/09/2027
--------------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 3800FP
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on April 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-1050 psi	Steam	UV
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-11300 psi	Air	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-1050 psi	Steam	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-11300 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-1050 psi	Steam	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-11300 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-1050 psi	Steam	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-11300 psi	Air	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-6300 psi	Air	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-6300 psi	Air	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-2300 psi	Air	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1500 psi	Air	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-800 psi	Steam	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-1500 psi	Air	UV

Design Name:	3800L, PCL, PCM pilots	NBCert #	57215
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/22/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.782 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV

3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Custom Safety Solutions, LLC, an affiliate of BS&B Safety Systems, LLC (CUS)

Minneapolis, MN 55439United States

This Company Manufactures or Assembles:

Design Name:	0.5" FRB WFT	NBCert #	77600
Manufacturer/Assembler	Designators	Expiration Date	

Manufacturer UD 06/12/2031

Design Type

[Rupture Disk Device] 0.5" FRB WFT
HolderDesignation: Single use assembly
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on September 7, 2000
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value:35.700 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1 NPS	1 NPS	0.216 in ²			85-450 psi	Air	UD

Design Name:	1/2" FRB A-6 M x F & M x M Stakul, W-6 FRB, W-6 FRB F	NBCert #	77217
Manufacturer/Assembler	Designators	Expiration Date	

Manufacturer UD 05/30/2031

Design Type

[Rupture Disk Device] 1/2" FRB A-6 M x F & M x M Stakul, W-6 FRB, W-6 FRB F
HolderDesignation: A-6
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 8, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 2.190 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	0.5 NPS	0.196 in ²			35-800 psi		UD

Design Name:	A-2 SK 0.5 FRB	NBCert #	77598
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	05/30/2031

Design Type

[Rupture Disk Device] A-2 SK 0.5 FRB
HolderDesignation: Integral
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on September 1, 2000
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 2.200 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	0.5 NPS	0.196 in ²			50-650 psi		UD

Design Name:	FRB (welded cassette)	NBCert #	77835
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	06/12/2031

Design Type

[Rupture Disk Device] FRB (welded cassette)
HolderDesignation: N/A
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on February 26, 2004
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 6.800 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375 NPS		0.09 in ²			60-400 psi		UD

Design Name:	SKA	NBCert #	77846
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	05/30/2031

Design Type

[Rupture Disk Device] SKA
HolderDesignation: Integral one piece design
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 13, 2004
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS		0.046 in ²	0.25 in		50-750 psi	Air	UD
0.375 NPS		0.085 in ²	0.375 in		50-750 psi		UD

Design Name: Welded FRB-Free Outlet		NBCert #	78443
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	05/30/2031
Design Type			
[Rupture Disk Device] Welded FRB-Free Outlet HolderDesignation: Integral Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on February 1, 2019 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.820 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125 NPS		0.036 in²			200-900 psi	Air	UD
0.25 NPS		0.046 in²			100-850 psi	Air	UD
0.375 NPS		0.096 in²			50-800 psi	Air	UD
0.5 NPS		0.196 in²			35-700 psi	Air	UD
0.75 NPS		0.442 in²			25-405 psi	Air	UD

Design Name: Welded FRB-Muffled Outlet		NBCert #	78454
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	05/30/2031
Design Type			
[Rupture Disk Device] Welded FRB-Muffled Outlet HolderDesignation: Integral Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on February 1, 2019 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.740 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125 NPS		0.036 in²			200-900 psi	Air	UD
0.25 NPS		0.046 in²			100-850 psi	Air	UD
0.375 NPS		0.096 in²			50-800 psi	Air	UD
0.5 NPS		0.196 in²			35-700 psi	Air	UD
0.75 NPS		0.442 in²			25-405 psi	Air	UD

Cv Techserv, Inc. (CVT)

Hastings, MN 55033United States

This Company Manufactures or Assembles:

Design Name: Kunkle 264, 265, 266 & 267				NBCert # 36267			
Manufacturer/Assembler			Designators		Expiration Date		
Assembler			UV		09/19/2030		
Design Type							
[Safety Relief Valve] Kunkle 264, 265, 266 & 267 Capacity Tests: Sec. UV at unknown lab on July 20, 1956 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.766 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.11 in²	0.375 in	0.115 in	15-2000 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.11 in²	0.375 in	0.115 in	15-3300 psi	Air	UV

Design Name: Kunkle 300,600				NBCert # 36076			
Manufacturer/Assembler			Designators		Expiration Date		
Assembler			UV, V		09/19/2030		
Design Type							
[Safety Valve] Kunkle 300,600 Capacity Tests: Sec. UV, V at unknown lab on February 10, 1961 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.307 in²	[F] 0.625 in	0.156 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.307 in²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.307 in²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	UV
1.25 NPS	1.5 NPS	0.503 in²	[G] 0.8 in	0.2 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.503 in²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.503 in²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	0.785 in²	[H] 1 in	0.25 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	0.785 in²	[H] 1 in	0.25 in	15-1000 psi	Steam	V

1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	V
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Air	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	V
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Air	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	V
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Air	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	V
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	V
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Air	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	UV

Design Name:	Kunkle 337	NBCert #	36278
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/19/2030

Design Type

[Safety Relief Valve] Kunkle 337
 Capacity Tests: Sec. UV at unknown lab on February 22, 1982
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.860 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	1.916 in ²	1.562 in	0.612 in	15-60 psi	Air	UV
2.5 NPS	2.5 NPS	2.786 in ²	1.883 in	0.755 in	15-60 psi	Air	UV
3 NPS	3 NPS	4.037 in ²	2.267 in	0.91 in	15-60 psi	Air	UV

Design Name:	Kunkle 6000, 6252 Series	NBCert #	36324
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	11/19/2030

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V

4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 910 to 919

NBCert #

36100

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

09/19/2030

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name: Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)

NBCert #

36111

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV, V

09/19/2030

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 , 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

Design Name:	Kunkle 920, 921, 927, Agco A (High Temp. water)	NBCert #	36098
Manufacturer/Assembler		Designators	Expiration Date
Assembler		V	09/19/2030

Design Type

[Safety Valve] Kunkle 920, 921, 927, Agco A (High Temp. water)
Capacity Tests: Sec. V at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Forced Flow Steam Generator/High Temp Hot Water (10% BD)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	V

Cyrus Shank Company (SHK)

Cicero, IL 60804United States

This Company Manufactures or Assembles:

Design Name:	800, 800D, 800QR, 800QRW, 800QRWX, 800QRM	NBCert #	51163
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/14/2030

Design Type

[Safety Relief Valve] 800, 800D, 800QR, 800QRW, 800QRWX, 800QRM
Capacity Tests: Sec. UV at National Board Testing Lab on June 3, 2002
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.420 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Cyrus Shank Company {SHK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.02771 in ²	0.466 in	0.12 in	50-400 psi	Air	UV

Design Name:	800OP, 800OPQR, 800D OP, 800SS OP, 800QRW OP	NBCert #	51253
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/21/2029

Design Type

[Safety Relief Valve] 800OP, 800OPQR, 800D OP, 800SS OP, 800QRW OP
Capacity Tests: Sec. UV at National Board Testing Lab on March 24, 2017
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.216 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Cyrus Shank Company {SHK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.162 in ²	0.466 in	0.12 in	250-300 psi	Air	UV

Design Name:	801, 801D, 801QR, 801QRW, 801QRM	NBCert #	51152
--------------	----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/21/2029

Design Type

[Safety Relief Valve] 801, 801D, 801QR, 801QRW, 801QRM
Capacity Tests: Sec. UV at National Board Testing Lab on February 28, 2002
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.730 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Cyrus Shank Company {SHK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.0487 in ²	0.466 in	0.125 in	75-400 psi	Air	UV

Design Name:	801DHC/801DHC QR	NBCert #	51208
--------------	------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 06/17/2029

Design Type

[Safety Relief Valve] 801DHC/801DHC QR
Capacity Tests: Sec. UV at National Board Testing Lab on April 8, 2011
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.781 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Cyrus Shank Company {SHK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS				75-400 psi	Air	UV

Design Name:	803	NBCert #	51129
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/14/2026

Design Type

[Safety Relief Valve] 803
Capacity Tests: Sec. UV at National Board Testing Lab on November 30, 1999
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.978 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Cyrus Shank Company {SHK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.1312 in ²	0.466 in	0.14 in	50-400 psi	Air	UV

Design Name:	803 LQ 100 psig liquid, 803 LQ QC 100 psig liquid	NBCert #	51073
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/02/2025

Design Type

[Relief Valve] 803 LQ 100 psig liquid, 803 LQ QC 100 psig liquid
Capacity Tests: Sec. UV at National Board Testing Lab on June 19, 1998
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value: 25.900 GPM
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Cyrus Shank Company {SHK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.1148 in ²	0.466 in		100-100 psi	Water	UV

Design Name: 803 LQ 75 psig (liquids)		NBCert #	51039
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	03/23/2027
Design Type			
[Relief Valve] 803 LQ 75 psig (liquids) Capacity Tests: Sec. UV at National Board Testing Lab on March 23, 1995 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:20.700 GPM Media - Test: Liquid; Certified: Liquid Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Cyrus Shank Company {SHK}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.1148 in²	0.466 in	0.14 in	75-75 psi	Water	UV

Design Name: 803LQ-50		NBCert # 51275
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/15/2025
Design Type		
<div>[Relief Valve] 803LQ-50 Capacity Tests: Sec. UV at National Board Testing Lab on May 28, 2019 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:19.200 GPM Media - Test: Liquid; Certified: Liquid Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Cyrus Shank Company {SHK}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	0.75 NPS	0.1148 in²	0.466 in	0.14 in	50-50 psi	Water	UV

Design Name: 804, 804QR Series		NBCert # 51017
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	09/15/2026
Design Type		
<div>[Safety Relief Valve] 804, 804QR Series</div> <div>Capacity Tests: Sec. UV at National Board Testing Lab on April 5, 2000</div> <div>Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method</div> <div>Certified Value: 3.040 SCFM/PSIA</div> <div>Media - Test: Air/Gas; Certified: Gas</div> <div>Set Pressure Definition: Pop</div> <div>Blowdown Characteristics: Fixed</div> <div>Flow Area Configuration: Curtain Area</div> <div>Designed by: Cyrus Shank Company {SHK}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.2821 in²	0.708 in	0.12 in	75-400 psi	Air	UV

Design Name:	804R, 804R-QR	NBCert #	51219
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/12/2030

Design Type

[Safety Relief Valve] 804R, 804R-QR
Capacity Tests: Sec. UV at National Board Testing Lab on July 6, 2012
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.630 SCFM/PSIA
Media - ; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Cyrus Shank Company {SHK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS		0.708 in	0.12 in	75-400 psi	Air	UV

Design Name:	805 LQ 100 psig	NBCert #	51062
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/24/2025

Design Type

[Relief Valve] 805 LQ 100 psig
Capacity Tests: Sec. UV at National Board Testing Lab on July 15, 1998
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:36.500 GPM
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Cyrus Shank Company {SHK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.25 NPS	0.445 in ²	1.05 in	0.135 in	100-100 psi	Water	UV

Design Name:	805R, 805R-QR	NBCert #	51220
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/12/2030

Design Type

[Safety Relief Valve] 805R, 805R-QR
Capacity Tests: Sec. UV at National Board Testing Lab on September 21, 2012
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.100 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Cyrus Shank Company {SHK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1 NPS	1.25 NPS	0.168 in ²	1.05 in		75-400 psi	Air	UV

Design Name: 805-T, 805QR, 815, 815QR Series		NBCert #	51028
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	09/26/2027
Design Type			
[Safety Relief Valve] 805-T, 805QR, 815, 815QR Series Capacity Tests: Sec. UV at unknown lab on January 27, 1984 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 4.090 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Cyrus Shank Company {SHK}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.25, 1.5 NPS	0.866 in ²	1.05 in		75-400 psi	Air	UV

Design Name: 812		NBCert # 51174
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/27/2027
Design Type		
<div>[Safety Relief Valve] 812</div> <div>Capacity Tests: Sec. UV at National Board Testing Lab on January 27, 2005</div> <div>Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method</div> <div>Certified Value: 1.339 SCFM/PSIA</div> <div>Media - Test: Air/Gas; Certified: Gas</div> <div>Set Pressure Definition: Pop</div> <div>Blowdown Characteristics: Fixed</div> <div>Flow Area Configuration: Nozzle/Full Lift</div> <div>Designed by: Cyrus Shank Company {SHK}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	1 NPS	0.1312 in ²	0.466 in	0.14 in	75-400 psi	Air	UV

Design Name: 813		NBCert # 51141
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	09/25/2029
Design Type		
<div>[Safety Relief Valve] 813 Capacity Tests: Sec. UV at National Board Testing Lab on August 23, 2001 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.990 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Cyrus Shank Company {SHK}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	1 NPS	0.1312 in ²	0.466 in	0.14 in	75-400 psi	Air	UV

Design Name:	814	NBCert #	51130
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/17/2029

Design Type

[Safety Relief Valve] 814
Capacity Tests: Sec. UV at National Board Testing Lab on May 17, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.290 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Cyrus Shank Company {SHK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1.25 NPS	0.2821 in ²	0.708 in		75-400 psi	Air	UV

Design Name:	850, 851	NBCert #	51051
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 08/24/2025

Design Type

[Safety Relief Valve] 850, 851
Capacity Tests: Sec. UV at National Board Testing Lab on July 15, 1998
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 6.170 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Cyrus Shank Company {SHK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.25 NPS	1.5, 2 NPS	0.442 in ²	0.75 in	0.5 in	150-400 psi	Air	UV

Design Name:	850DR, 851DR, 850AR, 851AR	NBCert #	51231
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 08/13/2025

Design Type

[Safety Relief Valve] 850DR, 851DR, 850AR, 851AR
Capacity Tests: Sec. UV at National Board Testing Lab on May 3, 2013
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.500 SCFM/PSIA
Media - ; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Cyrus Shank Company {SHK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.25 NPS	1.5, 2 NPS				150-400 psi	Air	UV

Design Name: 900, 901, 902, 903		NBCert #	51040
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	12/14/2030
Design Type			
[Safety Relief Valve] 900, 901, 902, 903 Capacity Tests: Sec. UV at National Board Testing Lab on May 28, 1997 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:15.180 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Cyrus Shank Company {SHK}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	2, 3 NPS	1.2275 in ²	1.25 in		150-400 psi	Air	UV

Design Name: CS 5602A, CS5602AQR		NBCert #	51185
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	09/27/2028	
Design Type			
[Safety Relief Valve] CS 5602A, CS5602AQR Capacity Tests: Sec. UV at National Board Testing Lab on July 22, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.320 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Cyrus Shank Company {SHK}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.282 in ²			75-400 psi	Air	UV

Design Name: CS 5602B, CS 5602BQR, CS 5602C, CS 5602CQR		NBCert #	51196
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	09/23/2028	
Design Type			
[Safety Relief Valve] CS 5602B, CS 5602BQR, CS 5602C, CS 5602CQR Capacity Tests: Sec. UV at National Board Testing Lab on September 1, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.650 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Cyrus Shank Company {SHK}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1 NPS	0.305 in ²	0.708 in	0.12 in	75-400 psi	Air	UV

Design Name: CS 5602R			NBCert # 51264				
Manufacturer/Assembler		Designators		Expiration Date			
Manufacturer		UV		09/21/2029			
Design Type							
[Safety Relief Valve] CS 5602R Capacity Tests: Sec. UV at National Board Testing Lab on May 11, 2017 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.781 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Cyrus Shank Company {SHK}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.0574 in²	0.708 in²	0.12 in	75-400 psi	Air	UV

Dalian Duta Technology Safety System co., Ltd. (DLE)

Dalian, PC 116620 People's Republic of China

This Company Manufactures or Assembles:

Design Name: LC			NBCert #		01797		
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			11/30/2028	
Design Type							
[Rupture Disk Device] LC HolderDesignation: LJ Capacity Tests: Sec. UD at National Board Testing Lab on August 19, 2021 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.260 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Dalian Duta Technology Safety System co., Ltd. {DLE}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.488 in²			70-5000 psi		UD
1 NPS		0.762 in²			60-5000 psi		UD
1.25 NPS		1.489 in²			50-5000 psi		UD
1.5 NPS		2.463 in²			45-5000 psi		UD
10 NPS		76.288 in²			20-1500 psi		UD
12 NPS		109.856 in²			20-1000 psi		UD
14 NPS		149.526 in²			15-1000 psi		UD
16 NPS		195.3 in²			15-100 psi		UD
18 NPS		257.465 in²			10-100 psi		UD

2 NPS	3.679 in ²	40-5000 psi	UD
2.5 NPS	5.961 in ²	35-5000 psi	UD
20 NPS	310.301 in ²	10-80 psi	UD
24 NPS	445.361 in ²	10-80 psi	UD
28 NPS	598.107 in ²	10-60 psi	UD
3 NPS	8.79 in ²	30-5000 psi	UD
4 NPS	13.414 in ²	30-4000 psi	UD
5 NPS	19.071 in ²	25-3000 psi	UD
6 NPS	30.374 in ²	25-2000 psi	UD
8 NPS	48.825 in ²	25-1500 psi	UD

Design Name: YC		NBCert # 01821	
Manufacturer/Assembler		Designators	Expiration Date

Manufacturer UD 11/30/2028

Design Type

[Rupture Disk Device] YC
HolderDesignation: YJ
Capacity Tests: Sec. UD at National Board Testing Lab on August 19, 2021
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 3.600 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Dalian Duta Technology Safety System co., Ltd. {DLE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.488 in ²			120-1500 psi		UD
1 NPS		0.762 in ²			100-1500 psi		UD
1.25 NPS		1.489 in ²			100-1500 psi		UD
1.5 NPS		2.463 in ²			80-1200 psi		UD
10 NPS		76.288 in ²			40-500 psi		UD
12 NPS		109.856 in ²			40-400 psi		UD
2 NPS		3.679 in ²			80-1200 psi		UD
2.5 NPS		5.961 in ²			60-1200 psi		UD
3 NPS		8.79 in ²			60-1200 psi		UD
4 NPS		13.414 in ²			60-1000 psi		UD
5 NPS		19.071 in ²			50-1000 psi		UD
6 NPS		30.374 in ²			50-800 psi		UD
8 NPS		48.825 in ²			50-600 psi		UD

Dante Valve Company (DAN)

Bellflower, CA 90706United States

This Company Manufactures or Assembles:

Design Name:	Kunkle 264, 265, 266 & 267	NBCert #	36267
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/10/2030

Design Type

[Safety Relief Valve] Kunkle 264, 265, 266 & 267
Capacity Tests: Sec. UV at unknown lab on July 20, 1956
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.766 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.115 in	15-2000 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.115 in	15-3300 psi	Air	UV

Design Name:	Kunkle 300,600	NBCert #	36076
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	10/25/2029

Design Type

[Safety Valve] Kunkle 300,600
Capacity Tests: Sec. UV, V at unknown lab on February 10, 1961
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	UV
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	V
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	V
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Air	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	V

2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Air	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	V
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Air	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	V
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	V
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Air	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	UV

Design Name: Kunkle 337

NBCert # 36278

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/18/2029

Design Type

[Safety Relief Valve] Kunkle 337
Capacity Tests: Sec. UV at unknown lab on February 22, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	1.916 in ²	1.562 in	0.612 in	15-60 psi	Air	UV
2.5 NPS	2.5 NPS	2.786 in ²	1.883 in	0.755 in	15-60 psi	Air	UV
3 NPS	3 NPS	4.037 in ²	2.267 in	0.91 in	15-60 psi	Air	UV

Design Name: Kunkle 6000, 6252 Series

NBCert # 36324

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	07/24/2029

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
 Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV

6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name:	Kunkle 910 to 919	NBCert #	36100
--------------	-------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/10/2030

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name:	Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)	NBCert #	36111
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	10/18/2029

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 , 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

DECON TECHNOLOGIES (DTI)

Vadodara, Gujarat, 390010India

This Company Manufactures or Assembles:

Design Name: 9 Series		NBCert #	44019
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	10/28/2030
Design Type			
[Safety Relief Valve] 9 Series Capacity Tests: Sec. UV at National Board Testing Lab on July 24, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.823 Unitless Media - Test: Air/Gas; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: TRILLIUM Flow Technologies - France SAS {SAR}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	0.236 in	0.07 in	15-4700 psi	Air	UV
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	0.236 in	0.07 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.124 in ²	0.398 in	0.1 in	14.5-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.124 in ²	0.398 in	0.1 in	14.5-4700 psi	Air	UV
0.75-1 NPS	1 NPS	0.222 in ²	0.531 in	0.13 in	14.5-2220 psi	Air	UV
0.75-1 NPS	1 NPS	0.222 in ²	0.531 in	0.13 in	14.5-2220 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.669 in	0.17 in	14.5-740 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.669 in	0.17 in	14.5-740 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	0.85 in	0.21 in	14.5-285 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	0.85 in	0.21 in	14.5-285 psi	Steam	UV

Design Name: 9 Series (Liquids)		NBCert #	44020
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	06/06/2030	

Design Type

[Relief Valve] 9 Series (Liquids)
 Capacity Tests: Sec. UV, V at National Board Testing Lab on July 24, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.632 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	[B] 0.236 in	0.07 in	15-6250 psi	Water	UV
0.5-1 NPS	1 NPS	0.124 in ²	[D] 0.398 in	0.1 in	14.5-6250 psi	Water	UV
0.75-1 NPS	1 NPS	0.222 in ²	[E] 0.531 in	0.13 in	14.5-2220 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	[F] 0.669 in	0.17 in	14.5-740 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	[G] 0.85 in	0.21 in	14.5-285 psi	Water	UV

Design Name: P3, P4 (liquids) NBCert # 92012

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

06/06/2030

Design Type

[Relief Valve] P3, P4 (liquids)
 Capacity Tests: Sec. UV, V at National Board Testing Lab on December 7, 1993
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.631 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Water	UV, V
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Water	UV, V
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Water	UV, V
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Water	UV, V
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Water	UV, V
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Water	UV, V
4 NPS	6 NPS	7.032 in ²	[P] 2.992 in	0.94 in	15-1300 psi	Water	UV, V
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Water	UV, V
6 NPS	8-10 NPS	15.267 in ²	[R] 4.409 in	1.477 in	15-500 psi	Water	UV, V
8 NPS	10 NPS	28.126 in ²	[T] 5.984 in	1.88 in	15-500 psi	Water	UV, V

Design Name: P3, P4, P5	NBCert # 92001
-------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/28/2030

Design Type

[Safety Relief Valve] P3, P4, P5
Capacity Tests: Sec. UV at unknown lab on June 5, 1986
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Air	UV
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Air	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-2900 psi	Steam	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Air	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-2900 psi	Steam	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Air	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-2900 psi	Steam	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Air	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Steam	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Air	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Steam	UV
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Air	UV
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Steam	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Air	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Steam	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Air	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Steam	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Air	UV

10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Steam	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Air	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Steam	UV

DHB Valves Inc, (DHB)	Nameplate Abbreviation: DHB VALVES
------------------------------	---

Montreal, QC H1A 3N5Canada

This Company Manufactures or Assembles:

Design Name: 2400	NBCert # 57451
-------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/19/2028

Design Type

[Safety Relief Valve] 2400
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on August 28, 2019
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.817 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75-1 NPS	0.049 in ²	[B] 0.25 in	0.08 in	20-2000 psi	Air	UV
0.5-1 NPS	1-2 NPS	0.11 in ²	[D] 0.375 in	0.12 in	20-1410 psi	Air	UV
0.75-1 NPS	1-2 NPS	0.196 in ²	[E] 0.5 in	0.175 in	20-600 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.295 in	20-4000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.365 in	20-3000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.435 in	20-2500 psi	Air	UV

Design Name: 2600 & 2600S	NBCert # 57057
---------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/08/2028

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV

1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)	NBCert # 57260
----------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/19/2028

Design Type

[Safety Relief Valve] 2600L (Air & Steam)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV

8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV
----------	------------	----------------------	--------------	----------	------------	-------	----

Design Name: 2600L (Liquids)			NBCert # 57068				
Manufacturer/Assembler			Designators		Expiration Date		

Assembler UV 09/08/2028

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S			NBCert # 57237				
Manufacturer/Assembler			Designators		Expiration Date		

Assembler UV 07/19/2028

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	07/19/2028
-----------	----	------------

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name:	4200 / 4400	NBCert #	57282
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 09/08/2028

Design Type

[Safety Valve] 4200 / 4400
Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.872 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

Design Name:	6400/6600 (previously 2500 & 4600)	NBCert #	57046
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 07/19/2028

Design Type

[Safety Valve] 6400/6600 (previously 2500 & 4600)
Capacity Tests: Sec. UV, V at Ohio State University (Robinson Laboratory) on January 28, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV

1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	V
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	V
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	V
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Air	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	V
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Air	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	V
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	V
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	UV

DonadonSDD Srl (DON)

Corbetta (Mi), 20011Italy

This Company Manufactures or Assembles:

Design Name: KRD	NBCert # 00516
------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	03/25/2027
--------------	----	------------

Design Type

[Rupture Disk Device] KRD
HolderDesignation: HRA, HRP, HRF
Capacity Tests: Sec. UD at National Board Testing Lab on September 10, 2014
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.480 Unitless
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: DonadonSDD Srl {DON}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.79 in ²			21-2000 psi	Water	UD
1.5 NPS		1.77 in ²			7-1500 psi	Water	UD
10 NPS		78.54 in ²			3-400 psi	Water	UD
12 NPS		113.1 in ²			3-200 psi	Water	UD
14 NPS		153.94 in ²			3-150 psi	Water	UD
16 NPS		201.06 in ²			3-150 psi	Water	UD
18 NPS		254.47 in ²			3-150 psi	Water	UD
2 NPS		3.14 in ²			6-1500 psi	Water	UD
2.5 NPS		4.91 in ²			6-900 psi	Water	UD
20 NPS		314.16 in ²			3-150 psi	Water	UD
24 NPS		452.39 in ²			3-50 psi	Water	UD
28 NPS		615.75 in ²			3-50 psi	Water	UD
3 NPS		7.07 in ²			6-900 psi	Water	UD
30 NPS		706.86 in ²			3-50 psi	Water	UD
32 NPS		804.25 in ²			3-30 psi	Water	UD
36 NPS		1017.88 in ²			3-30 psi	Water	UD
4 NPS		12.57 in ²			6-900 psi	Water	UD
5 NPS		19.63 in ²			6-900 psi	Water	UD
6 NPS		28.27 in ²			3-600 psi	Water	UD
8 NPS		50.27 in ²			3-600 psi	Water	UD
1 in		0.394 in ²		0 in	21-146 psi		UD
1.25 NPS		1.17 in ²		0 in	30-2000 psi	Water	UD
1.5 in		1.154 in ²		0 in	7-146 psi		UD
2 in		2.304 in ²		0 in	7-146 psi		UD
2.5 in		3.845 in ²		0 in	7-146 psi		UD
3 in		5.763 in ²		0 in	6-117 psi		UD
4 in		10.525 in ²		0 in	5-117 psi		UD
6 in		25.948 in ²		0 in	5-73 psi		UD

Design Name: SCD	NBCert # 00527
------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	03/25/2027

Design Type

[Rupture Disk Device] SCD
HolderDesignation: HIA, HIP, HIF
Capacity Tests: Sec. UD at National Board Testing Lab on March 25, 2015
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 1.330 Unitless
Media - Test: Air/Gas; Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: DonadonSDD Srl {DON}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.79 in ²			35-6000 psi	Air	UD
1 NPS		0.79 in ²			35-6000 psi	Water	UD
1.5 NPS		1.77 in ²			30-3500 psi	Air	UD
1.5 NPS		1.77 in ²			30-3500 psi	Water	UD
10 NPS		78.54 in ²			30-900 psi	Air	UD
10 NPS		78.54 in ²			30-900 psi	Water	UD
12 NPS		113.1 in ²			30-300 psi	Air	UD
12 NPS		113.1 in ²			30-300 psi	Water	UD
14 NPS		153.94 in ²			30-300 psi	Air	UD
14 NPS		153.94 in ²			30-300 psi	Water	UD
16 NPS		201.06 in ²			30-300 psi	Air	UD
16 NPS		201.06 in ²			30-300 psi	Water	UD
18 NPS		254.47 in ²			30-300 psi	Air	UD
18 NPS		254.47 in ²			30-300 psi	Water	UD
2 NPS		3.14 in ²			30-3500 psi	Air	UD
2 NPS		3.14 in ²			30-3500 psi	Water	UD
2.5 NPS		4.91 in ²			30-3000 psi	Air	UD
2.5 NPS		4.91 in ²			30-3000 psi	Water	UD
20 NPS		314.16 in ²			30-300 psi	Air	UD
20 NPS		314.16 in ²			30-300 psi	Water	UD
24 NPS		452.39 in ²			30-300 psi	Air	UD
24 NPS		452.39 in ²			30-300 psi	Water	UD
28 NPS		615.75 in ²			30-300 psi	Air	UD
28 NPS		615.75 in ²			30-300 psi	Water	UD
3 NPS		7.07 in ²			30-3000 psi	Air	UD
3 NPS		7.07 in ²			30-3000 psi	Water	UD
30 NPS		706.86 in ²			30-300 psi	Air	UD
30 NPS		706.86 in ²			30-300 psi	Water	UD
32 NPS		804.25 in ²			30-300 psi	Air	UD

32 NPS	804.25 in ²		30-300 psi	Water	UD
36 NPS	1017.88 in ²		30-300 psi	Air	UD
36 NPS	1017.88 in ²		30-300 psi	Water	UD
4 NPS	12.57 in ²		30-3000 psi	Air	UD
4 NPS	12.57 in ²		30-3000 psi	Water	UD
5 NPS	19.63 in ²		30-3000 psi	Air	UD
5 NPS	19.63 in ²		30-3000 psi	Water	UD
6 NPS	28.27 in ²		30-900 psi	Air	UD
6 NPS	28.27 in ²		30-900 psi	Water	UD
8 NPS	50.27 in ²		30-900 psi	Air	UD
8 NPS	50.27 in ²		30-900 psi	Water	UD
1 in	0.594 in ²	0 in	58-290 psi		UD
1.25 NPS	1.49 in ²	0 in	35-6000 psi	Air	UD
1.25 NPS	1.49 in ²	0 in	35-6000 psi	Water	UD
1.5 in	1.473 in ²	0 in	58-290 psi		UD
2 in	2.716 in ²	0 in	58-146 psi		UD
2.5 in	4.409 in ²	0 in	58-146 psi		UD
3 in	6.449 in ²	0 in	58-117 psi		UD
4 in	11.543 in ²	0 in	43-117 psi		UD
6 in	27.377 in ²	0 in	29-73 psi		UD

Design Name: SCR

NBCert #

00538

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	03/25/2027

Design Type

[Rupture Disk Device] SCR
HolderDesignation: HRA, HRP, HRF
Capacity Tests: Sec. UD at National Board Testing Lab on December 5, 2014
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.480 Unitless
Media - Test: Air/Gas; Certified: Compressible and Incompressible (KrgI)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: DonadonSDD Srl {DON}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.79 in ²			15-2000 psi	Air	UD
1.5 NPS		1.77 in ²			6-1500 psi	Air	UD
10 NPS		78.54 in ²			3-400 psi	Air	UD
12 NPS		113.1 in ²			3-300 psi	Air	UD
14 NPS		153.94 in ²			3-200 psi	Air	UD
16 NPS		201.06 in ²			3-150 psi	Air	UD
18 NPS		254.47 in ²			3-150 psi	Air	UD
2 NPS		3.14 in ²			6-1500 psi	Air	UD
2.5 NPS		4.91 in ²			6-900 psi	Air	UD

20 NPS	314.16 in ²		3-150 psi	Air	UD
24 NPS	452.39 in ²		3-120 psi	Air	UD
28 NPS	615.75 in ²		3-45 psi	Air	UD
3 NPS	7.07 in ²		6-900 psi	Air	UD
30 NPS	706.86 in ²		3-45 psi	Air	UD
32 NPS	804.25 in ²		3-30 psi	Air	UD
36 NPS	1017.88 in ²		3-30 psi	Air	UD
4 NPS	12.57 in ²		6-800 psi	Air	UD
5 NPS	19.63 in ²		6-800 psi	Air	UD
6 NPS	28.27 in ²		3-600 psi	Air	UD
8 NPS	50.27 in ²		3-600 psi	Air	UD
1 in	0.394 in ²	0 in	29-146 psi		UD
1.25 NPS	1.49 in ²	0 in	16-2000 psi	Air	UD
1.5 in	1.154 in ²	0 in	29-146 psi		UD
2 in	2.304 in ²	0 in	14-146 psi		UD
2.5 in	3.845 in ²	0 in	14-146 psi		UD
3 in	5.763 in ²	0 in	7-117 psi		UD
4 in	10.525 in ²	0 in	7-73 psi		UD
6 in	25.948 in ²	0 in	7-73 psi		UD

Dowco Valve Company, Inc. (DIA)

DeWitt, IA 52742United States

This Company Manufactures or Assembles:

Design Name:	2600 & 2600S	NBCert #	57057
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	07/17/2030
-----------	----	------------

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV

1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/14/2030

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV

8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV
----------	------------	----------------------	--------------	----------	------------	-------	----

Design Name: 2600L (Liquids)			NBCert # 57068				
Manufacturer/Assembler			Designators		Expiration Date		

Assembler UV 07/17/2030

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S			NBCert # 57237				
Manufacturer/Assembler			Designators		Expiration Date		

Assembler UV 07/17/2030

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/17/2030

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Dowco Valve Company, Inc. (DWC)

Nameplate Abbreviation: Dowco

Hastings, MN 55033United States

This Company Manufactures or Assembles:

Design Name:	119 Series	NBCert #	11361
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV, V	11/21/2028	

Design Type

[Safety Valve] 119 Series
Capacity Tests: Sec. UV, V at National Board Testing Lab on March 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Air	UV
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Steam	UV
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Steam	UV
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Steam	NV
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Steam	V
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Air	UV
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Steam	UV
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Steam	V
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Air	UV
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Steam	UV
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Steam	V
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Air	UV
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Steam	UV

6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Steam	V
-------	-------	------------------------	--------------	----------	------------	-------	---

Design Name: 19 Series			NBCert # 11282	
Manufacturer/Assembler		Designators		Expiration Date

Assembler UV, V 11/08/2028

Design Type

[Safety Valve] 19 Series
Capacity Tests: Sec. UV, V at unknown lab on March 27, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.826 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.129 in ²	[D] 0.406 in	0.101 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.129 in ²	[D] 0.406 in	0.101 in	15-300 psi	Steam	UV, V
0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Air	UV
0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Steam	UV, V
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Air	UV
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Steam	UV, V
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Air	UV
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Steam	UV, V

Design Name: 2600 & 2600S			NBCert # 57057	
Manufacturer/Assembler		Designators		Expiration Date

Assembler UV 11/21/2028

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV

1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)	NBCert # 57260
----------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	11/08/2028
-----------	----	------------

Design Type

[Safety Relief Valve] 2600L (Air & Steam)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV

8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV
----------	------------	----------------------	--------------	----------	------------	-------	----

Design Name: 2600L (Liquids)			NBCert # 57068				
Manufacturer/Assembler			Designators		Expiration Date		

Assembler UV 02/09/2029

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S			NBCert # 57237				
Manufacturer/Assembler			Designators		Expiration Date		

Assembler UV 11/08/2028

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	4200 / 4400	NBCert #	57282
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV, V	11/21/2028
-----------	-------	------------

Design Type

[Safety Valve] 4200 / 4400
 Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.872 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V

6 NPS

8 NPS

11.389 in²

[Q] 3.808 in

0.952 in

15-1480 psi

Steam

UV, V

Design Name:

500 Series (Liquids)

NBCert #

11473

Manufacturer/Assembler

Designators

Expiration Date

Assembler

UV

11/08/2028

Design Type

[Safety Relief Valve] 500 Series (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on February 25, 2000
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.689 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.129 in ²	[D] 0.406 in	0.102 in	15-1000 psi	Water	UV
0.75-1 NPS	1.25 NPS	0.229 in ²	[E] 0.539 in	0.135 in	15-1000 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-1000 psi	Water	UV
1.25-1.5 NPS	2 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-1000 psi	Water	UV
1.5-2 NPS	2.5 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-1000 psi	Water	UV
2 NPS	3 NPS	1.504 in ²	[J] 1.384 in	0.346 in	15-1000 psi	Water	UV

DRESSER AL RUSHAID VALVE & INSTRUMENT CO., LTD (DAR)

Nameplate Abbreviation: DARVICO

Jubail Industrial City, 31961Saudi Arabia

This Company Manufactures or Assembles:

Design Name:

1900, 1900-30 1900-35 LA & DALA
(Liquids)

NBCert #

18784

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

03/13/2030

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V

1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

03/12/2030

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV

3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series	NBCert # 18706
---------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	03/12/2030
--------------	----	------------

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV

0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/12/2030

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/12/2030

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert # 18751

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	06/26/2030

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM NBCert # 19066

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/27/2030

Design Type

[Safety Relief Valve] 1900-DM
Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV

3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D

NBCert #

19088

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

09/18/2030

Design Type

[Safety Relief Valve] 1900-DM-D

Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Curtain Area

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E

NBCert #

19099

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

02/27/2030

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2 NBCert # 18166

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

03/12/2030

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

03/12/2030

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name:	19110M & 19110H (Liquids)	NBCert #	19077
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/20/2031

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name:	2900 (39PV & 39MV pilots - Liquid)	NBCert #	18874
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/20/2031

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots - Liquid)
Capacity Tests: Sec. UV, V at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.127 in	15-6250 psi	Water	UV, V
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	UV, V
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.205 in	15-6250 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-6250 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-6000 psi	Water	UV, V
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-6000 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-3750 psi	Water	UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-2250 psi	Water	UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-1500 psi	Water	UV, V
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.738 in	15-1500 psi	Water	UV, V

8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-905 psi	Water	UV, V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV, V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.93 in	15-675 psi	Water	UV, V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-535 psi	Water	UV, V

Design Name:	2900 (39PV & 39MV pilots)	NBCert #	18863
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 06/09/2031

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV

6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots)

NBCert #

18447

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

03/12/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV

3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name:	3900 (39PV, 39MV pilots, liquid)	NBCert #	18458
--------------	----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	03/13/2030
--------------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV

6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Dresser International L.L.C (DIU)

Dubai, United Arab Emirates

This Company Manufactures or Assembles:

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
Manufacturer/Assembler		Designators	Expiration Date

Manufacturer	UV	12/05/2030
--------------	----	------------

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V

8-8 NPS	10 NPS	35 in²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V
Design Name: 1900, 1900-30, 1900-35				NBCert #	18201		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		12/05/2030		
Design Type							
[Safety Relief Valve] 1900, 1900-30, 1900-35 Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.855 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV

8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/05/2030

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/05/2030

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2

NBCert #

18144

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/05/2030

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert #

18751

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/05/2030

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 3.256 GPM/SQ. RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM

NBCert # 19066

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

12/05/2030

Design Type

[Safety Relief Valve] 1900-DM
 Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
 Set Pressure Definition(1): Pop; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name:	1900-DM-D	NBCert #	19088
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/05/2030

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name:	1900-DM-E	NBCert #	19099
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/05/2030

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/05/2030

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name:	1900E-2, 1900-30E-2 LA & DALA (Liquids)	NBCert #	18762
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/05/2030

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name:	19110M & 19110H (Liquids)	NBCert #	19077
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/16/2027

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name:	2900 (39PV & 39MV pilots - Liquid)	NBCert #	18874
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/16/2027

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots - Liquid)
Capacity Tests: Sec. UV, V at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.127 in	15-6250 psi	Water	UV, V
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	UV, V
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.205 in	15-6250 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-6250 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-6000 psi	Water	UV, V
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-6000 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-3750 psi	Water	UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-2250 psi	Water	UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-1500 psi	Water	UV, V
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.738 in	15-1500 psi	Water	UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-905 psi	Water	UV, V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV, V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.93 in	15-675 psi	Water	UV, V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-535 psi	Water	UV, V

Design Name:	2900 (39PV & 39MV pilots)	NBCert #	18863
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/16/2027

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
 Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV

12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
--------	--------	------------------------	---------------	----------	------------	-------	----

Design Name: 3900 (39PV, 39MV pilots)				NBCert # 18447			
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			12/16/2027	
Design Type							
[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots) Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - ; Certified: Air, Gas, Steam Set Pressure Definition(1): Pop; (2): Initial Audible Discharge Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV

4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid)			NBCert # 18458	
Manufacturer/Assembler		Designators		Expiration Date
Manufacturer		UV		12/16/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.743 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV

8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Dresser Italia SRL (GOI)

Nameplate Abbreviation: DILN

Casavatore(Naples), 80020Italy

This Company Manufactures or Assembles:

Design Name: 1700 & 2700		NBCert # 18100
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	06/06/2031
Design Type		
[Safety Valve] 1700 & 2700 Capacity Tests: Sec. UV, V at Dresser, Inc. on August 1, 1957 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Steam; Certified: Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	50-5800 psi	Steam	V
4 NPS	4 dual NPS	1.84 in ²	[K] 1.531 in	0.383 in	50-5800 psi	Steam	V
2-3 NPS	4, 6 NPS	2.545 in ²	[#3] 1.8 in	0.45 in	50-5800 psi	Steam	UV, V
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-2575 psi	Steam	UV
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	50-5800 psi	Steam	V
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	15-3100 psi	Steam	UV
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	50-5800 psi	Steam	V
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	15-3100 psi	Steam	UV
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	V

6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	15-1800 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	1.24 in	50-2200 psi	Steam	UV, V
8-10 NPS	10,12 NPS	28.3 in ²	[T] 6 in	1.5 in	50-1500 psi	Steam	UV, V

Design Name: 1700 & 2700 (Restricted Lift version of Cert. # 18100) NBCert # 18111

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 10/04/2025

Design Type

[Safety Valve] 1700 & 2700 (Restricted Lift version of Cert. # 18100)
Capacity Tests: Sec. UV, V at unknown lab on October 13, 1981
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	50-5800 psi	Steam	V
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	15-3100 psi	Steam	UV
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	50-5800 psi	Steam	V
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-2575 psi	Steam	UV
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	50-5800 psi	Steam	V
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	15-3100 psi	Steam	UV
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	50-5800 psi	Steam	V
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	15-3100 psi	Steam	UV
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.946 in	0.296 in	15-2000 psi	Steam	UV, V
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	15-1800 psi	Steam	UV

6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	0.372 in	50-2200 psi	Steam	V
8-10 NPS	10, 12 NPS	28.3 in ²	[T] 6 in	0.45 in	50-1500 psi	Steam	UV, V

Design Name: 1811, 1511 NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 06/15/2029

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA (Liquids) NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/16/2027

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/12/2031

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV

1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 1900/P, 1900-30/P			NBCert # 18290	
Manufacturer/Assembler		Designators	Expiration Date	
Manufacturer		UV, V	06/07/2031	

Design Type

[Safety Relief Valve] 1900/P, 1900-30/P
 Capacity Tests: Sec. NV, -Class 2, -Class 3, UV, V at Dresser, Inc. on October 11, 1954
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.851 Unitless; Certification Provisions: Organic Fluid Vaporizers (Part PVG)
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4460 psi	Steam	NV, -Class 2, -Class 3, UV, V
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6000 psi	Air	UV
1.5-2 NPS	2.5-3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-3705 psi	Air	UV
1.5-2 NPS	2.5-3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-3600 psi	Steam	NV, -Class 2, -Class 3, UV, V
1.5-2 NPS	2.5-3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-3600 psi	Steam	NV
1.5-2 NPS	2.5-3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-3600 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2735 psi	Steam	NV, -Class 2, -Class 3, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Steam	V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2700 psi	Steam	NV, -Class 2, -Class 3, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Steam	V
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2160 psi	Steam	NV, -Class 2, -Class 3, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3000 psi	Steam	V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, -Class 2, -Class 3, UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	15-1600 psi	Steam	NV, -Class 2, -Class 3, UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	15-1600 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, -Class 2, -Class 3, UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, -Class 2, -Class 3, UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, -Class 2, -Class 3, UV, V
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-500 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-500 psi	Steam	NV, -Class 2, -Class 3, UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-300 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-300 psi	Steam	NV, -Class 2, -Class 3, UV, V

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	11/20/2029
--------------	----	------------

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	11/20/2029
--------------	----	------------

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV

0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D/P, 1900-30D/P	NBCert #	18256
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 06/06/2031

Design Type

[Safety Relief Valve] 1900D/P, 1900-30D/P
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV, V at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.610 PPH/PSIA; (alternate medium): 1.997 SCFM/PSIA; Certification Provisions: Organic Fluid Vaporizers (Part PVG)
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4460 psi	Steam	NV, -Class 2, -Class 3, UV, V
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6000 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/20/2029

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/16/2027

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM-D NBCert # 19088

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

11/23/2027

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E NBCert # 19099

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

08/05/2028

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name:	1900E/P, 1900-30E/P	NBCert #	18278
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	06/06/2031

Design Type

[Safety Relief Valve] 1900E/P, 1900-30E/P
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV, V at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 9.980 PPH/PSIA; (alternate medium): 3.552 SCFM/PSIA; Certification Provisions: Organic Fluid Vaporizers (Part PVG)
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4460 psi	Steam	NV, -Class 2, -Class 3, UV, V
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6000 psi	Air	UV

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/20/2029

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name:	1900E-2, 1900-30E-2 LA & DALA (Liquids)	NBCert #	18762
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/16/2027

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V
Design Name: 19110M & 19110H (Liquids)NBCert #19077							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			11/20/2029	
Design Type							
[Relief Valve] 19110M & 19110H (Liquids) Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.264 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3
Design Name: 2900 (39PV & 39MV pilots - Liquid)NBCert #18874							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			12/09/2027	
Design Type							
[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots - Liquid) Capacity Tests: Sec. UV, V at Dresser, Inc. on June 25, 1999 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.670 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2279 in²	[E] 0.5387 in	0.127 in	15-6250 psi	Water	UV, V
1.5 NPS	2 - 3 NPS	0.3568 in²	[F] 0.674 in	0.16 in	15-6250 psi	Water	UV, V
1.5-2 NPS	2.5 - 3 NPS	0.5849 in²	[G] 0.863 in	0.205 in	15-6250 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.9127 in²	[H] 1.078 in	0.395 in	15-6250 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.496 in²	[J] 1.38 in	0.506 in	15-6000 psi	Water	UV, V
3 NPS	4 - 6 NPS	2.138 in²	[K] 1.65 in	0.605 in	15-6000 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	3.317 in²	[L] 2.055 in	0.753 in	15-3750 psi	Water	UV, V
4 NPS	6 NPS	4.186 in²	[M] 2.3086 in	0.846 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	5.047 in²	[N] 2.535 in	0.929 in	15-2250 psi	Water	UV, V

4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-2250 psi	Water	UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-1500 psi	Water	UV, V
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.738 in	15-1500 psi	Water	UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-905 psi	Water	UV, V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV, V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.93 in	15-675 psi	Water	UV, V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-535 psi	Water	UV, V

Design Name: 2900 (39PV & 39MV pilots) NBCert # 18863

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 06/07/2031

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV

Design Name: 2900 POSRV (39 PV, 39 MV Pilots) NBCert # 18964

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer V 06/06/2031

Design Type

[Pilot Operated Pressure Relief Valve] 2900 POSRV (39 PV, 39 MV Pilots)
Capacity Tests: Sec. V at Dresser, Inc. on November 2, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.851 Unitless; (alternate medium): 0.691 Unitless; Certification Provisions: Economizer Service (Prev. CC 2446)
Media - Test: Liquid, Steam; Certified: Steam and Water
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	50-5800 psi	Steam	V
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	50-5800 psi	Water	V
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	50-5800 psi	Steam	V
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	50-5800 psi	Water	V
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	50-5800 psi	Steam	V
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	50-5800 psi	Water	V
1.5-2 NPS	3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	50-5800 psi	Steam	V
1.5-2 NPS	3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	50-5800 psi	Water	V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	45-3750 psi	Steam	V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	45-3750 psi	Water	V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	50-5800 psi	Steam	V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	50-5800 psi	Water	V
3 NPS	4, 6 NPS	2.136 in ²	[K] 1.649 in	0.446 in	55-5800 psi	Steam	V
3 NPS	4, 6 NPS	2.136 in ²	[K] 1.649 in	0.446 in	55-5800 psi	Water	V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	60-6250 psi	Steam	V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	60-6250 psi	Water	V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	65-2250 psi	Steam	V

4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	65-2250 psi	Water	V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	40-2250 psi	Steam	V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	40-2250 psi	Water	V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	75-2250 psi	Steam	V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	75-2250 psi	Water	V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	85-1500 psi	Steam	V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	85-1500 psi	Water	V
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	40-1500 psi	Steam	V
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	40-1500 psi	Water	V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	40-905 psi	Steam	V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	40-905 psi	Water	V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	40-905 psi	Steam	V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	40-905 psi	Water	V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	40-675 psi	Steam	V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	40-675 psi	Water	V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	40-535 psi	Steam	V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	40-535 psi	Water	V

Design Name: 2900-TM (39PV & 39MV pilots) NBCert # 01427

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/15/2030

Design Type

[Pilot Operated Pressure Relief Valve] 2900-TM (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Water	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Water	UV

1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Water	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Water	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2000 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Water	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Water	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-300 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Water	UV

Design Name:	3900 (39PV, 39MV pilots)	NBCert #	18447
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	06/07/2031
--------------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV

4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid)

NBCert #

18458

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/09/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.743 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV

8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Design Name: 3900-TM (39PV, 39MV pilots) NBCert # 01438

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/15/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3900-TM (39PV, 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; (alternate medium): 0.743 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV

2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV

Dresser Machinery (Suzhou) Co., Ltd. (DMS)

Suzhou, Jiangsu, 215021People's Republic of China

This Company Manufactures or Assembles:

Design Name: 13900 TRH		NBCert # 18469
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/26/2030
Design Type		
[Pilot Operated Pressure Relief Valve] 13900 TRH Capacity Tests: Sec. UV at Dresser, Inc. on June 13, 1969 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.877 Unitless; Certification Provisions: Exceeds Lab Limits (Prev. CC 2397) Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC {DRJ}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
16 NPS	18 NPS	114 in ²	12.05 in	3.81 in	50-300 psi	Steam	UV
18 NPS	22 NPS	143.1 in ²	13.5 in	4.07 in	50-300 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	15 in	4.53 in	50-300 psi	Steam	UV

Design Name: 1541, 1543, 1541-3, 1543-3		NBCert # 18032
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	09/09/2031
Design Type		
[Safety Valve] 1541, 1543, 1541-3, 1543-3 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV

0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1700 & 2700

NBCert # 18100

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV, V

06/14/2029

Design Type

[Safety Valve] 1700 & 2700
Capacity Tests: Sec. UV, V at Dresser, Inc. on August 1, 1957
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	50-5800 psi	Steam	V
4 NPS	4 dual NPS	1.84 in ²	[K] 1.531 in	0.383 in	50-5800 psi	Steam	V
2-3 NPS	4, 6 NPS	2.545 in ²	[#3] 1.8 in	0.45 in	50-5800 psi	Steam	UV, V
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-2575 psi	Steam	UV
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	15-3100 psi	Steam	UV

2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	50-5800 psi	Steam	V
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	15-3100 psi	Steam	UV
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	50-5800 psi	Steam	V
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	15-3100 psi	Steam	UV
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	15-1800 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	1.24 in	50-2200 psi	Steam	UV, V
8-10 NPS	10,12 NPS	28.3 in ²	[T] 6 in	1.5 in	50-1500 psi	Steam	UV, V

Design Name:	1700 & 2700 (4" #7 & Ovrstd Q)	NBCert #	18087
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 07/23/2027

Design Type

[Safety Valve] 1700 & 2700 (4" #7 & Ovrstd Q)
Capacity Tests: Sec. UV, V at Dresser, Inc. on January 9, 2004
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.785 Unitless; Certification Provisions: Exceeds Lab Limits (Prev. CC 2397)
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 NPS	8 NPS	11.05 in ²	[#7] 3.75 in	0.938 in	15-1800 psi	Steam	V
4 NPS	8 NPS	11.05 in ²	[#7] 3.75 in	0.938 in	15-1800 psi	Steam	UV
4 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	25-2000 psi	Steam	V
4 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	25-1000 psi	Steam	UV

Design Name:	1700 & 2700 (4" #7 & Ovrstd Q) (Restricted Lift version of Cert. #18087)	NBCert #	18098
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 07/23/2027

Design Type

[Safety Valve] 1700 & 2700 (4" #7 & Ovrszd Q) (Restricted Lift version of Cert. #18087)
 Capacity Tests: Sec. UV, V at Dresser, Inc. on January 9, 2004
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.785 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Restricted Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 NPS	8 NPS	11.05 in ²	[7] 3.75 in	0.281 in	100-900 psi	Steam	V
4 NPS	8 NPS	11.05 in ²	[7] 3.75 in	0.281 in	100-900 psi	Steam	UV
4 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.296 in	100-1000 psi	Steam	UV
4 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.296 in	100-2000 psi	Steam	V

Design Name: 1700 & 2700 (Restricted Lift version of Cert. # 18100) NBCert # 18111

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	03/15/2027

Design Type

[Safety Valve] 1700 & 2700 (Restricted Lift version of Cert. # 18100)
 Capacity Tests: Sec. UV, V at unknown lab on October 13, 1981
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Restricted Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	50-5800 psi	Steam	V
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	15-3100 psi	Steam	UV
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	50-5800 psi	Steam	V
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-2575 psi	Steam	UV
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	50-5800 psi	Steam	V
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	15-3100 psi	Steam	UV
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	50-5800 psi	Steam	V
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	15-3100 psi	Steam	UV
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	15-2093 psi	Steam	UV

6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.946 in	0.296 in	15-2000 psi	Steam	UV, V
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	0.372 in	50-2200 psi	Steam	V
8-10 NPS	10, 12 NPS	28.3 in ²	[T] 6 in	0.45 in	50-1500 psi	Steam	UV, V

Design Name: 1811, 1511

NBCert #

18122

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV, V

06/15/2029

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	07/11/2029

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	06/15/2029

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name:	1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)	NBCert #	18223
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	11/18/2026
--------------	----	------------

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV

8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name:	1900/P, 1900-30/P	NBCert #	18290
--------------	-------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer V 08/25/2028

Design Type

[Safety Relief Valve] 1900/P, 1900-30/P
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV, V at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.851 Unitless; Certification Provisions: Organic Fluid Vaporizers (Part PVG)
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4460 psi	Steam	NV, -Class 2, -Class 3, UV, V
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6000 psi	Air	UV
1.5-2 NPS	2.5-3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-3705 psi	Air	UV
1.5-2 NPS	2.5-3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-3600 psi	Steam	NV, -Class 2, -Class 3, UV, V
1.5-2 NPS	2.5-3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-3600 psi	Steam	NV
1.5-2 NPS	2.5-3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-3600 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2735 psi	Steam	NV, -Class 2, -Class 3, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Steam	V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2700 psi	Steam	NV, -Class 2, -Class 3, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Steam	V
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2160 psi	Steam	NV, -Class 2, -Class 3, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3000 psi	Steam	V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, -Class 2, -Class 3, UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	15-1600 psi	Steam	NV, -Class 2, -Class 3, UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	15-1600 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	15-1600 psi	Steam	UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, -Class 2, -Class 3, UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, -Class 2, -Class 3, UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, -Class 2, -Class 3, UV, V
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-500 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-500 psi	Steam	NV, -Class 2, -Class 3, UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-300 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-300 psi	Steam	NV, -Class 2, -Class 3, UV, V

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 06/15/2029

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 06/15/2029

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D/P, 1900-30D/P

NBCert #

18256

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV, V

08/25/2028

Design Type

[Safety Relief Valve] 1900D/P, 1900-30D/P
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV, V at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.610 PPH/PSIA; (alternate medium): 1.997 SCFM/PSIA; Certification Provisions: Organic Fluid Vaporizers (Part PVG)
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4460 psi	Steam	NV, -Class 2, -Class 3, UV, V
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6000 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2

NBCert #

18144

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

06/15/2029

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert # 18751

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV, V

06/15/2029

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM NBCert # 19066

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

08/30/2027

Design Type

[Safety Relief Valve] 1900-DM
Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV

1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D

NBCert #

19088

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

08/30/2027

Design Type

[Safety Relief Valve] 1900-DM-D

Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Curtain Area

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E		NBCert # 19099
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/18/2028
Design Type		
[Safety Relief Valve] 1900-DM-E Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787) Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid Set Pressure Definition(1): Pop; (2): First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900E/P, 1900-30E/P		NBCert # 18278
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	08/25/2028
Design Type		
[Safety Relief Valve] 1900E/P, 1900-30E/P Capacity Tests: Sec. NV, -Class 2, -Class 3, UV, V at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 9.980 PPH/PSIA; (alternate medium): 3.552 SCFM/PSIA; Certification Provisions: Organic Fluid Vaporizers (Part PVG) Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4460 psi	Steam	NV, -Class 2, -Class 3, UV, V
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6000 psi	Air	UV

Design Name: 1900E-2, 1900-30E-2		NBCert # 18166
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	06/15/2029
Design Type		
[Safety Relief Valve] 1900E-2, 1900-30E-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	06/15/2029

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids) NBCert # 19077

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/25/2028

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 1982 NBCert # 18379

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	09/09/2031

Design Type

[Safety Relief Valve] 1982
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at unknown lab on May 6, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Air	NV, UV
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Steam	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Air	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Steam	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Air	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Steam	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Air	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Air	NV, UV

Design Name: 1982 LS, 820000LS

NBCert # 18380

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/26/2030

Design Type

[Relief Valve] 1982 LS, 820000LS
Capacity Tests: Sec. UV at Dresser, Inc. on December 19, 1984
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.758 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	NV
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	UV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	NV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	NV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	UV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	NV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	NV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	UV

Design Name:	2900 (39PV & 39MV pilots - Liquid)	NBCert #	18874
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	11/18/2026

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots - Liquid)
Capacity Tests: Sec. UV, V at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.127 in	15-6250 psi	Water	UV, V
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	UV, V
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.205 in	15-6250 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-6250 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-6000 psi	Water	UV, V
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-6000 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-3750 psi	Water	UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-2250 psi	Water	UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-1500 psi	Water	UV, V
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.738 in	15-1500 psi	Water	UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-905 psi	Water	UV, V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV, V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.93 in	15-675 psi	Water	UV, V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-535 psi	Water	UV, V

Design Name:	2900 (39PV & 39MV pilots)	NBCert #	18863
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/18/2026

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV

Design Name: 2900 POSRV (39 PV, 39 MV Pilots)		NBCert #	18964
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		V	11/18/2026

Design Type

[Pilot Operated Pressure Relief Valve] 2900 POSRV (39 PV, 39 MV Pilots)

Capacity Tests: Sec. V at Dresser, Inc. on November 2, 2005

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.851 Unitless; (alternate medium): 0.691 Unitless; Certification Provisions: Economizer Service (Prev. CC 2446)

Media - Test: Liquid, Steam; Certified: Steam and Water

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	50-5800 psi	Steam	V
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	50-5800 psi	Water	V
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	50-5800 psi	Steam	V
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	50-5800 psi	Water	V
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	50-5800 psi	Steam	V
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	50-5800 psi	Water	V
1.5-2 NPS	3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	50-5800 psi	Steam	V
1.5-2 NPS	3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	50-5800 psi	Water	V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	45-3750 psi	Steam	V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	45-3750 psi	Water	V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	50-5800 psi	Steam	V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	50-5800 psi	Water	V
3 NPS	4, 6 NPS	2.136 in ²	[K] 1.649 in	0.446 in	55-5800 psi	Steam	V
3 NPS	4, 6 NPS	2.136 in ²	[K] 1.649 in	0.446 in	55-5800 psi	Water	V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	60-6250 psi	Steam	V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	60-6250 psi	Water	V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	65-2250 psi	Steam	V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	65-2250 psi	Water	V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	40-2250 psi	Steam	V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	40-2250 psi	Water	V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	75-2250 psi	Steam	V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	75-2250 psi	Water	V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	85-1500 psi	Steam	V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	85-1500 psi	Water	V
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	40-1500 psi	Steam	V
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	40-1500 psi	Water	V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	40-905 psi	Steam	V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	40-905 psi	Water	V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	40-905 psi	Steam	V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	40-905 psi	Water	V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	40-675 psi	Steam	V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	40-675 psi	Water	V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	40-535 psi	Steam	V

12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	40-535 psi	Water	V
--------	--------	------------------------	---------------	----------	------------	-------	---

Design Name: 3900 (39PV, 39MV pilots)				NBCert # 18447			
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		05/13/2027		
Design Type							
[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots) Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - ; Certified: Air, Gas, Steam Set Pressure Definition(1): Pop; (2): Initial Audible Discharge Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV

4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid)			NBCert #	18458
Manufacturer/Assembler		Designators		Expiration Date
Manufacturer		UV		05/11/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.743 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV

8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Design Name: 3900-TM (39PV, 39MV pilots) NBCert # 01438

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/24/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3900-TM (39PV, 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; (alternate medium): 0.743 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV

2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV

10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV
--------	--------	-----------------------	----------	------	-------------	-------	----

Dresser Utility Solutions (DRS)
Nameplate Abbreviation: DRS

Houston, TX 77041United States

This Company Manufactures or Assembles:

Design Name: F84, F85		NBCert #	28066
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	06/05/2029
Design Type			
[Safety Relief Valve] F84, F85 Capacity Tests: Sec. UV at National Board Testing Lab on January 18, 1996 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Flow-Safe, Inc. {FLW}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.75 NPS	.5 - .75 NPS	0.003 in ²	[-1] 0.062 in	0.06 in	15-15000 psi	Air	UV
0.25-0.75 NPS	.5 - .75 NPS	0.008 in ²	[-1A] 0.098 in	0.039 in	500-15000 psi	Air	UV
0.25-0.75 NPS	.5, .75 NPS	0.015 in ²	[-2] 0.138 in	0.075 in	15-15000 psi	Air	UV
0.5-0.75 NPS	.5, .75 NPS	0.034 in ²	[-3] 0.209 in	0.113 in	15-890 psi	Air	UV
0.5-2 NPS	.5 - 1 NPS	0.065 in ²	[-4] 0.289 in	0.152 in	15-9612 psi	Air	UV
0.5-1 NPS	1 NPS	0.149 in ²	[-6] 0.436 in	0.211 in	15-6100 psi	Air	UV
0.75-1 NPS	1 NPS	0.261 in ²	[-8] 0.577 in	0.262 in	15-4292 psi	Air	UV
1.5 NPS	2 NPS	0.405 in ²	[F] 0.718 in	0.328 in	15-5000 psi	Air	UV
1.5 NPS	2 NPS	0.664 in ²	[G] 0.919 in	0.411 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	1.036 in ²	[H] 1.149 in	0.493 in	15-2750 psi	Air	UV
2 NPS	3 NPS	1.689 in ²	[J] 1.467 in	0.631 in	15-2700 psi	Air	UV

Dresser, LLC (DDT)
Nameplate Abbreviation: DLCT

Deer Park, TX 77536United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3		NBCert #	18032
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV, V	01/14/2026

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1700 & 2700

NBCert # 18100

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	03/17/2026

Design Type

[Safety Valve] 1700 & 2700
 Capacity Tests: Sec. UV, V at Dresser, Inc. on August 1, 1957
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	50-5800 psi	Steam	V
4 NPS	4 dual NPS	1.84 in ²	[K] 1.531 in	0.383 in	50-5800 psi	Steam	V
2-3 NPS	4, 6 NPS	2.545 in ²	[#3] 1.8 in	0.45 in	50-5800 psi	Steam	UV, V
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-2575 psi	Steam	UV
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	50-5800 psi	Steam	V
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	15-3100 psi	Steam	UV
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	50-5800 psi	Steam	V
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	15-3100 psi	Steam	UV
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	15-1800 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	1.24 in	50-2200 psi	Steam	UV, V
8-10 NPS	10,12 NPS	28.3 in ²	[T] 6 in	1.5 in	50-1500 psi	Steam	UV, V

Design Name: 1700 & 2700 (Restricted Lift version of Cert. # 18100) NBCert # 18111

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	08/11/2028

Design Type

[Safety Valve] 1700 & 2700 (Restricted Lift version of Cert. # 18100)
 Capacity Tests: Sec. UV, V at unknown lab on October 13, 1981
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Restricted Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	50-5800 psi	Steam	V
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	15-3100 psi	Steam	UV
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	50-5800 psi	Steam	V
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-2575 psi	Steam	UV
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	50-5800 psi	Steam	V
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	15-3100 psi	Steam	UV
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	50-5800 psi	Steam	V
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	15-3100 psi	Steam	UV
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.946 in	0.296 in	15-2000 psi	Steam	UV, V
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	0.372 in	50-2200 psi	Steam	V
8-10 NPS	10, 12 NPS	28.3 in ²	[T] 6 in	0.45 in	50-1500 psi	Steam	UV, V

Design Name: 1811, 1511

NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	03/02/2026

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA
(Liquids)

NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	01/13/2026

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V

1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

01/14/2026

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV

3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201) NBCert # 18223

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/11/2031

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV

1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name:	1900/P, 1900-30/P	NBCert #	18290
--------------	-------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	V	02/14/2029
--------------	---	------------

Design Type

[Safety Relief Valve] 1900/P, 1900-30/P
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV, V at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.851 Unitless; Certification Provisions: Organic Fluid Vaporizers (Part PVG)
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4460 psi	Steam	NV, -Class 2, -Class 3, UV, V
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6000 psi	Air	UV
1.5-2 NPS	2.5-3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-3705 psi	Air	UV
1.5-2 NPS	2.5-3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-3600 psi	Steam	NV, -Class 2, -Class 3, UV, V
1.5-2 NPS	2.5-3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-3600 psi	Steam	NV
1.5-2 NPS	2.5-3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-3600 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2735 psi	Steam	NV, -Class 2, -Class 3, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Steam	V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2700 psi	Steam	NV, -Class 2, -Class 3, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Steam	V
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2160 psi	Steam	NV, -Class 2, -Class 3, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3000 psi	Steam	V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, -Class 2, -Class 3, UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	15-1600 psi	Steam	NV, -Class 2, -Class 3, UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	15-1600 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, -Class 2, -Class 3, UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, -Class 2, -Class 3, UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, -Class 2, -Class 3, UV, V
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-500 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-500 psi	Steam	NV, -Class 2, -Class 3, UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-300 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-300 psi	Steam	NV, -Class 2, -Class 3, UV, V

Design Name: 19000 Series		NBCert # 18706
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/14/2026

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/15/2026

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV

1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D/P, 1900-30D/P	NBCert #	18256
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 10/27/2028

Design Type

[Safety Relief Valve] 1900D/P, 1900-30D/P
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV, V at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.610 PPH/PSIA; (alternate medium): 1.997 SCFM/PSIA; Certification Provisions: Organic Fluid Vaporizers (Part PVG)
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4460 psi	Steam	NV, -Class 2, -Class 3, UV, V
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6000 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/14/2026

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 03/03/2026

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM	NBCert # 19066
----------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	06/16/2027

Design Type

[Safety Relief Valve] 1900-DM
Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV

8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name:	1900-DM-D	NBCert #	19088
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 06/16/2027

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name:	1900-DM-E	NBCert #	19099
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 06/16/2027

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name:	1900E/P, 1900-30E/P	NBCert #	18278
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 10/27/2028

Design Type

[Safety Relief Valve] 1900E/P, 1900-30E/P
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV, V at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 9.980 PPH/PSIA; (alternate medium): 3.552 SCFM/PSIA; Certification Provisions: Organic Fluid Vaporizers (Part PVG)
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4460 psi	Steam	NV, -Class 2, -Class 3, UV, V
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6000 psi	Air	UV

Design Name: 1900E-2, 1900-30E-2 NBCert # 18166

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/14/2026

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	03/17/2026

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ. RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name:	19110M & 19110H (Liquids)	NBCert #	19077
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/18/2025

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name:	1982	NBCert #	18379
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/09/2026

Design Type

[Safety Relief Valve] 1982
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at unknown lab on May 6, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Air	NV, UV
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Steam	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Air	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Steam	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Air	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Steam	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Air	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Air	NV, UV

Design Name:	1982 LS, 820000LS	NBCert #	18380
--------------	-------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/17/2026

Design Type

[Relief Valve] 1982 LS, 820000LS
Capacity Tests: Sec. UV at Dresser, Inc. on December 19, 1984
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.758 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	NV
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	UV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	NV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	NV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	UV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	NV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	NV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	UV

Design Name:	2900 (39PV & 39MV pilots - Liquid)	NBCert #	18874
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 02/11/2026

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots - Liquid)
Capacity Tests: Sec. UV, V at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.127 in	15-6250 psi	Water	UV, V
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	UV, V
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.205 in	15-6250 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-6250 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-6000 psi	Water	UV, V

3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-6000 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-3750 psi	Water	UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-2250 psi	Water	UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-1500 psi	Water	UV, V
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.738 in	15-1500 psi	Water	UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-905 psi	Water	UV, V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV, V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.93 in	15-675 psi	Water	UV, V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-535 psi	Water	UV, V

Design Name: 2900 (39PV & 39MV pilots) NBCert # 18863

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/14/2026

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV

Design Name: 2900 POSRV (39 PV, 39 MV Pilots) NBCert # 18964

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	V	01/11/2031

Design Type

[Pilot Operated Pressure Relief Valve] 2900 POSRV (39 PV, 39 MV Pilots)
Capacity Tests: Sec. V at Dresser, Inc. on November 2, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.851 Unitless; (alternate medium): 0.691 Unitless; Certification Provisions: Economizer Service (Prev. CC 2446)
Media - Test: Liquid, Steam; Certified: Steam and Water
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	50-5800 psi	Steam	V
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	50-5800 psi	Water	V
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	50-5800 psi	Steam	V
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	50-5800 psi	Water	V
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	50-5800 psi	Steam	V
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	50-5800 psi	Water	V
1.5-2 NPS	3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	50-5800 psi	Steam	V
1.5-2 NPS	3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	50-5800 psi	Water	V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	45-3750 psi	Steam	V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	45-3750 psi	Water	V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	50-5800 psi	Steam	V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	50-5800 psi	Water	V
3 NPS	4, 6 NPS	2.136 in ²	[K] 1.649 in	0.446 in	55-5800 psi	Steam	V

3 NPS	4, 6 NPS	2.136 in ²	[K] 1.649 in	0.446 in	55-5800 psi	Water	V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	60-6250 psi	Steam	V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	60-6250 psi	Water	V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	65-2250 psi	Steam	V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	65-2250 psi	Water	V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	40-2250 psi	Steam	V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	40-2250 psi	Water	V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	75-2250 psi	Steam	V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	75-2250 psi	Water	V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	85-1500 psi	Steam	V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	85-1500 psi	Water	V
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	40-1500 psi	Steam	V
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	40-1500 psi	Water	V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	40-905 psi	Steam	V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	40-905 psi	Water	V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	40-905 psi	Steam	V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	40-905 psi	Water	V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	40-675 psi	Steam	V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	40-675 psi	Water	V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	40-535 psi	Steam	V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	40-535 psi	Water	V

Design Name: 2900-TM (39PV & 39MV pilots) NBCert # 01427

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/11/2028

Design Type

[Pilot Operated Pressure Relief Valve] 2900-TM (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Water	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV

1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Water	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Water	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2000 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Water	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Water	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-300 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV

12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Water	UV

Design Name:	3900 (39PV, 39MV pilots)	NBCert #	18447
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/14/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV

3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid) NBCert # 18458

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/13/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.743 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV

8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Design Name: 3900-TM (39PV, 39MV pilots) NBCert # 01438

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 08/11/2028

Design Type

[Pilot Operated Pressure Relief Valve] 3900-TM (39PV, 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; (alternate medium): 0.743 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV

2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV

10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV
--------	--------	-----------------------	----------	------	-------------	-------	----

Dresser, LLC. (DPT)

Pasadena, TX 77507United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3		NBCert # 18032
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 2, -Class 3, UV, V	08/28/2030
Design Type		
[Safety Valve] 1541, 1543, 1541-3, 1543-3 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV

2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1700 & 2700 (Restricted Lift version of Cert. # 18100) NBCert # 18111

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 08/29/2030

Design Type

[Safety Valve] 1700 & 2700 (Restricted Lift version of Cert. # 18100)
Capacity Tests: Sec. UV, V at unknown lab on October 13, 1981
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	50-5800 psi	Steam	V
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	15-3100 psi	Steam	UV
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	50-5800 psi	Steam	V
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-2575 psi	Steam	UV
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	50-5800 psi	Steam	V
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	15-3100 psi	Steam	UV
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	50-5800 psi	Steam	V
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	15-3100 psi	Steam	UV
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.946 in	0.296 in	15-2000 psi	Steam	UV, V
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	0.372 in	50-2200 psi	Steam	V
8-10 NPS	10, 12 NPS	28.3 in ²	[T] 6 in	0.45 in	50-1500 psi	Steam	UV, V

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 2, -Class 3, UV, V	12/19/2029

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 2, -Class 3, UV	08/28/2030

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name:	1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)	NBCert #	18223
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	NV, -Class 2, -Class 3, UV	01/18/2030
--------------	----------------------------	------------

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV

8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name:	1900/P, 1900-30/P	NBCert #	18290
--------------	-------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer V 08/28/2030

Design Type

[Safety Relief Valve] 1900/P, 1900-30/P
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV, V at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.851 Unitless; Certification Provisions: Organic Fluid Vaporizers (Part PVG)
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4460 psi	Steam	NV, -Class 2, -Class 3, UV, V
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6000 psi	Air	UV
1.5-2 NPS	2.5-3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-3705 psi	Air	UV
1.5-2 NPS	2.5-3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-3600 psi	Steam	NV, -Class 2, -Class 3, UV, V
1.5-2 NPS	2.5-3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-3600 psi	Steam	NV
1.5-2 NPS	2.5-3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-3600 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2735 psi	Steam	NV, -Class 2, -Class 3, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Steam	V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2700 psi	Steam	NV, -Class 2, -Class 3, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Steam	V
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2160 psi	Steam	NV, -Class 2, -Class 3, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3000 psi	Steam	V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, -Class 2, -Class 3, UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	15-1600 psi	Steam	NV, -Class 2, -Class 3, UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	15-1600 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	15-1600 psi	Steam	UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, -Class 2, -Class 3, UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, -Class 2, -Class 3, UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, -Class 2, -Class 3, UV, V
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-500 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-500 psi	Steam	NV, -Class 2, -Class 3, UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-300 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-300 psi	Steam	NV, -Class 2, -Class 3, UV, V

Design Name: 19000 Series, Liquid NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV, -Class 1, -Class 2, -Class 3, UV 12/19/2029

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D/P, 1900-30D/P NBCert # 18256

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 08/29/2030

Design Type

[Safety Relief Valve] 1900D/P, 1900-30D/P
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV, V at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.610 PPH/PSIA; (alternate medium): 1.997 SCFM/PSIA; Certification Provisions: Organic Fluid Vaporizers (Part PVG)
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4460 psi	Steam	NV, -Class 2, -Class 3, UV, V
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6000 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 NBCert # 18144

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 2, -Class 3, UV	08/27/2030

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert # 18751

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 2, -Class 3, UV, V	12/19/2029

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM	NBCert # 19066
----------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/19/2029

Design Type

[Safety Relief Valve] 1900-DM
Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV

12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D		NBCert # 19088
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/13/2030
Design Type		
<div>[Safety Relief Valve] 1900-DM-D</div> <div>Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010</div> <div>Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method</div> <div>Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)</div> <div>Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid</div> <div>Set Pressure Definition(1): Pop; (2): First Steady Stream</div> <div>Blowdown Characteristics: Fixed</div> <div>Flow Area Configuration: Curtain Area</div> <div>Designed by: Dresser, LLC. {DPT}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E		NBCert # 19099
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/13/2030
Design Type		
<div>[Safety Relief Valve] 1900-DM-E Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787) Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid Set Pressure Definition(1): Pop; (2): First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900-DM-RL, 1900-30DM-RL (Restricted Lift Version of Cert 19066)			NBCert # 19101	
Manufacturer/Assembler		Designators		Expiration Date
Manufacturer		UV		06/20/2030

Design Type

[Safety Relief Valve] 1900-DM-RL, 1900-30DM-RL (Restricted Lift Version of Cert 19066)

Holder Designation:

Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Restricted Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.119 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.119 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.152 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.152 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.182 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.182 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.226 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.226 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.254 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.254 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.279 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.279 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.338 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.338 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.445 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.445 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.535 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.535 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	0.682 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	0.682 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.728 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.728 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.879 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.879 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	1.103 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	1.103 in	15-300 psi	Water	UV

Design Name: 1900E/P, 1900-30E/P		NBCert # 18278
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	08/27/2030
Design Type		
[Safety Relief Valve] 1900E/P, 1900-30E/P Capacity Tests: Sec. NV, -Class 2, -Class 3, UV, V at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 9.980 PPH/PSIA; (alternate medium): 3.552 SCFM/PSIA; Certification Provisions: Organic Fluid Vaporizers (Part PVG) Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4460 psi	Steam	NV, -Class 2, -Class 3, UV, V
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6000 psi	Air	UV

Design Name: 1900E-2, 1900-30E-2		NBCert # 18166
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 2, -Class 3, UV	08/27/2030
Design Type		
[Safety Relief Valve] 1900E-2, 1900-30E-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids)		NBCert # 18762
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 2, -Class 3, UV, V	12/19/2029
Design Type		
[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids) Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.798 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V
Design Name: 19110M & 19110H (Liquids)NBCert #19077							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			NV, -Class 2, -Class 3, UV			01/18/2030	
Design Type							
[Relief Valve] 19110M & 19110H (Liquids) Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.264 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3
Design Name: 1982NBCert #18379							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			NV, -Class 2, -Class 3, UV			08/28/2030	
Design Type							
[Safety Relief Valve] 1982 Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at unknown lab on May 6, 1980 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.855 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.121 in²	0.393 in	0.092 in	15-500 psi	Air	NV, UV
0.5 NPS	.75 NPS	0.121 in²	0.393 in	0.092 in	15-500 psi	Steam	NV, UV
0.75 NPS	1 NPS	0.216 in²	0.524 in	0.123 in	15-500 psi	Air	NV, UV
0.75 NPS	1 NPS	0.216 in²	0.524 in	0.123 in	15-500 psi	Steam	NV, UV
1 NPS	1.5 NPS	0.332 in²	0.65 in	0.15 in	15-500 psi	Air	NV, UV
1 NPS	1.5 NPS	0.332 in²	0.65 in	0.15 in	15-500 psi	Steam	NV, UV
1.5 NPS	2 NPS	0.857 in²	1.045 in	0.243 in	15-500 psi	Air	NV, UV
1.5 NPS	2 NPS	0.857 in²	1.045 in	0.243 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in²	1.335 in	0.31 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in²	1.335 in	0.31 in	15-500 psi	Air	NV, UV

Design Name:	1982 LS, 820000LS	NBCert #	18380
--------------	-------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV, -Class 2, -Class 3, UV 03/13/2030

Design Type

[Relief Valve] 1982 LS, 820000LS
Capacity Tests: Sec. UV at Dresser, Inc. on December 19, 1984
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.758 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	NV
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	UV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	NV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	NV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	UV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	NV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	NV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	UV

Design Name:	2900 (39PV & 39MV pilots - Liquid)	NBCert #	18874
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/18/2030

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots - Liquid)
Capacity Tests: Sec. UV, V at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.127 in	15-6250 psi	Water	UV, V
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	UV, V
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.205 in	15-6250 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-6250 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-6000 psi	Water	UV, V

3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-6000 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-3750 psi	Water	UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-2250 psi	Water	UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-1500 psi	Water	UV, V
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.738 in	15-1500 psi	Water	UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-905 psi	Water	UV, V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV, V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.93 in	15-675 psi	Water	UV, V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-535 psi	Water	UV, V

Design Name: 2900 (39PV & 39MV pilots) NBCert # 18863

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/18/2030

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV

Design Name: 2900 POSRV (39 PV, 39 MV Pilots) NBCert # 18964

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	V	08/29/2030

Design Type

[Pilot Operated Pressure Relief Valve] 2900 POSRV (39 PV, 39 MV Pilots)
Capacity Tests: Sec. V at Dresser, Inc. on November 2, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.851 Unitless; (alternate medium): 0.691 Unitless; Certification Provisions: Economizer Service (Prev. CC 2446)
Media - Test: Liquid, Steam; Certified: Steam and Water
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	50-5800 psi	Steam	V
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	50-5800 psi	Water	V
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	50-5800 psi	Steam	V
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	50-5800 psi	Water	V
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	50-5800 psi	Steam	V
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	50-5800 psi	Water	V
1.5-2 NPS	3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	50-5800 psi	Steam	V
1.5-2 NPS	3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	50-5800 psi	Water	V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	45-3750 psi	Steam	V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	45-3750 psi	Water	V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	50-5800 psi	Steam	V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	50-5800 psi	Water	V
3 NPS	4, 6 NPS	2.136 in ²	[K] 1.649 in	0.446 in	55-5800 psi	Steam	V

3 NPS	4, 6 NPS	2.136 in ²	[K] 1.649 in	0.446 in	55-5800 psi	Water	V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	60-6250 psi	Steam	V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	60-6250 psi	Water	V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	65-2250 psi	Steam	V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	65-2250 psi	Water	V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	40-2250 psi	Steam	V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	40-2250 psi	Water	V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	75-2250 psi	Steam	V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	75-2250 psi	Water	V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	85-1500 psi	Steam	V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	85-1500 psi	Water	V
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	40-1500 psi	Steam	V
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	40-1500 psi	Water	V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	40-905 psi	Steam	V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	40-905 psi	Water	V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	40-905 psi	Steam	V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	40-905 psi	Water	V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	40-675 psi	Steam	V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	40-675 psi	Water	V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	40-535 psi	Steam	V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	40-535 psi	Water	V

Design Name:	3900 (39PV, 39MV pilots)	NBCert #	18447
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/18/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV

1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV

8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid) NBCert # 18458

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/18/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV

3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Design Name: 3900-TM (39PV, 39MV pilots)

NBCert #

01438

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

08/29/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3900-TM (39PV, 39MV pilots)

Capacity Tests: Sec. UV at Dresser, Inc. on May 19, 1988

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless; (alternate medium): 0.743 Unitless; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV

1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV

6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

East Coast Valve Services, Inc. (ECG)

Nameplate Abbreviation: EAST COAST
VALVE SERVICES

Groton, CT 06340 United States

This Company Manufactures or Assembles:

Design Name: 9 Series		NBCert #	44019
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	10/23/2026	
Design Type			
<div>[Safety Relief Valve] 9 Series</div> <div>Capacity Tests: Sec. UV at National Board Testing Lab on July 24, 1997</div> <div>Method of Establishing Relieving Capacity: Flow Capacity, K</div> <div>Certified Value: 0.823 Unitless</div> <div>Media - Test: Air/Gas; Certified: Air, Gas, Steam</div> <div>Set Pressure Definition: Initial Audible Discharge</div> <div>Blowdown Characteristics: Adjustable (Single Ring)</div> <div>Flow Area Configuration: Nozzle/Full Lift</div> <div>Designed by: TRILLIUM Flow Technologies - France SAS {SAR}</div>			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	0.236 in	0.07 in	15-4700 psi	Air	UV
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	0.236 in	0.07 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.124 in ²	0.398 in	0.1 in	14.5-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.124 in ²	0.398 in	0.1 in	14.5-4700 psi	Air	UV
0.75-1 NPS	1 NPS	0.222 in ²	0.531 in	0.13 in	14.5-2220 psi	Air	UV
0.75-1 NPS	1 NPS	0.222 in ²	0.531 in	0.13 in	14.5-2220 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.669 in	0.17 in	14.5-740 psi	Air	UV

1-1.5 NPS	1.5 NPS	0.352 in²	0.669 in	0.17 in	14.5-740 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.568 in²	0.85 in	0.21 in	14.5-285 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.568 in²	0.85 in	0.21 in	14.5-285 psi	Steam	UV
Design Name: 9 Series (Liquids)		NBCert #		44020			
Manufacturer/Assembler			Designators		Expiration Date		
Assembler			UV		10/23/2026		
Design Type							
[Relief Valve] 9 Series (Liquids) Capacity Tests: Sec. UV, V at National Board Testing Lab on July 24, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.632 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: TRILLIUM Flow Technologies - France SAS {SAR}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in²	[B] 0.236 in	0.07 in	15-6250 psi	Water	UV
0.5-1 NPS	1 NPS	0.124 in²	[D] 0.398 in	0.1 in	14.5-6250 psi	Water	UV
0.75-1 NPS	1 NPS	0.222 in²	[E] 0.531 in	0.13 in	14.5-2220 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.352 in²	[F] 0.669 in	0.17 in	14.5-740 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.568 in²	[G] 0.85 in	0.21 in	14.5-285 psi	Water	UV
Design Name: P3, P4 (liquids)		NBCert #		92012			
Manufacturer/Assembler			Designators		Expiration Date		
Assembler			UV		10/23/2026		
Design Type							
[Relief Valve] P3, P4 (liquids) Capacity Tests: Sec. UV, V at National Board Testing Lab on December 7, 1993 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.631 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: TRILLIUM Flow Technologies - France SAS {SAR}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.134 in²	[D] 0.413 in	0.128 in	15-10000 psi	Water	UV, V
1-1.5 NPS	2-3 NPS	0.273 in²	[E] 0.59 in	0.183 in	15-7500 psi	Water	UV, V
1.5 NPS	2-3 NPS	0.373 in²	[F] 0.689 in	0.214 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.589 in²	[G] 0.866 in	0.268 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.881 in²	[H] 1.059 in	0.328 in	15-5000 psi	Water	UV, V
2-3 NPS	3-4 NPS	1.457 in²	[J] 1.362 in	0.422 in	15-3200 psi	Water	UV, V
3 NPS	4-6 NPS	2.097 in²	[K] 1.634 in	0.506 in	15-3200 psi	Water	UV, V
3-4 NPS	4-6 NPS	3.284 in²	[L] 2.045 in	0.634 in	15-2000 psi	Water	UV, V

4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Water	UV, V
4 NPS	6 NPS	7.032 in ²	[P] 2.992 in	0.94 in	15-1300 psi	Water	UV, V
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Water	UV, V
6 NPS	8-10 NPS	15.267 in ²	[R] 4.409 in	1.477 in	15-500 psi	Water	UV, V
8 NPS	10 NPS	28.126 in ²	[T] 5.984 in	1.88 in	15-500 psi	Water	UV, V

Design Name: P3, P4, P5

NBCert # 92001

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

01/07/2027

Design Type

[Safety Relief Valve] P3, P4, P5
Capacity Tests: Sec. UV at unknown lab on June 5, 1986
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Air	UV
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Air	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-2900 psi	Steam	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Air	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-2900 psi	Steam	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Air	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-2900 psi	Steam	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Air	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Steam	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Air	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Steam	UV
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Air	UV

6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Steam	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Air	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Steam	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Air	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Steam	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Air	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Steam	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Air	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Steam	UV

Design Name:	STARFLOW-V	NBCert #	44110
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 12/07/2027

Design Type

[Safety Valve] STARFLOW-V
Capacity Tests: Sec. UV, V at National Board Testing Lab on April 26, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}
Comments: org. date added and V orif. area corrected from 38.548 to 38.485 JB 8-10-20
corrected H inlet to add 1.5" JB -8-2-21

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5-3 NPS	0.373 in ²	[F] 0.689 in	0.172 in	30-2250 psi	Steam	UV, V
1.25-2 NPS	1.5-3 NPS	0.589 in ²	[G] 0.8661 in	0.217 in	30-2250 psi	Steam	UV, V
1.5-2 NPS	2.5, 3 NPS	0.996 in ²	[H] 1.126 in	0.281 in	30-2250 psi	Steam	UV, V
1.5-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.3622 in	0.341 in	30-2250 psi	Steam	UV, V
2-3 NPS	3-6 NPS	1.667 in ²	[K] 1.457 in	0.364 in	30-2250 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.758 in ²	[L] 1.874 in	0.469 in	30-2250 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.983 in ²	[M] 2.252 in	0.563 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	5.303 in ²	[N] 2.5984 in	0.65 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	0.75 in	30-2250 psi	Steam	UV, V
6 NPS	8 NPS	10.148 in ²	[Q] 3.594 in	0.902 in	30-1494 psi	Steam	UV, V
6 NPS	8, 10 NPS	14.173 in ²	[R] 4.248 in	1.062 in	30-1494 psi	Steam	UV, V
8 NPS	10 NPS	23.997 in ²	[T] 5.528 in	1.382 in	30-740 psi	Steam	UV, V
10 NPS	14 NPS	38.485 in ²	[V] 7 in	1.75 in	30-740 psi	Steam	UV, V
12 NPS	2x12 NPS	55.438 in ²	[W] 8.402 in	2.1 in	30-740 psi	Steam	UV, V

Design Name:	Starsteam V Series	NBCert #	92034
--------------	--------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 12/07/2027

Design Type

[Safety Valve] Starsteam V Series
Capacity Tests: Sec. UV, V at National Board Testing Lab on August 3, 2012
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	3 NPS	0.996 in ²	[1] 1.125 in	0.2835 in	15-6525 psi	Steam	UV, V
2 NPS	3 NPS	1.667 in ²	[2] 1.456 in	0.3661 in	15-6525 psi	Steam	UV, V
2.5-6 NPS	6 NPS	2.758 in ²	[3] 1.874 in	0.4685 in	15-6525 psi	Steam	UV, V
3 NPS	6 NPS	3.983 in ²	[4] 2.251 in	0.562 in	15-6525 psi	Steam	UV, V
4 NPS	6 NPS	5.303 in ²	[5] 2.598 in	0.6496 in	15-6525 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[6] 3 in	0.752 in	15-3280 psi	Steam	UV, V
6 NPS	8 NPS	11.056 in ²	[Q] 3.751 in	0.9409 in	15-2798.5 psi	Steam	UV, V
6 NPS	10 NPS	15.904 in ²	[R] 4.5 in	1.126 in	15-1580 psi	Steam	UV, V
6 NPS	10 NPS	19.299 in ²	[RR] 4.957 in	1.239 in	15-1580 psi	Steam	UV, V
8 NPS	10 NPS	27.391 in ²	[T] 5.905 in	1.4764 in	15-1190 psi	Steam	UV, V

Elfab Limited (ELF)

Nameplate Abbreviation: ELFAB

North Shields, Tyne and Wear, NE29 8SDUnited Kingdom

This Company Manufactures or Assembles:

Design Name:	Double DSC-OPR	NBCert #	88028
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UD	05/18/2027	

Design Type

[Rupture Disk Device] Double DSC-OPR
HolderDesignation: Double HLD-REV
Capacity Tests: Sec. UD at Elfab Limited on March 17, 2021
Certified Value: 2.380 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration:
Designed by: Elfab Limited {ELF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.766 in ²			50-1523 psi		UD
1.5 NPS		1.63 in ²			27-1523 psi		UD
10 NPS		65.248 in ²			5-991 psi		UD
12 NPS		95.006 in ²			5-878 psi		UD
14 NPS		125.982 in ²			5-765 psi		UD

16 NPS	171.545 in ²	4-652 psi	UD
18 NPS	213.795 in ²	4-539 psi	UD
2 NPS	2.789 in ²	14-1523 psi	UD
2.5 NPS	4.119 in ²	10-1305 psi	UD
20 NPS	259.735 in ²	4-426 psi	UD
24 NPS	372.075 in ²	4-200 psi	UD
26 NPS	424.74 in ²	4-191 psi	UD
28 NPS	492.6 in ²	4-182 psi	UD
3 NPS	6.722 in ²	7-1088 psi	UD
30 NPS	565.49 in ²	4-173 psi	UD
32 NPS	643.3 in ²	4-163 psi	UD
34 NPS	726.34 in ²	4-154 psi	UD
36 NPS	814.3 in ²	4-145 psi	UD
4 NPS	10.923 in ²	5-1440 psi	UD
40 NPS	1005.31 in ²	4-136 psi	UD
6 NPS	23.322 in ²	5-1217 psi	UD
8 NPS	44.37 in ²	5-1104 psi	UD

Design Name: DSC-AGS

NBCert #

88129

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/24/2031

Design Type

[Rupture Disk Device] DSC-AGS

HolderDesignation: N/A

Capacity Tests: Sec. UD at National Board Testing Lab on January 20, 2004

Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl

Certified Value: 0.690 Unitless

Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)

Set Pressure Definition: Burst Pressure

Flow Area Configuration: MNFA

Designed by: Elfab Limited {ELF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.79 in ²	1 in		10-800 psi		UD
1.5 NPS		1.77 in ²	1.5 in		10-595 psi		UD
2 NPS		3.14 in ²	2 in		10-400 psi		UD
2.5 NPS		4.79 in ²	2.5 in		3-400 psi		UD
3 NPS		7.07 in ²	3 in		3-350 psi		UD
4 NPS		12.57 in ²	4 in		2-245 psi		UD
6 NPS		28.27 in ²	6 in		1.5-145 psi		UD
8 NPS		50.03 in ²	8 in		1-80 psi		UD
10 NPS		78.54 in ²	10 in		1-70 psi		UD
12 NPS		113.1 in ²	12 in		1-60 psi		UD
14 NPS		137.9 in ²	14 in		1-50 psi		UD
16 NPS		182.7 in ²	16 in		1-50 psi		UD

18 NPS	233.7 in ²	18 in	1-40 psi	UD
20 NPS	291 in ²	20 in	1-30 psi	UD

Design Name:	DSC-CDD	NBCert #	88152
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	10/31/2029
--------------	----	------------

Design Type

[Rupture Disk Device] DSC-CDD
HolderDesignation: HLD-STD
Capacity Tests: Sec. UD at National Board Testing Lab on July 6, 2006
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 1.400 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Elfab Limited {ELF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.78 in ²	1 in		369-12000 psi		UD
1.5 NPS		1.93 in ²	1.57 in		227-6000 psi		UD
2 NPS		3.14 in ²	2 in		188-6000 psi		UD
2.5 NPS		5.1 in ²	2.55 in		150-6000 psi		UD
3 NPS		7.74 in ²	3.14 in		100-6000 psi		UD
4 NPS		12.56 in ²	4 in		87-6000 psi		UD
6 NPS		27.33 in ²	5.9 in		70-6000 psi		UD
8 NPS		48.64 in ²	7.87 in		60-3600 psi		UD
10 NPS		76.04 in ²	9.84 in		52-3600 psi		UD
12 NPS		109.54 in ²	11.81 in		42-3600 psi		UD
14 NPS		148.92 in ²	13.77 in		42-2160 psi		UD
16 NPS		194.58 in ²	15.74 in		42-2160 psi		UD
18 NPS		246.33 in ²	17.71 in		42-1400 psi		UD
20 NPS		304.18 in ²	19.68 in		42-1400 psi		UD
24 NPS		438.17 in ²	23.62 in		42-1000 psi		UD

Design Name:	DSC-FCD	NBCert #	88062
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	04/25/2030
--------------	----	------------

Design Type

[Rupture Disk Device] DSC-FCD
HolderDesignation: HLD-STD
Capacity Tests: Sec. UD at National Board Testing Lab on January 7, 2002
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 2.200 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Elfab Limited {ELF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.607 in ²			20-30 psi	Air	UD
1.5 NPS		1.655 in ²			14.5-20 psi		UD
10 NPS		74.22 in ²			1-10 psi		UD
12 NPS		107.4 in ²			1-10 psi		UD
14 NPS		146.5 in ²			1-9 psi		UD
16 NPS		191.9 in ²			1-7 psi		UD
18 NPS		243.2 in ²			1-209 psi		UD
2 NPS		2.774 in ²			7-20 psi		UD
2.5 NPS		4.678 in ²			2-20 psi		UD
20 NPS		292.3 in ²			1-209 psi		UD
24 NPS		422.6 in ²			1-209 psi		UD
28 NPS		578.9 in ²			1-209 psi		UD
3 NPS		7.216 in ²			2-20 psi		UD
30 NPS		669.9 in ²			1-209 psi		UD
32 NPS		764.77 in ²			1-197 psi		UD
34 NPS		865.92 in ²			1-184 psi		UD
36 NPS		973.34 in ²			1-171 psi		UD
38 NPS		1087.05 in ²			1-158 psi		UD
4 NPS		11.81 in ²			2-20 psi		UD
40 NPS		1207.04 in ²			1-145 psi		UD
42 NPS		1333.31 in ²			1-132 psi		UD
44 NPS		1465.85 in ²			1-119 psi		UD
46 NPS		1604.68 in ²			1-106 psi		UD
48 NPS		1749.79 in ²			1-93 psi		UD
6 NPS		26.246 in ²			1-10 psi		UD
8 NPS		47.19 in ²			1-10 psi		UD

Design Name:	DSC-FCD/DCD	NBCert #	88208
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/08/2026

Design Type

[Rupture Disk Device] DSC-FCD/DCD
HolderDesignation: HLD-STD
Capacity Tests: Sec. UD at National Board Testing Lab on January 28, 2014
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 3.940 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Elfab Limited {ELF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.42 in ²			15-522 psi	Air	UD

1.5 NPS	1.12 in ²	10-522 psi	Air	UD
10 NPS	43.53 in ²	5-290 psi	Air	UD
12 NPS	73.3 in ²	5-248 psi	Air	UD
14 NPS	100.84 in ²	5-235 psi	Air	UD
16 NPS	132.21 in ²	5-222 psi	Air	UD
18 NPS	167.1 in ²	1-209 psi	Air	UD
2 NPS	1.86 in ²	10-522 psi	Air	UD
2.5 NPS	2.96 in ²	10-522 psi	Air	UD
20 NPS	206.81 in ²	1-197 psi	Air	UD
22 NPS	247.7 in ²	1-184 psi	Air	UD
24 NPS	294.4 in ²	1-171 psi	Air	UD
26 NPS	346.55 in ²	1-158 psi	Air	UD
28 NPS	408.06 in ²	1-145 psi	Air	UD
3 NPS	5.29 in ²	10-522 psi	Air	UD
30 NPS	459.57 in ²	1-145 psi	Air	UD
32 NPS	527.47 in ²	1-145 psi	Air	UD
34 NPS	593.93 in ²	1-145 psi	Air	UD
36 NPS	655.72 in ²	1-145 psi	Air	UD
38 NPS	742.45 in ²	1-145 psi	Air	UD
4 NPS	7.34 in ²	10-522 psi	Air	UD
40 NPS	811.36 in ²	1-145 psi	Air	UD
42 NPS	907.54 in ²	1-145 psi	Air	UD
44 NPS	983.56 in ²	1-145 psi	Air	UD
46 NPS	1089.18 in ²	1-145 psi	Air	UD
48 NPS	1172.32 in ²	1-145 psi	Air	UD
6 NPS	14.34 in ²	10-494 psi	Air	UD
8 NPS	26.63 in ²	5-378 psi	Air	UD

Design Name:	DSC-OFS	NBCert #	88163
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	01/22/2026
--------------	----	------------

Design Type

[Rupture Disk Device] DSC-OFS
HolderDesignation: HLD-REV, HLD-SAN, HLD-SAN(W)
Capacity Tests: Sec. UD at Elfab Limited on January 17, 2020
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.850 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Elfab Limited {ELF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 in		0.5 in ²			18-145 psi		UD
1 NPS		0.7 in ²			18-145 psi		UD

1.5 in	1.24 in ²	14-130 psi	UD
1.5 NPS	1.74 in ²	14-130 psi	UD
2 in	2.37 in ²	10-116 psi	UD
2 NPS	2.95 in ²	10-116 psi	UD
2.5 in	3.87 in ²	7-116 psi	UD
2.5 NPS	4.2 in ²	7-116 psi	UD
3 in	5.71 in ²	6-101.5 psi	UD
3 NPS	6.52 in ²	6-101.5 psi	UD
4 in	10.46 in ²	5-101.5 psi	UD
4 NPS	11.53 in ²	5-101.5 psi	UD
6 in	23.79 in ²	5-40 psi	UD
6 NPS	26.17 in ²	5-40 psi	UD

Design Name: DSC-OPR NBCert # 88185

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/28/2026

Design Type

[Rupture Disk Device] DSC-OPR
 HolderDesignation: HLD-REV, HLD-REV(W), HLD-SAN, HLD-SAN(W)
 Capacity Tests: Sec. UD at National Board Testing Lab on April 30, 2013
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 1.740 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Elfab Limited {ELF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 in	1 in	0.461 in ²	0.87 in		50-1500 psi		UD
1 NPS	1 NPS	0.766 in ²	1.12 in		50-1523 psi	Air	UD
1.5 in	1.5 in	1.146 in ²	1.37 in		30-1500 psi		UD
1.5 NPS	1.5 NPS	1.651 in ²	1.63 in		27-1523 psi	Air	UD
2 in	2 in	2.132 in ²	1.87 in		13-1000 psi		UD
2 NPS	2 NPS	2.789 in ²	2.13 in		14-1523 psi	Air	UD
2.5 in	2.5 in	3.484 in ²	2.37 in		13-1000 psi		UD
2.5 NPS	2.5 NPS	4.119 in ²	2.61 in		10-1305 psi	Air	UD
3 in	3 in	5.041 in ²	2.87 in		13-1000 psi		UD
3 NPS	3 NPS	6.722 in ²	3.35 in		7-1088 psi	Air	UD
4 in	4 in	8.923 in ²	3.83 in		13-1000 psi		UD
4 NPS	4 NPS	10.923 in ²	4.11 in		5-1440 psi	Air	UD
6 in	6 in	21.03 in ²	5.78 in		5-650 psi		UD
6 NPS	6 NPS	23.309 in ²	6.14 in		5-1217 psi	Air	UD
8 NPS	8 NPS	44.37 in ²	8.18 in		5-1104 psi	Air	UD
10 NPS	10 NPS	65.248 in ²	10.2 in		5-991 psi	Air	UD
12 NPS	12 NPS	95.006 in ²	12.2 in		5-878 psi	Air	UD

14 NPS	14 NPS	125.982 in ²	14.1 in	5-765 psi	Air	UD
16 NPS	16 NPS	171.545 in ²	16.5 in	4-652 psi	Air	UD
18 NPS	18 NPS	213.795 in ²	18 in	4-539 psi	Air	UD
20 NPS	20 NPS	259.735 in ²	20 in	4-426 psi	Air	UD
24 NPS	24 NPS	372.075 in ²	23.9 in	4-200 psi	Air	UD
26 NPS	26 NPS	424.74 in ²	26 in	4-191 psi	Air	UD
28 NPS	28 NPS	492.6 in ²	28 in	4-182 psi	Air	UD
30 NPS	30 NPS	565.49 in ²	30 in	4-173 psi	Air	UD
32 NPS	32 NPS	643.3 in ²	32 in	4-163 psi	Air	UD
34 NPS	34 NPS	726.34 in ²	34 in	4-154 psi	Air	UD
36 NPS	36 NPS	814.3 in ²	36 in	4-145 psi	Air	UD
40 NPS	40 NPS	1005.31 in ²	40 in	4-136 psi	Air	UD

Design Name: DSC-OPS NBCert # 88141

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 03/29/2031

Design Type

[Rupture Disk Device] DSC-OPS
HolderDesignation: HLD-REV, HLD-REV(W)
Capacity Tests: Sec. UD at National Board Testing Lab on August 4, 2006
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.800 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Elfab Limited {ELF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.923 in ²			14-70 psi		UD
1.5 NPS		1.996 in ²			6-60 psi		UD
10 NPS		76.838 in ²			2-50 psi		UD
12 NPS		112.854 in ²			2-50 psi		UD
2 NPS		3.387 in ²			5-50 psi		UD
2.5 NPS		4.97 in ²			5.5-50 psi		UD
3 NPS		8.114 in ²			2.5-50 psi		UD
4 NPS		12.914 in ²			2-50 psi		UD
6 NPS		27.661 in ²			2-50 psi		UD
8 NPS		52.007 in ²			2-50 psi		UD

Design Name: DSC-SGD NBCert # 88196

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 04/25/2030

Design Type

[Rupture Disk Device] DSC-SGD

Holder Designation: HLD-STD, HLD-STD(W), HLD-SAN, HLD-SAN(W)

Capacity Tests: Sec. UD at National Board Testing Lab on April 25, 2012

Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl

Certified Value: 0.680 Unitless

Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)

Set Pressure Definition: Burst Pressure

Flow Area Configuration: MNFA

Designed by: Elfab Limited {ELF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 in	1 in	0.378 in ²			100-1500 psi	Air	UD
1 in	1 in	0.378 in ²			100-1500 psi	Water	UD
1 NPS	1 NPS	0.5 in ²			100-2683 psi	Air	UD
1 NPS	1 NPS	0.5 in ²			100-2683 psi	Water	UD
1.5 in	1.5 in	0.938 in ²			100-1500 psi	Air	UD
1.5 in	1.5 in	0.938 in ²			100-1500 psi	Water	UD
1.5 NPS	1.5 NPS	1.24 in ²			100-2031 psi	Air	UD
1.5 NPS	1.5 NPS	1.24 in ²			100-2031 psi	Water	UD
10 NPS	10 NPS	48.44 in ²			50-1650 psi	Air	UD
10 NPS	10 NPS	48.44 in ²			50-1650 psi	Water	UD
12 NPS	12 NPS	69.75 in ²			50-1430 psi	Air	UD
12 NPS	12 NPS	69.75 in ²			50-1430 psi	Water	UD
14 NPS	14 NPS	94.94 in ²			50-1100 psi	Air	UD
14 NPS	14 NPS	94.94 in ²			50-1100 psi	Water	UD
16 NPS	16 NPS	124 in ²			50-990 psi	Air	UD
16 NPS	16 NPS	124 in ²			50-990 psi	Water	UD
18 NPS	18 NPS	156.94 in ²			50-880 psi	Air	UD
18 NPS	18 NPS	156.94 in ²			50-880 psi	Water	UD
2 in	2 in	1.748 in ²			100-1000 psi	Air	UD
2 in	2 in	1.748 in ²			100-1000 psi	Water	UD
2 NPS	2 NPS	2 in ²			100-1813 psi	Air	UD
2 NPS	2 NPS	2 in ²			100-1813 psi	Water	UD
2.5 in	2.5 in	2.808 in ²			100-1000 psi	Air	UD
2.5 in	2.5 in	2.808 in ²			100-1000 psi	Water	UD
2.5 NPS	2.5 NPS	3.27 in ²			100-1523 psi	Air	UD
2.5 NPS	2.5 NPS	3.27 in ²			100-1523 psi	Water	UD
20 NPS	20 NPS	193.75 in ²			50-790 psi	Air	UD
20 NPS	20 NPS	193.75 in ²			50-790 psi	Water	UD
24 NPS	24 NPS	279 in ²			50-660 psi	Air	UD
24 NPS	24 NPS	279 in ²			50-660 psi	Water	UD
26 NPS	26 NPS	327.44 in ²			50-625 psi	Air	UD
26 NPS	26 NPS	327.44 in ²			50-625 psi	Water	UD
28 NPS	28 NPS	379.75 in ²			50-590 psi	Air	UD

28 NPS	28 NPS	379.75 in ²	50-590 psi	Water	UD
3 in	3 in	4.118 in ²	75-1000 psi	Air	UD
3 in	3 in	4.118 in ²	75-1000 psi	Water	UD
3 NPS	3 NPS	4.96 in ²	75-1309 psi	Air	UD
3 NPS	3 NPS	4.96 in ²	75-1309 psi	Water	UD
30 NPS	30 NPS	435.94 in ²	50-555 psi	Air	UD
30 NPS	30 NPS	435.94 in ²	50-555 psi	Water	UD
32 NPS	32 NPS	496 in ²	50-525 psi	Air	UD
32 NPS	32 NPS	496 in ²	50-525 psi	Water	UD
34 NPS	34 NPS	559.94 in ²	50-490 psi	Air	UD
34 NPS	34 NPS	559.94 in ²	50-490 psi	Water	UD
36 NPS	36 NPS	627.45 in ²	50-455 psi	Air	UD
36 NPS	36 NPS	627.45 in ²	50-455 psi	Water	UD
38 NPS	38 NPS	699.44 in ²	50-420 psi	Air	UD
38 NPS	38 NPS	699.44 in ²	50-420 psi	Water	UD
4 in	4 in	7.334 in ²	68-1000 psi	Air	UD
4 in	4 in	7.334 in ²	68-1000 psi	Water	UD
4 NPS	4 NPS	8 in ²	68-1088 psi	Air	UD
4 NPS	4 NPS	8 in ²	68-1088 psi	Water	UD
40 NPS	40 NPS	775 in ²	50-385 psi	Air	UD
40 NPS	40 NPS	775 in ²	50-385 psi	Water	UD
42 NPS	42 NPS	854.44 in ²	50-350 psi	Air	UD
42 NPS	42 NPS	854.44 in ²	50-350 psi	Water	UD
44 NPS	44 NPS	937.75 in ²	50-315 psi	Air	UD
44 NPS	44 NPS	937.75 in ²	50-315 psi	Water	UD
46 NPS	46 NPS	1024.94 in ²	50-280 psi	Air	UD
46 NPS	46 NPS	1024.94 in ²	50-280 psi	Water	UD
48 NPS	48 NPS	1116 in ²	50-245 psi	Air	UD
48 NPS	48 NPS	1116 in ²	50-245 psi	Water	UD
6 in	6 in	16.704 in ²	25-650 psi	Air	UD
6 in	6 in	16.704 in ²	25-650 psi	Water	UD
6 NPS	6 NPS	17.43 in ²	75-1980 psi	Air	UD
6 NPS	6 NPS	17.43 in ²	75-1980 psi	Water	UD
8 NPS	8 NPS	31 in ²	75-1650 psi	Air	UD
8 NPS	8 NPS	31 in ²	75-1650 psi	Water	UD

Design Name: OPR

NBCert # 88118

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	11/17/2027

Design Type

[Rupture Disk Device] OPR
HolderDesignation: HLD-REV
Capacity Tests: Sec. UD at National Board Testing Lab on March 25, 2003
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 1.190 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Elfab Limited {ELF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.766 in ²			50-1523 psi		UD
1.5 NPS		1.651 in ²			27-1523 psi		UD
10 NPS		65.248 in ²			5-720 psi		UD
12 NPS		95.006 in ²			5-720 psi		UD
14 NPS		125.982 in ²			4-261 psi		UD
16 NPS		171.545 in ²			4-150 psi		UD
18 NPS		213.795 in ²			4-135 psi		UD
2 NPS		2.789 in ²			14-1523 psi		UD
2.5 NPS		4.119 in ²			10-1305 psi		UD
20 NPS		259.735 in ²			4-131 psi		UD
24 NPS		372.075 in ²			4-131 psi		UD
26 NPS		424.74 in ²			4-131 psi		UD
28 NPS		492.6 in ²			4-131 psi		UD
3 NPS		6.722 in ²			7-1088 psi		UD
30 NPS		565.49 in ²			4-131 psi		UD
32 NPS		642.4 in ²			4-131 psi		UD
34 NPS		726.34 in ²			4-131 psi		UD
36 NPS		814.3 in ²			4-131 psi		UD
4 NPS		10.923 in ²			5-1440 psi		UD
40 NPS		1005.31 in ²			4-131 psi		UD
6 NPS		23.309 in ²			5-870 psi		UD
8 NPS		44.37 in ²			5-720 psi		UD

Emerson Asia Pacific PTE Ltd. (TSG)

Nameplate Abbreviation: ESPM

Singapore, 629361Singapore

This Company Manufactures or Assembles:

Design Name:	243/249/443/449/546/843/849/943/5046/50 49/8043/8049	NBCert #	01292
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	01/22/2026	

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
 Capacity Tests: Sec. UV at unknown lab on August 8, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name: 253/259/453/459/853/859/953/959/5059/8053/8059 NBCert # 01304

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/22/2026

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
 Capacity Tests: Sec. UV at unknown lab on July 31, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.627 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV

4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 263/269/463/469/566/863/869/963/969/5066/5069 NBCert # 01315

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/22/2026

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069

Capacity Tests: Sec. UV at unknown lab on July 30, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.860 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/22/2026

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.767 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

01/22/2026

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV

4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids) NBCert # 01348

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/22/2026

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids)
Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.712 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name: 81P (Liquids) NBCert # 01102

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/22/2026

Design Type

[Relief Valve] 81P (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: 93% of pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name:	900 Series (Liquid), 7700, SNC	NBCert #	15499
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/22/2026

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name:	900 Series, 7700, SNC	NBCert #	15411
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/22/2026

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/10/2030

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.656 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV

1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 10/10/2030

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV

2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/10/2030

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV

3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Emerson Automation Solutions Final Control (Shanghai) Co., Ltd. (SAG)

Nameplate Abbreviation: EMRC

Shanghai, 201712People's Republic of China

This Company Manufactures or Assembles:

Design Name: 243/249/443/449/546/843/849/943/5046/50
49/8043/8049 NBCert # 01292

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	09/18/2030

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
 Capacity Tests: Sec. UV at unknown lab on August 8, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name: 253/259/453/459/853/859/953/959/5059/8053/8059 NBCert # 01304

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	09/18/2030

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
 Capacity Tests: Sec. UV at unknown lab on July 31, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.627 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV

4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 263/269/463/469/566/863/869/963/969/5066/5069 NBCert # 01315

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/18/2030

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069

Capacity Tests: Sec. UV at unknown lab on July 30, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.860 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/18/2030

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.767 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	09/18/2030

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV

4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids) NBCert # 01348

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	09/18/2030

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids)
Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.712 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name: 5200 Series (Water K = 0.674) NBCert # 36458

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	03/04/2027

Design Type

[Pilot Operated Pressure Relief Valve] 5200 Series (Water K = 0.674)
Capacity Tests: Sec. UV, V at National Board Testing Lab on August 5, 2011
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; (alternate medium): 0.674 Unitless; Certification Provisions: Economizer Service (Prev. CC 2446)
Media - Test: Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Initial Audible Discharge; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.347 in ²	[F] 0.665 in	0.207 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.347 in ²	[F] 0.665 in	0.207 in	15-6170 psi	Steam	UV, V
1-1.5 NPS	2 - 3 NPS	0.347 in ²	[F] 0.665 in	0.207 in	15-6170 psi	Water	V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-6170 psi	Steam	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-6170 psi	Water	V
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.331 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.331 in	15-3705 psi	Steam	UV, V
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.331 in	15-3705 psi	Water	V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-3705 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-3705 psi	Water	V
2.5-3 NPS	4 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-3705 psi	Air	UV
2.5-3 NPS	4 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-3705 psi	Steam	UV, V
2.5-3 NPS	4 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-3705 psi	Water	V
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-3705 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-3705 psi	Water	V
4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2220 psi	Steam	UV, V
4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2220 psi	Water	V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Water	V
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	1.263 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	1.263 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	1.263 in	15-1480 psi	Water	V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Water	V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	2 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	2 in	15-1480 psi	Steam	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	2 in	15-1480 psi	Water	V
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	2.55 in	15-1480 psi	Air	UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	2.55 in	15-1480 psi	Steam	UV, V
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	2.55 in	15-1480 psi	Water	V

Design Name: 81, 81P, 83, 84		NBCert #	01089
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	09/18/2030
Design Type			
[Safety Relief Valve] 81, 81P, 83, 84 Capacity Tests: Sec. UV at unknown lab on July 8, 1965 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.816 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC} Comments: Type 81P and 84 have fixed blowdown.			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 81P (Liquids)		NBCert #	01102
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	05/30/2030
Design Type			
[Relief Valve] 81P (Liquids) Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.720 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: 93% of pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V

0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name:	900 Series (Liquid), 7700, SNC	NBCert #	15499
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/14/2029

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name:	900 Series, 7700, SNC	NBCert #	15411
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/14/2029

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: 9340/9390	NBCert # 01258
------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/26/2027

Design Type

[Pilot Operated Pressure Relief Valve] 9340/9390
Capacity Tests: Sec. UV at Crosby Valve, LLC on September 8, 1989
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.629 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	3 NPS	3.35 in ²	2.067 in	0.545 in	15-50 psi	Air	UV
3 NPS	4 NPS	7.39 in ²	3.068 in	0.8 in	15-50 psi	Air	UV
4 NPS	6 NPS	12.73 in ²	4.026 in	1.05 in	15-50 psi	Air	UV
6 NPS	8 NPS	28.89 in ²	6.065 in	1.619 in	15-50 psi	Air	UV
8 NPS	10 NPS	50 in ²	7.981 in	2.125 in	15-50 psi	Air	UV
10 NPS	12 NPS	78.85 in ²	10.02 in	2.675 in	15-50 psi	Air	UV
12 NPS	16 NPS	113 in ²	12 in	3.25 in	15-50 psi	Air	UV

Design Name: BP	NBCert # 15501
-----------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/14/2029

Design Type

[Safety Relief Valve] BP
Capacity Tests: Sec. UV at Crosby Valve, LLC on August 24, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.841 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.0539 in ²	[#4] 0.262 in	0.06 in	50-3000 psi	Air	UV
0.75-1 NPS	1 NPS	0.0929 in ²	[#5] 0.344 in	0.085 in	50-3000 psi	Air	UV
0.75-1 NPS	1 NPS	0.114 in ²	[#5A] 0.381 in	0.098 in	50-3000 psi	Air	UV
0.75-1 NPS	1 NPS	0.1364 in ²	[#6] 0.417 in	0.112 in	50-3000 psi	Air	UV

Design Name: BP (Liquids) NBCert # 15534

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/14/2029

Design Type

[Relief Valve] BP (Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on September 15, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.631 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.0539 in ²	[#4] 0.262 in	0.06 in	50-3000 psi	Water	UV, V
0.75-1 NPS	1 NPS	0.0929 in ²	[#5] 0.344 in	0.085 in	50-3000 psi	Water	UV, V
0.75-1 NPS	1 NPS	0.114 in ²	[#5A] 0.381 in	0.098 in	50-3000 psi	Water	UV, V
0.75-1 NPS	1 NPS	0.1364 in ²	[#6] 0.417 in	0.112 in	50-3000 psi	Water	UV, V

Design Name: H Series (HCI, HSJ, HCA, HA, HB, HC, HCB, HCP, HJO, HN, HNA, HNB, HNP, HS, NBCert # 15006
HSA, HSB, HSC, HSP)

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV, V

10/10/2026

Design Type

[Safety Valve] H Series (HCI, HSJ, HCA, HA, HB, HC, HCB, HCP, HJO, HN, HNA, HNB, HNP, HS, HSA, HSB, HSC, HSP)
Capacity Tests: Sec. UV, V at unknown lab on September 1, 1939
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1.5 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-500 psi	Steam	UV, V
0.75 NPS	1.5 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-500 psi	Steam	UV, V
1-1.5 NPS	2 - 3 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-3100 psi	Steam	UV, V
1-2 NPS	2.5, 3 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-3100 psi	Steam	UV, V
1.5-2 NPS	3, 4, 6 NPS	0.785 in ²	[H] 1 in	0.25 in	15-5000 psi	Steam	UV, V
1.5 NPS	3 NPS	0.865 in ²	1.05 in	0.262 in	15-3100 psi	Steam	UV, V
1.5 NPS	3 NPS	0.994 in ²	[H2] 1.125 in	0.281 in	15-3100 psi	Steam	UV, V
2-3 NPS	3, 4, 6 NPS	1.288 in ²	[J] 1.281 in	0.32 in	15-5000 psi	Steam	UV, V
2 NPS	4 NPS	1.431 in ²	[J2] 1.35 in	0.338 in	15-3100 psi	Steam	UV, V
2.5-3 NPS	4, 6 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-6000 psi	Steam	UV, V
2.5 NPS	6 NPS	2.545 in ²	[K2] 1.8 in	0.45 in	15-6800 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.476 in	15-3100 psi	Steam	UV, V
3 NPS	6 NPS	3.341 in ²	[L2] 2.062 in	0.516 in	15-3100 psi	Steam	UV, V
3-4 NPS	6, 8 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-6000 psi	Steam	UV, V
3 NPS	6, 8 NPS	3.976 in ²	[M2] 2.25 in	0.563 in	15-6000 psi	Steam	UV, V
4 NPS	6 NPS	4.341 in ²	[N] 2.351 in	0.588 in	15-3100 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.712 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	7.07 in ²	[P2] 3 in	0.75 in	15-3100 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.937 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	12.25 in ²	[Q2] 3.95 in	0.988 in	15-3100 psi	Steam	UV, V
6 NPS	8, 10 NPS	16 in ²	[R] 4.513 in	1.128 in	15-3100 psi	Steam	UV, V
6 NPS	10 NPS	19.29 in ²	[RR] 4.956 in	1.239 in	15-3100 psi	Steam	UV, V
8 NPS	10, 12 NPS	26 in ²	[T] 5.75 in	1.437 in	15-500 psi	Steam	UV, V
8 NPS	12, 14 NPS	28.274 in ²	6 in	1.5 in	15-2000 psi	Steam	UV, V
10 NPS	14 NPS	44.18 in ²	7.5 in	1.875 in	15-500 psi	Steam	UV, V
12 NPS	16 NPS	63.62 in ²	9 in	2.25 in	15-500 psi	Steam	UV, V
14 NPS	18 NPS	86.59 in ²	10.5 in	2.625 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	95.21 in ²	11.01 in	2.753 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	114.04 in ²	12.05 in	3.02 in	15-500 psi	Steam	UV, V
18 NPS	24 NPS	143.14 in ²	13.5 in	3.375 in	15-500 psi	Steam	UV, V
20 NPS	24 NPS	176.71 in ²	15 in	3.75 in	15-500 psi	Steam	UV, V

Design Name: H Series (Restricted Lift version of Cert # 15006)				NBCert # 15567	
Manufacturer/Assembler			Designators		Expiration Date
Manufacturer			V		03/04/2027

Design Type

[Safety Valve] H Series (Restricted Lift version of Cert # 15006)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 6, 1996
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Restricted Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1.5 NPS	0.11 in ²	[D] 0.375 in	0.08 in	15-500 psi	Steam	UV, V
0.75 NPS	1.5 NPS	0.196 in ²	[E] 0.5 in	0.08 in	15-500 psi	Steam	UV, V
1-1.5 NPS	2, 2.5, 3 NPS	0.307 in ²	[F] 0.625 in	0.08 in	15-3100 psi	Steam	UV, V
1-2 NPS	2.5, 3 NPS	0.503 in ²	[G] 0.8 in	0.08 in	15-3100 psi	Steam	UV, V
1.5-2 NPS	3, 4 NPS	0.785 in ²	[H] 1 in	0.08 in	15-3100 psi	Steam	UV, V
1.5 NPS	3 NPS	0.865 in ²	1.05 in	0.08 in	15-3100 psi	Steam	UV, V
1.5 NPS	3 NPS	0.994 in ²	[H2] 1.125 in	0.084 in	15-3100 psi	Steam	UV, V
2-3 NPS	3,4,6 NPS	1.288 in ²	[J] 1.281 in	0.096 in	15-5000 psi	Steam	UV, V
2 NPS	4 NPS	1.431 in ²	[J2] 1.35 in	0.101 in	15-3100 psi	Steam	UV, V
2.5-3 NPS	4, 6 NPS	1.84 in ²	[K] 1.531 in	0.115 in	15-3100 psi	Steam	UV, V
2.5 NPS	6 NPS	2.545 in ²	[K2] 1.8 in	0.135 in	15-3100 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-3100 psi	Steam	UV, V
3 NPS	6 NPS	3.341 in ²	[L2] 2.062 in	0.155 in	15-3100 psi	Steam	UV, V
3-4 NPS	6 NPS	3.6 in ²	[M] 2.14 in	0.161 in	15-5000 psi	Steam	UV, V
3 NPS	6 NPS	3.976 in ²	[M2] 2.25 in	0.169 in	15-3100 psi	Steam	UV, V
4 NPS	6 NPS	4.341 in ²	[N] 2.351 in	0.176 in	15-3100 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.213 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	7.07 in ²	[P2] 3 in	0.225 in	15-3100 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.281 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	12.25 in ²	[Q2] 3.95 in	0.296 in	15-3100 psi	Steam	UV, V
6 NPS	8, 10 NPS	16 in ²	[R] 4.513 in	0.338 in	15-1200 psi	Steam	UV, V
6 NPS	10 NPS	19.29 in ²	[RR] 4.956 in	0.371 in	15-3100 psi	Steam	UV, V
8 NPS	10, 12 NPS	26 in ²	[T] 5.75 in	0.431 in	15-500 psi	Steam	UV, V
8 NPS	12, 14 NPS	28.274 in ²	6 in	0.45 in	15-2000 psi	Steam	UV, V
10 NPS	14 NPS	44.18 in ²	7.5 in	0.562 in	15-500 psi	Steam	UV, V
12 NPS	16 NPS	63.62 in ²	9 in	0.675 in	15-500 psi	Steam	UV, V
14 NPS	18 NPS	86.59 in ²	10.5 in	0.787 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	95.21 in ²	11.01 in	0.826 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	114.04 in ²	12.05 in	0.906 in	15-500 psi	Steam	UV, V
18 NPS	24 NPS	143.14 in ²	13.5 in	1.012 in	15-500 psi	Steam	UV, V
20 NPS	24 NPS	176.71 in ²	15 in	1.125 in	15-500 psi	Steam	UV, V

Design Name: HE			NBCert # 15039				
Manufacturer/Assembler		Designators		Expiration Date			
Manufacturer		V		08/31/2026			
Design Type							
[Safety Valve] HE							
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 15, 1970							
Method of Establishing Relieving Capacity: Flow Capacity, K							
Certified Value: 0.877 Unitless							
Media - Test: Steam; Certified: Steam							
Set Pressure Definition: Pop							
Blowdown Characteristics: Adjustable (Dual Ring)							
Flow Area Configuration: Nozzle/Full Lift							
Designed by: Emerson Automation Solutions Final Control US LP {AGC}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5 NPS	0.307 in²	0.625 in	0.156 in	15-3100 psi	Steam	NV, V
1.5 NPS	2.5 NPS	0.503 in²	0.8 in	0.2 in	15-3100 psi	Steam	NV, V
1.5 NPS	3 NPS	0.785 in²	[H] 1 in	0.25 in	15-3100 psi	Steam	NV, V
2 NPS	4 NPS	1.288 in²	[J] 1.281 in	0.32 in	15-3100 psi	Steam	NV, V
2.5 NPS	6 NPS	1.84 in²	[K] 1.531 in	0.382 in	15-3100 psi	Steam	NV, V
2.5 NPS	6 NPS	2.545 in²	[K2] 1.8 in	0.45 in	15-3100 psi	Steam	NV, V
3 NPS	6 NPS	3.6 in²	[M] 2.14 in	0.535 in	15-3100 psi	Steam	NV, V
3 NPS	6 NPS	3.976 in²	[M2] 2.25 in	0.562 in	15-3100 psi	Steam	NV, V
4 NPS	6 NPS	6.38 in²	2.85 in	0.712 in	15-3100 psi	Steam	NV, V
4 NPS	6, 8 NPS	7.069 in²	[P2] 3 in	0.75 in	15-3100 psi	Steam	NV, V
6 NPS	8 NPS	11.045 in²	3.75 in	0.937 in	15-3100 psi	Steam	NV, V
6-8 NPS	8, 10 NPS	16 in²	[R] 4.513 in	1.128 in	15-1500 psi	Steam	NV, V
8 NPS	10, 12, 14 NPS	19.369 in²	[R3] 4.966 in	1.242 in	15-3100 psi	Steam	NV, V
8 NPS	10, 12, 14 NPS	21.1 in²	[R5] 5.183 in	1.295 in	15-3100 psi	Steam	NV, V
8 NPS	14 NPS	22 in²	[R6] 5.295 in	1.324 in	15-3100 psi	Steam	NV, V
10 NPS	16 NPS	36.4 in²	[T2] 6.808 in	1.707 in	15-3100 psi	Steam	NV, V

Design Name: HL, HSL		NBCert #	15589
Manufacturer/Assembler	Designators		Expiration Date
Manufacturer	UV, V		10/09/2026
Design Type			
[Safety Valve] HL, HSL Capacity Tests: Sec. UV, V at Crosby Valve, LLC on November 3, 1999 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.869 Unitless Media - Test: Steam; Certified: Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	1.5 NPS	0.339 in ²	[F] 0.657 in	0.164 in	15-725 psi	Steam	UV, V
1.25-2 NPS	1.5 NPS	0.553 in ²	[G] 0.839 in	0.21 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.868 in ²	[H] 1.051 in	0.263 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.327 in ²	[J] 1.3 in	0.325 in	15-725 psi	Steam	UV, V
2-3 NPS	3-4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-725 psi	Steam	UV, V
2.5-4 NPS	4-6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-725 psi	Steam	UV, V
3 NPS	4-6 NPS	3.955 in ²	[M] 2.244 in	0.561 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	4.831 in ²	[N] 2.48 in	0.62 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	7.031 in ²	[P] 2.992 in	0.748 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[QQ] 3.75 in	0.937 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	0.984 in	15-725 psi	Steam	UV, V

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	02/14/2029

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V

3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

02/14/2029

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV

6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name:	JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Liquids) (Restricted lift version of Certification 15095)	NBCert #	01393
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 01/17/2029

Design Type

[Safety Relief Valve] JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Liquids) (Restricted lift version of Certification 15095)

Capacity Tests: Sec. NV, UV, V at unknown lab on October 14, 2015

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.656 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Restricted Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.137 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.137 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	0.493 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.616 in	15-1480 psi	Water	UV, V

6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Water	UV, V

Design Name:	JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Restricted Lift version of Certification 15512)	NBCert #	01382
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/17/2029

Design Type

[Safety Relief Valve] JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Restricted Lift version of Certification 15512)
Capacity Tests: Sec. UV at unknown lab on October 13, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.6949 in ²	0.892 in	0.137 in	15-2500 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	0.493 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.616 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Air	UV

Design Name:	JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB	NBCert #	15208
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 08/14/2029

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.865 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV

6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Design Name: JOS-E-RL/JBS-E-RL/JDS-E-RL (Restricted Lift version of cert 15208) NBCert # 01045

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 07/24/2029

Design Type

[Safety Relief Valve] JOS-E-RL/JBS-E-RL/JDS-E-RL (Restricted Lift version of cert 15208)

Capacity Tests: Sec. UV at unknown lab on May 26, 2015

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.865 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable (Single Ring)

Flow Area Configuration: Restricted Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-15000 psi	Air	UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.08 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.08 in	15-15000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.08 in	15-15000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.08 in	15-2000 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.08 in	15-15000 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.08 in	15-2000 psi	Steam	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.099 in	15-15000 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.099 in	15-2000 psi	Steam	UV

2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.127 in	15-10000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.127 in	15-2000 psi	Steam	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.152 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.152 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.18 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.18 in	15-3000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.189 in	15-2000 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.189 in	15-5000 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.213 in	15-2000 psi	Steam	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.213 in	15-5000 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.234 in	15-1480 psi	Steam	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.234 in	15-3000 psi	Air	UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.255 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.255 in	15-2250 psi	Steam	UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.284 in	15-1480 psi	Steam	UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.284 in	15-3000 psi	Air	UV
6 NPS	8 NPS	11.045 in ²	3.75 in	0.373 in	15-1000 psi	Steam	UV
6 NPS	8 NPS	11.045 in ²	3.75 in	0.373 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.174 in ²	3.937 in	0.373 in	15-2250 psi	Air	UV
6 NPS	8 NPS	12.174 in ²	3.937 in	0.373 in	15-2250 psi	Steam	UV
6 NPS	10 NPS	12.236 in ²	3.947 in	0.449 in	15-2250 psi	Air	UV
6 NPS	10 NPS	12.236 in ²	3.947 in	0.449 in	15-2250 psi	Steam	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.373 in	15-1480 psi	Steam	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.373 in	15-3000 psi	Air	UV
6 NPS	8 NPS	15.288 in ²	4.412 in	0.424 in	15-2250 psi	Air	UV
6 NPS	8 NPS	15.288 in ²	4.412 in	0.424 in	15-2250 psi	Steam	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.449 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.449 in	15-1480 psi	Steam	UV
8 NPS	10 NPS	18.254 in ²	4.821 in	0.572 in	15-2250 psi	Air	UV
8 NPS	10 NPS	18.254 in ²	4.821 in	0.572 in	15-2250 psi	Steam	UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	0.572 in	15-740 psi	Air	UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	0.572 in	15-740 psi	Steam	UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	0.592 in	15-740 psi	Air	UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	0.592 in	15-740 psi	Steam	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	0.731 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	0.731 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	0.933 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	0.933 in	15-325 psi	Steam	UV

Design Name:	Kunkle 6000, 6252 Series	NBCert #	36324
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV, V	09/11/2030
--------------	-------	------------

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V

4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 6933, 6934, 6935, 6254 NBCert # 36313

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer HV 09/11/2030

Design Type

[Safety Valve] Kunkle 6933, 6934, 6935, 6254
Capacity Tests: Sec. HV at unknown lab on October 31, 1984
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: (HV) Low Pressure Steam
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-15 psi	Steam	HV
0.75-1 NPS	1 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-15 psi	Steam	HV
1-1.25 NPS	1.25 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-15 psi	Steam	HV
1.25-1.5 NPS	1.5 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-15 psi	Steam	HV
1.5-2 NPS	2 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-15 psi	Steam	HV
1.5-2.5 NPS	2.5 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-15 psi	Steam	HV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-15 psi	Steam	HV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-15 psi	Steam	HV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-15 psi	Steam	HV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-15 psi	Steam	HV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-15 psi	Steam	HV

Design Name: Kunkle 910 to 919 NBCert # 36100

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/11/2030

Design Type

[Safety Relief Valve] Kunkle 910 to 919
 Capacity Tests: Sec. UV at unknown lab on May 19, 1969
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name: Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid) NBCert # 36111

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	09/11/2030

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
 Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.710 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

Design Name:	Kunkle 920, 921, 927, Agco A (High Temp. water)	NBCert #	36098
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		V	09/11/2030

Design Type

[Safety Valve] Kunkle 920, 921, 927, Agco A (High Temp. water)
Capacity Tests: Sec. V at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Forced Flow Steam Generator/High Temp Hot Water (10% BD)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	V

Emerson Automation Solutions Final Control UK, Ltd. (BRK)

Lancashire, M28 3NAUnited Kingdom

This Company Manufactures or Assembles:

Design Name:	20F (Liquid) (B, C, 4, 5, 8, 9 pilots) 4FF3, 4FF9, 8FF3, 8FF9	NBCert #	06107
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	05/16/2029

Design Type

[Pilot Operated Pressure Relief Valve] 20F (Liquid) (B, C, 4, 5, 8, 9 pilots) 4FF3, 4FF9, 8FF3, 8FF9
Capacity Tests: Sec. UV at National Board Testing Lab on October 15, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.696 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.338 in ²	[F] 0.656 in	0.21 in	29-6170 psi	Water	UV
1.5 NPS	3 NPS	0.871 in ²	[H] 1.053 in	0.3 in	29-6170 psi	Water	UV
2 NPS	3 NPS	1.427 in ²	[J] 1.348 in	0.38 in	29-6170 psi	Water	UV
3 NPS	4 NPS	3.167 in ²	[L] 2.008 in	0.668 in	29-3705 psi	Water	UV

4 NPS	6 NPS	7.068 in ²	[P] 3 in	1 in	29-3705 psi	Water	UV
6 NPS	8 NPS	17.758 in ²	[R] 4.755 in	1.584 in	29-1480 psi	Water	UV
8 NPS	10 NPS	28.86 in ²	[T] 6.062 in	2.021 in	29-1480 psi	Water	UV

Design Name:	20F(2,4,5,8,9 pilots) 2FF3, 2FF9, 4FF3, 4FF9, 8FF3, 8FF9	NBCert #	06118
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/16/2029

Design Type

[Pilot Operated Pressure Relief Valve] 20F(2,4,5,8,9 pilots) 2FF3, 2FF9, 4FF3, 4FF9, 8FF3, 8FF9
Capacity Tests: Sec. UV at National Board Testing Lab on October 16, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.849 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.338 in ²	[F] 0.656 in	0.164 in	26-6170 psi	Air	UV
1.5 NPS	3 NPS	0.871 in ²	[H] 1.053 in	0.264 in	26-6170 psi	Air	UV
2 NPS	3 NPS	1.427 in ²	[J] 1.348 in	0.337 in	26-6170 psi	Air	UV
3 NPS	4 NPS	3.167 in ²	[L] 2.008 in	0.585 in	26-3705 psi	Air	UV
4 NPS	6 NPS	7.068 in ²	[P] 3 in	0.875 in	26-3705 psi	Air	UV
6 NPS	8 NPS	17.758 in ²	[R] 4.755 in	1.386 in	26-1480 psi	Air	UV
8 NPS	10 NPS	28.86 in ²	[T] 6.062 in	1.768 in	26-1480 psi	Air	UV

Design Name:	20R (2,4,5,8,9 pilots) 2FR3, 2FR9, 4FR3, 4FR9, 8FR3, 8FR9	NBCert #	06129
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/16/2029

Design Type

[Pilot Operated Pressure Relief Valve] 20R (2,4,5,8,9 pilots) 2FR3, 2FR9, 4FR3, 4FR9, 8FR3, 8FR9
Capacity Tests: Sec. UV at National Board Testing Lab on October 15, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.849 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1945)
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.164 in ²	[D] 0.656 in	0.08 in	26-6170 psi	Air	UV
1-1.5 NPS	2 NPS	0.256 in ²	[E] 0.656 in	0.125 in	26-6170 psi	Air	UV
1.5 NPS	3 NPS	0.616 in ²	[G] 1.053 in	0.186 in	26-6170 psi	Air	UV
2 NPS	3 NPS	0.616 in ²	[G] 1.348 in	0.145 in	15-6170 psi	Air	UV
2 NPS	3 NPS	0.871 in ²	[H] 1.348 in	0.205 in	15-6170 psi	Air	UV
3 NPS	4 NPS	2.139 in ²	[K] 2.008 in	0.394 in	15-3705 psi	Air	UV

3 NPS	4 NPS	1.427 in ²	[J] 2.008 in	0.264 in	26-3705 psi	Air	UV
4 NPS	6 NPS	3.167 in ²	[L] 3 in	0.392 in	26-3705 psi	Air	UV
4 NPS	6 NPS	4.307 in ²	[M] 3 in	0.532 in	15-3705 psi	Air	UV
4 NPS	6 NPS	5.162 in ²	[N] 3 in	0.638 in	15-3705 psi	Air	UV
6 NPS	8 NPS	12.864 in ²	[Q] 4.755 in	1.003 in	26-1480 psi	Air	UV
8 NPS	10 NPS	22.118 in ²	[S] 6.062 in	0.531 in	26-1480 psi	Air	UV

Design Name: 20R (Liquid) (4, 5, 8, 9 pilots) 4FR3, 4FR9, 8FR3, 8FR9 NBCert # 06095

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/16/2029

Design Type

[Pilot Operated Pressure Relief Valve] 20R (Liquid) (4, 5, 8, 9 pilots) 4FR3, 4FR9, 8FR3, 8FR9
Capacity Tests: Sec. UV at National Board Testing Lab on October 15, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.696 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1945)
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.164 in ²	[D] 0.656 in	0.102 in	29-6170 psi	Water	UV
1-1.5 NPS	2 NPS	0.256 in ²	[E] 0.656 in	0.159 in	15-6170 psi	Water	UV
1.5-1.5 NPS	3 NPS	0.616 in ²	[G] 1.053 in	0.212 in	29-6170 psi	Water	UV
2 NPS	3 NPS	0.871 in ²	[H] 1.348 in	0.232 in	15-6170 psi	Water	UV
2 NPS	3 NPS	0.616 in ²	[G] 1.348 in	0.163 in	15-6170 psi	Water	UV
3 NPS	4 NPS	2.139 in ²	[K] 2.008 in	0.451 in	15-3705 psi	Water	UV
3 NPS	4 NPS	1.427 in ²	[J] 2.008 in	0.301 in	29-3705 psi	Water	UV
4 NPS	6 NPS	3.167 in ²	[L] 3 in	0.448 in	29-3705 psi	Water	UV
4 NPS	6 NPS	4.307 in ²	[M] 3 in	0.609 in	29-1480 psi	Water	UV
4 NPS	6 NPS	5.162 in ²	[N] 3 in	0.73 in	15-1480 psi	Water	UV
6 NPS	8 NPS	12.864 in ²	[Q] 4.755 in	1.147 in	29-1480 psi	Water	UV
8 NPS	10 NPS	22.118 in ²	[S] 6.062 in	1.548 in	15-1480 psi	Water	UV

Design Name: 243/249/443/449/546/843/849/943/5046/5049/8043/8049 NBCert # 01292

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 08/19/2026

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
Capacity Tests: Sec. UV at unknown lab on August 8, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name: 253/259/453/459/853/859/953/959/5059/8053/8059 NBCert # 01304

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

08/19/2026

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
Capacity Tests: Sec. UV at unknown lab on July 31, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.627 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name:	263/269/463/469/566/863/869/963/969/5066/5069	NBCert #	01315
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/19/2026

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069
Capacity Tests: Sec. UV at unknown lab on July 30, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name:	443/449/546/843/849/943/949/5046/5049 (Liquids)	NBCert #	01337
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	07/22/2026

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.767 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

07/22/2026

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV

4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids) NBCert # 01348

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	07/22/2026

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids)
Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.712 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name: 746-1, JCE/1 NBCert # 06062

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/13/2028

Design Type

[Safety Relief Valve] 746-1, JCE/1
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on December 13, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.738 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1 NPS	1.5 NPS	0.644 in ²	0.906 in	0.227 in	15-580 psi	Air	UV
1-1 NPS	1.5 NPS	0.644 in ²	0.906 in	0.227 in	15-580 psi	Steam	UV
1.25-1.25 NPS	2 NPS	1.024 in ²	1.142 in	0.285 in	15-580 psi	Air	UV
1.25-1.25 NPS	2 NPS	1.024 in ²	1.142 in	0.285 in	15-580 psi	Steam	UV
1.5-1.5 NPS	2.5 NPS	1.667 in ²	1.457 in	0.364 in	15-580 psi	Air	UV
1.5-1.5 NPS	2.5 NPS	1.667 in ²	1.457 in	0.364 in	15-580 psi	Steam	UV
2-2 NPS	3 NPS	2.576 in ²	1.811 in	0.453 in	15-580 psi	Air	UV
2-2 NPS	3 NPS	2.576 in ²	1.811 in	0.453 in	15-580 psi	Steam	UV
2.5-2.5 NPS	4 NPS	4.382 in ²	2.362 in	0.59 in	15-507 psi	Air	UV
2.5-2.5 NPS	4 NPS	4.382 in ²	2.362 in	0.59 in	15-507 psi	Steam	UV
3-3 NPS	4 NPS	6.664 in ²	2.913 in	0.728 in	15-464 psi	Air	UV
3-3 NPS	4 NPS	6.664 in ²	2.913 in	0.728 in	15-464 psi	Steam	UV
4-4 NPS	6 NPS	10.303 in ²	3.622 in	0.905 in	15-362 psi	Air	UV
4-4 NPS	6 NPS	10.303 in ²	3.622 in	0.905 in	15-362 psi	Steam	UV

Design Name: 746-3, JCE/3 (Liquids) NBCert # 06073

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/12/2028

Design Type

[Relief Valve] 746-3, JCE/3 (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on December 13, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.482 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1 NPS	1.5 NPS	0.644 in ²	0.906 in	0.227 in	15-580 psi	Water	UV
1.25-1.25 NPS	2 NPS	1.024 in ²	1.142 in	0.285 in	15-580 psi	Water	UV
1.5-1.5 NPS	2.5 NPS	1.667 in ²	1.457 in	0.364 in	15-580 psi	Water	UV
2-2 NPS	3 NPS	2.576 in ²	1.811 in	0.453 in	15-580 psi	Water	UV
2.5-2.5 NPS	4 NPS	4.382 in ²	2.362 in	0.59 in	15-507 psi	Water	UV
3-3 NPS	4 NPS	6.664 in ²	2.913 in	0.728 in	15-464 psi	Water	UV
4-4 NPS	6 NPS	10.303 in ²	3.622 in	0.905 in	15-362 psi	Water	UV

Design Name: 776 NBCert # 06185

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/05/2026

Design Type

[Safety Relief Valve] 776
Capacity Tests: Sec. UV at National Board Testing Lab on February 6, 2004
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.737 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.169 in ²	0.464 in	0.116 in	15-600 psi	Air	UV
0.75-1 NPS	1.25 NPS	0.486 in ²	0.787 in	0.196 in	15-560 psi	Air	UV
1.25 NPS	1.5 NPS	0.644 in ²	0.906 in	0.226 in	15-500 psi	Air	UV
1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.286 in	15-500 psi	Air	UV
2 NPS	2.5 NPS	1.666 in ²	1.456 in	0.364 in	15-450 psi	Air	UV

Design Name: 81, 81P, 83, 84 NBCert # 01089

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

08/19/2026

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name:	81P (Liquids)	NBCert #	01102
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 10/31/2026

Design Type

[Relief Valve] 81P (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: 93% of pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name:	900 Series (Liquid), 7700, SNC	NBCert #	15499
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 08/19/2026

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV

1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name:	900 Series, 7700, SNC	NBCert #	15411
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 08/19/2026

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name:	B Series	NBCert #	06006
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/15/2025

Design Type

[Safety Valve] B Series
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on February 9, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.857 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.062 in ²	0.281 in	0.07 in	15-5000 psi	Air	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.094 in	15-3600 psi	Air	UV
1 NPS	1.5 NPS	0.196 in ²	0.5 in	0.125 in	15-5000 psi	Air	UV
1.5 NPS	2 NPS	0.442 in ²	0.75 in	0.187 in	15-2500 psi	Air	UV

Design Name:	C Series	NBCert #	06017
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/18/2025

Design Type

[Relief Valve] C Series
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on December 8, 1987
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.509 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.062 in ²	0.281 in	0.07 in	15-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.093 in	15-3600 psi	Water	UV
1 NPS	1.5 NPS	0.196 in ²	0.5 in	0.125 in	15-5000 psi	Water	UV
1.5 NPS	2 NPS	0.442 in ²	0.75 in	0.187 in	15-2500 psi	Water	UV

Design Name:	D Series (Liquids), 716H7	NBCert #	06141
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/07/2026

Design Type

[Safety Relief Valve] D Series (Liquids), 716H7
Capacity Tests: Sec. UV at National Board Testing Lab on December 7, 1999
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.250 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.169 in ²	0.464 in	0.116 in	15-740 psi	Water	UV

Design Name:	D Series, 716H7	NBCert #	06130
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/07/2026

Design Type

[Safety Relief Valve] D Series, 716H7
Capacity Tests: Sec. UV at National Board Testing Lab on December 7, 1999
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.550 SCFM/PSIA; (alternate medium): 7.160 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.169 in ²	0.464 in	0.116 in	15-740 psi	Air	UV
0.5-1 NPS	1 NPS	0.169 in ²	0.464 in	0.116 in	15-740 psi	Steam	UV

Design Name: FBCSR NBCert # 81087

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

07/01/2027

Design Type

[Rupture Disk Device] FBCSR
Capacity Tests: Sec. UD at National Board Testing Lab on December 16, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.600 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			21.8-15000 psi		UD
1.5 NPS		2.03 in ²			14.5-10000 psi		UD
10 NPS		78.8 in ²			2.9-1250 psi		UD
12 NPS		112.9 in ²			2.9-1000 psi		UD
2 NPS		3.35 in ²			10.9-7500 psi		UD
2.5 NPS		4.78 in ²			9.4-6000 psi		UD
3 NPS		7.39 in ²			7.3-5000 psi		UD
4 NPS		12.73 in ²			5.1-3500 psi		UD
6 NPS		28.89 in ²			4.3-2250 psi		UD
8 NPS		50.02 in ²			3.6-1650 psi		UD

Design Name: FBCSV NBCert # 81076

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

12/09/2027

Design Type

[Rupture Disk Device] FBCSV
 HolderDesignation: CST, CSB, CSB-T
 Capacity Tests: Sec. UD at National Board Testing Lab on December 16, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 1.200 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			21.8-15000 psi		UD
1.5 NPS		2.03 in ²			14.5-10000 psi		UD
10 NPS		78.8 in ²			2.9-1250 psi		UD
12 NPS		112.9 in ²			2.9-1000 psi		UD
14 NPS		137.6 in ²			2.1-825 psi		UD
16 NPS		182.4 in ²			1.7-700 psi		UD
18 NPS		233.4 in ²			1.4-600 psi		UD
2 NPS		3.35 in ²			10.9-7500 psi		UD
2.5 NPS		4.78 in ²			9.4-6000 psi		UD
20 NPS		290.7 in ²			1-500 psi		UD
24 NPS		425 in ²			1-400 psi		UD
28 NPS		582 in ²			1-300 psi		UD
3 NPS		7.39 in ²			7.3-5000 psi		UD
30 NPS		671 in ²			1-250 psi		UD
32 NPS		767 in ²			1-200 psi		UD
36 NPS		975 in ²			1-150 psi		UD
4 NPS		12.73 in ²			5.1-3500 psi		UD
40 NPS		1209 in ²			1-110 psi		UD
44 NPS		1470 in ²			1-80 psi		UD
48 NPS		1752 in ²			1-50 psi		UD
6 NPS		28.89 in ²			4.3-2250 psi		UD
8 NPS		50.02 in ²			3.6-1650 psi		UD

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/19/2026

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.656 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/19/2026

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name:	JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Liquids) (Restricted lift version of Certification 15095)	NBCert #	01393
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/09/2027

Design Type

[Safety Relief Valve] JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Liquids) (Restricted lift version of Certification 15095)
Capacity Tests: Sec. NV, UV, V at unknown lab on October 14, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Water	UV, V

1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.137 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.137 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	0.493 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.616 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Water	UV, V

Design Name:	JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Restricted Lift version of Certification 15512)	NBCert #	01382
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/09/2027

Design Type

[Safety Relief Valve] JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Restricted Lift version of Certification 15512)
Capacity Tests: Sec. UV at unknown lab on October 13, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Air	UV

1.5-2 NPS	3 NPS	0.6949 in ²	0.892 in	0.137 in	15-2500 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	0.493 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.616 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 08/22/2026

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV

4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Design Name: LRB		NBCert #	81009
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	06/25/2027

Design Type

[Rupture Disk Device] LRB
 HolderDesignation: RBH, RBH-T
 Capacity Tests: Sec. UD at National Board Testing Lab on December 4, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 1.000 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			29-5500 psi		UD
1.5 NPS		2.04 in ²			26-5500 psi		UD
10 NPS		77.72 in ²			14.5-600 psi		UD
12 NPS		113.1 in ²			14.5-500 psi		UD
14 NPS		137.9 in ²			14.5-400 psi		UD
16 NPS		182.7 in ²			14.5-300 psi		UD
18 NPS		233.7 in ²			14.5-250 psi		UD
2 NPS		3.36 in ²			23-5500 psi		UD
2.5 NPS		4.79 in ²			20-2500 psi		UD
20 NPS		291 in ²			14.5-200 psi		UD
3 NPS		7.39 in ²			18-1750 psi		UD
4 NPS		12.73 in ²			14.5-1300 psi		UD
6 NPS		28.89 in ²			14.5-900 psi		UD
8 NPS		50.03 in ²			14.5-750 psi		UD

Design Name: LRF

NBCert # 81133

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	07/09/2027

Design Type

[Rupture Disk Device] LRF
 HolderDesignation: RBH, RBH-T
 Capacity Tests: Sec. UD at National Board Testing Lab on March 4, 2010
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 1.390 Unitless
 Media - Test: Air/Gas; Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.85 in ²			130-5500 psi		UD
1.5 NPS		2 in ²			105-5500 psi		UD
10 NPS		76.97 in ²			45-600 psi		UD
12 NPS		110.5 in ²			45-500 psi		UD
14 NPS		135 in ²			45-400 psi		UD
16 NPS		178.9 in ²			45-300 psi		UD
18 NPS		228.9 in ²			45-250 psi		UD

2 NPS	3.28 in ²	75-5500 psi	UD
2.5 NPS	4.67 in ²	79-3750 psi	UD
20 NPS	285.1 in ²	45-200 psi	UD
3 NPS	7.25 in ²	65-2625 psi	UD
4 NPS	12.42 in ²	55-1950 psi	UD
6 NPS	28.28 in ²	45-900 psi	UD
8 NPS	48.93 in ²	45-750 psi	UD

Design Name:	RBF	NBCert #	81100
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 11/13/2025

Design Type

[Rupture Disk Device] RBF
HolderDesignation: RBH
Capacity Tests: Sec. UD at National Board Testing Lab on December 16, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 1.000 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.85 in ²			29-5500 psi		UD
1.5 NPS		2 in ²			26-5500 psi		UD
10 NPS		76.97 in ²			14.5-600 psi		UD
12 NPS		110.45 in ²			14.5-500 psi		UD
14 NPS		134.96 in ²			14.5-400 psi		UD
16 NPS		178.9 in ²			14.5-300 psi		UD
18 NPS		228.9 in ²			14.5-250 psi		UD
2 NPS		3.28 in ²			23-5500 psi		UD
2.5 NPS		4.67 in ²			20-3750 psi		UD
20 NPS		285.1 in ²			14.5-200 psi		UD
3 NPS		7.25 in ²			18-2625 psi		UD
4 NPS		12.42 in ²			18-1950 psi		UD
6 NPS		28.28 in ²			14.5-900 psi		UD
8 NPS		48.93 in ²			14.5-750 psi		UD

Design Name:	RBH	NBCert #	81010
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 07/07/2027

Design Type

[Rupture Disk Device] RBH
 HolderDesignation: RBH, RBH-T
 Capacity Tests: Sec. UD at National Board Testing Lab on December 4, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.500 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.3 in ²			87-5500 psi		UD
0.75 NPS		0.53 in ²			87-5500 psi		UD
1 NPS		0.86 in ²			29-5500 psi		UD
1.5 NPS		2.04 in ²			26-5500 psi		UD
10 NPS		77.72 in ²			14.5-600 psi		UD
12 NPS		113.1 in ²			14.5-500 psi		UD
14 NPS		137.9 in ²			14.5-400 psi		UD
16 NPS		182.7 in ²			14.5-300 psi		UD
18 NPS		233.7 in ²			14.5-250 psi		UD
2 NPS		3.36 in ²			23-5500 psi		UD
2.5 NPS		4.79 in ²			20-3750 psi		UD
20 NPS		291 in ²			14.5-200 psi		UD
3 NPS		7.39 in ²			18-2625 psi		UD
4 NPS		12.73 in ²			14.5-1950 psi		UD
6 NPS		28.89 in ²			14.5-900 psi		UD
8 NPS		50.03 in ²			14.5-750 psi		UD

Design Name: WB 100/200 (Liquids)

NBCert #

06028

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/15/2025

Design Type

[Relief Valve] WB 100/200 (Liquids)
 Capacity Tests: Sec. UV at unknown lab on November 7, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.588 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.121 in ²	[D] 0.393 in	0.098 in	15-6000 psi	Water	UV
1-1.5 NPS	2, 3 NPS	0.216 in ²	[E] 0.524 in	0.132 in	15-6000 psi	Water	UV
1.5 NPS	2, 3 NPS	0.338 in ²	[F] 0.656 in	0.164 in	15-5000 psi	Water	UV
1.5-2 NPS	3 NPS	0.558 in ²	[G] 0.843 in	0.211 in	15-3600 psi	Water	UV
1.5-2 NPS	3 NPS	0.871 in ²	[H] 1.053 in	0.263 in	15-3000 psi	Water	UV

2-3 NPS	3, 4 NPS	1.429 in ²	[J] 1.349 in	0.337 in	15-3000 psi	Water	UV
3 NPS	4, 6 NPS	2.04 in ²	[K] 1.611 in	0.403 in	15-2500 psi	Water	UV
3-4 NPS	4, 6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-1500 psi	Water	UV
4 NPS	6 NPS	3.986 in ²	[M] 2.255 in	0.564 in	15-1200 psi	Water	UV
4 NPS	6 NPS	4.817 in ²	[N] 2.476 in	0.619 in	15-1000 psi	Water	UV
4 NPS	6 NPS	7.082 in ²	[P] 3.003 in	0.751 in	15-1000 psi	Water	UV
6 NPS	8 NPS	12.266 in ²	[Q] 3.951 in	0.988 in	15-600 psi	Water	UV
6 NPS	8, 10 NPS	17.76 in ²	[R] 4.755 in	1.189 in	15-300 psi	Water	UV
8 NPS	10 NPS	28.86 in ²	[T] 6.061 in	1.515 in	15-300 psi	Water	UV

Design Name:	WB 300/400	NBCert #	06039
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/19/2030

Design Type

[Safety Relief Valve] WB 300/400
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on February 9, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.122 in ²	[D] 0.393 in	0.098 in	15-2900 psi	Steam	UV
1-1.5 NPS	2, 3 NPS	0.122 in ²	[D] 0.393 in	0.098 in	15-6000 psi	Air	UV
1-1.5 NPS	2, 3 NPS	0.216 in ²	[E] 0.524 in	0.132 in	15-2900 psi	Steam	UV
1-1.5 NPS	2, 3 NPS	0.216 in ²	[E] 0.524 in	0.132 in	15-6000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.338 in ²	[F] 0.656 in	0.164 in	15-2900 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.338 in ²	[F] 0.656 in	0.164 in	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	0.558 in ²	[G] 0.843 in	0.26 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.558 in ²	[G] 0.843 in	0.26 in	15-3600 psi	Air	UV
1.5-2 NPS	3 NPS	0.871 in ²	[H] 1.053 in	0.263 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.871 in ²	[H] 1.053 in	0.263 in	15-3000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.429 in ²	[J] 1.349 in	0.337 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.429 in ²	[J] 1.349 in	0.337 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.038 in ²	[K] 1.611 in	0.403 in	15-2500 psi	Air	UV
3 NPS	4, 6 NPS	2.038 in ²	[K] 1.611 in	0.403 in	15-2500 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-1500 psi	Steam	UV
4 NPS	6 NPS	3.994 in ²	[M] 2.255 in	0.563 in	15-1200 psi	Air	UV
4 NPS	6 NPS	3.994 in ²	[M] 2.255 in	0.563 in	15-1200 psi	Steam	UV
4 NPS	6 NPS	4.815 in ²	[N] 2.476 in	0.619 in	15-1000 psi	Air	UV
4 NPS	6 NPS	4.815 in ²	[N] 2.476 in	0.619 in	15-1000 psi	Steam	UV

4 NPS	6 NPS	7.082 in ²	[P] 3.003 in	0.751 in	15-1000 psi	Air	UV
4 NPS	6 NPS	7.082 in ²	[P] 3.003 in	0.751 in	15-1000 psi	Steam	UV
6 NPS	8 NPS	12.26 in ²	[Q] 3.951 in	0.988 in	15-600 psi	Air	UV
6 NPS	8 NPS	12.26 in ²	[Q] 3.951 in	0.988 in	15-600 psi	Steam	UV
6 NPS	8, 10 NPS	17.76 in ²	[R] 4.755 in	1.188 in	15-300 psi	Air	UV
6 NPS	8, 10 NPS	17.76 in ²	[R] 4.755 in	1.188 in	15-300 psi	Steam	UV
8 NPS	10 NPS	28.86 in ²	[T] 6.061 in	1.515 in	15-300 psi	Air	UV
8 NPS	10 NPS	28.86 in ²	[T] 6.061 in	1.515 in	15-300 psi	Steam	UV

Design Name: WB 300B NBCert # 06084

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/19/2029

Design Type

[Safety Relief Valve] WB 300B
Capacity Tests: Sec. UV at National Board Testing Lab on October 21, 1991
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.833 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control UK, Ltd. {BRK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2, 2.5 NPS	0.338 in ²	[F] 0.656 in	0.164 in	15-5000 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.558 in ²	[G] 0.843 in	0.21 in	15-3600 psi	Air	UV
1.5-2 NPS	3 NPS	0.871 in ²	[H] 1.053 in	0.263 in	15-2750 psi	Air	UV
2-3 NPS	3, 4 NPS	1.429 in ²	[J] 1.349 in	0.337 in	15-2700 psi	Air	UV
3 NPS	4, 6 NPS	2.04 in ²	[K] 1.611 in	0.402 in	15-2160 psi	Air	UV
3-4 NPS	4, 6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-1500 psi	Air	UV
4 NPS	6 NPS	3.986 in ²	[M] 2.255 in	0.563 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.817 in ²	[N] 2.476 in	0.619 in	15-1000 psi	Air	UV
4 NPS	6 NPS	7.081 in ²	[P] 3.003 in	0.751 in	15-1000 psi	Air	UV
6 NPS	8 NPS	12.265 in ²	[Q] 3.951 in	0.987 in	15-600 psi	Air	UV
6 NPS	8, 10 NPS	17.76 in ²	[R] 4.755 in	1.188 in	15-300 psi	Air	UV
8 NPS	10 NPS	28.85 in ²	[T] 6.061 in	1.515 in	15-300 psi	Air	UV

Emerson Automation Solutions Final Control US LP (AGC)

Nameplate Abbreviation: EMRT

Stafford, TX 77477 United States

This Company Manufactures or Assembles:

Design Name:	243/249/443/449/546/843/849/943/5046/5049/8043/8049	NBCert #	01292
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/20/2030

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049

Capacity Tests: Sec. UV at unknown lab on August 8, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name:	253/259/453/459/853/859/953/959/5059/8053/8059	NBCert #	01304
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/06/2030

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059

Capacity Tests: Sec. UV at unknown lab on July 31, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.627 Unitless

Media - Test: Air/Gas; Certified: Air, Gas

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Curtain Area

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV

1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 263/269/463/469/566/863/869/963/969/506
6/5069 NBCert # 01315

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/20/2030

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069

Capacity Tests: Sec. UV at unknown lab on July 30, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.860 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids)		NBCert #	01337
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV, V	11/06/2030
Design Type			
[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids) Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.767 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 443/449/843/849 (Air/Gas & Liquid)		NBCert #	15040
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/14/2028
Design Type			
[Pilot Operated Pressure Relief Valve] 443/449/843/849 (Air/Gas & Liquid) Capacity Tests: Sec. UV at Anderson Greenwood Crosby on October 12, 2021 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless; (alternate medium): 0.767 Unitless; Certification Provisions: Multiple Media (Code Case 2787) Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid Set Pressure Definition(1): Initial Audible Discharge; (2): First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Air	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV

4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Air	UV
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Air	UV
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Air	UV

Design Name: 453/459/853/859 (Air/Gas & Liquid) NBCert # 15084

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/11/2028

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859 (Air/Gas & Liquid)
Capacity Tests: Sec. UV at Anderson Greenwood Crosby on December 6, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.627 Unitless; (alternate medium): 0.491 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Initial Audible Discharge; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Air	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Air	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Air	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Air	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Air	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Air	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Air	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Air	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Air	UV

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	11/06/2030

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids) NBCert # 01348

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/04/2030

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids)
 Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.712 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name: 463/469/863/869 (Air/Gas & Liquid) NBCert # 15062

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

09/14/2028

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/863/869 (Air/Gas & Liquid)
 Capacity Tests: Sec. UV at Anderson Greenwood Crosby on October 12, 2021
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.860 Unitless; (alternate medium): 0.712 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
 Set Pressure Definition(1): Initial Audible Discharge; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-7600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV

8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Air	UV

Design Name: 5087 (1.500" Orifice) NBCert # 02147

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/19/2025

Design Type

[Pilot Operated Pressure Relief Valve] 5087 (1.500" Orifice)
Capacity Tests: Sec. UV at Crosby Valve, LLC on February 14, 2019
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 32.920 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 in	4 in	1.77 in ²	1.5 in	1.329 in	6000-12500 psi	Water	UV

Design Name: 5200 Series (Water K = 0.674) NBCert # 36458

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 01/05/2030

Design Type

[Pilot Operated Pressure Relief Valve] 5200 Series (Water K = 0.674)
Capacity Tests: Sec. UV, V at National Board Testing Lab on August 5, 2011
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; (alternate medium): 0.674 Unitless; Certification Provisions: Economizer Service (Prev. CC 2446)
Media - Test: Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Initial Audible Discharge; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.347 in ²	[F] 0.665 in	0.207 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.347 in ²	[F] 0.665 in	0.207 in	15-6170 psi	Steam	UV, V
1-1.5 NPS	2 - 3 NPS	0.347 in ²	[F] 0.665 in	0.207 in	15-6170 psi	Water	V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-6170 psi	Steam	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-6170 psi	Water	V
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.331 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.331 in	15-3705 psi	Steam	UV, V
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.331 in	15-3705 psi	Water	V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-3705 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-3705 psi	Water	V

2.5-3 NPS	4 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-3705 psi	Air	UV
2.5-3 NPS	4 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-3705 psi	Steam	UV, V
2.5-3 NPS	4 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-3705 psi	Water	V
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-3705 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-3705 psi	Water	V
4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2220 psi	Steam	UV, V
4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2220 psi	Water	V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Water	V
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	1.263 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	1.263 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	1.263 in	15-1480 psi	Water	V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Water	V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	2 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	2 in	15-1480 psi	Steam	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	2 in	15-1480 psi	Water	V
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	2.55 in	15-1480 psi	Air	UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	2.55 in	15-1480 psi	Steam	UV, V
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	2.55 in	15-1480 psi	Water	V

Design Name: 63B (.312", #5 orifice)

NBCert #

01056

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

09/13/2028

Design Type

[Safety Relief Valve] 63B (.312", #5 orifice)
Capacity Tests: Sec. UV at Crosby Valve, LLC on December 3, 1975
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.180 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1 NPS	0.077 in ²	[#5] 0.312 in	0.15 in	37-531 psi	Air	UV

Design Name: 63B (.437", #7 orifice)		NBCert #	01067
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	09/13/2028
Design Type			
[Safety Relief Valve] 63B (.437", #7 orifice) Capacity Tests: Sec. UV at Crosby Valve, LLC on December 3, 1975 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.370 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.15 in ²	[#7] 0.437 in	0.16 in	45-374 psi	Air	UV

Design Name: 727		NBCert #	01247
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	12/18/2028
Design Type			
[Pilot Operated Pressure Relief Valve] 727 Capacity Tests: Sec. UV at Crosby Valve, LLC on August 19, 1987 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.788 Unitless Media - Test: Air/Gas; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	0.25 in ²	[E] 0.564 in	0.058 in	15-1480 psi	Air	UV
1.5 NPS	2 NPS	0.25 in ²	[E] 0.564 in	0.058 in	15-1480 psi	Steam	UV
2-2 NPS	3 NPS	0.629 in ²	[G] 0.895 in	0.14 in	15-1480 psi	Air	UV
2-2 NPS	3 NPS	0.629 in ²	[G] 0.895 in	0.14 in	15-1480 psi	Steam	UV
2-2 NPS	3 NPS	0.981 in ²	[H] 1.118 in	0.224 in	15-1480 psi	Air	UV
2-2 NPS	3 NPS	0.981 in ²	[H] 1.118 in	0.224 in	15-1480 psi	Steam	UV
2-2 NPS	3 NPS	1.635 in ²	[J] 1.443 in	0.65 in	15-1480 psi	Air	UV
2-2 NPS	3 NPS	1.635 in ²	[J] 1.443 in	0.65 in	15-1480 psi	Steam	UV
3 NPS	4 NPS	1.635 in ²	[J] 1.443 in	0.275 in	15-1480 psi	Air	UV
3 NPS	4 NPS	1.635 in ²	[J] 1.443 in	0.275 in	15-1480 psi	Steam	UV
3-3 NPS	4 NPS	2.298 in ²	[K] 1.711 in	0.41 in	15-1480 psi	Air	UV
3-3 NPS	4 NPS	2.298 in ²	[K] 1.711 in	0.41 in	15-1480 psi	Steam	UV
3-3 NPS	4 NPS	3.557 in ²	[L] 2.128 in	0.751 in	15-1480 psi	Air	UV
3-3 NPS	4 NPS	3.557 in ²	[L] 2.128 in	0.751 in	15-1480 psi	Steam	UV
4 NPS	6 NPS	3.557 in ²	[L] 2.128 in	0.374 in	15-1480 psi	Air	UV

4 NPS	6 NPS	3.557 in ²	[L] 2.128 in	0.374 in	15-1480 psi	Steam	UV
4-4 NPS	6 NPS	4.505 in ²	[M] 2.395 in	0.659 in	15-1480 psi	Air	UV
4-4 NPS	6 NPS	4.505 in ²	[M] 2.395 in	0.659 in	15-1480 psi	Steam	UV
4-4 NPS	6 NPS	5.425 in ²	[N] 2.628 in	0.824 in	15-1480 psi	Air	UV
4-4 NPS	6 NPS	5.425 in ²	[N] 2.628 in	0.824 in	15-1480 psi	Steam	UV
4-4 NPS	6 NPS	7.911 in ²	[P] 3.174 in	1.536 in	15-1480 psi	Air	UV
4-4 NPS	6 NPS	7.911 in ²	[P] 3.174 in	1.536 in	15-1480 psi	Steam	UV
6-6 NPS	8 NPS	13.813 in ²	[Q] 4.194 in	1.302 in	15-1480 psi	Air	UV
6-6 NPS	8 NPS	13.813 in ²	[Q] 4.194 in	1.302 in	15-1480 psi	Steam	UV
6-6 NPS	8 NPS	20 in ²	[R] 5.046 in	2.304 in	15-1480 psi	Air	UV
6-6 NPS	8 NPS	20 in ²	[R] 5.046 in	2.304 in	15-1480 psi	Steam	UV
6-6 NPS	8 NPS	22.99 in ²	[RR] 5.41 in	2.304 in	15-1480 psi	Air	UV
6-6 NPS	8 NPS	22.99 in ²	[RR] 5.41 in	2.304 in	15-1480 psi	Steam	UV
8-8 NPS	10 NPS	32.5 in ²	[T] 6.433 in	2.943 in	15-1480 psi	Air	UV
8-8 NPS	10 NPS	32.5 in ²	[T] 6.433 in	2.943 in	15-1480 psi	Steam	UV

Design Name:	81, 81P, 83, 84	NBCert #	01089
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/09/2028

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 81P (Liquids)		NBCert #	01102
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV, V	09/20/2028
Design Type			
[Relief Valve] 81P (Liquids) Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.720 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: 93% of pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name: 83F		NBCert #	01113
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	09/13/2028
Design Type			
[Safety Relief Valve] 83F Capacity Tests: Sec. UV at Crosby Valve, LLC on April 14, 1987 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.779 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.26 in ²	[E] 0.576 in	0.178 in	15-500 psi	Air	UV
1.5 NPS	2 NPS	0.66 in ²	[G] 0.917 in	0.318 in	15-500 psi	Air	UV
2 NPS	3 NPS	1.697 in ²	[J] 1.47 in	0.548 in	15-500 psi	Air	UV

Design Name: 900 Series (Liquid), 7700, SNC		NBCert #	15499
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV, V	10/22/2025

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.661 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name: 900 Series, 7700, SNC

NBCert #

15411

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/22/2025

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV

1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name:	91/94	NBCert #	01124
--------------	-------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/09/2028

Design Type

[Pilot Operated Pressure Relief Valve] 91/94
Capacity Tests: Sec. UV at Crosby Valve, LLC on January 18, 1971
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.770 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	3 NPS	2.924 in ²	1.93 in	0.83 in	15-50 psi	Air	UV
3 NPS	4 NPS	6.243 in ²	2.82 in	1.2 in	15-50 psi	Air	UV
4 NPS	6 NPS	10.326 in ²	3.627 in	1.46 in	15-50 psi	Air	UV
6 NPS	8 NPS	22.217 in ²	5.32 in	1.88 in	15-50 psi	Air	UV
8 NPS	10 NPS	39.571 in ²	7.1 in	2.52 in	15-50 psi	Air	UV
10 NPS	12 NPS	56.5 in ²	8.5 in	3.02 in	15-50 psi	Air	UV
12 NPS	16 NPS	89.874 in ²	10.7 in	3.8 in	15-50 psi	Air	UV

Design Name:	93	NBCert #	01135
--------------	----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/13/2028

Design Type

[Pilot Operated Pressure Relief Valve] 93
Capacity Tests: Sec. UV at Phillips Petroleum on November 30, 1966
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.845 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	3 NPS	2.29 in ²	1.927 in	1.06 in	15-50 psi	Air	UV
3 NPS	4 NPS	5.16 in ²	2.81 in	1.24 in	15-50 psi	Air	UV
4 NPS	6 NPS	8.74 in ²	3.627 in	1.57 in	15-50 psi	Air	UV
6 NPS	8 NPS	19.56 in ²	5.31 in	2.26 in	15-50 psi	Air	UV
8 NPS	10 NPS	36.4 in ²	7.1 in	3.12 in	15-50 psi	Air	UV

10 NPS	12 NPS	51 in ²	8.5 in	3.02 in	15-30 psi	Air	UV
12 NPS	16 NPS	84 in ²	10.7 in	4.71 in	15-30 psi	Air	UV

Design Name:	9340/9390	NBCert #	01258
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/14/2028

Design Type

[Pilot Operated Pressure Relief Valve] 9340/9390
Capacity Tests: Sec. UV at Crosby Valve, LLC on September 8, 1989
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.629 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	3 NPS	3.35 in ²	2.067 in	0.545 in	15-50 psi	Air	UV
3 NPS	4 NPS	7.39 in ²	3.068 in	0.8 in	15-50 psi	Air	UV
4 NPS	6 NPS	12.73 in ²	4.026 in	1.05 in	15-50 psi	Air	UV
6 NPS	8 NPS	28.89 in ²	6.065 in	1.619 in	15-50 psi	Air	UV
8 NPS	10 NPS	50 in ²	7.981 in	2.125 in	15-50 psi	Air	UV
10 NPS	12 NPS	78.85 in ²	10.02 in	2.675 in	15-50 psi	Air	UV
12 NPS	16 NPS	113 in ²	12 in	3.25 in	15-50 psi	Air	UV

Design Name:	95	NBCert #	01146
--------------	----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/13/2028

Design Type

[Pilot Operated Pressure Relief Valve] 95
Capacity Tests: Sec. UV at Crosby Valve, LLC on July 30, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.852 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	3 NPS	2.926 in ²	1.93 in	0.96 in	15-150 psi	Air	UV
3 NPS	4 NPS	6.246 in ²	2.82 in	1.23 in	15-150 psi	Air	UV
4 NPS	6 NPS	10.321 in ²	3.625 in	1.82 in	15-150 psi	Air	UV
6 NPS	8 NPS	22.145 in ²	5.31 in	2.2 in	15-150 psi	Air	UV

Design Name:	BP	NBCert #	15501
--------------	----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/22/2025

Design Type

[Safety Relief Valve] BP
Capacity Tests: Sec. UV at Crosby Valve, LLC on August 24, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.841 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.0539 in ²	[#4] 0.262 in	0.06 in	50-3000 psi	Air	UV
0.75-1 NPS	1 NPS	0.0929 in ²	[#5] 0.344 in	0.085 in	50-3000 psi	Air	UV
0.75-1 NPS	1 NPS	0.114 in ²	[#5A] 0.381 in	0.098 in	50-3000 psi	Air	UV
0.75-1 NPS	1 NPS	0.1364 in ²	[#6] 0.417 in	0.112 in	50-3000 psi	Air	UV

Design Name:	BP (Liquids)	NBCert #	15534
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	10/22/2025

Design Type

[Relief Valve] BP (Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on September 15, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.631 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.0539 in ²	[#4] 0.262 in	0.06 in	50-3000 psi	Water	UV, V
0.75-1 NPS	1 NPS	0.0929 in ²	[#5] 0.344 in	0.085 in	50-3000 psi	Water	UV, V
0.75-1 NPS	1 NPS	0.114 in ²	[#5A] 0.381 in	0.098 in	50-3000 psi	Water	UV, V
0.75-1 NPS	1 NPS	0.1364 in ²	[#6] 0.417 in	0.112 in	50-3000 psi	Water	UV, V

Design Name:	H Series (HCI, HSJ, HCA, HA, HB, HC, HCB, HCP, HJO, HN, HNA, HNB, HNP, HS, HSA, HSB, HSC, HSP)	NBCert #	15006
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	06/07/2027

Design Type

[Safety Valve] H Series (HCI, HSJ, HCA, HA, HB, HC, HCB, HCP, HJO, HN, HNA, HNB, HNP, HS, HSA, HSB, HSC, HSP)

Capacity Tests: Sec. UV, V at unknown lab on September 1, 1939

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Steam; Certified: Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1.5 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-500 psi	Steam	UV, V
0.75 NPS	1.5 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-500 psi	Steam	UV, V
1-1.5 NPS	2 - 3 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-3100 psi	Steam	UV, V
1-2 NPS	2.5, 3 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-3100 psi	Steam	UV, V
1.5-2 NPS	3, 4, 6 NPS	0.785 in ²	[H] 1 in	0.25 in	15-5000 psi	Steam	UV, V
1.5 NPS	3 NPS	0.865 in ²	1.05 in	0.262 in	15-3100 psi	Steam	UV, V
1.5 NPS	3 NPS	0.994 in ²	[H2] 1.125 in	0.281 in	15-3100 psi	Steam	UV, V
2-3 NPS	3, 4, 6 NPS	1.288 in ²	[J] 1.281 in	0.32 in	15-5000 psi	Steam	UV, V
2 NPS	4 NPS	1.431 in ²	[J2] 1.35 in	0.338 in	15-3100 psi	Steam	UV, V
2.5-3 NPS	4, 6 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-6000 psi	Steam	UV, V
2.5 NPS	6 NPS	2.545 in ²	[K2] 1.8 in	0.45 in	15-6800 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.476 in	15-3100 psi	Steam	UV, V
3 NPS	6 NPS	3.341 in ²	[L2] 2.062 in	0.516 in	15-3100 psi	Steam	UV, V
3-4 NPS	6, 8 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-6000 psi	Steam	UV, V
3 NPS	6, 8 NPS	3.976 in ²	[M2] 2.25 in	0.563 in	15-6000 psi	Steam	UV, V
4 NPS	6 NPS	4.341 in ²	[N] 2.351 in	0.588 in	15-3100 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.712 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	7.07 in ²	[P2] 3 in	0.75 in	15-3100 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.937 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	12.25 in ²	[Q2] 3.95 in	0.988 in	15-3100 psi	Steam	UV, V
6 NPS	8, 10 NPS	16 in ²	[R] 4.513 in	1.128 in	15-3100 psi	Steam	UV, V
6 NPS	10 NPS	19.29 in ²	[RR] 4.956 in	1.239 in	15-3100 psi	Steam	UV, V
8 NPS	10, 12 NPS	26 in ²	[T] 5.75 in	1.437 in	15-500 psi	Steam	UV, V
8 NPS	12, 14 NPS	28.274 in ²	6 in	1.5 in	15-2000 psi	Steam	UV, V
10 NPS	14 NPS	44.18 in ²	7.5 in	1.875 in	15-500 psi	Steam	UV, V
12 NPS	16 NPS	63.62 in ²	9 in	2.25 in	15-500 psi	Steam	UV, V
14 NPS	18 NPS	86.59 in ²	10.5 in	2.625 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	95.21 in ²	11.01 in	2.753 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	114.04 in ²	12.05 in	3.02 in	15-500 psi	Steam	UV, V
18 NPS	24 NPS	143.14 in ²	13.5 in	3.375 in	15-500 psi	Steam	UV, V
20 NPS	24 NPS	176.71 in ²	15 in	3.75 in	15-500 psi	Steam	UV, V

Design Name:	H Series (Restricted Lift version of Cert # 15006)	NBCert #	15567
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV, V	09/02/2029
--------------	-------	------------

Design Type

[Safety Valve] H Series (Restricted Lift version of Cert # 15006)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 6, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Restricted Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1.5 NPS	0.11 in ²	[D] 0.375 in	0.08 in	15-500 psi	Steam	UV, V
0.75 NPS	1.5 NPS	0.196 in ²	[E] 0.5 in	0.08 in	15-500 psi	Steam	UV, V
1-1.5 NPS	2, 2.5, 3 NPS	0.307 in ²	[F] 0.625 in	0.08 in	15-3100 psi	Steam	UV, V
1-2 NPS	2.5, 3 NPS	0.503 in ²	[G] 0.8 in	0.08 in	15-3100 psi	Steam	UV, V
1.5-2 NPS	3, 4 NPS	0.785 in ²	[H] 1 in	0.08 in	15-3100 psi	Steam	UV, V
1.5 NPS	3 NPS	0.865 in ²	1.05 in	0.08 in	15-3100 psi	Steam	UV, V
1.5 NPS	3 NPS	0.994 in ²	[H2] 1.125 in	0.084 in	15-3100 psi	Steam	UV, V
2-3 NPS	3,4,6 NPS	1.288 in ²	[J] 1.281 in	0.096 in	15-5000 psi	Steam	UV, V
2 NPS	4 NPS	1.431 in ²	[J2] 1.35 in	0.101 in	15-3100 psi	Steam	UV, V
2.5-3 NPS	4, 6 NPS	1.84 in ²	[K] 1.531 in	0.115 in	15-3100 psi	Steam	UV, V
2.5 NPS	6 NPS	2.545 in ²	[K2] 1.8 in	0.135 in	15-3100 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-3100 psi	Steam	UV, V
3 NPS	6 NPS	3.341 in ²	[L2] 2.062 in	0.155 in	15-3100 psi	Steam	UV, V
3-4 NPS	6 NPS	3.6 in ²	[M] 2.14 in	0.161 in	15-5000 psi	Steam	UV, V
3 NPS	6 NPS	3.976 in ²	[M2] 2.25 in	0.169 in	15-3100 psi	Steam	UV, V
4 NPS	6 NPS	4.341 in ²	[N] 2.351 in	0.176 in	15-3100 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.213 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	7.07 in ²	[P2] 3 in	0.225 in	15-3100 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.281 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	12.25 in ²	[Q2] 3.95 in	0.296 in	15-3100 psi	Steam	UV, V
6 NPS	8, 10 NPS	16 in ²	[R] 4.513 in	0.338 in	15-1200 psi	Steam	UV, V
6 NPS	10 NPS	19.29 in ²	[RR] 4.956 in	0.371 in	15-3100 psi	Steam	UV, V
8 NPS	10, 12 NPS	26 in ²	[T] 5.75 in	0.431 in	15-500 psi	Steam	UV, V
8 NPS	12, 14 NPS	28.274 in ²	6 in	0.45 in	15-2000 psi	Steam	UV, V
10 NPS	14 NPS	44.18 in ²	7.5 in	0.562 in	15-500 psi	Steam	UV, V
12 NPS	16 NPS	63.62 in ²	9 in	0.675 in	15-500 psi	Steam	UV, V
14 NPS	18 NPS	86.59 in ²	10.5 in	0.787 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	95.21 in ²	11.01 in	0.826 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	114.04 in ²	12.05 in	0.906 in	15-500 psi	Steam	UV, V

18 NPS	24 NPS	143.14 in ²	13.5 in	1.012 in	15-500 psi	Steam	UV, V
20 NPS	24 NPS	176.71 in ²	15 in	1.125 in	15-500 psi	Steam	UV, V

Design Name:	HE	NBCert #	15039
--------------	----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer V 06/14/2030

Design Type

[Safety Valve] HE
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 15, 1970
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5 NPS	0.307 in ²	0.625 in	0.156 in	15-3100 psi	Steam	NV, V
1.5 NPS	2.5 NPS	0.503 in ²	0.8 in	0.2 in	15-3100 psi	Steam	NV, V
1.5 NPS	3 NPS	0.785 in ²	[H] 1 in	0.25 in	15-3100 psi	Steam	NV, V
2 NPS	4 NPS	1.288 in ²	[J] 1.281 in	0.32 in	15-3100 psi	Steam	NV, V
2.5 NPS	6 NPS	1.84 in ²	[K] 1.531 in	0.382 in	15-3100 psi	Steam	NV, V
2.5 NPS	6 NPS	2.545 in ²	[K2] 1.8 in	0.45 in	15-3100 psi	Steam	NV, V
3 NPS	6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-3100 psi	Steam	NV, V
3 NPS	6 NPS	3.976 in ²	[M2] 2.25 in	0.562 in	15-3100 psi	Steam	NV, V
4 NPS	6 NPS	6.38 in ²	2.85 in	0.712 in	15-3100 psi	Steam	NV, V
4 NPS	6, 8 NPS	7.069 in ²	[P2] 3 in	0.75 in	15-3100 psi	Steam	NV, V
6 NPS	8 NPS	11.045 in ²	3.75 in	0.937 in	15-3100 psi	Steam	NV, V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.513 in	1.128 in	15-1500 psi	Steam	NV, V
8 NPS	10, 12, 14 NPS	19.369 in ²	[R3] 4.966 in	1.242 in	15-3100 psi	Steam	NV, V
8 NPS	10, 12, 14 NPS	21.1 in ²	[R5] 5.183 in	1.295 in	15-3100 psi	Steam	NV, V
8 NPS	14 NPS	22 in ²	[R6] 5.295 in	1.324 in	15-3100 psi	Steam	NV, V
10 NPS	16 NPS	36.4 in ²	[T2] 6.808 in	1.707 in	15-3100 psi	Steam	NV, V

Design Name:	HL, HSL	NBCert #	15589
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 08/22/2029

Design Type

[Safety Valve] HL, HSL
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on November 3, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.869 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	1.5 NPS	0.339 in ²	[F] 0.657 in	0.164 in	15-725 psi	Steam	UV, V
1.25-2 NPS	1.5 NPS	0.553 in ²	[G] 0.839 in	0.21 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.868 in ²	[H] 1.051 in	0.263 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.327 in ²	[J] 1.3 in	0.325 in	15-725 psi	Steam	UV, V
2-3 NPS	3-4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-725 psi	Steam	UV, V
2.5-4 NPS	4-6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-725 psi	Steam	UV, V
3 NPS	4-6 NPS	3.955 in ²	[M] 2.244 in	0.561 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	4.831 in ²	[N] 2.48 in	0.62 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	7.031 in ²	[P] 2.992 in	0.748 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[QQ] 3.75 in	0.937 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	0.984 in	15-725 psi	Steam	UV, V

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Air/Gas & Liquid)	NBCert #	15107
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/11/2028

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Air/Gas & Liquid)
Capacity Tests: Sec. UV at Crosby Valve, LLC on July 13, 2022
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless; (alternate medium): 0.656 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Air	UV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV

3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Air	UV
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Air	UV
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Air	UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 10/22/2025

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV

1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 10/22/2025

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV

2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name:	JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Liquids) (Restricted lift version of Certification 15095)	NBCert #	01393
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 11/24/2027

Design Type

[Safety Relief Valve] JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Liquids) (Restricted lift version of Certification 15095)
Capacity Tests: Sec. NV, UV, V at unknown lab on October 14, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.137 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.137 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Water	NV

3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	0.493 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.616 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Water	UV, V

Design Name:	JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Restricted Lift version of Certification 15512)	NBCert #	01382
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	02/03/2028
--------------	----	------------

Design Type

[Safety Relief Valve] JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Restricted Lift version of Certification 15512)
Capacity Tests: Sec. UV at unknown lab on October 13, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.6949 in ²	0.892 in	0.137 in	15-2500 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	0.493 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.616 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 10/22/2025

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.865 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV

6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Design Name:	JOS-E-RL/JBS-E-RL/JDS-E-RL (Restricted Lift version of cert 15208)	NBCert #	01045
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	09/23/2027

Design Type

[Safety Relief Valve] JOS-E-RL/JBS-E-RL/JDS-E-RL (Restricted Lift version of cert 15208)
Capacity Tests: Sec. UV at unknown lab on May 26, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-15000 psi	Air	UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.08 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.08 in	15-15000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.08 in	15-15000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.08 in	15-2000 psi	Steam	UV

1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.08 in	15-15000 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.08 in	15-2000 psi	Steam	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.099 in	15-15000 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.099 in	15-2000 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.127 in	15-10000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.127 in	15-2000 psi	Steam	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.152 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.152 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.18 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.18 in	15-3000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.189 in	15-2000 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.189 in	15-5000 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.213 in	15-2000 psi	Steam	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.213 in	15-5000 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.234 in	15-1480 psi	Steam	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.234 in	15-3000 psi	Air	UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.255 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.255 in	15-2250 psi	Steam	UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.284 in	15-1480 psi	Steam	UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.284 in	15-3000 psi	Air	UV
6 NPS	8 NPS	11.045 in ²	3.75 in	0.373 in	15-1000 psi	Steam	UV
6 NPS	8 NPS	11.045 in ²	3.75 in	0.373 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.174 in ²	3.937 in	0.373 in	15-2250 psi	Air	UV
6 NPS	8 NPS	12.174 in ²	3.937 in	0.373 in	15-2250 psi	Steam	UV
6 NPS	10 NPS	12.236 in ²	3.947 in	0.449 in	15-2250 psi	Air	UV
6 NPS	10 NPS	12.236 in ²	3.947 in	0.449 in	15-2250 psi	Steam	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.373 in	15-1480 psi	Steam	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.373 in	15-3000 psi	Air	UV
6 NPS	8 NPS	15.288 in ²	4.412 in	0.424 in	15-2250 psi	Air	UV
6 NPS	8 NPS	15.288 in ²	4.412 in	0.424 in	15-2250 psi	Steam	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.449 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.449 in	15-1480 psi	Steam	UV
8 NPS	10 NPS	18.254 in ²	4.821 in	0.572 in	15-2250 psi	Air	UV
8 NPS	10 NPS	18.254 in ²	4.821 in	0.572 in	15-2250 psi	Steam	UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	0.572 in	15-740 psi	Air	UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	0.572 in	15-740 psi	Steam	UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	0.592 in	15-740 psi	Air	UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	0.592 in	15-740 psi	Steam	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	0.731 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	0.731 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	0.933 in	15-325 psi	Air	UV

Design Name: JQU - 1.5 (with breaking pin)		NBCert #	15275
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	06/21/2030	
Design Type			
[Safety Relief Valve] JQU - 1.5 (with breaking pin) Capacity Tests: Sec. UV at Crosby Valve, LLC on May 1, 1978 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 9.260 SCFM/PSIA Media - Test: Steam; Certified: Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	4 NPS	0.849 in ²	1.04 in	0.26 in	15-375 psi	Air	UV

Design Name: JQU - 1.5 (without breaking pin)		NBCert #	15286
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	04/18/2030	
Design Type			
[Safety Relief Valve] JQU - 1.5 (without breaking pin) Capacity Tests: Sec. UV at Crosby Valve, LLC on May 1, 1978 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 9.430 SCFM/PSIA Media - Test: Steam; Certified: Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	4 NPS	0.849 in ²	1.04 in	0.26 in	15-375 psi	Air	UV

Design Name: JQU - 4 (with breaking pin)		NBCert # 15297
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	06/21/2030
Design Type		
<div>[Safety Relief Valve] JQU - 4 (with breaking pin) Capacity Tests: Sec. UV at unknown lab on July 6, 1959 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:39.800 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 NPS	6 NPS	3.141 in ²	2 in	0.5 in	50-375 psi	Air	UV

Design Name:	Kunkle 1, 2	NBCert #	36223
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	07/28/2027

Design Type

[Safety Valve] Kunkle 1, 2
Capacity Tests: Sec. UV at unknown lab on July 1, 1953
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.823 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, Top NPS	0.049 in ²	0.75 in	0.029 in	15-250 psi	Air	UV
0.5-0.75 NPS	.75, Top NPS	0.049 in ²	0.75 in	0.029 in	15-250 psi	Steam	UV
1 NPS	1, Top NPS	0.0844 in ²	1 in	0.038 in	15-250 psi	Air	UV
1 NPS	1, Top NPS	0.0844 in ²	1 in	0.038 in	15-250 psi	Steam	UV

Design Name:	Kunkle 189, 363, 389	NBCert #	36043
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/21/2027

Design Type

[Safety Relief Valve] Kunkle 189, 363, 389
Capacity Tests: Sec. UV at unknown lab on April 15, 1958
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.874 Unitless
Media - ; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.034 in ²	0.5 in	0.031 in	50-2500 psi	Air	UV

Design Name:	Kunkle 264, 265, 266 & 267	NBCert #	36267
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	07/28/2027

Design Type

[Safety Relief Valve] Kunkle 264, 265, 266 & 267
Capacity Tests: Sec. UV at unknown lab on July 20, 1956
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.766 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.115 in	15-2000 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.115 in	15-3300 psi	Air	UV

Design Name: Kunkle 30 NBCert # 36335

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/21/2027

Design Type

[Safety Relief Valve] Kunkle 30
Capacity Tests: Sec. UV at unknown lab on December 18, 1989
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.186 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS			0.157 in	0.1 in	60-4000 psi	Air	UV

Design Name: Kunkle 300,600 NBCert # 36076

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	07/28/2027

Design Type

[Safety Valve] Kunkle 300,600
Capacity Tests: Sec. UV, V at unknown lab on February 10, 1961
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	UV
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	V
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	V

1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Air	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	V
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Air	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	V
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Air	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	V
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	V
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Air	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	UV

Design Name:	Kunkle 330. 330S, 333S	NBCert #	36087
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/07/2027

Design Type

[Safety Relief Valve] Kunkle 330. 330S, 333S
Capacity Tests: Sec. UV at unknown lab on June 14, 1972
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.026 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.5 NPS			0.047 in	0.05 in	1000-7500 psi	Air	UV

Design Name:	Kunkle 337	NBCert #	36278
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 07/08/2027

Design Type

[Safety Relief Valve] Kunkle 337
Capacity Tests: Sec. UV at unknown lab on February 22, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	1.916 in ²	1.562 in	0.612 in	15-60 psi	Air	UV
2.5 NPS	2.5 NPS	2.786 in ²	1.883 in	0.755 in	15-60 psi	Air	UV
3 NPS	3 NPS	4.037 in ²	2.267 in	0.91 in	15-60 psi	Air	UV

Design Name: Kunkle 537 NBCert # 36289

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

HV

07/28/2027

Design Type

[Safety Relief Valve] Kunkle 537
Capacity Tests: Sec. HV at unknown lab on March 29, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.806 Unitless
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.533 in ²	0.824 in	0.33 in	15-160 psi	Steam	HV
1 NPS	1.25 NPS	0.833 in ²	1.03 in	0.412 in	15-160 psi	Steam	HV
1.5 NPS	2 NPS	1.767 in ²	1.5 in	0.6 in	15-160 psi	Steam	HV
2 NPS	2.5 NPS	3.142 in ²	2 in	0.82 in	15-160 psi	Steam	HV

Design Name: Kunkle 541-A/542-A (.295 orifice) NBCert # 36469

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

04/21/2027

Design Type

[Safety Relief Valve] Kunkle 541-A/542-A (.295 orifice)
Capacity Tests: Sec. UV at unknown lab on December 14, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.000 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS		0.068 in ²	0.295 in	0.126 in	15-200 psi	Air	UV

Design Name: Kunkle 541-C/542-C/548-C (.422 Orifice) NBCert # 36302

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/21/2027

Design Type

[Safety Relief Valve] Kunkle 541-C/542-C/548-C (.422 Orifice)
Capacity Tests: Sec. UV at unknown lab on May 20, 1988
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.000 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	Side NPS	0.14 in ²	0.422 in	0.2 in	15-400 psi	Air	UV

Design Name: Kunkle 548-A (.295 Orifice) NBCert # 36290

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/21/2027

Design Type

[Safety Relief Valve] Kunkle 548-A (.295 Orifice)
Capacity Tests: Sec. UV at unknown lab on May 20, 1988
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.000 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.375 NPS	Side NPS	0.068 in ²	0.295 in	0.126 in	15-400 psi	Air	UV

Design Name: Kunkle 6000, 6252 Series NBCert # 36324

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	06/07/2027

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V

0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 6933, 6934, 6935, 6254

NBCert #

36313

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

HV

05/06/2027

Design Type

[Safety Valve] Kunkle 6933, 6934, 6935, 6254
 Capacity Tests: Sec. HV at unknown lab on October 31, 1984
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless; Certification Provisions: (HV) Low Pressure Steam
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-15 psi	Steam	HV
0.75-1 NPS	1 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-15 psi	Steam	HV
1-1.25 NPS	1.25 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-15 psi	Steam	HV
1.25-1.5 NPS	1.5 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-15 psi	Steam	HV
1.5-2 NPS	2 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-15 psi	Steam	HV
1.5-2.5 NPS	2.5 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-15 psi	Steam	HV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-15 psi	Steam	HV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-15 psi	Steam	HV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-15 psi	Steam	HV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-15 psi	Steam	HV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-15 psi	Steam	HV

Design Name: Kunkle 910 to 919

NBCert # 36100

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/06/2027

Design Type

[Safety Relief Valve] Kunkle 910 to 919
 Capacity Tests: Sec. UV at unknown lab on May 19, 1969
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV

2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name:	Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)	NBCert #	36111
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV, V	04/22/2027
--------------	-------	------------

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 , 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

Design Name:	Kunkle 920, 921, 927, Agco A (High Temp. water)	NBCert #	36098
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	V	07/28/2027
--------------	---	------------

Design Type

[Safety Valve] Kunkle 920, 921, 927, Agco A (High Temp. water)
Capacity Tests: Sec. V at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Forced Flow Steam Generator/High Temp Hot Water (10% BD)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	V

Design Name:	Kunkle Fig. 930	NBCert #	36122
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	05/06/2027

Design Type

[Safety Valve] Kunkle Fig. 930
Capacity Tests: Sec. HV at unknown lab on April 13, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.818 Unitless; Certification Provisions: (HV) Low Pressure Steam
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	2.164 in ²	1.66 in	0.498 in	15-15 psi	Steam	HV
2.5 NPS	2.5 NPS	3.079 in ²	1.98 in	0.594 in	15-15 psi	Steam	HV
3 NPS	3 NPS	4.753 in ²	2.46 in	0.738 in	15-15 psi	Steam	HV

Design Name:	PVR-3	NBCert #	15354
--------------	-------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/29/2029

Design Type

[Safety Relief Valve] PVR-3
Capacity Tests: Sec. UV at Crosby Valve, LLC on July 14, 1980
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:47.130 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS	4 NPS	3.757 in ²	2.187 in	0.8 in	15-125 psi	Air	UV

Design Name:	PVR-4	NBCert #	15365
--------------	-------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/16/2030

Design Type

[Safety Relief Valve] PVR-4
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 26, 1981
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:87.570 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 NPS	5 NPS	7.67 in ²	3.125 in	1.125 in	15-125 psi	Air	UV

Emerson LLP (ELP)

060005, Atyrau, Kazakhstan

This Company Manufactures or Assembles:

Design Name:	900 Series (Liquid), 7700, SNC	NBCert #	15499
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	05/15/2031
-----------	----	------------

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name:	900 Series, 7700, SNC	NBCert #	15411
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	08/20/2030
-----------	----	------------

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/31/2030

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.656 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV

1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/20/2030

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV

2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/20/2030

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV

3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Emerson Process Management Arabia LTD. (EMR)

Jubail Industrial City, 31961 Saudi Arabia

This Company Manufactures or Assembles:

Design Name: 243/249/443/449/546/843/849/943/5046/5049/8043/8049 NBCert # 01292

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/06/2027

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
 Capacity Tests: Sec. UV at unknown lab on August 8, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name: 253/259/453/459/853/859/953/959/5059/8053/8059 NBCert # 01304

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/06/2027

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
 Capacity Tests: Sec. UV at unknown lab on July 31, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.627 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV

4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 263/269/463/469/566/863/869/963/969/5066/5069 NBCert # 01315

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/06/2027

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069

Capacity Tests: Sec. UV at unknown lab on July 30, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.860 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/07/2027

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.767 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/07/2027

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV

4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids) NBCert # 01348

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/07/2027

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids)
Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.712 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name: 900 Series (Liquid), 7700, SNC NBCert # 15499

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/07/2027

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name:	900 Series, 7700, SNC	NBCert #	15411
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	09/29/2027
-----------	----	------------

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Liquids)	NBCert #	15095
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	04/07/2027
-----------	----	------------

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V

8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/06/2027

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/ABNBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/06/2027

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV

6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Emerson Process Management LTDA (EMO)

Sorocaba Sao Paulo, 18087-105Brazil

This Company Manufactures or Assembles:

Design Name:	243/249/443/449/546/843/849/943/5046/5049/8043/8049	NBCert #	01292
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/11/2030

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049

Capacity Tests: Sec. UV at unknown lab on August 8, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV

8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name:	253/259/453/459/853/859/953/959/5059/8053/8059	NBCert #	01304
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	11/11/2030
--------------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
 Capacity Tests: Sec. UV at unknown lab on July 31, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.627 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name:	263/269/463/469/566/863/869/963/969/5066/5069	NBCert #	01315
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	11/11/2030
--------------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069
 Capacity Tests: Sec. UV at unknown lab on July 30, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.860 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV

2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/12/2030

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)

Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.767 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 443/449/843/849 (Air/Gas & Liquid) NBCert # 15040

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/12/2030

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/843/849 (Air/Gas & Liquid)
 Capacity Tests: Sec. UV at Anderson Greenwood Crosby on October 12, 2021
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless; (alternate medium): 0.767 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
 Set Pressure Definition(1): Initial Audible Discharge; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Air	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Air	UV
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Air	UV
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Air	UV

Design Name: 453/459/853/859 (Air/Gas & Liquid) NBCert # 15084

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/12/2030

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859 (Air/Gas & Liquid)
 Capacity Tests: Sec. UV at Anderson Greenwood Crosby on December 6, 2021
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.627 Unitless; (alternate medium): 0.491 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
 Set Pressure Definition(1): Initial Audible Discharge; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Air	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV

2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Air	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Air	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Air	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Air	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Air	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Air	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Air	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Air	UV

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

11/12/2030

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.491 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV

4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids) NBCert # 01348

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/12/2030

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids)
Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.712 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name: 463/469/863/869 (Air/Gas & Liquid) NBCert # 15062

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/12/2030

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/863/869 (Air/Gas & Liquid)
Capacity Tests: Sec. UV at Anderson Greenwood Crosby on October 12, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless; (alternate medium): 0.712 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Initial Audible Discharge; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-7600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Air	UV

Design Name: 81, 81P, 83, 84	NBCert # 01089
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/11/2030

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV

1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name:	81P (Liquids)	NBCert #	01102
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/13/2030

Design Type

[Relief Valve] 81P (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: 93% of pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name:	900 Series (Liquid), 7700, SNC	NBCert #	15499
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 10/18/2025

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV

0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name: 900 Series, 7700, SNC NBCert # 15411

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 10/11/2028

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 10/18/2025

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.656 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/11/2030

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.865 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV

6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Design Name:	Kunkle 910 to 919	NBCert #	36100
--------------	-------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 07/17/2025

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV

1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name:	Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)	NBCert #	36111
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 07/18/2025

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 , 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

EMERSON PROCESS MANAGEMENT S.A. DE C.V. (EMP)

Toluca, 50223Mexico

This Company Manufactures or Assembles:

Design Name:	243/249/443/449/546/843/849/943/5046/5049/8043/8049	NBCert #	01292
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/29/2027

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
Capacity Tests: Sec. UV at unknown lab on August 8, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name:	253/259/453/459/853/859/953/959/5059/8053/8059	NBCert #	01304
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	09/29/2027
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
Capacity Tests: Sec. UV at unknown lab on July 31, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.627 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name:	443/449/546/843/849/943/949/5046/5049 (Liquids)	NBCert #	01337
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	09/30/2027
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.767 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name:	453/459/853/859/953/959/5059 (Liquids)	NBCert #	01326
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	09/29/2027
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.491 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV

2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 81, 81P, 83, 84	NBCert # 01089
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	09/29/2027
-----------	----	------------

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name:	900 Series (Liquid), 7700, SNC	NBCert #	15499
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/30/2027

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name:	900 Series, 7700, SNC	NBCert #	15411
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/28/2027

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV

0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/30/2027

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV

3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/11/2030

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/28/2027

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.865 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV

6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Emerson Regulator Technologies - Fromex S.A. de C.V. (FCF)

Nameplate Abbreviation: Fromex

Nuevo Laredo, Tamaulipas, 88275Mexico

This Company Manufactures or Assembles:

Design Name: 2" 63EGLP		NBCert #	22116
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	07/08/2027
Design Type			
[Safety Relief Valve] 2" 63EGLP Capacity Tests: Sec. UV at Anderson Greenwood Crosby on April 16, 2021 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:31.780 SCFM/PSIA; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Regulator Technologies - Fromex S.A. de C.V. {FCF}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	4.441 in ²	2.378 in	0.793 in	85-375 psi	Air	UV

Design Name: 4" 63EGLP		NBCert # 22127
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/08/2025
Design Type		
[Safety Relief Valve] 4" 63EGLP Capacity Tests: Sec. UV at Anderson Greenwood Crosby on May 11, 2018 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:111.78 SCFM/PSIA; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Regulator Technologies - Fromex S.A. de C.V. {FCF}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 NPS	4 NPS	9.96 in ²	4.38 in	2 in	85-375 psi	Air	UV

Design Name: C776		NBCert # 36425
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	07/08/2027
Design Type		
[Safety Relief Valve] C776 Capacity Tests: Sec. UV at Crosby Valve, LLC on July 15, 2002 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.790 Unitless Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Regulator Technologies - Fromex S.A. de C.V. {FCF}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.169 in ²	0.465 in	0.116 in	15-600 psi	Air	UV
1 NPS	1.25 NPS	0.34 in ²	0.658 in	0.164 in	15-500 psi	Air	UV
0.75-1 NPS	1.25 NPS	0.486 in ²	0.787 in	0.197 in	15-600 psi	Air	UV
1.25 NPS	1.5 NPS	0.645 in ²	0.906 in	0.227 in	15-500 psi	Air	UV
1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.286 in	15-500 psi	Air	UV
2-2.5 NPS	2.5 NPS	1.667 in ²	1.457 in	0.364 in	15-500 psi	Air	UV

Design Name: Cash C600		NBCert # 36492
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/14/2028

Design Type

[Safety Valve] Cash C600
Capacity Tests: Sec. UV at unknown lab on March 11, 2015
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.792 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Regulator Technologies - Fromex S.A. de C.V. {FCF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.5 NPS		0.065 in ²	0.289 in	0.072 in	90-600 psi	Air	UV
0.5625 in		0.065 in ²	0.289 in	0.072 in	90-600 psi	Air	UV

Design Name: H282/ H284/ H882/ H884/ H5112/ H5114/ H8112/ H8114/H5118/H8118 NBCert # 22284

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/26/2031

Design Type

[Safety Relief Valve] H282/ H284/ H882/ H884/ H5112/ H5114/ H8112/ H8114/H5118/H8118
Capacity Tests: Sec. UV at National Board Testing Lab on November 7, 2002
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:30.900 SCFM/PSIA; Certification Provisions: Cert. @ 20% OP
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Regulator Technologies - Fromex S.A. de C.V. {FCF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		2.463 in ²			100-400 psi	Air	UV

Design Name: H722/H822/H823 Series NBCert # 22262

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/11/2031

Design Type

[Safety Relief Valve] H722/H822/H823 Series
Capacity Tests: Sec. UV at National Board Testing Lab on October 21, 2002
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:10.200 SCFM/PSIA; Certification Provisions: Cert. @ 20% OP
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Regulator Technologies - Fromex S.A. de C.V. {FCF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		0.823 in ²	1.09 in		100-400 psi	Air	UV

Design Name: H733/H833/H733F3/H833F3 NBCert # 22295

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	07/01/2031

Design Type

[Safety Relief Valve] H733/H833/H733F3/H833F3
 Capacity Tests: Sec. UV at National Board Testing Lab on April 23, 2013
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 29.770 SCFM/PSIA; Certification Provisions: Cert. @ 20% OP
 Media - Test: Air/Gas; Certified: Gas
 Set Pressure Definition: Start-to-Leak
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Regulator Technologies - Fromex S.A. de C.V. {FCF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS		2.463 in ²	1.84 in		100-400 psi	Air	UV

ENE Petro Services SDN BHD (ENE)

Selangor, 68000Malaysia

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S NBCert # 57057

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/25/2025

Design Type

[Safety Relief Valve] 2600 & 2600S
 Capacity Tests: Sec. UV at unknown lab on June 11, 1972
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.858 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV

3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Liquids)	NBCert # 57068
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	10/25/2025
-----------	----	------------

Design Type

[Relief Valve] 2600L (Liquids)
 Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.652 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V

1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S

NBCert #

57237

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

10/25/2025

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV

2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids) NBCert # 57248

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/25/2025

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800 NBCert # 57024

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/25/2025

Design Type

[Pilot Operated Pressure Relief Valve] 3800
Capacity Tests: Sec. UV at unknown lab on May 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV

1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name:	3800L, PCL, PCM pilots	NBCert #	57215
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	10/25/2025
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.782 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Engineered Controls International, LLC (REG)

Nameplate Abbreviation: ECII

Elon, NC 27244United States

This Company Manufactures or Assembles:

Design Name:	3131 (20% OP)	NBCert #	46033
Manufacturer/Assembler	Designators	Expiration Date	

Manufacturer

UV

04/28/2026

Design Type

[Safety Relief Valve] 3131 (20% OP)
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on February 27, 1981
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 6.161 SCFM/PSIA; Certification Provisions: Cert. @ 20% OP
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Engineered Controls International, LLC {REG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	Top NPS	0.423 in ²	0.734 in		225-290 psi	Air	UV

Design Name: 3135 (20% OP)		NBCert #	46358
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/06/2029
Design Type			
[Safety Relief Valve] 3135 (20% OP) Capacity Tests: Sec. UV at Engineered Controls International, LLC on October 22, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:5343.0 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	Top NPS	1.055 in ²	1.159 in		250 psi	Air	UV

Design Name: 6555 Series		NBCert #	46314
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	07/25/2028
Design Type			
[Safety Relief Valve] 6555 Series Capacity Tests: Sec. UV at Engineered Controls International, LLC on December 5, 2005 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:700.00 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	Top NPS	0.255 in ²	0.57 in	0.143 in	250 psi	Air	UV

Design Name: 7534 (20% OP)		NBCert #	46099
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	02/03/2030
Design Type			
[Safety Relief Valve] 7534 (20% OP) Capacity Tests: Sec. UV at unknown lab on February 9, 1981 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:33.120 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		2.472 in ²	1.843 in		250-250 psi	Air	UV

Design Name:	7583 (20% OP)	NBCert #	46101
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/22/2029

Design Type

[Safety Relief Valve] 7583 (20% OP)
Capacity Tests: Sec. UV at unknown lab on January 21, 1981
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.740 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Engineered Controls International, LLC {REG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	Top NPS	0.374 in ²	0.795 in	0.199 in	250-250 psi	Air	UV

Design Name:	8543 (20% OP)	NBCert #	46156
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/03/2027

Design Type

[Safety Relief Valve] 8543 (20% OP)
Capacity Tests: Sec. UV at unknown lab on May 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 4.450 SCFM/PSIA; Certification Provisions: Cert. @ 20% OP
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Engineered Controls International, LLC {REG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS		0.304 in ²	0.65 in	0.163 in	225-312 psi	Air	UV

Design Name:	8544 (20% OP)	NBCert #	46167
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/17/2026

Design Type

[Safety Relief Valve] 8544 (20% OP)
Capacity Tests: Sec. UV at unknown lab on December 20, 1985
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.979 SCFM/PSIA; Certification Provisions: Cert. @ 20% OP
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Engineered Controls International, LLC {REG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	Top NPS	0.228 in ²	0.57 in	0.143 in	229-386 psi	Air	UV

Design Name:	8546G (20% OP)	NBCert #	46347
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/20/2025

Design Type

[Safety Relief Valve] 8546G (20% OP)
Capacity Tests: Sec. UV at Engineered Controls International, LLC on July 18, 2008
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:651.00 SCFM; Certification Provisions: Cert. @ 20% OP
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Engineered Controls International, LLC {REG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.159 in ²	0.45 in		250 psi	Air	UV

Design Name:	8546T (20% OP)	NBCert #	46336
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/20/2025

Design Type

[Safety Relief Valve] 8546T (20% OP)
Capacity Tests: Sec. UV at Engineered Controls International, LLC on July 18, 2008
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:792.00 SCFM; Certification Provisions: Cert. @ 20% OP
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Engineered Controls International, LLC {REG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.159 in ²	0.45 in		312 psi	Air	UV

Design Name:	8684 (20% OP)	NBCert #	46178
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	07/25/2028

Design Type

[Safety Relief Valve] 8684 (20% OP)
Capacity Tests: Sec. UV at unknown lab on January 22, 1981
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 8.150 SCFM/PSIA; Certification Provisions: Cert. @ 20% OP
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Engineered Controls International, LLC {REG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	Top NPS	0.593 in ²	0.921 in	0.305 in	250-250 psi	Air	UV

Design Name: 8685 (20% OP)		NBCert #	46189
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	04/23/2029
Design Type			
[Safety Relief Valve] 8685 (20% OP) Capacity Tests: Sec. UV at unknown lab on January 22, 1981 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:12.820 SCFM/PSIA; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS		1.06 in ²	1.218 in	0.305 in	250-250 psi	Air	UV

Design Name: A3149 (20% OP) (200-358psi)		NBCert #	46077
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	02/03/2030
Design Type			
[Safety Relief Valve] A3149 (20% OP) (200-358psi) Capacity Tests: Sec. UV at unknown lab on February 9, 1981 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:29.086 SCFM/PSIA; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2.5 NPS		2.11 in ²	1.641 in	0.41 in	200-358 psi	Air	UV

Design Name: A8434G, BA8434G		NBCert #	46112
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	04/29/2031
Design Type			
[Safety Relief Valve] A8434G, BA8434G Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on April 29, 1988 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:3456.0 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		0.7234 in ²	1.015 in	0.254 in	250-250 psi	Air	UV

Design Name: A8434N		NBCert #	46123
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	04/23/2029
Design Type			
[Safety Relief Valve] A8434N Capacity Tests: Sec. UV at REGO CO on January 22, 1983 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:3659.0 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	Top NPS	0.7324 in ²	1.015 in	0.254 in	265-0 psi	Air	UV

Design Name: A8436G, VA8436G, BA8436G		NBCert #	46134
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	03/06/2031
Design Type			
[Safety Relief Valve] A8436G, VA8436G, BA8436G Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on May 2, 1988 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:9598.0 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS		2.253 in ²	1.766 in	0.442 in	250-250 psi	Air	UV

Design Name: A8436N, VA8436N (20% OP)		NBCert #	46145
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	05/08/2030
Design Type			
[Safety Relief Valve] A8436N, VA8436N (20% OP) Capacity Tests: Sec. UV at unknown lab on January 21, 1981 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:9839.0 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Designed by: Engineered Controls International, LLC {REG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS		2.253 in ²	1.766 in		265-265 psi	Air	UV

Design Name: AA3130A250		NBCert #	46000
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	10/04/2029
Design Type			
[Safety Relief Valve] AA3130A250 Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on February 9, 1981 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:1706.0 SCFM Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	Top NPS	0.423 in ²	0.734 in	0.184 in	250-0 psi	Air	UV

Design Name: AA3130UA250		NBCert #	46011
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	07/25/2028
Design Type			
[Safety Relief Valve] AA3130UA250 Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on August 30, 1978 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:1838.0 SCFM Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	Top NPS	0.423 in ²	0.734 in	0.184 in	250-0 psi	Air	UV

Design Name: AA3130UA265		NBCert #	46022
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	05/22/2029
Design Type			
[Safety Relief Valve] AA3130UA265 Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on August 30, 1978 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:1912.0 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	Top NPS	0.423 in ²	0.734 in	0.184 in	265-0 psi	Air	UV

Design Name: AA3135 (20% OP)		NBCert #	46268
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	04/23/2029
Design Type			
[Safety Relief Valve] AA3135 (20% OP) Capacity Tests: Sec. UV at Engineered Controls International, LLC on October 13, 2000 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:19.250 SCFM/PSIA; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS		1.196 in ²	1.234 in	0.309 in	225-265 psi	Air	UV

Design Name: AA3135A150		NBCert #	46055
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	05/23/2029
Design Type			
[Safety Relief Valve] AA3135A150 Capacity Tests: Sec. UV at REGO CO on February 20, 1980 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:2969.0 SCFM Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	Top NPS	1.196 in ²	1.234 in	0.309 in	150-0 psi	Air	UV

Design Name: AA3135A300		NBCert #	46066
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	04/23/2029
Design Type			
[Safety Relief Valve] AA3135A300 Capacity Tests: Sec. UV at REGO CO on February 20, 1980 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:5733.0 SCFM Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	Top NPS	1.055 in ²	1.159 in	0.288 in	300-0 psi	Air	UV

Design Name: AR4104A, AR5104A, AR4104B, AR5104B NBCert # 46392

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/13/2025

Design Type

[Safety Relief Valve] AR4104A, AR5104A, AR4104B, AR5104B
Capacity Tests: Sec. UV at Engineered Controls International, LLC on June 6, 2013
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.400 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Engineered Controls International, LLC {REG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	1 NPS	0.135 in ²	0.415 in	0.104 in	75-500 psi	Air	UV

Design Name: AR4106A, AR5106A, AR4106B, AR5106B NBCert # 46471

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	06/26/2030

Design Type

[Safety Relief Valve] AR4106A, AR5106A, AR4106B, AR5106B
HolderDesignation:
Capacity Tests: Sec. UV at National Board Testing Lab on January 31, 2024
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.080 SCFM/PSIA; (alternate medium): 0.000
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Engineered Controls International, LLC {REG}
Comments: Current certicaiton is effective for date codes after 3C24. This certification replaced old cert number 46369.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.135 in ²	0.415 in	0.104 in	75-400 psi	Air	UV

Design Name: AR4112A, AR5112A, AR4112B, AR5112B NBCert # 46381

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/13/2030

Design Type

[Safety Relief Valve] AR4112A, AR5112A, AR4112B, AR5112B
Capacity Tests: Sec. UV at Engineered Controls International, LLC on February 7, 2012
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 7.860 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Engineered Controls International, LLC {REG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	0.65 in ²	0.91 in	0.248 in	80-425 psi	Air	UV

Design Name: B-19434B & C-19434B 325-375		NBCert #	46505
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	06/26/2030
Design Type			
[Safety Relief Valve] B-19434B & C-19434B 325-375 HolderDesignation: Capacity Tests: Sec. UV at National Board Testing Lab on March 11, 2024 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.620 SCFM/PSIA; (alternate medium): 0.000 Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG} Comments: Current certifaicon is effective for date codes after 7E23. This certification replaced old cert number 46325.			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.118 in ²	0.387 in	0 in	350-375 psi	Air	UV

Design Name: NG9008MA		NBCert #	46437
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	07/25/2028
Design Type			
[Safety Relief Valve] NG9008MA Capacity Tests: Sec. UV at National Board Testing Lab on July 25, 2022 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.892 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 in	0.375 NPS	0.062 in ²	0.281 in	0.07 in	200-460 psi	Air	UV

Design Name: PRV19430 , PRV29430		NBCert #	46279
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	08/27/2026
Design Type			
[Safety Relief Valve] PRV19430 , PRV29430 Capacity Tests: Sec. UV at Engineered Controls International, LLC on February 11, 2000 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.692 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Engineered Controls International, LLC {REG} Comments: Date codes prior to 12D20 had a slope of 0.783 scfm.			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.5625 NPS		0.062 in ²	0.281 in		90-600 psi	Air	UV

Design Name: PRV19430, PRV29430 (Low Pressure) NBCert # 46415

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/14/2029

Design Type

[Safety Relief Valve] PRV19430, PRV29430 (Low Pressure)
Capacity Tests: Sec. UV at National Board Testing Lab on October 16, 2017
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.750 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Engineered Controls International, LLC {REG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.5625 NPS		0.062 in ²	0.281 in		15-89 psi	Air	UV

Design Name: PRV19534K NBCert # 46426

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	06/10/2026

Design Type

[Safety Relief Valve] PRV19534K
Capacity Tests: Sec. UV at National Board Testing Lab on July 25, 2019
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.805 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Engineered Controls International, LLC {REG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.056 in ²	0.266 in	0.07 in	800-1000 psi	Air	UV

Enviro Valve, Inc. (ENV)

Broken Arrow, OK 74012 United States

This Company Manufactures or Assembles:

Design Name: EVSP			NBCert # 58025	
Manufacturer/Assembler		Designators		Expiration Date
Manufacturer		UD		10/17/2030

Design Type

[Breaking Bar Non-reclosing Device] EVSP
 Capacity Tests: Sec. UD at National Board Testing Lab on July 18, 2013
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 3.710 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Breaking Pressure
 Flow Area Configuration: MNFA
 Designed by: Enviro Valve, Inc. {ENV}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
8 NPS	8 NPS	24.2 in ²	7.3 in		15-90 psi		UD
8 NPS	8 NPS	25.13 in ²	7.3 in		5-15 psi		UD
10 NPS	10 NPS	43.95 in ²	9.31 in		15-90 psi		UD
10 NPS	10 NPS	45.52 in ²	9.33 in		5-15 psi		UD
12 NPS	12 NPS	70.99 in ²	11.2 in		15-90 psi		UD
12 NPS	12 NPS	72.69 in ²	11.23 in		5-15 psi		UD
14 NPS	14 NPS	87.29 in ²	12.38 in		15-90 psi		UD
14 NPS	14 NPS	89 in ²	12.41 in		5-15 psi		UD
16 NPS	16 NPS	118.86 in ²	14.28 in		15-90 psi		UD
16 NPS	16 NPS	119.95 in ²	14.3 in		5-15 psi		UD
18 NPS	18 NPS	160.12 in ²	16.21 in		5-15 psi		UD
18 NPS	18 NPS	159.36 in ²	16.21 in		15-90 psi		UD
20 NPS	20 NPS	202.47 in ²	18.12 in		5-15 psi		UD
20 NPS	20 NPS	201.91 in ²	18.12 in		15-90 psi		UD
24 NPS	24 NPS	311.54 in ²	21.95 in		5-15 psi		UD
24 NPS	24 NPS	310.41 in ²	21.95 in		15-90 psi		UD
30 NPS	30 NPS	437.48 in ²	26.83 in		5-30 psi		UD
32 NPS	32 NPS	518.19 in ²	28.36 in	0 in	5-30 psi		UD
34 NPS	34 NPS	556.85 in ²	29.36 in	0 in	5-30 psi		UD
36 NPS	36 NPS	675.38 in ²	32.2 in	0 in	5-30 psi		UD
48 NPS	48 NPS	1270.8 in ²	44.25 in		5-30 psi		UD

Equipment and Controls, Inc. (ICE)

Nameplate Abbreviation: ECI

Lawrence, PA 15055United States

This Company Manufactures or Assembles:

Design Name:	243/249/443/449/546/843/849/943/5046/5049/8043/8049	NBCert #	01292
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	07/24/2029	

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
 Capacity Tests: Sec. UV at unknown lab on August 8, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name: 253/259/453/459/853/859/953/959/5059/8053/8059 NBCert # 01304

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/24/2029

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
 Capacity Tests: Sec. UV at unknown lab on July 31, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.627 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV

4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 263/269/463/469/566/863/869/963/969/5066/5069 NBCert # 01315

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/24/2029

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069

Capacity Tests: Sec. UV at unknown lab on July 30, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.860 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/24/2029

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.767 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/24/2029

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV

4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids) NBCert # 01348

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/24/2029

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids)
Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.712 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name: 81, 81P, 83, 84 NBCert # 01089

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/24/2029

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name:	900 Series (Liquid), 7700, SNC	NBCert #	15499
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/25/2029

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name:	900 Series, 7700, SNC	NBCert #	15411
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/24/2029

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Liquids)	NBCert #	15095
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/24/2029

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V

1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name:	JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB	NBCert #	15208
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	07/24/2029
-----------	----	------------

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV

6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

EXION ASIA PTE LTD (OSA)

Singapore, 627635Singapore

This Company Manufactures or Assembles:

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
Manufacturer/Assembler	Designators	Expiration Date	

Assembler UV 06/26/2030

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V

6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35 NBCert # 18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/26/2030

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series	NBCert # 18706
---------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	03/06/2030
-----------	----	------------

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/10/2027

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/26/2030

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/26/2030

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900E-2, 1900-30E-2 NBCert # 18166

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 03/26/2030

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 03/26/2030

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids) NBCert # 19077

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 05/26/2027

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ. RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 3900 (39PV, 39MV pilots) NBCert # 18447

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/26/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV

1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV

12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid) NBCert # 18458

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/26/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Experitec, Inc. (EXP)

St. Peters, MO 63376United States

This Company Manufactures or Assembles:

Design Name: 243/249/443/449/546/843/849/943/5046/5049/8043/8049 NBCert # 01292

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/05/2030

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049

Capacity Tests: Sec. UV at unknown lab on August 8, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV

Design Name: 253/259/453/459/853/859/953/959/5059/8053/8059		NBCert #	01304
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	04/05/2030
Design Type			
[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059 Capacity Tests: Sec. UV at unknown lab on July 31, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.627 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition(1): Pop; (2): Initial Audible Discharge Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot Flow Area Configuration: Curtain Area Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 263/269/463/469/566/863/869/963/969/5066/5069		NBCert #	01315
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	04/05/2030
Design Type			
[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069 Capacity Tests: Sec. UV at unknown lab on July 30, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.860 Unitless Media - Test: Air/Gas; Certified: Air, Gas, Steam Set Pressure Definition(1): Pop; (2): Initial Audible Discharge Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in²	1.92 in	1.155 in	15-720 psi	Steam	UV

3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 81, 81P, 83, 84 NBCert # 01089

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/05/2030

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name:	900 Series (Liquid), 7700, SNC	NBCert #	15499
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/05/2030

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name:	900 Series, 7700, SNC	NBCert #	15411
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/05/2030

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV

0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/05/2030

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV

3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/05/2030

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV

4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

F. H. Gaskins Co., Inc. (FHG)

Norfolk, VA 23504United States

This Company Manufactures or Assembles:

Design Name:	1541, 1543, 1541-3, 1543-3	NBCert #	18032
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	12/06/2028

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name:	1811, 1511	NBCert #	18122
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	12/06/2028

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA
(Liquids)

NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	11/15/2029

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V

1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/22/2029

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV

3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/14/2031

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/01/2028

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900-DM

NBCert # 19066

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/14/2029

Design Type

[Safety Relief Valve] 1900-DM
Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 3900 (39PV, 39MV pilots)		NBCert # 18447
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/26/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

F.C. Kingston Company Division of Storm Manufacturing Group (KNG)

Nameplate Abbreviation: Kingston

Torrance, CA 90501United States

This Company Manufactures or Assembles:

Design Name: 110C

NBCert # 35008

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/18/2028

Design Type

[Safety Relief Valve] 110C
Capacity Tests: Sec. UV at Ladewig Valve Company on November 1, 1967
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.590 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.375 NPS		0.069 in ²	0.296 in	0.074 in	25-600 psi	Air	UV

Design Name: 112C (.250" Orif.) NBCert # 35019

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/22/2027

Design Type

[Safety Relief Valve] 112C (.250" Orif.)
Capacity Tests: Sec. UV at unknown lab on February 11, 1966
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.510 SCFM/PSIA; (alternate medium): 1.430 PPH/PSIA
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.375 NPS		0.049 in ²	0.25 in	0.062 in	25-450 psi	Air	UV
0.25-0.375 NPS		0.049 in ²	0.25 in	0.062 in	36-56 psi	Steam	UV

Design Name: 112C (.375" Orif.) NBCert # 35020

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/22/2027

Design Type

[Safety Relief Valve] 112C (.375" Orif.)
Capacity Tests: Sec. UV at Phillips Petroleum on February 11, 1966
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.780 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.11 in ²	0.375 in	0.094 in	25-300 psi	Air	UV

Design Name: 710D		NBCert # 35154
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/28/2031
Design Type		
[Safety Relief Valve] 710D Capacity Tests: Sec. UV at National Board Testing Lab on January 23, 2013 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.200 SCFM/PSIA; (alternate medium): 6.180 PPH/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.137 in ²	[D] 0.418 in	0.104 in	15-250 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.137 in ²	[D] 0.418 in	0.104 in	15-400 psi	Air	UV

Design Name: Fig. 114 & 115 (.219" Orif.)		NBCert # 35053
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/04/2028
Design Type		
[Safety Relief Valve] Fig. 114 & 115 (.219" Orif.) Capacity Tests: Sec. UV at Phillips Petroleum on May 8, 1961 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.520 SCFM/PSIA; (alternate medium): 1.460 PPH/PSIA Media - Test: Air/Gas; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS	Side NPS	0.038 in ²	0.219 in	0.055 in	25-300 psi	Air	UV
0.25 NPS	Side NPS	0.038 in ²	0.219 in	0.055 in	35-50 psi	Steam	UV

Design Name: Fig. 114 & 115 (.265 Orif.)		NBCert # 35064
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/24/2026
Design Type		
[Safety Relief Valve] Fig. 114 & 115 (.265 Orif.) Capacity Tests: Sec. UV at Phillips Petroleum on October 23, 1961 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.690 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375 NPS		0.055 in²	0.265 in	0.066 in	25-275 psi	Air	UV
Design Name: Fig. 114 & 115 (.312" Orif.)			NBCert #		35075		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		10/24/2026		
Design Type							
[Safety Relief Valve] Fig. 114 & 115 (.312" Orif.) Capacity Tests: Sec. UV at Phillips Petroleum on October 23, 1961 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.850 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.076 in²	0.312 in	0.078 in	25-275 psi	Air	UV
Design Name: Fig. 114 (.437" Orif.)			NBCert #		35031		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		10/24/2026		
Design Type							
[Safety Relief Valve] Fig. 114 (.437" Orif.) Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on January 17, 1982 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.600 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.15 in²	0.437 in	0.144 in	25-250 psi	Air	UV
Design Name: Fig. 114 (.625" Orif.)			NBCert #		35042		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		12/22/2026		
Design Type							
[Safety Relief Valve] Fig. 114 (.625" Orif.) Capacity Tests: Sec. UV at Phillips Petroleum on January 17, 1962 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.370 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.307 in²	0.625 in	0.156 in	25-250 psi	Air	UV
Design Name: Fig. 118C & 119 (.302" Orif.)			NBCert #		35086		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		05/04/2028		
Design Type							
[Safety Relief Valve] Fig. 118C & 119 (.302" Orif.) Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on June 4, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.070 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS		0.068 in²	0.295 in	0.074 in	25-300 psi	Air	UV
Design Name: Fig. 118C & 119 (.359" Orif.)			NBCert #		35097		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		03/12/2027		
Design Type							
[Safety Relief Valve] Fig. 118C & 119 (.359" Orif.) Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on June 24, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.540 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-0.5 NPS		0.101 in²	0.359 in	0.123 in	25-300 psi	Air	UV
Design Name: Fig. 118C & 119 (.578" Orif)			NBCert #		35109		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		04/13/2031		
Design Type							
[Safety Relief Valve] Fig. 118C & 119 (.578" Orif) Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on June 1, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.670 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS		0.262 in²	0.578 in	0.144 in	25-300 psi	Air	UV
Design Name: KHV25							
NBCert # 35211							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			09/27/2030	
Design Type							
[Safety Relief Valve] KHV25 HolderDesignation: Capacity Tests: Sec. UV at National Board Testing Lab on January 1, 1900 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.720 SCFM/PSIA; (alternate medium): 0.000 Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.375 NPS		0.049 in²	0.25 in	0.135 in	25-315 psi	Air	UV
Design Name: KNGM45							
NBCert # 35222							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			04/30/2031	
Design Type							
[Safety Relief Valve] KNGM45 HolderDesignation: Capacity Tests: Sec. UV at National Board Testing Lab on September 18, 2024 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.110 SCFM/PSIA; (alternate medium): 5.930 PPH/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.5, 0.75 NPS	0.145 in²	0.43 in	0.315 in	15-75 psi	Steam	UV
0.5-0.75 NPS	0.5, 0.75 NPS	0.145 in²	0.43 in	0.315 in	15-75 psi	Air	UV
Design Name: KSV10H							
NBCert # 35200							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			05/04/2028	

Design Type

[Safety Relief Valve] KSV10H
Capacity Tests: Sec. UV at National Board Testing Lab on March 7, 2022
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.467 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.25 NPS		0.0314 in ²	0.2 in	0.1 in	25-300 psi	Air	UV

Design Name: KSV25 (0.25 Orifice) NBCert # 35121

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

08/17/2030

Design Type

[Safety Relief Valve] KSV25 (0.25 Orifice)
Capacity Tests: Sec. UV at National Board Testing Lab on July 10, 1997
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.726 SCFM/PSIA; (alternate medium): 2.040 PPH/PSIA
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.375 NPS		0.049 in ²	0.25 in		20-450 psi	Air	UV
0.125-0.375 NPS		0.049 in ²	0.25 in		25-54 psi	Steam	UV

Design Name: KSV30 NBCert # 35187

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

07/29/2026

Design Type

[Safety Relief Valve] KSV30
Capacity Tests: Sec. UV at National Board Testing Lab on March 6, 2020
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.900 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.145 in ²	0.43 in	0.158 in	20-300 psi	Air	UV

Design Name: KSV35		NBCert #	35198
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	07/29/2026
Design Type			
[Safety Relief Valve] KSV35 Capacity Tests: Sec. UV at National Board Testing Lab on March 6, 2020 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.400 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS		0.233 in ²	0.545 in	0.2 in	20-300 psi	Air	UV

Design Name: KSV40		NBCert #	35176
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	07/29/2026
Design Type			
[Safety Relief Valve] KSV40 Capacity Tests: Sec. UV at National Board Testing Lab on June 26, 2020 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 7.070 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: F.C. Kingston Company Division of Storm Manufacturing Group {KNG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.25 NPS		0.478 in ²	0.78 in	0.3 in	20-300 psi	Air	UV

F.W. Webb Company (STP)		Nameplate Abbreviation: F.W. Webb Co	
Buffalo, NY 14215United States			

This Company Manufactures or Assembles:

Design Name: 119 Series		NBCert #	11361
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV, V	10/12/2028

Design Type

[Safety Valve] 119 Series
 Capacity Tests: Sec. UV, V at National Board Testing Lab on March 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Air	UV
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Steam	UV
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Steam	UV
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Steam	NV
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Steam	V
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Air	UV
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Steam	UV
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Steam	V
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Air	UV
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Steam	UV
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Steam	V
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Air	UV
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Steam	UV
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Steam	V

Design Name: 19 Series

NBCert # 11282

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	10/12/2028

Design Type

[Safety Valve] 19 Series
 Capacity Tests: Sec. UV, V at unknown lab on March 27, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.826 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.129 in ²	[D] 0.406 in	0.101 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.129 in ²	[D] 0.406 in	0.101 in	15-300 psi	Steam	UV, V
0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Air	UV
0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Steam	UV, V
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Air	UV
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Steam	UV, V
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Air	UV
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Steam	UV, V

Design Name: 500 Series

NBCert # 11462

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/12/2028

Design Type

[Safety Valve] 500 Series
 Capacity Tests: Sec. UV at National Board Testing Lab on June 12, 2000
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.861 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.129 in ²	[D] 0.406 in	0.102 in	15-2000 psi	Air	UV
0.5-0.75 NPS	.75, 1 NPS	0.129 in ²	[D] 0.406 in	0.102 in	15-2000 psi	Steam	UV
0.75-1 NPS	1.25 NPS	0.229 in ²	[E] 0.539 in	0.135 in	15-2000 psi	Air	UV
0.75-1 NPS	1.25 NPS	0.229 in ²	[E] 0.539 in	0.135 in	15-2000 psi	Steam	UV
1-1.25 NPS	1.5 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-2000 psi	Air	UV
1-1.25 NPS	1.5 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-2000 psi	Steam	UV
1.25-1.5 NPS	2 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-2000 psi	Air	UV
1.25-1.5 NPS	2 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-2000 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-2000 psi	Air	UV

1.5-2 NPS	2.5 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-2000 psi	Steam	UV
2 NPS	3 NPS	1.504 in ²	[J] 1.384 in	0.346 in	15-2000 psi	Air	UV
2 NPS	3 NPS	1.504 in ²	[J] 1.384 in	0.346 in	15-2000 psi	Steam	UV

Design Name: 500 Series (Liquids) NBCert # 11473

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/12/2028

Design Type

[Safety Relief Valve] 500 Series (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on February 25, 2000
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.689 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.129 in ²	[D] 0.406 in	0.102 in	15-1000 psi	Water	UV
0.75-1 NPS	1.25 NPS	0.229 in ²	[E] 0.539 in	0.135 in	15-1000 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-1000 psi	Water	UV
1.25-1.5 NPS	2 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-1000 psi	Water	UV
1.5-2 NPS	2.5 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-1000 psi	Water	UV
2 NPS	3 NPS	1.504 in ²	[J] 1.384 in	0.346 in	15-1000 psi	Water	UV

F.W. Webb Process Controls Division (SEV)

Nameplate Abbreviation: FW WEBB

Winslow, ME 04901 United States

This Company Manufactures or Assembles:

Design Name: 119 Series NBCert # 11361

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 12/13/2025

Design Type

[Safety Valve] 119 Series
Capacity Tests: Sec. UV, V at National Board Testing Lab on March 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Air	UV

1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Steam	UV
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Steam	UV
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Steam	NV
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Steam	V
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Air	UV
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Steam	UV
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Steam	V
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Air	UV
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Steam	UV
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Steam	V
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Air	UV
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Steam	UV
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Steam	V

Design Name:	19 Series	NBCert #	11282
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 01/14/2026

Design Type

[Safety Valve] 19 Series
Capacity Tests: Sec. UV, V at unknown lab on March 27, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.826 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.129 in ²	[D] 0.406 in	0.101 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.129 in ²	[D] 0.406 in	0.101 in	15-300 psi	Steam	UV, V
0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Air	UV
0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Steam	UV, V
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Air	UV
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Steam	UV, V

1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Steam	UV, V
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Air	UV
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Steam	UV, V

Design Name: Kunkle 6000, 6252 Series NBCert # 36324

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	05/11/2026

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V

2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 910 to 919

NBCert # 36100

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

05/11/2026

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name:	Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)	NBCert #	36111
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	05/11/2026	

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 , 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

Farris Brasil Industria de Valvulas Ltda. (FBV)

Nameplate Abbreviation: Farris Brasil

Sao Carlos-SP, Brazil

This Company Manufactures or Assembles:

Design Name:	2400	NBCert #	57451
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	06/09/2027	

Design Type

[Safety Relief Valve] 2400
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on August 28, 2019
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.817 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75-1 NPS	0.049 in ²	[B] 0.25 in	0.08 in	20-2000 psi	Air	UV
0.5-1 NPS	1-2 NPS	0.11 in ²	[D] 0.375 in	0.12 in	20-1410 psi	Air	UV
0.75-1 NPS	1-2 NPS	0.196 in ²	[E] 0.5 in	0.175 in	20-600 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.295 in	20-4000 psi	Air	UV

1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.365 in	20-3000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.435 in	20-2500 psi	Air	UV

Design Name: 2600 & 2600S NBCert # 57057

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/05/2026

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV

8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

11/05/2026

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV

3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids) NBCert # 57068

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/05/2026

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V

8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S NBCert # 57237

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/05/2026

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids) NBCert # 57248

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/05/2026

Design Type

[Relief Valve] 2700L, 3700L (Liquids)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.676 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800

NBCert #

57024

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

11/05/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3800

Capacity Tests: Sec. UV at unknown lab on May 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.859 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (3): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV

2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name: 3800FP

NBCert # 57035

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

11/05/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3800FP

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on April 26, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.801 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (3): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-1050 psi	Steam	UV
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-11300 psi	Air	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-1050 psi	Steam	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-11300 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-1050 psi	Steam	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-11300 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-1050 psi	Steam	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-11300 psi	Air	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-1050 psi	Steam	UV

4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-6300 psi	Air	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-6300 psi	Air	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-2300 psi	Air	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1500 psi	Air	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-800 psi	Steam	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-1500 psi	Air	UV

Design Name: 3800L, PCL, PCM pilots NBCert # 57215

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/05/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.782 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Farris Engineering (FEE)

Corby, NN17 5XZUnited Kingdom

This Company Manufactures or Assembles:

Design Name: 2400		NBCert # 57451
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/24/2028
Design Type		
[Safety Relief Valve] 2400 Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on August 28, 2019 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.817 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75-1 NPS	0.049 in ²	[B] 0.25 in	0.08 in	20-2000 psi	Air	UV
0.5-1 NPS	1-2 NPS	0.11 in ²	[D] 0.375 in	0.12 in	20-1410 psi	Air	UV
0.75-1 NPS	1-2 NPS	0.196 in ²	[E] 0.5 in	0.175 in	20-600 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.295 in	20-4000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.365 in	20-3000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.435 in	20-2500 psi	Air	UV

Design Name: 2600 & 2600S		NBCert # 57057
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/13/2025
Design Type		
[Safety Relief Valve] 2600 & 2600S Capacity Tests: Sec. UV at unknown lab on June 11, 1972 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.858 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV

1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)	NBCert # 57260
----------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	08/13/2025
--------------	----	------------

Design Type

[Safety Relief Valve] 2600L (Air & Steam)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV

8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV
----------	------------	----------------------	--------------	----------	------------	-------	----

Design Name: 2600L (Liquids)			NBCert # 57068				
Manufacturer/Assembler			Designators		Expiration Date		

Manufacturer UV 08/13/2025

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S			NBCert # 57237				
Manufacturer/Assembler			Designators		Expiration Date		

Manufacturer UV 08/13/2025

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	08/13/2025
--------------	----	------------

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800	NBCert # 57024
-------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	01/27/2026
--------------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 3800
Capacity Tests: Sec. UV at unknown lab on May 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV

8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name: 3800FP NBCert # 57035

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 08/13/2025

Design Type

[Pilot Operated Pressure Relief Valve] 3800FP
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on April 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-1050 psi	Steam	UV
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-11300 psi	Air	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-1050 psi	Steam	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-11300 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-1050 psi	Steam	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-11300 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-1050 psi	Steam	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-11300 psi	Air	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-6300 psi	Air	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-6300 psi	Air	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-2300 psi	Air	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1500 psi	Air	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-800 psi	Steam	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-1500 psi	Air	UV

Design Name: 3800L, PCL, PCM pilots NBCert # 57215

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/27/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots
 Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.782 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition(1): Pop; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Farris Engineering Division of Curtiss-Wright Flow Control (UK) Ltd.
(FED)

 Nameplate Abbreviation: Farris
 Engineering Div. of Curtiss-Wright F.C.
 UK LTD.

Northants, NN17 4AZ United Kingdom

This Company Manufactures or Assembles:

Design Name: 2400			NBCert # 57451					
Manufacturer/Assembler			Designators			Expiration Date		
Manufacturer			UV			02/28/2030		

Design Type

[Safety Relief Valve] 2400
 Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on August 28, 2019
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.817 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75-1 NPS	0.049 in ²	[B] 0.25 in	0.08 in	20-2000 psi	Air	UV
0.5-1 NPS	1-2 NPS	0.11 in ²	[D] 0.375 in	0.12 in	20-1410 psi	Air	UV
0.75-1 NPS	1-2 NPS	0.196 in ²	[E] 0.5 in	0.175 in	20-600 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.295 in	20-4000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.365 in	20-3000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.435 in	20-2500 psi	Air	UV

Design Name: 2600 & 2600S

NBCert # 57057

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/28/2030

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV

4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name:	2600 Series Restricted Lift version of Cert Number 57057	NBCert #	57406
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	02/28/2030
--------------	----	------------

Design Type

[Safety Relief Valve] 2600 Series Restricted Lift version of Cert Number 57057
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 10, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Air	UV
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Steam	UV
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Air	UV
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Steam	UV
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Air	UV
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Steam	UV
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.08 in	15-7000 psi	Air	UV
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.08 in	15-7000 psi	Steam	UV

1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.095 in	15-6000 psi	Air	UV
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.095 in	15-6000 psi	Steam	UV
2-3 in	3. 4 in	1.43 in ²	[J] 1.35 in	0.122 in	15-6000 psi	Air	UV
2-3 in	3. 4 in	1.43 in ²	[J] 1.35 in	0.122 in	15-6000 psi	Steam	UV
3 in	4, 6 in	2.042 in ²	[K] 1.612 in	0.145 in	15-5000 psi	Air	UV
3 in	4, 6 in	2.042 in ²	[K] 1.612 in	0.145 in	15-5000 psi	Steam	UV
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.181 in	15-4000 psi	Air	UV
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.181 in	15-4000 psi	Steam	UV
4 in	6 in	4 in ²	[M] 2.257 in	0.203 in	15-3000 psi	Air	UV
4 in	6 in	4 in ²	[M] 2.257 in	0.203 in	15-3000 psi	Steam	UV
4 in	6 in	4.822 in ²	[N] 2.478 in	0.223 in	15-3000 psi	Air	UV
4 in	6 in	4.822 in ²	[N] 2.478 in	0.223 in	15-3000 psi	Steam	UV
4 in	6 in	7.087 in ²	[P] 3.004 in	0.27 in	15-2500 psi	Air	UV
4 in	6 in	7.087 in ²	[P] 3.004 in	0.27 in	15-2500 psi	Steam	UV
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.356 in	15-2000 psi	Air	UV
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.356 in	15-2000 psi	Steam	UV
6 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.428 in	15-1500 psi	Air	UV
6 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.428 in	15-1500 psi	Steam	UV
8 in	10 in	28.94 in ²	[T] 6.07 in	0.546 in	15-1000 psi	Air	UV
8 in	10 in	28.94 in ²	[T] 6.07 in	0.546 in	15-1000 psi	Steam	UV
8 in	10 in	31.5 in ²	[U] 6.333 in	0.57 in	15-300 psi	Air	UV
8 in	10 in	31.5 in ²	[U] 6.333 in	0.57 in	15-300 psi	Steam	UV
10 in	14 in	49.4 in ²	[V] 7.93 in	0.714 in	15-1000 psi	Air	UV
10 in	14 in	49.4 in ²	[V] 7.93 in	0.714 in	15-1000 psi	Steam	UV
12 in	16 in	63.62 in ²	[W] 9 in	0.81 in	15-1000 psi	Air	UV
12 in	16 in	63.62 in ²	[W] 9 in	0.81 in	15-1000 psi	Steam	UV
16 in	18 in	104 in ²	[W2] 11.507 in	1.036 in	15-750 psi	Air	UV
16 in	18 in	104 in ²	[W2] 11.507 in	1.036 in	15-750 psi	Steam	UV
16 in	20 in	113.1 in ²	[X] 12 in	1.08 in	15-750 psi	Air	UV
16 in	20 in	113.1 in ²	[X] 12 in	1.08 in	15-750 psi	Steam	UV
18 in	24 in	143.1 in ²	[Y] 13.5 in	1.215 in	15-750 psi	Air	UV
18 in	24 in	143.1 in ²	[Y] 13.5 in	1.215 in	15-750 psi	Steam	UV
20 in	24 in	176.7 in ²	[Z] 15 in	1.35 in	15-750 psi	Air	UV
20 in	24 in	176.7 in ²	[Z] 15 in	1.35 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert # 57260

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/28/2030

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name:	2600L (Air & Steam) Series Restricted Lift version of Cert Number 57260	NBCert #	57439
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	02/28/2030
--------------	----	------------

Design Type

[Safety Relief Valve] 2600L (Air & Steam) Series Restricted Lift version of Cert Number 57260
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 6, 2018
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.08 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.08 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.08 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.089 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.089 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.111 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.111 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.142 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.142 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.169 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.169 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.211 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.211 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.237 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.237 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.26 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.26 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.315 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.315 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.415 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.415 in	15-2000 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	0.5 in	15-1500 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	0.5 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	0.638 in	15-1000 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	0.638 in	15-1000 psi	Steam	UV
8 NPS	10 NPS	31.5 in ²	[U] 6.333 in	0.665 in	15-300 psi	Air	UV

8 NPS	10 NPS	31.5 in ²	[U] 6.333 in	0.665 in	15-300 psi	Steam	UV
-------	--------	----------------------	--------------	----------	------------	-------	----

Design Name:	2600L (Liquids)	NBCert #	57068
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/28/2030

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name:	2600L (Liquids) Series Restricted Lift version of Cert Number 57068.	NBCert #	57417
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/28/2030

Design Type

[Safety Relief Valve] 2600L (Liquids) Series Restricted Lift version of Cert Number 57068.
Capacity Tests: Sec. UV, V at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on January 23, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Water	UV, V
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-6000 psi	Water	UV, V
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-5000 psi	Water	UV, V
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.098 in	15-3600 psi	Water	UV, V
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.122 in	15-2750 psi	Water	UV, V
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.156 in	15-2700 psi	Water	UV, V
3 in	4, 6 in	2.041 in ²	[K] 1.612 in	0.187 in	15-2200 psi	Water	UV, V
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.232 in	15-1500 psi	Water	UV, V
4 in	6 in	4 in ²	[M] 2.257 in	0.261 in	15-1100 psi	Water	UV, V
4 in	6 in	4.822 in ²	[N] 2.478 in	0.287 in	15-1000 psi	Water	UV, V
4 in	6 in	7.087 in ²	[P] 3.004 in	0.348 in	15-1000 psi	Water	UV, V
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.458 in	15-900 psi	Water	UV, V
6-8 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.551 in	15-600 psi	Water	UV, V
8 in	10 in	28.94 in ²	[T] 6.07 in	0.702 in	15-300 psi	Water	UV, V
8 in	10 in	31.5 in ²	[U] 6.333 in	0.741 in	15-300 psi	Water	UV, V

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/28/2030

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV

1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/28/2030

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name:	3800	NBCert #	57024
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/28/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3800
Capacity Tests: Sec. UV at unknown lab on May 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV

1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name: 3800FP	NBCert # 57035
---------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/28/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3800FP
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on April 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-1050 psi	Steam	UV
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-11300 psi	Air	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-1050 psi	Steam	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-11300 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-1050 psi	Steam	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-11300 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-1050 psi	Steam	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-11300 psi	Air	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-6300 psi	Air	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-6300 psi	Air	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-2300 psi	Air	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1500 psi	Air	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-800 psi	Steam	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-1500 psi	Air	UV

Design Name:	3800L PCM	NBCert #	57394
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	02/28/2030
--------------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 3800L PCM
Capacity Tests: Sec. UV at unknown lab on May 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless; (alternate medium): 0.782 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Initial Audible Discharge; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV

1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Design Name: 3800L, PCL, PCM pilots				NBCert # 57215			
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		02/28/2030		
Design Type							
[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.782 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition(1): Pop; (2): First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation (TFO)

Nameplate Abbreviation: Farris
Engineering Div. of Curtiss-Wright
F.C.C.

Brecksville, OH 44141United States

This Company Manufactures or Assembles:

Design Name: 1850, 1850H, 1851, 1852, 1855, 1856M, 2850, 2852, 2856, 2850H			NBCert # 57002	
Manufacturer/Assembler		Designators		Expiration Date
Manufacturer		UV		11/07/2029

Design Type

[Safety Relief Valve] 1850, 1850H, 1851, 1852, 1855, 1856M, 2850, 2852, 2856, 2850H

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on May 5, 1979

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.652 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Curtain Area

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1, 1.5 NPS	0.107 in ²	0.5 in	0.068 in	15-2500 psi	Air	UV
0.5-0.75 NPS	1, 1.5 NPS	0.107 in ²	0.5 in	0.068 in	15-800 psi	Steam	UV
0.75-1 NPS	1 - 1.5 NPS	0.24 in ²	0.75 in	0.102 in	15-800 psi	Air	UV
0.75-1 NPS	1 - 1.5 NPS	0.24 in ²	0.75 in	0.102 in	15-800 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.411 in ²	1 in	0.131 in	15-300 psi	Air	UV
1 NPS	1.5, 2 NPS	0.411 in ²	1 in	0.131 in	15-300 psi	Steam	UV
1.5 NPS	2, 2.5 NPS	0.668 in ²	1.25 in	0.17 in	15-200 psi	Air	UV
1.5 NPS	2, 2.5 NPS	0.668 in ²	1.25 in	0.17 in	15-200 psi	Steam	UV
1.5-1.5 NPS	2, 2.5 NPS	0.961 in ²	1.5 in	0.204 in	15-300 psi	Air	UV
1.5-1.5 NPS	2, 2.5 NPS	0.961 in ²	1.5 in	0.204 in	15-300 psi	Steam	UV
2-2.5 NPS	3 NPS	1.539 in ²	2 in	0.245 in	15-300 psi	Air	UV
2-2.5 NPS	3 NPS	1.539 in ²	2 in	0.245 in	15-300 psi	Steam	UV
2.5-3 NPS	4 NPS	2.662 in ²	2.5 in	0.339 in	15-250 psi	Air	UV
2.5-3 NPS	4 NPS	2.662 in ²	2.5 in	0.339 in	15-250 psi	Steam	UV
3 NPS	4 NPS	3.836 in ²	3 in	0.407 in	15-250 psi	Air	UV
3 NPS	4 NPS	3.836 in ²	3 in	0.407 in	15-250 psi	Steam	UV

Design Name: 1890, 1892, 1895, 1896

NBCert #

57013

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/02/2027

Design Type

[Safety Relief Valve] 1890, 1892, 1895, 1896

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 19, 1988

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 4.410 PPH/PSIA; (alternate medium): 1.570 SCFM/PSIA

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.094 in	15-800 psi	Air	UV
0.5-0.75 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.094 in	15-800 psi	Air	NV
0.5-0.75 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.094 in	15-800 psi	Steam	UV
0.5-0.75 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.094 in	15-800 psi	Steam	NV

Design Name: 1890L, 1892L, 1895L, 1896L (Liquids)		NBCert #	57192
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	08/02/2027
Design Type			
[Relief Valve] 1890L, 1892L, 1895L, 1896L (Liquids) Capacity Tests: Sec. UV at unknown lab on January 14, 1993 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.210 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	3/4, 1 NPS	0.11 in ²	0.375 in	0.08 in	15-800 psi	Water	UV

Design Name: 2400		NBCert #	57451
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	04/30/2031
Design Type			
[Safety Relief Valve] 2400 Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on August 28, 2019 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.817 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75-1 NPS	0.049 in ²	[B] 0.25 in	0.08 in	20-2000 psi	Air	UV
0.5-1 NPS	1-2 NPS	0.11 in ²	[D] 0.375 in	0.12 in	20-1410 psi	Air	UV
0.75-1 NPS	1-2 NPS	0.196 in ²	[E] 0.5 in	0.175 in	20-600 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.295 in	20-4000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.365 in	20-3000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.435 in	20-2500 psi	Air	UV

Design Name: 2600 & 2600S		NBCert #	57057
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	08/02/2027

Design Type

[Safety Relief Valve] 2600 & 2600S

Capacity Tests: Sec. UV at unknown lab on June 11, 1972

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable (Single Ring)

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV

12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600 Series Restricted Lift version of Cert Number 57057 NBCert # 57406

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 08/31/2029

Design Type

[Safety Relief Valve] 2600 Series Restricted Lift version of Cert Number 57057
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 10, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Air	UV
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Steam	UV
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Air	UV
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Steam	UV
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Air	UV
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Steam	UV
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.08 in	15-7000 psi	Air	UV
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.08 in	15-7000 psi	Steam	UV
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.095 in	15-6000 psi	Air	UV
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.095 in	15-6000 psi	Steam	UV
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.122 in	15-6000 psi	Air	UV
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.122 in	15-6000 psi	Steam	UV
3 in	4, 6 in	2.042 in ²	[K] 1.612 in	0.145 in	15-5000 psi	Air	UV
3 in	4, 6 in	2.042 in ²	[K] 1.612 in	0.145 in	15-5000 psi	Steam	UV
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.181 in	15-4000 psi	Air	UV
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.181 in	15-4000 psi	Steam	UV
4 in	6 in	4 in ²	[M] 2.257 in	0.203 in	15-3000 psi	Air	UV
4 in	6 in	4 in ²	[M] 2.257 in	0.203 in	15-3000 psi	Steam	UV
4 in	6 in	4.822 in ²	[N] 2.478 in	0.223 in	15-3000 psi	Air	UV
4 in	6 in	4.822 in ²	[N] 2.478 in	0.223 in	15-3000 psi	Steam	UV

4 in	6 in	7.087 in ²	[P] 3.004 in	0.27 in	15-2500 psi	Air	UV
4 in	6 in	7.087 in ²	[P] 3.004 in	0.27 in	15-2500 psi	Steam	UV
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.356 in	15-2000 psi	Air	UV
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.356 in	15-2000 psi	Steam	UV
6 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.428 in	15-1500 psi	Air	UV
6 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.428 in	15-1500 psi	Steam	UV
8 in	10 in	28.94 in ²	[T] 6.07 in	0.546 in	15-1000 psi	Air	UV
8 in	10 in	28.94 in ²	[T] 6.07 in	0.546 in	15-1000 psi	Steam	UV
8 in	10 in	31.5 in ²	[U] 6.333 in	0.57 in	15-300 psi	Air	UV
8 in	10 in	31.5 in ²	[U] 6.333 in	0.57 in	15-300 psi	Steam	UV
10 in	14 in	49.4 in ²	[V] 7.93 in	0.714 in	15-1000 psi	Air	UV
10 in	14 in	49.4 in ²	[V] 7.93 in	0.714 in	15-1000 psi	Steam	UV
12 in	16 in	63.62 in ²	[W] 9 in	0.81 in	15-1000 psi	Air	UV
12 in	16 in	63.62 in ²	[W] 9 in	0.81 in	15-1000 psi	Steam	UV
16 in	18 in	104 in ²	[W2] 11.507 in	1.036 in	15-750 psi	Air	UV
16 in	18 in	104 in ²	[W2] 11.507 in	1.036 in	15-750 psi	Steam	UV
16 in	20 in	113.1 in ²	[X] 12 in	1.08 in	15-750 psi	Air	UV
16 in	20 in	113.1 in ²	[X] 12 in	1.08 in	15-750 psi	Steam	UV
18 in	24 in	143.1 in ²	[Y] 13.5 in	1.215 in	15-750 psi	Air	UV
18 in	24 in	143.1 in ²	[Y] 13.5 in	1.215 in	15-750 psi	Steam	UV
20 in	24 in	176.7 in ²	[Z] 15 in	1.35 in	15-750 psi	Air	UV
20 in	24 in	176.7 in ²	[Z] 15 in	1.35 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	07/06/2026

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV

1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name:	2600L (Air & Steam) Series Restricted Lift version of Cert Number 57260	NBCert #	57439
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	07/17/2030
--------------	----	------------

Design Type

[Safety Relief Valve] 2600L (Air & Steam) Series Restricted Lift version of Cert Number 57260
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 6, 2018
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.08 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.08 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.08 in	15-2900 psi	Steam	UV

1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.089 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.089 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.111 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.111 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.142 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.142 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.169 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.169 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.211 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.211 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.237 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.237 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.26 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.26 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.315 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.315 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.415 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.415 in	15-2000 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	0.5 in	15-1500 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	0.5 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	0.638 in	15-1000 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	0.638 in	15-1000 psi	Steam	UV
8 NPS	10 NPS	31.5 in ²	[U] 6.333 in	0.665 in	15-300 psi	Air	UV
8 NPS	10 NPS	31.5 in ²	[U] 6.333 in	0.665 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids) NBCert # 57068

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	08/07/2027

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V

2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2600L (Liquids) Series Restricted Lift version of Cert Number 57068. NBCert # 57417

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 06/12/2029

Design Type

[Safety Relief Valve] 2600L (Liquids) Series Restricted Lift version of Cert Number 57068.
Capacity Tests: Sec. UV, V at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on January 23, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Water	UV, V
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-6000 psi	Water	UV, V
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-5000 psi	Water	UV, V
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.098 in	15-3600 psi	Water	UV, V
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.122 in	15-2750 psi	Water	UV, V
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.156 in	15-2700 psi	Water	UV, V
3 in	4, 6 in	2.041 in ²	[K] 1.612 in	0.187 in	15-2200 psi	Water	UV, V
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.232 in	15-1500 psi	Water	UV, V
4 in	6 in	4 in ²	[M] 2.257 in	0.261 in	15-1100 psi	Water	UV, V
4 in	6 in	4.822 in ²	[N] 2.478 in	0.287 in	15-1000 psi	Water	UV, V
4 in	6 in	7.087 in ²	[P] 3.004 in	0.348 in	15-1000 psi	Water	UV, V
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.458 in	15-900 psi	Water	UV, V
6-8 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.551 in	15-600 psi	Water	UV, V
8 in	10 in	28.94 in ²	[T] 6.07 in	0.702 in	15-300 psi	Water	UV, V
8 in	10 in	31.5 in ²	[U] 6.333 in	0.741 in	15-300 psi	Water	UV, V

Design Name: 2600M	NBCert # 57226
--------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/09/2030

Design Type

[Safety Relief Valve] 2600M
HolderDesignation:
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on November 7, 2024
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless; (alternate medium): 0.689 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Water/Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-3600 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-3600 psi	Water	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2750 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2750 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2700 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2700 psi	Water	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2200 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2200 psi	Water	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-1500 psi	Water	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-1100 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-1000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-1000 psi	Water	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-1000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-1000 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-600 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-600 psi	Water	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-300 psi	Water	UV

8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Water	UV

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	08/02/2027
--------------	----	------------

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
 Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	08/07/2027
--------------	----	------------

Design Type

[Relief Valve] 2700L, 3700L (Liquids)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.676 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800

NBCert #

57024

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

08/02/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3800

Capacity Tests: Sec. UV at unknown lab on May 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.859 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (3): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV

2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name: 3800FP

NBCert # 57035

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

08/01/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3800FP
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on April 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-1050 psi	Steam	UV
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-11300 psi	Air	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-1050 psi	Steam	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-11300 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-1050 psi	Steam	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-11300 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-1050 psi	Steam	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-11300 psi	Air	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-1050 psi	Steam	UV

4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-6300 psi	Air	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-6300 psi	Air	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-2300 psi	Air	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1500 psi	Air	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-800 psi	Steam	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-1500 psi	Air	UV

Design Name:	3800L PCM	NBCert #	57394
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/31/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3800L PCM
Capacity Tests: Sec. UV at unknown lab on May 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless; (alternate medium): 0.782 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Initial Audible Discharge; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV

2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Design Name: 3800L, PCL, PCM pilots

NBCert #

57215

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

04/27/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.782 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV

1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Design Name: 4200 / 4400

NBCert #

57282

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV, V

10/10/2027

Design Type

[Safety Valve] 4200 / 4400
Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.872 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

Design Name:	6400/6600 (previously 2500 & 4600)	NBCert #	57046
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV, V	07/16/2027
--------------	-------	------------

Design Type

[Safety Valve] 6400/6600 (previously 2500 & 4600)
Capacity Tests: Sec. UV, V at Ohio State University (Robinson Laboratory) on January 28, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	V
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	V
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	V
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Air	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	V
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	V

3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Air	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	V
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	V
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	UV

Farris Engineering, Division of Curtiss-Wright Flow Control Corporation (FIC)

Nameplate Abbreviation: Farris Engineering, Div. of Curtiss-Wright F.C.C.

Brantford, ON N3T 5M1Canada

This Company Manufactures or Assembles:

Design Name:	1850, 1850H, 1851, 1852, 1855, 1856M, 2850, 2852, 2856, 2850H	NBCert #	57002
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/18/2030

Design Type

[Safety Relief Valve] 1850, 1850H, 1851, 1852, 1855, 1856M, 2850, 2852, 2856, 2850H
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on May 5, 1979
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1, 1.5 NPS	0.107 in ²	0.5 in	0.068 in	15-2500 psi	Air	UV
0.5-0.75 NPS	1, 1.5 NPS	0.107 in ²	0.5 in	0.068 in	15-800 psi	Steam	UV
0.75-1 NPS	1 - 1.5 NPS	0.24 in ²	0.75 in	0.102 in	15-800 psi	Air	UV
0.75-1 NPS	1 - 1.5 NPS	0.24 in ²	0.75 in	0.102 in	15-800 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.411 in ²	1 in	0.131 in	15-300 psi	Air	UV
1 NPS	1.5, 2 NPS	0.411 in ²	1 in	0.131 in	15-300 psi	Steam	UV
1.5 NPS	2, 2.5 NPS	0.668 in ²	1.25 in	0.17 in	15-200 psi	Air	UV
1.5 NPS	2, 2.5 NPS	0.668 in ²	1.25 in	0.17 in	15-200 psi	Steam	UV
1.5-1.5 NPS	2, 2.5 NPS	0.961 in ²	1.5 in	0.204 in	15-300 psi	Air	UV

1.5-1.5 NPS	2, 2.5 NPS	0.961 in ²	1.5 in	0.204 in	15-300 psi	Steam	UV
2-2.5 NPS	3 NPS	1.539 in ²	2 in	0.245 in	15-300 psi	Air	UV
2-2.5 NPS	3 NPS	1.539 in ²	2 in	0.245 in	15-300 psi	Steam	UV
2.5-3 NPS	4 NPS	2.662 in ²	2.5 in	0.339 in	15-250 psi	Air	UV
2.5-3 NPS	4 NPS	2.662 in ²	2.5 in	0.339 in	15-250 psi	Steam	UV
3 NPS	4 NPS	3.836 in ²	3 in	0.407 in	15-250 psi	Air	UV
3 NPS	4 NPS	3.836 in ²	3 in	0.407 in	15-250 psi	Steam	UV

Design Name:	1890, 1892, 1895, 1896	NBCert #	57013
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV, UV 10/15/2027

Design Type

[Safety Relief Valve] 1890, 1892, 1895, 1896
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 4.410 PPH/PSIA; (alternate medium): 1.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.094 in	15-800 psi	Air	UV
0.5-0.75 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.094 in	15-800 psi	Air	NV
0.5-0.75 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.094 in	15-800 psi	Steam	UV
0.5-0.75 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.094 in	15-800 psi	Steam	NV

Design Name:	1890L, 1892L, 1895L, 1896L (Liquids)	NBCert #	57192
--------------	--------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV, UV 12/17/2025

Design Type

[Relief Valve] 1890L, 1892L, 1895L, 1896L (Liquids)
Capacity Tests: Sec. UV at unknown lab on January 14, 1993
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.210 GPM/SQ. RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	3/4, 1 NPS	0.11 in ²	0.375 in	0.08 in	15-800 psi	Water	UV

Design Name:	2400	NBCert #	57451
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV, UV 03/14/2029

Design Type

[Safety Relief Valve] 2400
 Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on August 28, 2019
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.817 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75-1 NPS	0.049 in ²	[B] 0.25 in	0.08 in	20-2000 psi	Air	UV
0.5-1 NPS	1-2 NPS	0.11 in ²	[D] 0.375 in	0.12 in	20-1410 psi	Air	UV
0.75-1 NPS	1-2 NPS	0.196 in ²	[E] 0.5 in	0.175 in	20-600 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.295 in	20-4000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.365 in	20-3000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.435 in	20-2500 psi	Air	UV

Design Name: 2600 & 2600S NBCert # 57057

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, UV	09/18/2026

Design Type

[Safety Relief Valve] 2600 & 2600S
 Capacity Tests: Sec. UV at unknown lab on June 11, 1972
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.858 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV

3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

08/10/2026

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV

1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids)	NBCert # 57068
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	NV, UV	10/15/2027
--------------	--------	------------

Design Type

[Relief Valve] 2600L (Liquids)
 Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.652 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V

1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2600L (Liquids) Series Restricted Lift
version of Cert Number 57068.

NBCert #

57417

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

NV, UV

05/02/2030

Design Type

[Safety Relief Valve] 2600L (Liquids) Series Restricted Lift version of Cert Number 57068.

Capacity Tests: Sec. UV, V at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on January 23, 2017

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.652 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Restricted Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Water	UV, V
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-6000 psi	Water	UV, V
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-5000 psi	Water	UV, V
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.098 in	15-3600 psi	Water	UV, V
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.122 in	15-2750 psi	Water	UV, V
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.156 in	15-2700 psi	Water	UV, V
3 in	4, 6 in	2.041 in ²	[K] 1.612 in	0.187 in	15-2200 psi	Water	UV, V
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.232 in	15-1500 psi	Water	UV, V
4 in	6 in	4 in ²	[M] 2.257 in	0.261 in	15-1100 psi	Water	UV, V
4 in	6 in	4.822 in ²	[N] 2.478 in	0.287 in	15-1000 psi	Water	UV, V
4 in	6 in	7.087 in ²	[P] 3.004 in	0.348 in	15-1000 psi	Water	UV, V
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.458 in	15-900 psi	Water	UV, V
6-8 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.551 in	15-600 psi	Water	UV, V
8 in	10 in	28.94 in ²	[T] 6.07 in	0.702 in	15-300 psi	Water	UV, V

8 in 10 in 31.5 in² [U] 6.333 in 0.741 in 15-300 psi Water UV, V

Design Name: 2600L M-LBD		NBCert # 57114
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 2	01/20/2029
Design Type		
[Relief Valve] 2600L M-LBD Capacity Tests: Sec. NV, -Class 2 at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on January 19, 2023 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:87.464 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Farris Engineering, Division of Curtiss-Wright Flow Control Corporation {FIC}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 NPS	6 NPS	4.794 in ²	3.004 in	0.7 in	15-1100 psi	Water	NV, -Class 2

Design Name: 26JB14L-141/S3/SP		NBCert # 57125
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 1	04/06/2029
Design Type		
[Relief Valve] 26JB14L-141/S3/SP Capacity Tests: Sec. NV, -Class 1 at National Board Testing Lab on February 17, 2023 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:21.493 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Farris Engineering, Division of Curtiss-Wright Flow Control Corporation {FIC}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS	4 NPS	0.8 in ²	1.054 in	0.18 in	1400-1400 psi	Water	NV, -Class 1

Design Name: 2700, 2700S, 3700, 3700S		NBCert # 57237
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 1, -Class 2, -Class 3, UV	11/19/2030
Design Type		
[Safety Relief Valve] 2700, 2700S, 3700, 3700S Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV

0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids)

NBCert #

57248

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

NV, -Class 1, -Class 2, -Class 3, UV

10/18/2030

Design Type

[Relief Valve] 2700L, 3700L (Liquids)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.676 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 4200 / 4400		NBCert # 57282
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	10/17/2030
Design Type		
[Safety Valve] 4200 / 4400 Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.872 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

Design Name: 4700		NBCert # 57428
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 2, -Class 3	05/07/2029
Design Type		
[Safety Relief Valve] 4700 Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at National Board Testing Lab on October 13, 1993 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.458 SCFM/PSIA; (alternate medium): 1.287 PPH/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Annulus Designed by: Farris Engineering, Division of Curtiss-Wright Flow Control Corporation {FIC}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	0.75-1.5 NPS	0.028 in ²	[B] 0.395 in	0.02 in	15-6000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	0.75-1.5 NPS	0.028 in ²	[B] 0.395 in	0.02 in	15-6000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 4700L (liquids)		NBCert # 57259
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, UV	09/10/2026

Design Type

[Relief Valve] 4700L (liquids)
 Capacity Tests: Sec. NV, UV at National Board Testing Lab (Picaway) on May 21, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.654 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Annular
 Designed by: Farris Engineering, Division of Curtiss-Wright Flow Control Corporation {FIC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1, 1.5 NPS	0.028 in ²	[B] 0.395 in	0.047 in	15-6000 psi	Water	UV
0.5-1 NPS	.75, 1, 1.5 NPS	0.049 in ²	[C] 0.395 in	0.062 in	15-6000 psi	Water	UV
1 NPS	1.5 NPS	0.062 in ²	[C] 0.395 in	0.062 in	15-6000 psi	Water	UV
0.5-1 NPS	.75, 1, 1.5 NPS	0.123 in ²	[D] 0.66 in	0.099 in	15-6000 psi	Water	UV
0.5-1 NPS	.75, 1, 1.5 NPS	0.225 in ²	[E] 0.66 in	0.134 in	15-6000 psi	Water	UV

Design Name: 6400/6600 (previously 2500 & 4600) NBCert # 57046

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV, V

06/24/2027

Design Type

[Safety Valve] 6400/6600 (previously 2500 & 4600)
 Capacity Tests: Sec. UV, V at Ohio State University (Robinson Laboratory) on January 28, 1972
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.858 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	V
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	V
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Air	UV

2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	V
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Air	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	V
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Air	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	V
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	V
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	UV

Design Name: 954C55

NBCert # 57440

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

NV

12/11/2025

Design Type

[Vacuum Relief Valve] 954C55
Capacity Tests: Sec. NV, -Class 2, -Class 3 at National Board Testing Lab on December 11, 2019
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 23.300 SCFM/F(P*(P-Po))^{0.5}
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Farris Engineering, Division of Curtiss-Wright Flow Control Corporation {FIC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	2.776 in ²	1.88 in		-0.5--2.5 psi	Air	NV

Gyeongsangnam-do,, Republic of Korea

This Company Manufactures or Assembles:

Design Name:	KSRBKH	NBCert #	02260
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UD	10/13/2026	

Design Type

[Rupture Disk Device] KSRBKH
 HolderDesignation: BFS
 Capacity Tests: Sec. UD at National Board Testing Lab on November 20, 2019
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 3.540 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: FDC Co., Ltd. {FDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.46 in ²			116-1460 psi		UD
1 NPS		0.78 in ²			75-1460 psi		UD
1.5 NPS		1.7 in ²			58-1460 psi		UD
10 NPS		68.5 in ²			7-300 psi		UD
12 NPS		101 in ²			7-240 psi		UD
14 NPS		133 in ²			7-150 psi		UD
16 NPS		172 in ²			7-150 psi		UD
18 NPS		223.62 in ²			7-150 psi		UD
2 NPS		3.3 in ²			29-1460 psi		UD
2.5 NPS		4.75 in ²			18.5-880 psi		UD
20 NPS		277.91 in ²			7-150 psi		UD
24 NPS		401.93 in ²			7-150 psi		UD
26 NPS		476.14 in ²			7-100 psi		UD
28 NPS		556.63 in ²			7-100 psi		UD
3 NPS		7.35 in ²			16-880 psi		UD
30 NPS		643.41 in ²			7-80 psi		UD
32 NPS		736.47 in ²			7-80 psi		UD
34 NPS		835.81 in ²			7-80 psi		UD
36 NPS		934.6 in ²			7-80 psi		UD
38 NPS		998.24 in ²			7-80 psi		UD
4 NPS		12.4 in ²			9.2-730 psi		UD
40 NPS		1130.35 in ²			7-80 psi		UD
5 NPS		18.63 in ²			8.7-730 psi		UD

6 NPS	27.75 in ²	7.5-1070 psi	UD
8 NPS	43.84 in ²	7.5-440 psi	UD

Design Name: KSRC	NBCert # 00695
-------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	01/04/2030
--------------	----	------------

Design Type

[Rupture Disk Device] KSRC
HolderDesignation: SS
Capacity Tests: Sec. UD at National Board Testing Lab on March 30, 2016
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.750 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: FDC Co., Ltd. {FDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.48 in ²			30-4640 psi		UD
1 NPS		0.66 in ²			30-4640 psi		UD
1.5 NPS		1.69 in ²			23-2900 psi		UD
10 NPS		73.56 in ²			6-900 psi		UD
12 NPS		105.8 in ²			6-720 psi		UD
14 NPS		133.82 in ²			4-720 psi		UD
16 NPS		179.3 in ²			4-720 psi		UD
18 NPS		210.87 in ²			4-720 psi		UD
2 NPS		3.04 in ²			30-2900 psi		UD
2.5 NPS		4.77 in ²			26-2770 psi		UD
20 NPS		271.16 in ²			3.5-580 psi		UD
24 NPS		398.24 in ²			4-580 psi		UD
26 NPS		500 in ²			4-170 psi		UD
28 NPS		583 in ²			4-170 psi		UD
3 NPS		7.09 in ²			20-2770 psi		UD
30 NPS		671 in ²			4-170 psi		UD
32 NPS		766 in ²			4-170 psi		UD
36 NPS		975 in ²			4-170 psi		UD
4 NPS		11.41 in ²			14.5-2480 psi		UD
40 NPS		1209 in ²			4-170 psi		UD
42 NPS		1336 in ²			4-170 psi		UD
44 NPS		1469 in ²			4-170 psi		UD
5 NPS		15.27 in ²			14-2480 psi		UD
6 NPS		25.36 in ²			12-2390 psi		UD
8 NPS		46.09 in ²			8-1750 psi		UD

Design Name: KSRO	NBCert # 01539
-------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	10/17/2030
--------------	----	------------

Design Type

[Rupture Disk Device] KSRO
HolderDesignation: N/A
Capacity Tests: Sec. UD at National Board Testing Lab on February 14, 2018
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.490 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: FDC Co., Ltd. {FDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.3 in ²			50-150 psi		UD
0.75 NPS		0.52 in ²			33-150 psi		UD
1 NPS		0.84 in ²			15-150 psi		UD
1.5 NPS		1.98 in ²			15-150 psi		UD
10 NPS		73.89 in ²			1-60 psi		UD
12 NPS		106.4 in ²			1-60 psi		UD
14 NPS		133.92 in ²			1-60 psi		UD
16 NPS		177.4 in ²			1-60 psi		UD
18 NPS		226.98 in ²			1-60 psi		UD
2 NPS		3.26 in ²			12-150 psi		UD
2.5 NPS		4.65 in ²			8-150 psi		UD
20 NPS		282.66 in ²			1-60 psi		UD
22 NPS		344.75 in ²			1-60 psi		UD
24 NPS		412.33 in ²			1-60 psi		UD
26 NPS		486.32 in ²			1-40 psi		UD
28 NPS		566.41 in ²			1-40 psi		UD
3 NPS		7.18 in ²			2-150 psi		UD
30 NPS		652.6 in ²			1-40 psi		UD
32 NPS		744.89 in ²			1-40 psi		UD
34 NPS		843.29 in ²			1-40 psi		UD
36 NPS		947.79 in ²			1-40 psi		UD
38 NPS		1066 in ²			1-40 psi		UD
4 NPS		11.82 in ²			2-150 psi		UD
40 NPS		1175.09 in ²			1-40 psi		UD
42 NPS		1301.86 in ²			1-40 psi		UD
44 NPS		1430.54 in ²			1-40 psi		UD
46 NPS		1561.81 in ²			1-40 psi		UD
48 NPS		1702.47 in ²			1-40 psi		UD
6 NPS		26.6 in ²			1-100 psi		UD

8 NPS	47.45 in²	1-100 psi	UD
-------	-----------	-----------	----

Design Name: KSRSR		NBCert #	00943
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	08/18/2028

Design Type
[Rupture Disk Device] KSRSR HolderDesignation: FS, FS(SP), FS(PT) Full Bolted Capacity Tests: Sec. UD at National Board Testing Lab on March 30, 2016 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.680 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: FDC Co., Ltd. {FDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.3 in²			190-1460 psi		UD
0.75 NPS		0.53 in²			80-1460 psi		UD
1 NPS		0.86 in²			80-1460 psi		UD
1.5 NPS		2.03 in²			34-1460 psi		UD
10 NPS		63.87 in²			28-300 psi		UD
12 NPS		102.78 in²			28-240 psi		UD
14 NPS		137.92 in²			28-150 psi		UD
16 NPS		176.41 in²			28-150 psi		UD
18 NPS		221.57 in²			28-150 psi		UD
2 NPS		3.17 in²			40-1460 psi		UD
2.5 NPS		4.77 in²			40-880 psi		UD
20 NPS		272.62 in²			28-150 psi		UD
24 NPS		393.13 in²			28-150 psi		UD
26 NPS		500 in²			20-100 psi		UD
28 NPS		583 in²			20-100 psi		UD
3 NPS		7.38 in²			28-880 psi		UD
30 NPS		671 in²			15-80 psi		UD
32 NPS		766 in²			15-80 psi		UD
4 NPS		11.61 in²			28-730 psi		UD
5 NPS		19.55 in²			28-730 psi		UD
6 NPS		28.71 in²			28-1070 psi		UD
8 NPS		49.23 in²			28-440 psi		UD

Design Name: KSRSR(C)		NBCert #	01528
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	10/17/2030

Design Type

[Rupture Disk Device] KSRSR(C)
 HolderDesignation: FS
 Capacity Tests: Sec. UD at National Board Testing Lab on November 17, 2017
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.590 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: FDC Co., Ltd. {FDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.3 in ²			65-2160 psi		UD
0.75 NPS		0.53 in ²			43.5-2160 psi		UD
1 NPS		0.86 in ²			43.5-2160 psi		UD
1.5 NPS		1.86 in ²			20-2160 psi		UD
10 NPS		64.44 in ²			5-720 psi		UD
12 NPS		86.59 in ²			5-720 psi		UD
14 NPS		118.04 in ²			4-131 psi		UD
16 NPS		143.49 in ²			4-131 psi		UD
18 NPS		180.57 in ²			4-131 psi		UD
2 NPS		2.78 in ²			13-1523 psi		UD
2.5 NPS		4.42 in ²			15-1305 psi		UD
20 NPS		216.05 in ²			4-131 psi		UD
24 NPS		315.73 in ²			4-131 psi		UD
26 NPS		365.51 in ²			4-131 psi		UD
28 NPS		444.5 in ²			4-131 psi		UD
3 NPS		7.06 in ²			10-1440 psi		UD
30 NPS		521.25 in ²			4-131 psi		UD
32 NPS		616.4 in ²			4-131 psi		UD
4 NPS		10.12 in ²			5-1440 psi		UD
5 NPS		16.53 in ²			5-1440 psi		UD
6 NPS		24.48 in ²			5-870 psi		UD
8 NPS		40.5 in ²			5-800 psi		UD

Fike Corporation (FIK)

Nameplate Abbreviation: Fike

Blue Springs, MO 64015United States

This Company Manufactures or Assembles:

Design Name: 1" RD540 SC

NBCert # 80165

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UD

04/11/2030

Design Type

[Rupture Disk Device] 1" RD540 SC
HolderDesignation: None
Capacity Tests: Sec. UD at Fike Corporation on March 5, 2024
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 1.200 Unitless; (alternate medium): 0.000
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.501 in ²			15-25 psi		UD

Design Name: 1/2 " P ST FS NBCert # 80525

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

10/10/2026

Design Type

[Rupture Disk Device] 1/2 " P ST FS
HolderDesignation: Screw type flat seat
Capacity Tests: Sec. UD at Fike Corporation on February 9, 2004
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl
Certified Value: 5.390 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.15 in ²	0.438 in		42-15000 psi		UD
0.5 NPS		0.196 in ²	0.5 in		42-10000 psi		UD

Design Name: 1/2 " SCR D ST FS Cross Scored NBCert # 80536

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

10/09/2026

Design Type

[Rupture Disk Device] 1/2 " SCR D ST FS Cross Scored
HolderDesignation: Screw type flat seat
Capacity Tests: Sec. UD at Fike Corporation on March 20, 2003
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl
Certified Value: 5.390 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.15 in ²	0.438 in		450-15000 psi		UD
0.5 NPS		0.196 in ²	0.5 in		450-10000 psi		UD

Design Name:	1/2 " SCRD ST FS Double Hinge	NBCert #	80547
--------------	-------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	10/09/2026
--------------	----	------------

Design Type

[Rupture Disk Device] 1/2 " SCRD ST FS Double Hinge
HolderDesignation: Screw type flat seat
Capacity Tests: Sec. UD at Fike Corporation on March 17, 2003
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl
Certified Value: 5.390 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.15 in ²	0.438 in		80-15000 psi		UD
0.5 NPS		0.196 in ²	0.5 in		80-10000 psi		UD

Design Name:	1/2" Poly SD Cross Score	NBCert #	80356
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	06/12/2030
--------------	----	------------

Design Type

[Rupture Disk Device] 1/2" Poly SD Cross Score
HolderDesignation: Poly-SD
Capacity Tests: Sec. UD at Fike Corporation on March 8, 2002
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 2.390 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.196 in ²			450-4500 psi		UD

Design Name:	1/2" Poly SD Cross Score (liquid)	NBCert #	80345
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	09/13/2030
--------------	----	------------

Design Type

[Rupture Disk Device] 1/2" Poly SD Cross Score (liquid)
HolderDesignation: Poly SD
Capacity Tests: Sec. UD at Fike Corporation on March 12, 2002
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krl
Certified Value: 5.710 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.196 in ²			450-4500 psi		UD

Design Name: 1/2" Poly SD Double Hinge (DH)		NBCert #	80299
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	04/15/2029
Design Type			
[Rupture Disk Device] 1/2" Poly SD Double Hinge (DH) HolderDesignation: Poly-SD Capacity Tests: Sec. UD at Fike Corporation on February 13, 2002 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 3.040 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Fike Corporation {FIK}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.196 in ²			80-3000 psi		UD

Design Name: 1/2" Poly SD Double Hinge (DH) liquid		NBCert #	80301
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	04/13/2029
Design Type			
[Rupture Disk Device] 1/2" Poly SD Double Hinge (DH) liquid HolderDesignation: Poly-SD Capacity Tests: Sec. UD at Fike Corporation on February 13, 2002 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krl Certified Value: 5.300 Unitless Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Fike Corporation {FIK}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.196 in ²			80-3000 psi		UD

Design Name: 3/4" Poly SD Double Hinge (DH)		NBCert #	80288
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	05/16/2030
Design Type			
[Rupture Disk Device] 3/4" Poly SD Double Hinge (DH) HolderDesignation: Poly-SD Capacity Tests: Sec. UD at Fike Corporation on February 25, 2002 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 2.400 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Fike Corporation {FIK}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.442 in ²			50-2500 psi		UD

Design Name:	A10423-X w. P type disk	NBCert #	80772
--------------	-------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD3	08/26/2031
--------------	-----	------------

Design Type

[Rupture Disk Device] A10423-X w. P type disk
HolderDesignation: Union Type
Media - ; Certified: Air, Gas, Liquid
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}
Comments: Sizes listed in table are tubing sizes. 1/4" Disk is used for all sizes listed in table.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125 NPS		0.04 in ²			5000-66000 psi		UD3
0.25 NPS		0.09 in ²			5000-66000 psi		UD3
0.375 NPS		0.125 in ²			5000-66000 psi		UD3
0.5625 NPS		0.188 in ²			5000-66000 psi		UD3

Design Name:	A8457-X with A8483-5 Housing	NBCert #	80255
--------------	------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	01/30/2026
--------------	----	------------

Design Type

[Rupture Disk Device] A8457-X with A8483-5 Housing
HolderDesignation: A8483-5
Capacity Tests: Sec. UD at National Board Testing Lab on November 9, 2000
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 7.490 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.132 in ²			275-3500 psi		UD

Design Name:	A8701-X	NBCert #	80402
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	10/18/2030
--------------	----	------------

Design Type

[Rupture Disk Device] A8701-X
Capacity Tests: Sec. UD at Fike Corporation on November 8, 2002
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 2.750 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		2.45 in ²	[-1]		150-1300 psi		UD
3 NPS		5.33 in ²	[-2]		100-1300 psi		UD
3 NPS		4.97 in ²	[-4]		100-1300 psi		UD
4 NPS		9.1 in ²	[-3]		100-1300 psi		UD
5 NPS		13.51 in ²			100-1300 psi		UD
6 NPS		21.9 in ²	[-5]		75-1300 psi		UD
8 NPS		31 in ²	[6,7]		75-1300 psi		UD

Design Name:	A9111-X	NBCert #	80659
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	10/31/2025
--------------	----	------------

Design Type

[Rupture Disk Device] A9111-X
HolderDesignation: A8483-2
Capacity Tests: Sec. UD at Fike Corporation on November 21, 2007
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 2.580 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.5 NPS	0.302 in ²			16-100 psi		UD

Design Name:	A9225-X	NBCert #	80671
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	10/04/2026
--------------	----	------------

Design Type

[Rupture Disk Device] A9225-X
HolderDesignation: A8509-3
Capacity Tests: Sec. UD at Fike Corporation on April 10, 2008
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 0.550 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS	3 NPS	7.393 in ²			14-50 psi		UD

Design Name:	A9930-X	NBCert #	80110
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	09/22/2027
--------------	----	------------

Design Type							
[Rupture Disk Device] A9930-X HolderDesignation: N/A-Integral Welded Assembly Capacity Tests: Sec. UD at Fike Corporation on July 20, 2021 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 8.150 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Fike Corporation {FIK}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 in					1346-2625 psi		UD

Design Name:		Atlas, RD300, & RD500 Double Disc		NBCert #	80783	
Manufacturer/Assembler			Designators		Expiration Date	
Manufacturer			UD		11/21/2025	
Design Type						

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
Design Name:	Atlas, RD300, & RD500 Double Disc (Liquid)			NBCert #	80794		
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			11/21/2025	
Design Type							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
Design Name:		ATLAS, RD300, RD500		NBCert #	80716		
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			03/29/2030	
Design Type							

[Rupture Disk Device] ATLAS, RD300, RD500
 HolderDesignation: Atlas
 Capacity Tests: Sec. UD at Fike Corporation on February 27, 2012
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.650 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.7 in ²			200-1500 psi	Air	UD
1.5 NPS		1.8 in ²			120-1200 psi	Air	UD
10 NPS		61.3 in ²			50-520 psi	Air	UD
12 NPS		89.2 in ²			50-425 psi	Air	UD
14 NPS		117 in ²			6-300 psi	Air	UD
16 NPS		153 in ²			5-250 psi	Air	UD
18 NPS		195 in ²			5-200 psi	Air	UD
2 NPS		2.93 in ²			75-1060 psi	Air	UD
20 NPS		239 in ²			4.5-180 psi	Air	UD
24 NPS		346 in ²			3.5-150 psi	Air	UD
26 NPS		408 in ²			3.5-150 psi	Air	UD
28 NPS		474 in ²			3.5-150 psi	Air	UD
3 NPS		6.35 in ²			60-865 psi	Air	UD
30 NPS		541 in ²			3.5-140 psi	Air	UD
32 NPS		617 in ²			3.25-125 psi	Air	UD
36 NPS		784 in ²			3.25-100 psi	Air	UD
4 NPS		10.9 in ²			60-750 psi	Air	UD
42 NPS		1066 in ²			3.25-115 psi	Air	UD
6 NPS		22.1 in ²			165-290 psi	Air	UD
8 NPS		39.4 in ²			50-525 psi	Air	UD

Design Name:	ATLAS, RD300, RD500 (Liquid)	NBCert #	80727
--------------	------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 05/17/2030

Design Type

[Rupture Disk Device] ATLAS, RD300, RD500 (Liquid)
Capacity Tests: Sec. UD at Fike Corporation on February 27, 2012
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 1.500 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.7 in ²			200-1500 psi	Water	UD
1.5 NPS		1.8 in ²			120-1200 psi	Water	UD
10 NPS		61.3 in ²			50-520 psi	Water	UD
12 NPS		89.2 in ²			50-425 psi	Water	UD
2 NPS		2.93 in ²			75-1060 psi	Water	UD
3 NPS		6.35 in ²			60-865 psi	Water	UD
4 NPS		10.9 in ²			60-750 psi	Water	UD

6 NPS	22.1 in ²	165-290 psi	Water	UD
8 NPS	39.4 in ²	50-525 psi	Water	UD

Design Name:	Axius SC	NBCert #	80626
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 11/19/2029

Design Type

[Rupture Disk Device] Axius SC
 HolderDesignation: Axius SC Sanitary
 Capacity Tests: Sec. UD at Fike Corporation on June 26, 2007
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 1.880 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.41 in ²			25-275 psi		UD
1.5 NPS		1.109 in ²			10-200 psi		UD
2 NPS		2.111 in ²			10-145 psi		UD
3 NPS		5.007 in ²			10-80 psi		UD
38 DN		1.109 in ²			10-200 psi		UD
4 NPS		9.022 in ²			10-60 psi		UD
40 DN		1.33 in ²			10-170 psi		UD
50 DN		2.111 in ²			10-140 psi		UD
51 DN		2.111 in ²			10-140 psi		UD
76 DN		5.007 in ²			10-80 psi		UD

Design Name:	Axius, RD320, RD520	NBCert #	80558
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 12/10/2027

Design Type

[Rupture Disk Device] Axius, RD320, RD520
 HolderDesignation: SRL, SRLO - GI, -TQ
 Capacity Tests: Sec. UD at Fike Corporation on September 19, 2005
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 0.450 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			9.2-65 psi		UD
1.5 NPS		2.04 in ²			8-65 psi		UD
10 NPS		64.9 in ²			8-50 psi		UD
12 NPS		94.2 in ²			8-35 psi		UD

2 NPS	3.36 in ²	8-65 psi	UD
3 NPS	7.39 in ²	6.9-65 psi	UD
4 NPS	12.7 in ²	6.7-65 psi	UD
6 NPS	23.6 in ²	8-65 psi	Air UD
8 NPS	41.8 in ²	8-65 psi	Air UD

Design Name: Axius, RD320, RD520 (gas) NBCert # 80615

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 05/24/2028

Design Type

[Rupture Disk Device] Axius, RD320, RD520 (gas)
HolderDesignation: XL, GI
Capacity Tests: Sec. UD at Fike Corporation on September 6, 2006
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.450 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			65-600 psi		UD
1.5 NPS		2.04 in ²			65-385 psi		UD
10 NPS		59.5 in ²			50-100 psi		UD
12 NPS		86.4 in ²			35-70 psi		UD
2 NPS		3.36 in ²			65-470 psi		UD
3 NPS		7.39 in ²			65-430 psi		UD
4 NPS		12.6 in ²			65-300 psi		UD
6 NPS		21.6 in ²			65-200 psi		UD
8 NPS		38.4 in ²			65-150 psi		UD

Design Name: Axius, RD320, RD520 (liquid) NBCert # 80604

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/09/2028

Design Type

[Rupture Disk Device] Axius, RD320, RD520 (liquid)
HolderDesignation: XL, GI
Capacity Tests: Sec. UD at Fike Corporation on September 6, 2006
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 1.250 Unitless
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			65-600 psi		UD
1.5 NPS		2.04 in ²			65-385 psi		UD

10 NPS	59.5 in ²	50-100 psi	UD
12 NPS	86.4 in ²	35-70 psi	UD
2 NPS	3.36 in ²	65-470 psi	UD
3 NPS	7.39 in ²	65-430 psi	UD
4 NPS	12.6 in ²	65-300 psi	UD
6 NPS	21.6 in ²	65-200 psi	UD
8 NPS	38.4 in ²	65-150 psi	UD

Design Name:	Axius, RD320, RD520 Double Disc (Axius DD)	NBCert #	80749
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/31/2025

Design Type

[Rupture Disk Device] Axius, RD320, RD520 Double Disc (Axius DD)
HolderDesignation: XL
Capacity Tests: Sec. UD at Fike Corporation on October 31, 2013
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.680 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			10-600 psi	Air	UD
1.5 NPS		2.04 in ²			8-485 psi	Air	UD
10 NPS		59.5 in ²			8-100 psi	Air	UD
12 NPS		86.4 in ²			8-70 psi	Air	UD
2 NPS		3.36 in ²			8-470 psi	Air	UD
3 NPS		7.39 in ²			7-430 psi	Air	UD
4 NPS		12.6 in ²			7-300 psi	Air	UD
6 NPS		21.6 in ²			8-200 psi	Air	UD
8 NPS		38.4 in ²			8-150 psi	Air	UD

Design Name:	Axius, RD320, RD520 Double Disc (Axius DD) (Liquid)	NBCert #	80750
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/31/2025

Design Type

[Rupture Disk Device] Axius, RD320, RD520 Double Disc (Axius DD) (Liquid)
HolderDesignation: XL DD
Capacity Tests: Sec. UD at Fike Corporation on October 31, 2013
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 1.100 Unitless
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			10-600 psi	Water	UD
1.5 NPS		2.04 in ²			8-485 psi	Water	UD
10 NPS		59.5 in ²			8-100 psi	Water	UD
12 NPS		86.4 in ²			8-70 psi	Water	UD
2 NPS		3.36 in ²			8-470 psi	Water	UD
3 NPS		7.39 in ²			7-430 psi	Water	UD
4 NPS		12.6 in ²			7-300 psi	Water	UD
6 NPS		21.6 in ²			8-200 psi	Water	UD
8 NPS		38.4 in ²			8-150 psi	Water	UD

Design Name:	FSR Scored	NBCert #	80075
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	09/11/2025
--------------	----	------------

Design Type

[Rupture Disk Device] FSR Scored
HolderDesignation: FSR
Capacity Tests: Sec. UD at National Board Testing Lab on September 11, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.550 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.785 in ²			146-6000 psi		UD
1.5 NPS		1.77 in ²			240-6000 psi		UD
10 NPS		78.9 in ²			22-3000 psi		UD
12 NPS		113 in ²			19-3000 psi		UD
14 NPS		138 in ²			16-2500 psi		UD
16 NPS		183 in ²			28-1800 psi		UD
18 NPS		234 in ²			23-1500 psi		UD
2 NPS		3.36 in ²			195-9000 psi		UD
2.5 NPS		4.79 in ²			195-6000 psi		UD
20 NPS		291 in ²			23-1200 psi		UD
24 NPS		425 in ²			19-900 psi		UD
28 NPS		583 in ²			100-600 psi		UD
3 NPS		7.39 in ²			50-6000 psi		UD
3.5 NPS		9.89 in ²			50-6000 psi		UD
30 NPS		672 in ²			110-500 psi		UD
32 NPS		767 in ²			100-400 psi		UD
34 NPS		868 in ²			105-300 psi		UD
36 NPS		976 in ²			105-250 psi		UD

4 NPS	12.7 in ²	47-6000 psi	UD
6 NPS	28.9 in ²	47-7500 psi	UD
8 NPS	50 in ²	28-6000 psi	UD

Design Name: FSR Scored (Liquid) NBCert # 80514

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	05/07/2026

Design Type

[Rupture Disk Device] FSR Scored (Liquid)
 HolderDesignation: GI
 Capacity Tests: Sec. UD at Fike Corporation on November 18, 2004
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 2.400 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.59 in ²			285-6000 psi		UD
1.5 NPS		1.35 in ²			240-6000 psi		UD
10 NPS		78.9 in ²			22-3000 psi		UD
12 NPS		113 in ²			19-3000 psi		UD
14 NPS		138 in ²			16-2500 psi		UD
16 NPS		183 in ²			28-1800 psi		UD
18 NPS		234 in ²			23-1500 psi		UD
2 NPS		3.36 in ²			195-6000 psi		UD
20 NPS		291 in ²			23-1200 psi		UD
24 NPS		425 in ²			19-900 psi		UD
28 NPS		583 in ²			100-600 psi		UD
3 NPS		7.39 in ²			50-6000 psi		UD
3.5 NPS		9.89 in ²			50-6000 psi		UD
30 NPS		672 in ²			110-500 psi		UD
32 NPS		767 in ²			100-400 psi		UD
34 NPS		868 in ²			105-300 psi		UD
36 NPS		976 in ²			105-250 psi		UD
4 NPS		12.7 in ²			47-6000 psi		UD
6 NPS		28.9 in ²			47-7500 psi		UD
8 NPS		50 in ²			28-6000 psi		UD

Design Name: HO, HOV with Union Type holder NBCert # 80479

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	08/22/2025

Design Type

[Rupture Disk Device] HO, HOV with Union Type holder
HolderDesignation: UT
Capacity Tests: Sec. UD at Fike Corporation on October 8, 2003
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 3.500 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.694 in ²			29-6000 psi		UD
1.5 NPS		1.43 in ²			20-3000 psi		UD
2 NPS		2.95 in ²			13-1000 psi		UD

Design Name: HO/HOV NBCert # 80064

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

01/14/2026

Design Type

[Rupture Disk Device] HO/HOV
HolderDesignation: CONV
Capacity Tests: Sec. UD at National Board Testing Lab on January 14, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 2.020 Unitless
Media - Test: Air/Gas; Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.694 in ²			29-6000 psi		UD
1.5 NPS		1.43 in ²			20-3000 psi		UD
10 NPS		67.2 in ²			2.4-720 psi		UD
12 NPS		99.4 in ²			2.4-720 psi		UD
14 NPS		138 in ²			2.4-720 psi		UD
16 NPS		183 in ²			2.3-720 psi		UD
18 NPS		234 in ²			2-720 psi		UD
2 NPS		3.34 in ²			13-3000 psi		UD
20 NPS		291 in ²			1.8-720 psi		UD
24 NPS		425 in ²			1.5-720 psi		UD
3 NPS		7.31 in ²			8.4-3000 psi		UD
4 NPS		12.7 in ²			4.8-3000 psi		UD
6 NPS		27.1 in ²			3.6-2160 psi		UD
8 NPS		47.2 in ²			2.7-1440 psi		UD

Design Name: HOV Flat Seat Multi-Petal		NBCert #	80581
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	10/20/2029
Design Type			
[Rupture Disk Device] HOV Flat Seat Multi-Petal HolderDesignation: HOV Capacity Tests: Sec. UD at Fike Corporation on July 11, 2006 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 0.990 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Fike Corporation {FIK}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		3.34 in ²			133-720 psi		UD
24 NPS		387 in ²			10-65 psi		UD
26 NPS		459 in ²			10-65 psi		UD
28 NPS		539 in ²			10-65 psi		UD
3 NPS		7.31 in ²			95-720 psi		UD
30 NPS		624 in ²			10-65 psi		UD
32 NPS		716 in ²			10-45 psi		UD
34 NPS		814 in ²			10-45 psi		UD
36 NPS		918 in ²			10-37 psi		UD
38 NPS		1030 in ²			10-37 psi		UD
4 NPS		12.7 in ²			88-720 psi		UD
40 NPS		1150 in ²			10-37 psi		UD
42 NPS		1270 in ²			10-30 psi		UD
44 NPS		1400 in ²			10-30 psi		UD
48 NPS		1680 in ²			10-30 psi		UD
8 NPS		47.2 in ²			44-720 psi		UD
12 NPS	NPS	98.3 in ²	0 in	0 in	15-100 psi		UD
14 NPS	NPS	137 in ²	0 in	0 in	15-100 psi		UD

Design Name: HOV Flat Seat Single Hinge		NBCert #	80570
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	12/10/2027
Design Type			
[Rupture Disk Device] HOV Flat Seat Single Hinge HolderDesignation: HOV Capacity Tests: Sec. UD at Fike Corporation on April 19, 2006 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl Certified Value: 0.990 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Fike Corporation {FIK}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		3.34 in ²			15.9-285 psi		UD
24 NPS		387 in ²			1.5-40 psi		UD
26 NPS		459 in ²			1.5-35 psi		UD
28 NPS		539 in ²			1.5-35 psi		UD
3 NPS		7.31 in ²			11.4-285 psi		UD
30 NPS		624 in ²			1.5-30 psi		UD
32 NPS		716 in ²			1.5-30 psi		UD
34 NPS		814 in ²			1.5-30 psi		UD
36 NPS		918 in ²			1.5-25 psi		UD
38 NPS		1030 in ²			1.5-25 psi		UD
4 NPS		12.7 in ²			8-285 psi		UD
40 NPS		1150 in ²			1.5-25 psi		UD
42 NPS		1270 in ²			1.5-20 psi		UD
44 NPS		1400 in ²			1.5-20 psi		UD
48 NPS		1680 in ²			1.5-20 psi		UD
8 NPS		47.2 in ²			4.5-285 psi		UD
14 NPS	NPS	137 in ²	0 in	0 in	4.5-40 psi		UD

Design Name: P, CP, CPC - Union Type Holder NBCert # 80457

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 08/19/2026

Design Type

[Rupture Disk Device] P, CP, CPC - Union Type Holder
HolderDesignation: UT
Capacity Tests: Sec. UD at Fike Corporation on October 22, 2003
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 4.800 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.196 in ²			61-6000 psi		UD
0.75 NPS		0.432 in ²			42-6000 psi		UD
1 NPS		0.719 in ²			30-6000 psi		UD
1.5 NPS		1.77 in ²			23-3000 psi		UD
2 NPS		2.95 in ²			15-1000 psi		UD

Design Name: P, CP,CPC NBCert # 80132

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 08/21/2025

Design Type

[Rupture Disk Device] P, CP,CPC
 HolderDesignation: A, B, C, D, E, F, G, GI, H, I, UT, ST
 Capacity Tests: Sec. UD at National Board Testing Lab on February 8, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 1.350 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.442 in ²			42-10000 psi		UD
1 NPS		0.785 in ²			30-6000 psi		UD
1.5 NPS		1.77 in ²			23-3000 psi		UD
10 NPS		78.5 in ²			3.6-720 psi		UD
12 NPS		113 in ²			3.2-720 psi		UD
14 NPS		138 in ²			2.8-720 psi		UD
16 NPS		183 in ²			2.5-720 psi		UD
18 NPS		234 in ²			2.3-720 psi		UD
2 NPS		3.34 in ²			15-3000 psi		UD
20 NPS		291 in ²			2-720 psi		UD
24 NPS		425 in ²			1.5-720 psi		UD
3 NPS		7.37 in ²			8.5-3000 psi		UD
4 NPS		12.7 in ²			7-3000 psi		UD
6 NPS		28.9 in ²			6-2160 psi		UD
8 NPS		50 in ²			4-1440 psi		UD

Design Name: Poly SD Cross Score, Liquid NBCert # 80334

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	04/14/2029

Design Type

[Rupture Disk Device] Poly SD Cross Score, Liquid
 HolderDesignation: GI
 Capacity Tests: Sec. UD at Fike Corporation on February 11, 2002
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 1.100 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.442 in ²			250-3000 psi		UD
1 NPS		0.785 in ²			124-2700 psi		UD
1.5 NPS		1.77 in ²			115-2400 psi		UD
10 NPS		78.9 in ²			22-600 psi		UD
12 NPS		113 in ²			18.6-500 psi		UD
14 NPS		138 in ²			15.8-450 psi		UD

16 NPS	183 in ²	27.9-400 psi	UD
18 NPS	234 in ²	23-300 psi	UD
2 NPS	3.36 in ²	70-2100 psi	UD
20 NPS	291 in ²	23-250 psi	UD
24 NPS	425 in ²	18.6-150 psi	UD
3 NPS	7.39 in ²	52-1800 psi	UD
4 NPS	12.7 in ²	47-1500 psi	UD
6 NPS	28.9 in ²	47-800 psi	UD
8 NPS	50 in ²	27.9-700 psi	UD

Design Name:	Poly-SD Cross Score	NBCert #	80020
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	12/06/2030
--------------	----	------------

Design Type

[Rupture Disk Device] Poly-SD Cross Score
HolderDesignation: Poly SD
Capacity Tests: Sec. UD at National Board Testing Lab on September 11, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.990 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.442 in ²			250-3000 psi		UD
1 NPS		0.785 in ²			124-2700 psi		UD
1.5 NPS		1.77 in ²			115-2400 psi		UD
10 NPS		78.9 in ²			22-600 psi		UD
12 NPS		113 in ²			19-500 psi		UD
14 NPS		138 in ²			16-450 psi		UD
16 NPS		183 in ²			28-400 psi		UD
18 NPS		234 in ²			23-300 psi		UD
2 NPS		3.36 in ²			70-2100 psi		UD
2.5 NPS		4.79 in ²			70-2100 psi		UD
20 NPS		291 in ²			23-250 psi		UD
24 NPS		425 in ²			19-150 psi		UD
3 NPS		7.39 in ²			52-1800 psi		UD
4 NPS		12.7 in ²			47-1500 psi		UD
6 NPS		28.9 in ²			47-800 psi		UD
8 NPS		50 in ²			28-700 psi		UD

Design Name:	Poly-SD Double Hinge	NBCert #	80019
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	09/11/2025

Design Type
[Rupture Disk Device] Poly-SD Double Hinge HolderDesignation: Poly-SD Capacity Tests: Sec. UD at National Board Testing Lab on September 11, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 0.340 Unitless Media - Test: Air/Gas; Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.785 in ²			32-2250 psi		UD
1.5 NPS		1.77 in ²			28-1800 psi		UD
2 NPS		3.36 in ²			21-1600 psi		UD
3 NPS		7.39 in ²			14-1300 psi		UD
4 NPS		12.7 in ²			14-1100 psi		UD
6 NPS		28.9 in ²			14-700 psi		UD

Design Name:	Poly-SD Single Hinge	NBCert #	80008
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	11/23/2025

Design Type
[Rupture Disk Device] Poly-SD Single Hinge HolderDesignation: Poly SD Capacity Tests: Sec. UD at National Board Testing Lab on November 23, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 0.340 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.785 in ²			31-2250 psi		UD
1.5 NPS		1.77 in ²			27.5-1800 psi		UD
2 NPS		3.36 in ²			21.2-1600 psi		UD
3 NPS		7.39 in ²			14-1300 psi		UD
4 NPS		12.7 in ²			14-1100 psi		UD
6 NPS		28.9 in ²			14-700 psi		UD

Design Name:	Poly-SD, SCRD-V (Double Disc)	NBCert #	80592
--------------	-------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	12/21/2029

Design Type

[Rupture Disk Device] Poly-SD, SCRD-V (Double Disc)
 HolderDesignation: Poly SD
 Capacity Tests: Sec. UD at Fike Corporation on August 25, 2006
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 1.500 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS		67.2 in ²			22-600 psi		UD
12 NPS		99.4 in ²			19-500 psi		UD
14 NPS		138 in ²			16-450 psi		UD
16 NPS		183 in ²			28-400 psi		UD
18 NPS		234 in ²			23-300 psi		UD
2 NPS		3.36 in ²			100-2100 psi		UD
20 NPS		291 in ²			23-250 psi		UD
24 NPS		425 in ²			19-150 psi		UD
3 NPS		7.35 in ²			70-1800 psi		UD
4 NPS		12.7 in ²			62-1500 psi		UD
6 NPS		22.3 in ²			47-800 psi		UD
8 NPS		40.7 in ²			28-700 psi		UD

Design Name: PV, CP-C, CPV, CPV-C NBCert # 80053

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UD

05/17/2030

Design Type

[Rupture Disk Device] PV, CP-C, CPV, CPV-C
 HolderDesignation: CONV A, B, C, D, E, F, G, GI, H, I
 Capacity Tests: Sec. UD at National Board Testing Lab on September 10, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 3.500 Unitless
 Media - Test: Air/Gas; Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.407 in ²			96-10000 psi		UD
1 NPS		0.694 in ²			73-6000 psi		UD
1.5 NPS		1.43 in ²			48-3000 psi		UD
10 NPS		67.2 in ²			7.4-720 psi		UD
12 NPS		99.4 in ²			6.5-720 psi		UD
14 NPS		138 in ²			5.6-720 psi		UD
16 NPS		183 in ²			4.8-720 psi		UD
18 NPS		234 in ²			4.4-720 psi		UD
2 NPS		3.34 in ²			31-3000 psi		UD

20 NPS	291 in ²	3.9-720 psi	UD
24 NPS	425 in ²	3.3-720 psi	UD
3 NPS	7.31 in ²	22-3000 psi	UD
4 NPS	12.6 in ²	16.6-3000 psi	UD
6 NPS	27.1 in ²	12.5-2160 psi	UD
8 NPS	47.2 in ²	9.6-1440 psi	UD

Design Name:	PV, CP-P, CPV, CPV-C with Union Type Holder	NBCert #	80468
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 08/21/2025

Design Type

[Rupture Disk Device] PV, CP-P, CPV, CPV-C with Union Type Holder
HolderDesignation: UT
Capacity Tests: Sec. UD at Fike Corporation on December 8, 2003
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 8.800 Unitless
Media - Test: Air/Gas; Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.138 in ²			164-6000 psi		UD
0.75 NPS		0.33 in ²			96-6000 psi		UD
1 NPS		0.562 in ²			73-6000 psi		UD
1.5 NPS		1.16 in ²			48-3000 psi		UD
2 NPS		2.39 in ²			31-1000 psi		UD

Design Name:	RD540	NBCert #	80806
--------------	-------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 07/29/2027

Design Type

[Rupture Disk Device] RD540
HolderDesignation: XL, XLO
Capacity Tests: Sec. UD at Fike Corporation on May 25, 2021
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.424 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			2.63-10 psi		UD
1.5 NPS		2.04 in ²			1.84-10 psi		UD
2 NPS		3.36 in ²			2-10 psi		UD
3 NPS		7.39 in ²			1.72-10 psi		UD
4 NPS		12.7 in ²			1.75-10 psi		UD

Design Name: RD540 SC		NBCert #	80143
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	04/11/2030
Design Type			
[Rupture Disk Device] RD540 SC HolderDesignation: None Capacity Tests: Sec. UD at Fike Corporation on March 7, 2024 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.720 Unitless; (alternate medium): 0.000 Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Fike Corporation {FIK}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		1.263 in ²			3-10 psi		UD
2 NPS		2.414 in ²			3-10 psi		UD
3 NPS		5.72 in ²			2.5-10 psi		UD
38 DN		1.263 in ²			3-10 psi		UD
4 NPS		10.308 in ²			2.5-10 psi		UD
40 DN		1.52 in ²			3-10 psi		UD
50 DN		2.414 in ²			3-10 psi		UD
51 DN		2.414 in ²			3-10 psi		UD
76 DN		5.72 in ²			2.5-10 psi		UD

Design Name: SCRD FSR-VT		NBCert #	80154
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	10/28/2029
Design Type			
[Rupture Disk Device] SCRD FSR-VT HolderDesignation: FSR-VT Capacity Tests: Sec. UD at National Board Testing Lab on March 29, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 2.380 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Fike Corporation {FIK}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.785 in ²			285-6000 psi		UD
1.5 NPS		1.77 in ²			240-6000 psi		UD
10 NPS		78.9 in ²			22-1480 psi		UD
12 NPS		113 in ²			19-1000 psi		UD
14 NPS		138 in ²			16-910 psi		UD
16 NPS		183 in ²			28-800 psi		UD
18 NPS		234 in ²			23-700 psi		UD

2 NPS	3.36 in ²	195-6000 psi	UD
2.5 NPS	4.79 in ²	195-6000 psi	UD
20 NPS	291 in ²	23-600 psi	UD
24 NPS	425 in ²	19-540 psi	UD
3 NPS	7.39 in ²	50-6000 psi	UD
3.5 NPS	9.89 in ²	50-6000 psi	UD
4 NPS	12.7 in ²	47-6000 psi	UD
6 NPS	28.9 in ²	47-6000 psi	UD
8 NPS	50 in ²	28-6000 psi	UD

Design Name:	SCRD-FSR-SQ	NBCert #	80761
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 08/19/2027

Design Type

[Rupture Disk Device] SCRD-FSR-SQ
HolderDesignation: Gi / FSR-SQ
Capacity Tests: Sec. UD at Fike Corporation on May 16, 2015
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 2.000 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.275 in ²			6000-40000 psi	Air	UD
10 NPS		57.3 in ²			400-4000 psi	Air	UD
12 NPS		84.7 in ²			400-600 psi	Air	UD
14 NPS		104.3 in ²			400-750 psi	Air	UD
16 NPS		139.8 in ²			400-600 psi	Air	UD
18 NPS		180.6 in ²			400-600 psi	Air	UD
2 NPS		2.4 in ²			500-4000 psi	Air	UD
20 NPS		226.4 in ²			150-600 psi	Air	UD
3 NPS		5.25 in ²			400-4000 psi	Air	UD
4 NPS		9.12 in ²			400-4000 psi	Air	UD
6 NPS		29.42 in ²			400-6900 psi	Air	UD

Design Name:	SCRD-FSR-VT (Liquid)	NBCert #	80187
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 12/19/2029

Design Type

[Rupture Disk Device] SCRD-FSR-VT (Liquid)
 HolderDesignation: FSR-VT
 Capacity Tests: Sec. UD at National Board Testing Lab on July 6, 2000
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 8.710 Unitless
 Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.59 in ²			285-6000 psi		UD
1.5 NPS		1.35 in ²			240-6000 psi		UD
10 NPS		78.9 in ²			22-1480 psi		UD
12 NPS		113 in ²			19-1000 psi		UD
14 NPS		138 in ²			16-910 psi		UD
16 NPS		183 in ²			28-800 psi		UD
18 NPS		234 in ²			23-700 psi		UD
2 NPS		3.36 in ²			195-6000 psi		UD
2.5 NPS		4.79 in ²			195-6000 psi		UD
20 NPS		291 in ²			23-600 psi		UD
24 NPS		425 in ²			19-540 psi		UD
3 NPS		7.39 in ²			50-6000 psi		UD
3.5 NPS		9.89 in ²			50-6000 psi		UD
4 NPS		12.7 in ²			47-6000 psi		UD
6 NPS		28.9 in ²			47-6000 psi		UD
8 NPS		50 in ²			28-6000 psi		UD

Design Name: SCRD-V Cross Score

NBCert #

80200

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/20/2029

Design Type

[Rupture Disk Device] SCRD-V Cross Score
 HolderDesignation: GI, TQ
 Capacity Tests: Sec. UD at Fike Corporation on August 1, 2011
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 1.500 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS		67.2 in ²			22-600 psi	Air	UD
12 NPS		99.4 in ²			18.6-500 psi	Air	UD
14 NPS		138 in ²			15.8-450 psi	Air	UD
16 NPS		183 in ²			27.8-400 psi	Air	UD
18 NPS		234 in ²			23-300 psi	Air	UD

2 NPS	3.36 in ²	100-2100 psi	Air	UD
20 NPS	291 in ²	23-250 psi	Air	UD
24 NPS	425 in ²	18.6-150 psi	Air	UD
3 NPS	7.35 in ²	70-1800 psi	Air	UD
4 NPS	12.7 in ²	62.1-1500 psi	Air	UD
6 NPS	22.3 in ²	47-800 psi	Air	UD
8 NPS	40.7 in ²	27.9-700 psi	Air	UD

Design Name:	SR-H	NBCert #	80097
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 11/23/2025

Design Type

[Rupture Disk Device] SR-H
HolderDesignation: N/A
Capacity Tests: Sec. UD at National Board Testing Lab on November 23, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 1.880 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		1.34 in ²			18-163 psi		UD
2 NPS		2.55 in ²			13-117 psi		UD
3 NPS		6.1 in ²			13-150 psi		UD
4 NPS		11 in ²			10-64 psi		UD
40 DN		1.6 in ²			16-163 psi		UD
50 DN		2.72 in ²			13-117 psi		UD

Design Name:	SRL	NBCert #	80031
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/11/2025

Design Type

[Rupture Disk Device] SRL
HolderDesignation: SRL -GI, -TQ, SRLO-GI, -TQ, XL
Capacity Tests: Sec. UD at National Board Testing Lab on September 11, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.430 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			27-352 psi		UD
1.25 NPS		1.5 in ²			28-320 psi		UD
1.5 NPS		1.67 in ²			27-352 psi		UD

2 NPS	3.36 in ²	17-291 psi	UD
2.5 NPS	4.36 in ²	17-291 psi	UD
3 NPS	7.39 in ²	13-220 psi	UD
3.5 NPS	8.89 in ²	13-220 psi	UD
4 NPS	12.7 in ²	10-198 psi	UD
6 NPS	25.2 in ²	8-165 psi	UD
8 NPS	44.8 in ²	8-148 psi	UD

Design Name:	SRL (gas/liq.)	NBCert #	80277
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 12/10/2027

Design Type

[Rupture Disk Device] SRL (gas/liq.)
HolderDesignation: SRL, XL
Capacity Tests: Sec. UD at Fike Corporation on February 14, 2002
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.590 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			27-352 psi		UD
1.5 NPS		1.67 in ²			27-352 psi		UD
2 NPS		3.36 in ²			17-291 psi		UD
2.5 NPS		4.36 in ²			17-291 psi		UD
3 NPS		7.39 in ²			13-220 psi		UD
3.5 NPS		8.89 in ²			13-220 psi		UD
4 NPS		12.7 in ²			10-195 psi		UD
6 NPS		25.2 in ²			8-198 psi		UD
8 NPS		44.8 in ²			8-148 psi		UD

Design Name:	SRX	NBCert #	80042
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/16/2025

Design Type

[Rupture Disk Device] SRX
HolderDesignation: SRX -GI, -TQ
Capacity Tests: Sec. UD at National Board Testing Lab on September 11, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.990 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Fike Corporation {FIK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			95-720 psi		UD
1.5 NPS		1.54 in ²			80-720 psi		UD
10 NPS		69.6 in ²			27-350 psi		UD
12 NPS		102 in ²			24-250 psi		UD
14 NPS		138 in ²			27-165 psi		UD
16 NPS		183 in ²			22-150 psi		UD
18 NPS		234 in ²			22-135 psi		UD
2 NPS		3.36 in ²			74-720 psi		UD
2.5 NPS		4.26 in ²			74-720 psi		UD
20 NPS		291 in ²			18-120 psi		UD
24 NPS		425 in ²			18-120 psi		UD
3 NPS		7.39 in ²			54-720 psi		UD
3.5 NPS		8.36 in ²			54-720 psi		UD
4 NPS		12.7 in ²			45-720 psi		UD
6 NPS		25.3 in ²			36-630 psi		UD
8 NPS		43.3 in ²			32-500 psi		UD

Fisher Jeon Gas Equipment (Chengdu) Co., Ltd. (FJG)

Chengdu City, Sichuan Province, 610045People's Republic of China

This Company Manufactures or Assembles:

Design Name: C776			NBCert # 36425	
Manufacturer/Assembler		Designators		Expiration Date
Manufacturer		UV		02/13/2030

Design Type

[Safety Relief Valve] C776
Capacity Tests: Sec. UV at Crosby Valve, LLC on July 15, 2002
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.790 Unitless
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Regulator Technologies - Fromex S.A. de C.V. {FCF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.169 in ²	0.465 in	0.116 in	15-600 psi	Air	UV
1 NPS	1.25 NPS	0.34 in ²	0.658 in	0.164 in	15-500 psi	Air	UV
0.75-1 NPS	1.25 NPS	0.486 in ²	0.787 in	0.197 in	15-600 psi	Air	UV
1.25 NPS	1.5 NPS	0.645 in ²	0.906 in	0.227 in	15-500 psi	Air	UV
1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.286 in	15-500 psi	Air	UV

2-2.5 NPS	2.5 NPS	1.667 in ²	1.457 in	0.364 in	15-500 psi	Air	UV
-----------	---------	-----------------------	----------	----------	------------	-----	----

Flotech, LLC (FLO)

Jacksonville, FL 32218United States

This Company Manufactures or Assembles:

Design Name:	2600 & 2600S	NBCert #	57057
Manufacturer/Assembler	Designators	Expiration Date	

Assembler UV 01/11/2030

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV

6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam) NBCert # 57260

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/11/2030

Design Type

[Safety Relief Valve] 2600L (Air & Steam)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV

1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids)	NBCert # 57068
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/11/2030

Design Type

[Relief Valve] 2600L (Liquids)
 Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.652 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V

4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S NBCert # 57237

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/11/2030

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids)		NBCert #	57248
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	01/11/2030
Design Type			
[Relief Valve] 2700L, 3700L (Liquids) Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.676 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800		NBCert #	57024
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	01/11/2030
Design Type			
[Pilot Operated Pressure Relief Valve] 3800 Capacity Tests: Sec. UV at unknown lab on May 20, 1994 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.859 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition(1): Pop; (3): Initial Audible Discharge Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV

1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name: 3800FP

NBCert #

57035

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

01/11/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3800FP

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on April 26, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.801 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (3): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-1050 psi	Steam	UV
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-11300 psi	Air	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-1050 psi	Steam	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-11300 psi	Air	UV

2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-1050 psi	Steam	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-11300 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-1050 psi	Steam	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-11300 psi	Air	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-6300 psi	Air	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-6300 psi	Air	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-2300 psi	Air	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1500 psi	Air	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-800 psi	Steam	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-1500 psi	Air	UV

Design Name: 4200 / 4400

NBCert # 57282

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV, V

01/11/2030

Design Type

[Safety Valve] 4200 / 4400
Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.872 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

Design Name: Kunkle 337

NBCert # 36278

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

01/11/2030

Design Type

[Safety Relief Valve] Kunkle 337
Capacity Tests: Sec. UV at unknown lab on February 22, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	1.916 in ²	1.562 in	0.612 in	15-60 psi	Air	UV
2.5 NPS	2.5 NPS	2.786 in ²	1.883 in	0.755 in	15-60 psi	Air	UV
3 NPS	3 NPS	4.037 in ²	2.267 in	0.91 in	15-60 psi	Air	UV

Design Name: Kunkle 6000, 6252 Series NBCert # 36324

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV, V	01/11/2030
-----------	-------	------------

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV

2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 910 to 919

NBCert # 36100

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/11/2030

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV

1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name:	Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)	NBCert #	36111
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/11/2030

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 , 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

Flow-Safe, Inc. (FLW)

Nameplate Abbreviation: Flow Safe, Inc.

Orchard Park, NY 14127United States

This Company Manufactures or Assembles:

Design Name:	F7100, F7200, F7300, F7400, F7500	NBCert #	28000
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/18/2029

Design Type

[Pilot Operated Pressure Relief Valve] F7100, F7200, F7300, F7400, F7500
Capacity Tests: Sec. UV at National Board Testing Lab on January 5, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.824 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Flow-Safe, Inc. {FLW}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.521 in ²	0.815 in	0.43 in	1500-6000 psi	Air	UV
1 NPS	2 NPS	0.719 in ²	0.957 in	0.43 in	15-2220 psi	Air	UV
1.5 NPS	3 NPS	0.95 in ²	1.1 in	0.665 in	3706-6000 psi	Air	UV
1.5 NPS	3 NPS	1.404 in ²	1.337 in	0.665 in	1000-3705 psi	Air	UV
1.5 NPS	3 NPS	1.767 in ²	1.5 in	0.665 in	15-1480 psi	Air	UV
2 NPS	3, 3 dual NPS	1.774 in ²	1.503 in	0.865 in	3706-6000 psi	Air	UV
2 NPS	3, 3 dual NPS	2.241 in ²	1.689 in	0.865 in	1481-3705 psi	Air	UV
2 NPS	3, 3 dual NPS	2.953 in ²	1.939 in	0.865 in	15-1480 psi	Air	UV
3 NPS	4, 4 dual NPS	5.408 in ²	2.624 in	1.235 in	1481-3705 psi	Air	UV
3 NPS	4, 4 dual NPS	6.605 in ²	2.9 in	1.235 in	15-1480 psi	Air	UV
4 NPS	6, 6 dual NPS	10.315 in ²	3.624 in	1.53 in	1481-3705 psi	Air	UV
4 NPS	6, 6 dual NPS	11.437 in ²	3.816 in	1.53 in	15-1480 psi	Air	UV
6 NPS	8, 8 dual NPS	26.06 in ²	5.76 in	2.2 in	15-1480 psi	Air	UV
8 NPS	10, 8 dual, 10 dual NPS	45.66 in ²	7.625 in	2.86 in	15-1480 psi	Air	UV
10 NPS	12 NPS	71.85 in ²	9.565 in	3.64 in	15-750 psi	Air	UV
12 NPS	16 NPS	111.87 in ²	11.935 in	4.17 in	15-285 psi	Air	UV

Design Name: F7100, F7300, F7400, F7500 (Liquids) NBCert # 28011

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 10/28/2029

Design Type

[Pilot Operated Pressure Relief Valve] F7100, F7300, F7400, F7500 (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on January 5, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.634 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Flow-Safe, Inc. {FLW}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.522 in ²	0.815 in	0.43 in	2221-6000 psi	Water	UV
1 NPS	2 NPS	0.719 in ²	0.957 in	0.43 in	15-2220 psi	Water	UV
1.5 NPS	3 NPS	0.95 in ²	1.1 in	0.665 in	3706-6000 psi	Water	UV
1.5 NPS	3 NPS	1.404 in ²	1.337 in	0.665 in	1481-3705 psi	Water	UV
1.5 NPS	3 NPS	1.767 in ²	1.5 in	0.665 in	15-1480 psi	Water	UV
2 NPS	3 NPS	1.774 in ²	1.503 in	0.865 in	3706-6000 psi	Water	UV
2 NPS	3 NPS	2.24 in ²	1.689 in	0.865 in	1481-3705 psi	Water	UV
2 NPS	3 NPS	2.953 in ²	1.939 in	0.865 in	15-1480 psi	Water	UV
3 NPS	4 NPS	5.408 in ²	2.624 in	1.235 in	1481-3705 psi	Water	UV
3 NPS	4 NPS	6.605 in ²	2.9 in	1.235 in	15-1480 psi	Water	UV
4 NPS	6 NPS	10.315 in ²	3.624 in	1.53 in	1481-3705 psi	Water	UV

4 NPS	6 NPS	11.437 in ²	3.816 in	1.53 in	15-1480 psi	Water	UV
6 NPS	8 NPS	26.06 in ²	5.76 in	2.2 in	15-1480 psi	Water	UV
8 NPS	10 NPS	45.66 in ²	7.625 in	2.86 in	15-1480 psi	Water	UV
10 NPS	12 NPS	71.85 in ²	9.565 in	3.64 in	15-750 psi	Water	UV
12 NPS	16 NPS	111.87 in ²	11.935 in	4.17 in	15-285 psi	Water	UV

Design Name: F8100, F8200, F8300, F8400, F8500 NBCert # 28022

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 10/06/2027

Design Type

[Pilot Operated Pressure Relief Valve] F8100, F8200, F8300, F8400, F8500
Capacity Tests: Sec. UV at National Board Testing Lab on August 30, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Flow-Safe, Inc. {FLW}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.134 in ²	[D] 0.815 in	0.43 in	2221-6000 psi	Air	UV
1 NPS	2 NPS	0.235 in ²	[E] 0.815 in	0.43 in	2221-6000 psi	Air	UV
1 NPS	2 NPS	0.358 in ²	[F] 0.815 in	0.43 in	2221-3705 psi	Air	UV
1 NPS	2 NPS	0.134 in ²	[D] 0.957 in	0.43 in	15-2220 psi	Air	UV
1 NPS	2 NPS	0.235 in ²	[E] 0.957 in	0.43 in	15-2220 psi	Air	UV
1 NPS	2 NPS	0.358 in ²	[F] 0.957 in	0.43 in	15-2220 psi	Air	UV
1.5 NPS	3 NPS	0.358 in ²	[F] 1.1 in	0.665 in	3706-6000 psi	Air	UV
1.5 NPS	3 NPS	0.588 in ²	[G] 1.1 in	0.665 in	3706-6000 psi	Air	UV
1.5 NPS	3 NPS	0.916 in ²	[H] 1.1 in	0.665 in	3706-6000 psi	Air	UV
1.5 NPS	3 NPS	0.358 in ²	[F] 1.337 in	0.665 in	1481-3705 psi	Air	UV
1.5 NPS	3 NPS	0.916 in ²	[H] 1.337 in	0.665 in	1481-3705 psi	Air	UV
1.5 NPS	3 NPS	0.588 in ²	[G] 1.337 in	0.665 in	1481-3705 psi	Air	UV
1.5 NPS	3 NPS	0.588 in ²	[G] 1.5 in	0.665 in	15-1480 psi	Air	UV
1.5 NPS	3 NPS	0.358 in ²	[F] 1.5 in	0.665 in	15-1480 psi	Air	UV
1.5 NPS	3 NPS	0.916 in ²	[H] 1.5 in	0.665 in	15-1480 psi	Air	UV
2 NPS	3, 3 dual NPS	0.916 in ²	[H] 1.503 in	0.865 in	3706-6000 psi	Air	UV
2 NPS	3, 3 dual NPS	1.503 in ²	[J] 1.503 in	0.865 in	3706-6000 psi	Air	UV
2 NPS	3, 3 dual NPS	0.588 in ²	[G] 1.503 in	0.865 in	3706-6000 psi	Air	UV
2 NPS	3, 3 dual NPS	1.503 in ²	[J] 1.689 in	0.865 in	1481-3705 psi	Air	UV
2 NPS	3, 3 dual NPS	0.916 in ²	[H] 1.689 in	0.865 in	1481-3705 psi	Air	UV
2 NPS	3, 3 dual NPS	0.588 in ²	[G] 1.689 in	0.865 in	1481-3705 psi	Air	UV
2 NPS	3, 3 dual NPS	0.588 in ²	[G] 1.939 in	0.865 in	15-1480 psi	Air	UV
2 NPS	3, 3 dual NPS	0.916 in ²	[H] 1.939 in	0.865 in	15-1480 psi	Air	UV
2 NPS	3, 3 dual NPS	1.503 in ²	[J] 1.939 in	0.865 in	15-1480 psi	Air	UV

3 NPS	4, 4 dual NPS	3.277 in ²	[L] 2.624 in	1.235 in	1481-3705 psi	Air	UV
3 NPS	4, 4 dual NPS	2.147 in ²	[K] 2.624 in	1.235 in	1481-3705 psi	Air	UV
3 NPS	4, 4 dual NPS	1.503 in ²	[J] 2.624 in	1.235 in	1481-3705 psi	Air	UV
3 NPS	4, 4 dual NPS	1.503 in ²	[J] 2.9 in	1.235 in	15-1480 psi	Air	UV
3 NPS	4, 4 dual NPS	2.147 in ²	[K] 2.9 in	1.235 in	15-1480 psi	Air	UV
3 NPS	4, 4 dual NPS	3.277 in ²	[L] 2.9 in	1.235 in	15-1480 psi	Air	UV
4 NPS	6, 6 dual NPS	4.147 in ²	[M] 3.624 in	1.53 in	1481-3705 psi	Air	UV
4 NPS	6, 6 dual NPS	5.014 in ²	[N] 3.624 in	1.53 in	1481-3705 psi	Air	UV
4 NPS	6, 6 dual NPS	3.277 in ²	[L] 3.624 in	1.53 in	1481-3705 psi	Air	UV
4 NPS	6, 6 dual NPS	7.397 in ²	[P] 3.624 in	1.53 in	1481-3705 psi	Air	UV
4 NPS	6, 6 dual NPS	5.014 in ²	[N] 3.816 in	1.53 in	15-1480 psi	Air	UV
4 NPS	6, 6 dual NPS	3.277 in ²	[L] 3.816 in	1.53 in	15-1480 psi	Air	UV
4 NPS	6, 6 dual NPS	4.147 in ²	[M] 3.816 in	1.53 in	15-1480 psi	Air	UV
4 NPS	6, 6 dual NPS	7.397 in ²	[P] 3.816 in	1.53 in	15-1480 psi	Air	UV
6 NPS	8, 8 dual NPS	18.704 in ²	[R] 5.76 in	2.2 in	15-1480 psi	Air	UV
6 NPS	8, 8 dual NPS	12.913 in ²	[Q] 5.76 in	2.2 in	15-1480 psi	Air	UV
8 NPS	10, 8 dual, 10 dual NPS	30.409 in ²	[T] 7.625 in	2.86 in	15-1480 psi	Air	UV
8 NPS	10 NPS	16.53 in ²	[R-1] 7.625 in	2.86 in	15-1480 psi	Air	UV
10 NPS	12 NPS	51 in ²	[V] 9.565 in	3.64 in	15-750 psi	Air	UV
12 NPS	16 NPS	78.81 in ²	[W] 11.935 in	4.17 in	15-285 psi	Air	UV

Design Name:	F8100, F8300, F8500 (High Beta Ratio Sizes) (Liquid)	NBCert #	28156
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/27/2027

Design Type

[Pilot Operated Pressure Relief Valve] F8100, F8300, F8500 (High Beta Ratio Sizes) (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on March 12, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.730 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Flow-Safe, Inc. {FLW}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS	4 NPS	3.277 in ²	[L] 2.624 in	1.235 in	15-3705 psi	Water	UV
4 NPS	6 NPS	7.397 in ²	[P] 3.816 in	1.53 in	15-3705 psi	Water	UV
6 NPS	8 NPS	18.704 in ²	[R] 5.76 in	2.2 in	15-1480 psi	Water	UV
8 NPS	10 NPS	30.409 in ²	[T] 7.625 in	2.86 in	15-1480 psi	Water	UV
10 NPS	12 NPS	51 in ²	[V] 9.565 in	3.64 in	15-750 psi	Water	UV
12 NPS	16 NPS	78.81 in ²	[W] 10.017 in	4.17 in	15-285 psi	Water	UV

Design Name:	F8100, F8300, F8500 (liquid)	NBCert #	28099
--------------	------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	09/26/2025

Design Type

[Pilot Operated Pressure Relief Valve] F8100, F8300, F8500 (liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on February 12, 2008
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.830 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Flow-Safe, Inc. {FLW}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.134 in ²	[D] 0.815 in	0.43 in	2221-6000 psi	Water	UV
1 NPS	2 NPS	0.235 in ²	[E] 0.815 in	0.43 in	2221-6000 psi	Water	UV
1 NPS	2 NPS	0.235 in ²	[E] 0.957 in	0.43 in	15-2220 psi	Water	UV
1 NPS	2 NPS	0.134 in ²	[D] 0.957 in	0.43 in	15-2220 psi	Water	UV
1 NPS	2 NPS	0.358 in ²	[F] 0.957 in	0.43 in	15-2220 psi	Water	UV
1.5 NPS	3 NPS	0.358 in ²	[F] 1.1 in	0.665 in	3706-6000 psi	Water	UV
1.5 NPS	3 NPS	0.358 in ²	[F] 1.337 in	0.665 in	1481-3705 psi	Water	UV
1.5 NPS	3 NPS	0.588 in ²	[G] 1.337 in	0.665 in	1481-3705 psi	Water	UV
1.5 NPS	3 NPS	0.916 in ²	[H] 1.5 in	0.665 in	15-1480 psi	Water	UV
1.5 NPS	3 NPS	0.358 in ²	[F] 1.5 in	0.665 in	15-1480 psi	Water	UV
1.5 NPS	3 NPS	0.588 in ²	[G] 1.5 in	0.665 in	15-1480 psi	Water	UV
2 NPS	3 NPS	0.588 in ²	[G] 1.503 in	0.865 in	3706-6000 psi	Water	UV
2 NPS	3 NPS	0.916 in ²	[H] 1.503 in	0.865 in	3706-6000 psi	Water	UV
2 NPS	3 NPS	0.588 in ²	[G] 1.689 in	0.865 in	1481-3705 psi	Water	UV
2 NPS	3 NPS	0.916 in ²	[H] 1.689 in	0.865 in	1481-3705 psi	Water	UV
2 NPS	3 NPS	0.588 in ²	[G] 1.939 in	0.865 in	15-1480 psi	Water	UV
2 NPS	3 NPS	0.916 in ²	[H] 1.939 in	0.865 in	15-1480 psi	Water	UV
2 NPS	3 NPS	1.503 in ²	[J] 1.939 in	0.865 in	15-1480 psi	Water	UV
3 NPS	4 NPS	1.503 in ²	[J] 2.624 in	1.235 in	1481-3705 psi	Water	UV
3 NPS	4 NPS	2.147 in ²	[K] 2.624 in	1.235 in	1481-3705 psi	Water	UV
3 NPS	4 NPS	3.277 in ²	[L] 2.9 in	1.235 in	15-1480 psi	Water	UV
3 NPS	4 NPS	1.503 in ²	[J] 2.9 in	1.235 in	15-1480 psi	Water	UV
3 NPS	4 NPS	2.147 in ²	[K] 2.9 in	1.235 in	15-1480 psi	Water	UV
4 NPS	6 NPS	3.277 in ²	[L] 3.624 in	1.53 in	1481-3705 psi	Water	UV
4 NPS	6 NPS	4.147 in ²	[M] 3.624 in	1.53 in	1481-3705 psi	Water	UV
4 NPS	6 NPS	5.014 in ²	[N] 3.624 in	1.53 in	1481-3705 psi	Water	UV
4 NPS	6 NPS	3.277 in ²	[L] 3.816 in	1.53 in	15-1480 psi	Water	UV
4 NPS	6 NPS	4.147 in ²	[M] 3.816 in	1.53 in	15-1480 psi	Water	UV
4 NPS	6 NPS	5.014 in ²	[N] 3.816 in	1.53 in	15-1480 psi	Water	UV

6 NPS	8 NPS	12.913 in ²	[Q] 5.76 in	2.2 in	15-1480 psi	Water	UV
-------	-------	------------------------	-------------	--------	-------------	-------	----

Design Name:	F84, F85	NBCert #	28066
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/18/2029

Design Type

[Safety Relief Valve] F84, F85
Capacity Tests: Sec. UV at National Board Testing Lab on January 18, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Flow-Safe, Inc. {FLW}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.75 NPS	.5 - .75 NPS	0.003 in ²	[-1] 0.062 in	0.06 in	15-15000 psi	Air	UV
0.25-0.75 NPS	.5 - .75 NPS	0.008 in ²	[-1A] 0.098 in	0.039 in	500-15000 psi	Air	UV
0.25-0.75 NPS	.5, .75 NPS	0.015 in ²	[-2] 0.138 in	0.075 in	15-15000 psi	Air	UV
0.5-0.75 NPS	.5, .75 NPS	0.034 in ²	[-3] 0.209 in	0.113 in	15-890 psi	Air	UV
0.5-2 NPS	.5 - 1 NPS	0.065 in ²	[-4] 0.289 in	0.152 in	15-9612 psi	Air	UV
0.5-1 NPS	1 NPS	0.149 in ²	[-6] 0.436 in	0.211 in	15-6100 psi	Air	UV
0.75-1 NPS	1 NPS	0.261 in ²	[-8] 0.577 in	0.262 in	15-4292 psi	Air	UV
1.5 NPS	2 NPS	0.405 in ²	[F] 0.718 in	0.328 in	15-5000 psi	Air	UV
1.5 NPS	2 NPS	0.664 in ²	[G] 0.919 in	0.411 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	1.036 in ²	[H] 1.149 in	0.493 in	15-2750 psi	Air	UV
2 NPS	3 NPS	1.689 in ²	[J] 1.467 in	0.631 in	15-2700 psi	Air	UV

Design Name:	F84L, F88 (liquids)	NBCert #	28055
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/18/2029

Design Type

[Safety Relief Valve] F84L, F88 (liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on August 26, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.798 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: 93% of pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Flow-Safe, Inc. {FLW}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.261 in ²	[#8] 0.577 in	0.27 in	30-4292 psi	Water	UV
1.5 NPS	2 NPS	0.663 in ²	[G] 0.919 in	0.34 in	30-3705 psi	Water	UV
2 NPS	3 NPS	1.69 in ²	[J] 1.467 in	0.6 in	30-2700 psi	Water	UV

Design Name: F84L-2		NBCert #	28123
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	12/21/2028
Design Type			
[Safety Relief Valve] F84L-2 Capacity Tests: Sec. UV at National Board Testing Lab on October 5, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.353 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: 93% of pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Flow-Safe, Inc. {FLW}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.015 in ²	[-2] 0.138 in	0.07 in	200-24277 psi	Water	UV

Design Name: F84L-2 LP		NBCert #	28167
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	09/01/2028
Design Type			
[Safety Relief Valve] F84L-2 LP Capacity Tests: Sec. UV at National Board Testing Lab on December 7, 2015 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.362 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: 93% of pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Flow-Safe, Inc. {FLW}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 in	0.5-1 in	0.015 in ²	0.138 in	0.07 in	50-2085 psi	Water	UV

Design Name: F84L-3, F88-3 (Liquid)		NBCert #	28145
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/15/2027
Design Type			
[Safety Relief Valve] F84L-3, F88-3 (Liquid) Capacity Tests: Sec. UV at National Board Testing Lab on August 12, 2014 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.070 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: 93% of pop Blowdown Characteristics: Fixed Flow Area Configuration: Annulus Designed by: Flow-Safe, Inc. {FLW}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 in	1 in	0.065 in ²	[-3] 0.577 in	0.27 in	50-8382 psi	Water	UV

Design Name: F84L-4, F88-4 (Liquids)		NBCert #	28044
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	12/18/2029
Design Type			
[Relief Valve] F84L-4, F88-4 (Liquids) Capacity Tests: Sec. UV at National Board Testing Lab on December 18, 1996 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.790 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: 93% of pop Blowdown Characteristics: Fixed Flow Area Configuration: Annular Designed by: Flow-Safe, Inc. {FLW}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.116 in ²	[4] 0.577 in	0.27 in	30-8382 psi	Water	UV

Design Name: F88-3		NBCert #	28134
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/15/2027
Design Type			
[Safety Valve] F88-3 Capacity Tests: Sec. UV at National Board Testing Lab on September 4, 2014 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.060 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Annulus Designed by: Flow-Safe, Inc. {FLW}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 in	1 in	0.065 in ²	[-3] 0.546 in	0.27 in	50-4292 psi	Air	UV

Design Name: F88-4		NBCert #	28088
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	09/26/2025
Design Type			
[Safety Relief Valve] F88-4 Capacity Tests: Sec. UV at National Board Testing Lab on October 20, 2004 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.870 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Annulus Designed by: Flow-Safe, Inc. {FLW}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.116 in ²	0.577 in	0.27 in	50-4292 psi	Air	UV

Design Name: F88-8		NBCert #	28077
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/08/2027
Design Type			
[Safety Relief Valve] F88-8 Capacity Tests: Sec. UV at National Board Testing Lab on October 20, 2004 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 4.200 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Flow-Safe, Inc. {FLW}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.261 in ²	0.577 in	0.27 in	50-4292 psi	Air	UV

Design Name: F88-G		NBCert #	28112
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	12/21/2028
Design Type			
[Safety Valve] F88-G Capacity Tests: Sec. UV at National Board Testing Lab on November 15, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:10.300 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Flow-Safe, Inc. {FLW}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	0.663 in ²	[G] 0.919 in	0.34 in	50-3705 psi	Air	UV

Design Name: F88-J		NBCert #	28101
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	12/21/2028
Design Type			
[Safety Valve] F88-J Capacity Tests: Sec. UV at National Board Testing Lab on November 15, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:27.100 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Flow-Safe, Inc. {FLW}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	3 NPS	1.69 in ²	[J] 1.467 in	0.6 in	50-2700 psi	Air	UV

Fluid Handling LLC (Bell & Gossett, McDonnell & Miller) (BGT)

Nameplate Abbreviation: Bell & Gossett

Morton Grove, IL 60053United States

This Company Manufactures or Assembles:

Design Name:	1170 & McDonnell & Miller 250-1	NBCert #	31015
--------------	---------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	02/23/2031

Design Type

[Safety Relief Valve] 1170 & McDonnell & Miller 250-1
Capacity Tests: Sec. HV at unknown lab on November 19, 1982
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 24561 BTU/HR/PSIA
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fluid Handling LLC (Bell & Gossett, McDonnell & Miller) {BGT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1 NPS	0.886 in ²	1.062 in	0.343 in	15-125 psi	Steam	HV

Design Name:	3301 & McDonnell & Miller 260-1-1/2	NBCert #	31026
--------------	-------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	10/11/2030

Design Type

[Safety Relief Valve] 3301 & McDonnell & Miller 260-1-1/2
Capacity Tests: Sec. HV at unknown lab on September 28, 1981
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 71910 BTU/HR/PSIA
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fluid Handling LLC (Bell & Gossett, McDonnell & Miller) {BGT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	2.58 in ²	1.812 in	0.453 in	30-50 psi	Steam	HV

Design Name:	790 & McDonnell & Miller 250-3/4	NBCert #	31004
--------------	----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	03/08/2031

Design Type

[Safety Relief Valve] 790 & McDonnell & Miller 250-3/4
Capacity Tests: Sec. HV at unknown lab on November 19, 1982
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 16668 BTU/HR/PSIA
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fluid Handling LLC (Bell & Gossett, McDonnell & Miller) {BGT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.52 in ²	0.814 in	0.343 in	15-125 psi	Steam	HV

Fluid Mechanics Valve Company (FMV)

Nameplate Abbreviation: F/M

Houston, TX 77041United States

This Company Manufactures or Assembles:

Design Name: 1511, 1521, 1611, 1621NBCert # 25007

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/13/2026

Design Type

[Safety Relief Valve] 1511, 1521, 1611, 1621
Capacity Tests: Sec. UV at Dresser, Inc. on June 20, 1989
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.654 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fluid Mechanics Valve Company {FMV}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-2 NPS	.75 - 2.5 NPS		0.25 in	0.0625 in	40-15000 psi	Air	UV

Design Name: 1513, 1523, 1613, 1623NBCert # 25018

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/13/2026

Design Type

[Safety Relief Valve] 1513, 1523, 1613, 1623
Capacity Tests: Sec. UV at Dresser, Inc. on June 20, 1989
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.577 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fluid Mechanics Valve Company {FMV}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-2 NPS	1 - 2.5 NPS		0.375 in	0.0937 in	40-6000 psi	Air	UV

Design Name:	1524 - 1548, 1624 - 1648	NBCert #	25029
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/15/2026

Design Type

[Safety Relief Valve] 1524 - 1548, 1624 - 1648
Capacity Tests: Sec. UV at Dresser, Inc. on June 20, 1989
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.842 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Designed by: Fluid Mechanics Valve Company {FMV}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	1.5 - 3 NPS	0.196 in ²	0.5 in	0.125 in	40-7500 psi	Air	UV
1-2 NPS	1.5 - 3 NPS	0.307 in ²	0.625 in	0.156 in	40-6000 psi	Air	UV
1.5-3 NPS	2 - 3 NPS	0.503 in ²	0.8 in	0.2 in	40-3800 psi	Air	UV
1.5-3 NPS	2 - 4 NPS	0.785 in ²	1 in	0.25 in	40-3000 psi	Air	UV
2-4 NPS	2.5 - 4 NPS	1.289 in ²	1.281 in	0.32 in	40-1100 psi	Air	UV

Design Name:	3900 Model (392 Series), .250 Soft Seat	NBCert #	25063
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/15/2026

Design Type

[Relief Valve] 3900 Model (392 Series), .250 Soft Seat
Capacity Tests: Sec. UV at National Board Testing Lab on October 29, 2002
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.797 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fluid Mechanics Valve Company {FMV}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.5 NPS	0.049 in ²	0.25 in	0.087 in	75-2000 psi	Water	UV

Design Name:	4000 & 4200 (.312 soft seat)	NBCert #	25030
--------------	------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/31/2027

Design Type

[Safety Relief Valve] 4000 & 4200 (.312 soft seat)
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on September 3, 1987
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.340 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fluid Mechanics Valve Company {FMV}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-2 NPS	.75 - 2 NPS		0.312 in	0.078 in	50-6000 psi	Air	UV

Design Name: 4000 & 4200 Model (405 & 425) NBCert # 25041

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

08/13/2026

Design Type

[Safety Relief Valve] 4000 & 4200 Model (405 & 425)
Capacity Tests: Sec. UV at unknown lab on May 4, 1983
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.240 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fluid Mechanics Valve Company {FMV}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-2 NPS	1 - 2 NPS	0.15 in ²	0.437 in	0.109 in	50-3500 psi	Air	UV

Forum US, Inc. (CPV)

Stafford, TX 77477United States

This Company Manufactures or Assembles:

Design Name: ARV Series 1 NBCert # 00909

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

V

03/18/2027

Design Type

[Power Actuated Relief Valve] ARV Series 1
Capacity Tests: Sec. V at National Board Testing Lab on March 18, 2016
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:26.700 PPH/PSIA
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Power Actuated
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Forum US, Inc. {CPV}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	3 NPS	0.601 in²	0.875 in		100-5000 psi	Steam	V
Design Name:		ARV Series 2		NBCert #	00921		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			V		03/18/2027		
Design Type							
[Power Actuated Relief Valve] ARV Series 2 Capacity Tests: Sec. V at National Board Testing Lab on March 18, 2016 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.866 Unitless Media - Test: Steam; Certified: Steam Set Pressure Definition: Power Actuated Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Forum US, Inc. {CPV}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	3 NPS	0.785 in ²	1 in		100-5000 psi	Steam	V
2.5 NPS	4 NPS	2.405 in ²	1.75 in		100-6000 psi	Steam	V
3 NPS	6 NPS	3.141 in ²	2 in		100-6000 psi	Steam	V
4 NPS	6 NPS	4.908 in ²	2.5 in		100-6000 psi	Steam	V
4 NPS	6 NPS	7.069 in ²	3 in		100-5000 psi	Steam	V
6 NPS	8 NPS	15.9 in ²	4.5 in	0 in	15-5000 psi	Steam	V

Freedom Valve Solutions LLC (FVS)										Nameplate Abbreviation: Freedom Valve Solutions	
Odessa, TX 79764United States											

This Company Manufactures or Assembles:

Design Name: 459/462		NBCert # 37112
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/18/2029
Design Type		
<div>[Safety Relief Valve] 459/462</div> <div>Capacity Tests: Sec. UV at National Board Testing Lab on February 17, 1997</div> <div>Method of Establishing Relieving Capacity: Flow Capacity, K</div> <div>Certified Value: 0.811 Unitless</div> <div>Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam</div> <div>Set Pressure Definition: Initial Audible Discharge</div> <div>Blowdown Characteristics: Fixed</div> <div>Flow Area Configuration: Nozzle/Full Lift</div> <div>Designed by: LESER GmbH & Co. KG {LES}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Air	UV

0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Air	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Steam	UV

Design Name: 459/462 liquids NBCert # 37101

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/18/2029

Design Type

[Relief Valve] 459/462 liquids
Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.566 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Water	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Water	UV
0.5-1.5 NPS	1-2.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Water	UV
1-2 NPS	1.5-2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Water	UV

Design Name: 526 NBCert # 37224

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/18/2029

Design Type

[Safety Relief Valve] 526
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 22, 2001
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Air	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-2900 psi	Steam	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-2900 psi	Steam	UV

1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Air	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-2900 psi	Steam	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Steam	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Air	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Steam	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Air	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Steam	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Air	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Steam	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Air	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Steam	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Air	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Steam	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Air	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Steam	UV

Fukui Seisakusho Company, Limited (FKI)

Hirakata, Osaka, 573-1132Japan

This Company Manufactures or Assembles:

Design Name:	PCV	NBCert #	27188
Manufacturer/Assembler	Designators	Expiration Date	

Manufacturer

V

09/27/2030

Design Type

[Power Actuated Relief Valve] PCV

Capacity Tests: Sec. V at National Board Testing Lab on September 27, 2012

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.818 Unitless

Media - Test: Steam; Certified: Steam

Set Pressure Definition: Power Actuated

Blowdown Characteristics: Adjustable

Flow Area Configuration: Nozzle/Full Lift

Designed by: Fukui Seisakusho Company, Limited {FKI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	3 NPS	0.486 in ²	0.787 in	0.276 in	150-5500 psi	Steam	V
1.5 NPS	3 NPS	0.701 in ²	0.945 in	0.331 in	150-5500 psi	Steam	V
1.5 NPS	3 NPS	1.095 in ²	1.181 in	0.629 in	150-5500 psi	Steam	V
2 NPS	4 NPS	1.711 in ²	1.476 in	0.787 in	150-5500 psi	Steam	V
2.5 NPS	4 NPS	2.922 in ²	1.929 in	1.023 in	150-5500 psi	Steam	V
3 NPS	6 NPS	4.382 in ²	2.362 in	1.259 in	150-5500 psi	Steam	V
4 NPS	6 NPS	6.847 in ²	2.953 in	1.574 in	150-5500 psi	Steam	V
6 NPS	8 NPS	15.407 in ²	4.429 in	2.362 in	150-3000 psi	Steam	V
8 NPS	10 NPS	27.39 in ²	5.906 in	3.149 in	150-800 psi	Steam	V

Design Name:	PSH 2-1/2 K 4	NBCert #	27098
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer V 10/09/2027

Design Type

[Power Actuated Relief Valve] PSH 2-1/2 K 4
Capacity Tests: Sec. V at National Board Testing Lab on October 26, 1999
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:87.900 PPH/PSIA
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Power Actuated
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fukui Seisakusho Company, Limited {FKI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2.5 NPS	4 NPS	2.006 in ²	[K] 1.598 in	0.511 in	500-5000 psi	Steam	V

Design Name:	PSH 2-1/2 L 4	NBCert #	27100
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer V 10/09/2027

Design Type

[Power Actuated Relief Valve] PSH 2-1/2 L 4
Capacity Tests: Sec. V at National Board Testing Lab on October 26, 1999
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:121.90 PPH/PSIA
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Power Actuated
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fukui Seisakusho Company, Limited {FKI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2.5 NPS	4 NPS	2.922 in ²	[L] 1.928 in	0.59 in	500-5000 psi	Steam	V

Design Name:	PSL Series	NBCert #	27021
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/22/2031

Design Type

[Pilot Operated Pressure Relief Valve] PSL Series
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on February 22, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.843 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fukui Seisakusho Company, Limited {FKI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	3 NPS	2.466 in ²	1.772 in	0.552 in	15-740 psi	Air	UV
2.5 NPS	3 NPS	4.094 in ²	2.283 in	0.709 in	15-740 psi	Air	UV
3 NPS	4 NPS	6.136 in ²	2.795 in	0.867 in	15-740 psi	Air	UV
4 NPS	6 NPS	10.3 in ²	3.622 in	1.103 in	15-740 psi	Air	UV
6 NPS	8 NPS	22.19 in ²	5.315 in	1.615 in	15-740 psi	Air	UV
8 NPS	10 NPS	39.45 in ²	7.087 in	2.126 in	15-740 psi	Air	UV
10 NPS	12 NPS	56.8 in ²	8.504 in	2.56 in	15-740 psi	Air	UV
12 NPS	16 NPS	90.07 in ²	10.709 in	3.228 in	15-740 psi	Air	UV
14 NPS	18 NPS	115.48 in ²	12.126 in	3.759 in	15-740 psi	Air	UV
16 NPS	18 NPS	161.3 in ²	14.331 in	4.443 in	15-740 psi	Air	UV
18 NPS	24 NPS	202.65 in ²	16.063 in	4.98 in	15-740 psi	Air	UV
20 NPS	24 NPS	246.53 in ²	17.717 in	5.492 in	15-740 psi	Air	UV

Design Name: RE Series

NBCert # 27032

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	09/29/2030

Design Type

[Safety Relief Valve] RE Series
Capacity Tests: Sec. UV at unknown lab on October 1, 1979
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.869 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fukui Seisakusho Company, Limited {FKI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-2 NPS	1-3 NPS	0.1053 in ²	[DS] 0.3661 in	0.0945 in	15-10000 psi	Air	UV
0.75-2 NPS	1-3 NPS	0.1053 in ²	[DS] 0.3661 in	0.0945 in	15-6000 psi	Steam	UV
0.75-2 NPS	1-3 NPS	0.1368 in ²	[D] 0.4173 in	0.106 in	15-10000 psi	Air	UV
0.75-2 NPS	1-3 NPS	0.1368 in ²	[D] 0.4173 in	0.106 in	15-6000 psi	Steam	UV
15-15 mm	1-3 NPS	0.1368 in ²	[D] 0.4173 in	0.106 in	15-10000 psi	Air	UV
15-15 mm	1-3 NPS	0.1368 in ²	[D] 0.4173 in	0.106 in	15-6000 psi	Steam	UV
0.75-2 NPS	1-3 NPS	0.1872 in ²	[ES] 0.4882 in	0.122 in	15-10000 psi	Air	UV
0.75-2 NPS	1-3 NPS	0.1872 in ²	[ES] 0.4882 in	0.122 in	15-6000 psi	Steam	UV
0.75-2 NPS	1-3 NPS	0.2812 in ²	[E] 0.5984 in	0.15 in	15-10000 psi	Air	UV

0.75-2 NPS	1-3 NPS	0.2812 in ²	[E] 0.5984 in	0.15 in	15-6000 psi	Steam	UV
1-2 NPS	2-3 NPS	0.3772 in ²	[F] 0.693 in	0.174 in	15-10000 psi	Air	UV
1-2 NPS	2-3 NPS	0.3772 in ²	[F] 0.693 in	0.174 in	15-6000 psi	Steam	UV
1.5-2 NPS	2-4 NPS	0.5217 in ²	[GS] 0.815 in	0.205 in	15-10000 psi	Air	UV
1.5-2 NPS	2-4 NPS	0.5217 in ²	[GS] 0.815 in	0.205 in	15-6000 psi	Steam	UV
1.5-2 NPS	2-4 NPS	0.5945 in ²	[G] 0.87 in	0.221 in	15-10000 psi	Air	UV
1.5-2 NPS	2-4 NPS	0.5945 in ²	[G] 0.87 in	0.221 in	15-6000 psi	Steam	UV
1.5-2 NPS	2-4 NPS	0.9212 in ²	[H] 1.083 in	0.272 in	15-10000 psi	Air	UV
1.5-2 NPS	2-4 NPS	0.9212 in ²	[H] 1.083 in	0.272 in	15-6000 psi	Steam	UV
2-3 NPS	3-6 NPS	1.089 in ²	[JS] 1.177 in	0.295 in	15-3000 psi	Air	UV
2-3 NPS	3-6 NPS	1.089 in ²	[JS] 1.177 in	0.295 in	15-3000 psi	Steam	UV
1.5-2 NPS	2-4 NPS	1.095 in ²	[H2] 1.181 in	0.295 in	15-10000 psi	Air	UV
1.5-2 NPS	2-4 NPS	1.095 in ²	[H2] 1.181 in	0.295 in	15-6000 psi	Steam	UV
2-3 NPS	3-6 NPS	1.491 in ²	[J] 1.378 in	0.346 in	15-3000 psi	Air	UV
2-3 NPS	3-6 NPS	1.491 in ²	[J] 1.378 in	0.346 in	15-3000 psi	Steam	UV
2.5-3 NPS	3-6 NPS	2.128 in ²	[K] 1.646 in	0.413 in	15-3000 psi	Air	UV
2.5-3 NPS	3-6 NPS	2.128 in ²	[K] 1.646 in	0.413 in	15-3000 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.517 in	15-3500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.517 in	15-3500 psi	Steam	UV
4 NPS	6 NPS	3.643 in ²	[MS] 2.154 in	0.539 in	15-3000 psi	Air	UV
4 NPS	6 NPS	3.643 in ²	[MS] 2.154 in	0.539 in	15-3000 psi	Steam	UV
4 NPS	6 NPS	4.165 in ²	[M] 2.303 in	0.579 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.165 in ²	[M] 2.303 in	0.579 in	15-3000 psi	Steam	UV
4 NPS	6 NPS	5.063 in ²	[N] 2.539 in	0.638 in	15-1500 psi	Air	UV
4 NPS	6 NPS	5.063 in ²	[N] 2.539 in	0.638 in	15-1500 psi	Steam	UV
4 NPS	6 NPS	7.407 in ²	[P] 3.071 in	0.768 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	7.407 in ²	[P] 3.071 in	0.768 in	15-2000 psi	Air	UV
6 NPS	8, 10 NPS	10.918 in ²	[QS] 3.728 in	0.933 in	15-800 psi	Air	UV
6 NPS	8, 10 NPS	10.918 in ²	[QS] 3.728 in	0.933 in	15-800 psi	Steam	UV
6 NPS	8, 10 NPS	13.042 in ²	[Q] 4.075 in	1.02 in	15-800 psi	Air	UV
6 NPS	8, 10 NPS	13.042 in ²	[Q] 4.075 in	1.02 in	15-800 psi	Steam	UV
6 NPS	8, 10 NPS	15.353 in ²	[RS] 4.421 in	1.106 in	15-800 psi	Air	UV
6 NPS	8, 10 NPS	15.353 in ²	[RS] 4.421 in	1.106 in	15-800 psi	Steam	UV
6 NPS	8, 10 NPS	18.505 in ²	[R] 4.854 in	1.216 in	15-800 psi	Air	UV
6 NPS	8, 10 NPS	18.505 in ²	[R] 4.854 in	1.216 in	15-800 psi	Steam	UV
8 NPS	10 NPS	29.244 in ²	[T] 6.102 in	1.528 in	15-600 psi	Air	UV
8 NPS	10 NPS	29.244 in ²	[T] 6.102 in	1.528 in	15-600 psi	Steam	UV
8 NPS	10 NPS	32.98 in ²	[Ts] 6.48 in	1.622 in	15-600 psi	Air	UV
8 NPS	10 NPS	32.98 in ²	[Ts] 6.48 in	1.622 in	15-600 psi	Steam	UV
10 NPS	14 NPS	47.97 in ²	[V] 7.815 in	1.957 in	15-500 psi	Air	UV
10 NPS	14 NPS	47.97 in ²	[V] 7.815 in	1.957 in	15-500 psi	Steam	UV

12 NPS	16 NPS	68.96 in ²	[W] 9.37 in	2.343 in	15-500 psi	Air	UV
12 NPS	16 NPS	68.96 in ²	[W] 9.37 in	2.343 in	15-500 psi	Steam	UV
14 NPS	18 NPS	94.08 in ²	[Y] 10.945 in	2.737 in	15-500 psi	Air	UV
14 NPS	18 NPS	94.08 in ²	[Y] 10.945 in	2.737 in	15-500 psi	Steam	UV
16 NPS	18 NPS	103.8 in ²	[Z] 11.496 in	2.753 in	15-500 psi	Air	UV
16 NPS	18 NPS	103.8 in ²	[Z] 11.496 in	2.753 in	15-500 psi	Steam	UV
16 NPS	18 NPS	123.49 in ²	[Z2] 12.539 in	3.138 in	15-500 psi	Air	UV
16 NPS	18 NPS	123.49 in ²	[Z2] 12.539 in	3.138 in	15-500 psi	Steam	UV
18 NPS	24 NPS	155.15 in ²	[A] 14.055 in	3.516 in	15-500 psi	Air	UV
18 NPS	24 NPS	155.15 in ²	[A] 14.055 in	3.516 in	15-500 psi	Steam	UV
20 NPS	24 NPS	191.87 in ²	[B] 15.63 in	3.91 in	15-500 psi	Air	UV
20 NPS	24 NPS	191.87 in ²	[B] 15.63 in	3.91 in	15-500 psi	Steam	UV

Design Name: RECL & REBL (Liquids) NBCert # 27043

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 05/29/2030

Design Type

[Relief Valve] RECL & REBL (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 14, 1986
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.717 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fukui Seisakusho Company, Limited {FKI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.5 NPS	1-3 NPS	0.06 in ²	[C] 0.2756 in	0.069 in	15-10000 psi	Water	UV, V
0.75-2 NPS	1-3 NPS	0.1053 in ²	[DS] 0.3661 in	0.0945 in	15-10000 psi	Water	UV
0.75-2 NPS	1-3 NPS	0.1368 in ²	[D] 0.4173 in	0.106 in	15-10000 psi	Water	UV, V
15-15 mm	1-3 NPS	0.1368 in ²	[D] 0.4173 in	0.106 in	15-10000 psi	Water	UV, V
0.75-2 NPS	1-3 NPS	0.1872 in ²	[ES] 0.4882 in	0.122 in	15-10000 psi	Water	UV
0.75-2 NPS	1-3 NPS	0.2812 in ²	[E] 0.5984 in	0.15 in	15-10000 psi	Water	UV, V
1-2 NPS	2-3 NPS	0.3772 in ²	[F] 0.693 in	0.174 in	15-10000 psi	Water	UV, V
1.5-2 NPS	2-4 NPS	0.5217 in ²	[GS] 0.815 in	0.205 in	15-10000 psi	Water	UV
1.5-2 NPS	2-4 NPS	0.5945 in ²	[G] 0.87 in	0.221 in	15-10000 psi	Water	UV, V
1.5-2 NPS	2-4 NPS	0.9212 in ²	[H] 1.083 in	0.272 in	15-10000 psi	Water	UV, V
2-3 NPS	3-6 NPS	1.089 in ²	[JS] 1.177 in	0.295 in	15-3000 psi	Water	UV
1.5-2 NPS	2-4 NPS	1.095 in ²	[H2] 1.181 in	0.295 in	15-10000 psi	Water	UV, V
2-3 NPS	3-6 NPS	1.491 in ²	[J] 1.378 in	0.346 in	15-3000 psi	Water	UV, V
2.5-3 NPS	3-6 NPS	2.128 in ²	[K] 1.646 in	0.413 in	15-3000 psi	Water	UV, V
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.517 in	15-3500 psi	Water	UV, V
4 NPS	6 NPS	3.643 in ²	[MS] 2.154 in	0.539 in	15-3000 psi	Water	UV
4-4 NPS	6 NPS	4.165 in ²	[M] 2.303 in	0.579 in	15-3000 psi	Water	UV, V

4-4 NPS	6 NPS	5.063 in ²	[N] 2.539 in	0.638 in	15-1500 psi	Water	UV, V
4-4 NPS	6 NPS	7.407 in ²	[P] 3.071 in	0.768 in	15-2000 psi	Water	UV, V
6 NPS	8-10 NPS	10.918 in ²	[QS] 3.728 in	0.933 in	15-800 psi	Water	UV
6-6 NPS	8-10 NPS	13.042 in ²	[Q] 4.075 in	1.02 in	15-800 psi	Water	UV, V
6 NPS	8-10 NPS	15.353 in ²	[RS] 4.421 in	1.106 in	15-800 psi	Water	UV
6-6 NPS	8-10 NPS	18.505 in ²	[R] 4.854 in	1.216 in	15-800 psi	Water	UV, V
8-8 NPS	10 NPS	29.244 in ²	[T] 6.102 in	1.528 in	15-600 psi	Water	UV, V
8-8 NPS	10 NPS	32.979 in ²	[Ts] 6.48 in	1.622 in	15-600 psi	Water	UV, V
10-10 NPS	14 NPS	47.97 in ²	[V] 7.815 in	1.957 in	15-500 psi	Water	UV, V
12-12 NPS	16 NPS	68.96 in ²	[W] 9.37 in	2.343 in	15-500 psi	Water	UV, V
14-14 NPS	18 NPS	94.08 in ²	[Y] 10.945 in	2.737 in	15-500 psi	Water	UV, V
16-16 NPS	18 NPS	103.8 in ²	[Z] 11.496 in	2.753 in	15-500 psi	Water	UV, V
16-16 NPS	18 NPS	123.49 in ²	[Z2] 12.539 in	3.138 in	15-500 psi	Water	UV, V
18-18 NPS	24 NPS	155.15 in ²	[A] 14.055 in	3.516 in	15-500 psi	Water	UV, V
20-20 NPS	24 NPS	191.87 in ²	[B] 15.63 in	3.91 in	15-500 psi	Water	UV, V

Design Name:	RP Series	NBCert #	27054
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/09/2030

Design Type

[Pilot Operated Pressure Relief Valve] RP Series
Capacity Tests: Sec. UV at unknown lab on February 21, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fukui Seisakusho Company, Limited {FKI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 NPS	0.124 in ²	[D] 0.397 in	0.1 in	15-12500 psi	Air	UV
1-2 NPS	2 NPS	0.124 in ²	[D] 0.397 in	0.1 in	15-6000 psi	Steam	UV
1-2 NPS	2 NPS	0.219 in ²	[E] 0.528 in	0.134 in	15-12500 psi	Air	UV
1-2 NPS	2 NPS	0.219 in ²	[E] 0.528 in	0.134 in	15-6000 psi	Steam	UV
1-2 NPS	2 NPS	0.343 in ²	[F] 0.661 in	0.166 in	15-12500 psi	Air	UV
1-2 NPS	2 NPS	0.343 in ²	[F] 0.661 in	0.166 in	15-6000 psi	Steam	UV
1.25-3 NPS	3, 4 NPS	0.562 in ²	[G] 0.846 in	0.212 in	15-12500 psi	Air	UV
1.25-3 NPS	3, 4 NPS	0.562 in ²	[G] 0.846 in	0.212 in	15-6000 psi	Steam	UV
1.5-2 NPS	3, 4 NPS	0.874 in ²	[H] 1.055 in	0.264 in	15-12500 psi	Air	UV
1.5-2 NPS	3, 4 NPS	0.874 in ²	[H] 1.055 in	0.264 in	15-6000 psi	Steam	UV
1.5-3 NPS	3, 4 NPS	1.35 in ²	[I] 1.311 in	0.328 in	15-6000 psi	Air	UV
1.5-3 NPS	3, 4 NPS	1.35 in ²	[I] 1.311 in	0.328 in	15-6000 psi	Steam	UV
1.5-3 NPS	3,4 NPS	1.431 in ²	[J] 1.35 in	0.338 in	15-12500 psi	Air	UV
1.5-3 NPS	3,4 NPS	1.431 in ²	[J] 1.35 in	0.338 in	15-6000 psi	Steam	UV

2-3 NPS	3, 4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-12500 psi	Air	UV
2-3 NPS	3, 4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-6000 psi	Steam	UV
2 NPS	3, Dual 3 NPS	2.53 in ²	[2] 1.795 in	0.449 in	15-4000 psi	Air	UV
2 NPS	3, Dual 3 NPS	2.53 in ²	[2] 1.795 in	0.449 in	15-4000 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.179 in ²	[L] 2.012 in	0.503 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.179 in ²	[L] 2.012 in	0.503 in	15-5000 psi	Steam	UV
3-4 NPS	6 NPS	4.011 in ²	[M] 2.26 in	0.565 in	15-4000 psi	Air	UV
3-4 NPS	6 NPS	4.011 in ²	[M] 2.26 in	0.565 in	15-4000 psi	Steam	UV
3-4 NPS	6 NPS	4.83 in ²	[N] 2.48 in	0.62 in	15-4000 psi	Air	UV
3-4 NPS	6 NPS	4.83 in ²	[N] 2.48 in	0.62 in	15-4000 psi	Steam	UV
3 NPS	4, Dual 4 NPS	5.628 in ²	[3] 2.677 in	0.67 in	15-4000 psi	Air	UV
3 NPS	4, Dual 4 NPS	5.628 in ²	[3] 2.677 in	0.67 in	15-4000 psi	Steam	UV
4 NPS	6 NPS	7.116 in ²	[P] 3.01 in	0.753 in	15-4000 psi	Air	UV
4 NPS	6 NPS	7.116 in ²	[P] 3.01 in	0.753 in	15-4000 psi	Steam	UV
4 NPS	6, Dual 6 NPS	9.621 in ²	[4] 3.5 in	0.875 in	15-2000 psi	Air	UV
4 NPS	6, Dual 6 NPS	9.621 in ²	[4] 3.5 in	0.875 in	15-2000 psi	Steam	UV
6 NPS	8 NPS	12.3 in ²	[Q] 3.957 in	0.99 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.3 in ²	[Q] 3.957 in	0.99 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.8 in ²	[R] 4.76 in	1.19 in	15-2000 psi	Air	UV
6 NPS	8, 10 NPS	17.8 in ²	[R] 4.76 in	1.19 in	15-2000 psi	Steam	UV
6 NPS	Dual 8 NPS	21.53 in ²	[5] 5.236 in	1.309 in	15-2000 psi	Air	UV
6 NPS	Dual 8 NPS	21.53 in ²	[5] 5.236 in	1.309 in	15-2000 psi	Steam	UV
8 NPS	10 NPS	28.91 in ²	[T] 6.067 in	1.517 in	15-1500 psi	Air	UV
8 NPS	10 NPS	28.91 in ²	[T] 6.067 in	1.517 in	15-1500 psi	Steam	UV
8 NPS	Dual 8 NPS	29.43 in ²	[6] 6.122 in	1.531 in	15-1500 psi	Air	UV
8 NPS	Dual 8 NPS	29.43 in ²	[6] 6.122 in	1.531 in	15-1500 psi	Steam	UV
8-10 NPS	Dual 10, 14 NPS	44.18 in ²	[V, 7] 7.5 in	1.875 in	15-1500 psi	Air	UV
8-10 NPS	Dual 10, 14 NPS	44.18 in ²	[V, 7] 7.5 in	1.875 in	15-1500 psi	Steam	UV
10-12 NPS	14, 16 NPS	63.62 in ²	[W] 9 in	2.25 in	15-500 psi	Air	UV
10-12 NPS	14, 16 NPS	63.62 in ²	[W] 9 in	2.25 in	15-500 psi	Steam	UV
12-14 NPS	16, 18 NPS	86.59 in ²	[Y] 10.5 in	2.625 in	15-500 psi	Air	UV
12-14 NPS	16, 18 NPS	86.59 in ²	[Y] 10.5 in	2.625 in	15-500 psi	Steam	UV
14-16 NPS	20 NPS	95.38 in ²	[Z] 11.02 in	2.753 in	15-500 psi	Air	UV
14-16 NPS	20 NPS	95.38 in ²	[Z] 11.02 in	2.753 in	15-500 psi	Steam	UV
14-16 NPS	20 NPS	113.1 in ²	[Z1] 12 in	3 in	15-500 psi	Air	UV
14-16 NPS	20 NPS	113.1 in ²	[Z1] 12 in	3 in	15-500 psi	Steam	UV
16-18 NPS	24 NPS	143.1 in ²	[A] 13.5 in	3.375 in	15-500 psi	Air	UV
16-18 NPS	24 NPS	143.1 in ²	[A] 13.5 in	3.375 in	15-500 psi	Steam	UV
18-20 NPS	24 NPS	176.7 in ²	[B] 15 in	3.75 in	15-500 psi	Air	UV
18-20 NPS	24 NPS	176.7 in ²	[B] 15 in	3.75 in	15-500 psi	Steam	UV
20 NPS	24 NPS	227 in ²	[B2] 17 in	4.25 in	15-500 psi	Air	UV

20 NPS	24 NPS	227 in ²	[B2] 17 in	4.25 in	15-500 psi	Steam	UV
--------	--------	---------------------	------------	---------	------------	-------	----

Design Name:	RPE (Water K = 0.681)	NBCert #	27177
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 09/27/2029

Design Type

[Pilot Operated Pressure Relief Valve] RPE (Water K = 0.681)
Capacity Tests: Sec. UV, V at National Board Testing Lab on May 17, 2011
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.875 Unitless
Media - Test: Liquid, Steam; Certified: Steam and Water
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fukui Seisakusho Company, Limited {FKI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.219 in ²	[13.4] 0.528 in	0.194 in	50-6000 psi	Steam	UV, V
1 NPS	2 NPS	0.219 in ²	[13.4] 0.528 in	0.194 in	50-6000 psi	Water	UV, V
1 NPS	2.5 NPS	0.377 in ²	[17.6] 0.693 in	0.196 in	50-6000 psi	Steam	UV, V
1 NPS	2.5 NPS	0.377 in ²	[17.6] 0.693 in	0.196 in	50-6000 psi	Water	UV, V
1.25-1.5 NPS	2.5-3 NPS	0.594 in ²	[22.1] 0.87 in	0.236 in	50-6000 psi	Steam	UV, V
1.25-1.5 NPS	2.5-3 NPS	0.594 in ²	[22.1] 0.87 in	0.236 in	50-6000 psi	Water	UV, V
1.25-1.5 NPS	2.5-3 NPS	1.009 in ²	[28.8] 1.134 in	0.335 in	50-6000 psi	Steam	UV, V
1.25-1.5 NPS	2.5-3 NPS	1.009 in ²	[28.8] 1.134 in	0.335 in	50-6000 psi	Water	UV, V
1.5 NPS	3 NPS	1.576 in ²	[36] 1.417 in	0.393 in	50-6000 psi	Steam	UV, V
1.5 NPS	3 NPS	1.576 in ²	[36] 1.417 in	0.393 in	50-6000 psi	Water	UV, V
2 NPS	3 NPS	2.465 in ²	[45] 1.772 in	0.512 in	50-6000 psi	Steam	UV, V
2 NPS	3 NPS	2.465 in ²	[45] 1.772 in	0.512 in	50-6000 psi	Water	UV, V
3 NPS	4-6 NPS	6.309 in ²	[72] 2.835 in	0.787 in	50-6000 psi	Steam	UV, V
3 NPS	4-6 NPS	6.309 in ²	[72] 2.835 in	0.787 in	50-6000 psi	Water	UV, V
4 NPS	6 NPS	9.854 in ²	[90] 3.543 in	0.945 in	50-2500 psi	Steam	UV, V
4 NPS	6 NPS	9.854 in ²	[90] 3.543 in	0.945 in	50-2500 psi	Water	UV, V
6 NPS	8 NPS	22.176 in ²	[135] 5.315 in	1.417 in	50-1500 psi	Steam	UV, V
6 NPS	8 NPS	22.176 in ²	[135] 5.315 in	1.417 in	50-1500 psi	Water	UV, V
8 NPS	10 NPS	39.427 in ²	[180] 7.087 in	1.89 in	50-1500 psi	Steam	UV, V
8 NPS	10 NPS	39.427 in ²	[180] 7.087 in	1.89 in	50-1500 psi	Water	UV, V

Design Name:	RPSL (Liquids)	NBCert #	27065
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/09/2030

Design Type

[Pilot Operated Pressure Relief Valve] RPSL (Liquids)
 Capacity Tests: Sec. UV at unknown lab on January 15, 1986
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.743 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Designed by: Fukui Seisakusho Company, Limited {FKI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 NPS	0.124 in ²	[D] 0.397 in	0.1 in	15-10000 psi	Water	UV
1-2 NPS	2 NPS	0.219 in ²	[E] 0.528 in	0.134 in	15-10000 psi	Water	UV
1-2 NPS	2 NPS	0.343 in ²	[F] 0.661 in	0.166 in	15-10000 psi	Water	UV
1.25-3 NPS	3, 4 NPS	0.562 in ²	[G] 0.846 in	0.212 in	15-10000 psi	Water	UV
1.5-2 NPS	3, 4 NPS	0.874 in ²	[H] 1.055 in	0.264 in	15-10000 psi	Water	UV
1.5-3 NPS	3, 4 NPS	1.35 in ²	[1] 1.311 in	0.328 in	15-6000 psi	Water	UV
2-3 NPS	3, 4 NPS	1.431 in ²	[J] 1.35 in	0.338 in	15-10000 psi	Water	UV
2-3 NPS	3, 4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-10000 psi	Water	UV
2 NPS	3, Dual 3 NPS	2.53 in ²	[2] 1.795 in	0.449 in	15-4000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.179 in ²	[L] 2.012 in	0.503 in	15-5000 psi	Water	UV
3-4 NPS	6 NPS	4.011 in ²	[M] 2.26 in	0.565 in	15-4000 psi	Water	UV
3-4 NPS	6 NPS	4.83 in ²	[N] 2.48 in	0.62 in	15-4000 psi	Water	UV
3 NPS	4, Dual 4 NPS	5.628 in ²	[3] 2.677 in	0.67 in	15-4000 psi	Water	UV
4 NPS	6 NPS	7.116 in ²	[P] 3.01 in	0.753 in	15-4000 psi	Water	UV
4 NPS	6, Dual 6 NPS	9.621 in ²	[4] 3.5 in	0.875 in	15-2000 psi	Water	UV
6 NPS	8 NPS	12.3 in ²	[Q] 3.957 in	0.99 in	15-2000 psi	Water	UV
6 NPS	8, 10 NPS	17.8 in ²	[R] 4.76 in	1.19 in	15-2000 psi	Water	UV
6 NPS	Dual 8 NPS	21.53 in ²	[5] 5.236 in	1.309 in	15-2000 psi	Water	UV
8 NPS	10 NPS	28.91 in ²	[T] 6.067 in	1.517 in	15-1500 psi	Water	UV
8 NPS	Dual 8 NPS	29.43 in ²	[6] 6.122 in	1.531 in	15-1500 psi	Water	UV
8-10 NPS	Dual 10, 14 NPS	44.18 in ²	[V, 7] 7.5 in	1.875 in	15-1500 psi	Water	UV
10-12 NPS	14, 16 NPS	63.62 in ²	[W] 9 in	2.25 in	15-500 psi	Water	UV
12-14 NPS	16, 18 NPS	86.59 in ²	[Y] 10.5 in	2.625 in	15-500 psi	Water	UV
14-16 NPS	20 NPS	95.38 in ²	[Z] 11.02 in	2.753 in	15-500 psi	Water	UV
14-16 NPS	20 NPS	113.1 in ²	[Z1] 12 in	3 in	15-500 psi	Water	UV
16-18 NPS	24 NPS	143.1 in ²	[A] 13.5 in	3.375 in	15-500 psi	Water	UV
18-20 NPS	24 NPS	176.7 in ²	[B] 15 in	3.75 in	15-500 psi	Water	UV
20 NPS	24 NPS	227 in ²	[B2] 17 in	4.25 in	15-500 psi	Water	UV

Design Name: RTE

NBCert # 27144

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/22/2027

Design Type

[Safety Relief Valve] RTE
Capacity Tests: Sec. UV at National Board Testing Lab on October 27, 2004
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.200 SCFM/PSIA; (alternate medium): 6.180 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fukui Seisakusho Company, Limited {FKI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1, 2 NPS	0.137 in ²	0.417 in	0.106 in	50-15000 psi	Air	UV
0.75-1 NPS	1, 2 NPS	0.137 in ²	0.417 in	0.106 in	50-2900 psi	Steam	UV

Design Name: RTE Liquid NBCert # 27133

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/22/2027

Design Type

[Relief Valve] RTE Liquid
Capacity Tests: Sec. UV at National Board Testing Lab on October 26, 2004
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.980 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Heavy Flow
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fukui Seisakusho Company, Limited {FKI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1, 2 NPS	0.137 in ²	0.417 in	0.106 in	50-15000 psi	Water	UV

Design Name: SL Series NBCert # 27076

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV, V

06/05/2030

Design Type

[Safety Valve] SL Series
Capacity Tests: Sec. UV, V at National Board Testing Lab (Picaway) on November 16, 1979
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Fukui Seisakusho Company, Limited {FKI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1-2 NPS	0.122 in ²	[D] 0.394 in	0.098 in	15-5500 psi	Steam	UV, V
0.75-1 NPS	1-2 NPS	0.216 in ²	[E] 0.524 in	0.134 in	15-5500 psi	Steam	UV, V
1-2 NPS	2-4 NPS	0.336 in ²	[F1] 0.654 in	0.0906 in	15-5500 psi	Steam	UV, V
1-2 NPS	2-4 NPS	0.336 in ²	[F] 0.654 in	0.165 in	15-5500 psi	Steam	UV, V
1-2 NPS	2-4 NPS	0.439 in ²	[19] 0.748 in	0.189 in	15-5500 psi	Steam	UV, V

1.25-2 NPS	2.5-4 NPS	0.548 in ²	[G1] 0.835 in	0.146 in	15-5500 psi	Steam	UV, V
1.25-2 NPS	2.5-4 NPS	0.548 in ²	[G] 0.835 in	0.209 in	15-5500 psi	Steam	UV, V
1.25-2 NPS	2.5-4 NPS	0.701 in ²	[24] 0.945 in	0.236 in	15-5500 psi	Steam	UV, V
1.5-2 NPS	3-4 NPS	0.861 in ²	[H] 1.047 in	0.264 in	15-5500 psi	Steam	UV, V
1.5-2 NPS	3-4 NPS	1.095 in ²	[30] 1.181 in	0.295 in	15-5500 psi	Steam	UV, V
2-3 NPS	3-6 NPS	1.408 in ²	[J] 1.339 in	0.335 in	15-5500 psi	Steam	UV, V
2-3 NPS	3-6 NPS	1.758 in ²	[38] 1.496 in	0.374 in	15-5500 psi	Steam	UV, V
2-3 NPS	3-6 NPS	1.804 in ²	[J3] 1.515 in	0.38 in	15-5500 psi	Steam	UV, V
2.5-4 NPS	4-8 NPS	2.006 in ²	[K] 1.598 in	0.402 in	15-5500 psi	Steam	UV, V
2.5-4 NPS	4-8 NPS	2.676 in ²	[K2] 1.846 in	0.465 in	15-5500 psi	Steam	UV, V
2.5-4 NPS	4-8 NPS	2.863 in ²	[K3] 1.909 in	0.477 in	15-5500 psi	Steam	UV, V
2.5-4 NPS	4-8 NPS	2.922 in ²	[49] 1.929 in	0.484 in	15-5500 psi	Steam	UV, V
2.5-4 NPS	4-8 NPS	3.117 in ²	[L] 1.992 in	0.5 in	15-5500 psi	Steam	UV, V
3-4 NPS	4-6 NPS	3.819 in ²	[56] 2.205 in	0.551 in	15-5500 psi	Steam	UV, V
3-4 NPS	4-6 NPS	3.927 in ²	[M] 2.236 in	0.559 in	15-5500 psi	Steam	UV, V
3-4 NPS	6-8 NPS	4.008 in ²	[M2] 2.259 in	0.565 in	15-5500 psi	Steam	UV, V
3-4 NPS	6-8 NPS	4.741 in ²	[N] 2.457 in	0.614 in	15-3500 psi	Steam	UV, V
3.5-4 NPS	6-8 NPS	5.143 in ²	[65] 2.559 in	0.642 in	15-3500 psi	Steam	UV, V
3.5-4 NPS	6-8 NPS	5.301 in ²	[N2] 2.598 in	0.65 in	15-3500 psi	Steam	UV, V
4-6 NPS	6-8 NPS	6.487 in ²	[73] 2.874 in	0.72 in	15-3500 psi	Steam	UV, V
4-6 NPS	6-8 NPS	6.793 in ²	[74.7] 2.941 in	0.736 in	15-3500 psi	Steam	UV, V
4-6 NPS	6-8 NPS	6.975 in ²	[P] 2.98 in	0.748 in	15-3500 psi	Steam	UV, V
4-6 NPS	6-8 NPS	7.388 in ²	[77.9] 3.067 in	0.768 in	15-3500 psi	Steam	UV, V
4.5-6 NPS	8-10 NPS	8.184 in ²	[82] 3.228 in	0.807 in	15-3500 psi	Steam	UV, V
4.5-6 NPS	8-10 NPS	8.465 in ²	[Q0] 3.283 in	0.823 in	15-3500 psi	Steam	UV, V
5-6 NPS	8-10 NPS	9.43 in ²	[88] 3.465 in	0.866 in	15-2000 psi	Steam	UV, V
5-6 NPS	8-10 NPS	9.948 in ²	[Q1] 3.559 in	0.89 in	15-1500 psi	Steam	UV, V
5.5-6 NPS	8-10 NPS	12.07 in ²	[Q] 3.921 in	0.98 in	15-1500 psi	Steam	UV, V
6 NPS	8-10 NPS	13.422 in ²	[105] 4.134 in	1.035 in	15-1500 psi	Steam	UV, V
6 NPS	8-10 NPS	13.914 in ²	[106.9] 4.209 in	1.055 in	15-1500 psi	Steam	UV, V
6 NPS	8-10 NPS	16.1 in ²	[115] 4.528 in	1.134 in	15-1500 psi	Steam	UV, V
6 NPS	8-10 NPS	17.48 in ²	[R] 4.717 in	1.181 in	15-1500 psi	Steam	UV, V
6 NPS	10 NPS	19.67 in ²	[RR] 5.004 in	1.251 in	15-1500 psi	Steam	UV, V
8 NPS	10-12 NPS	28.43 in ²	[T] 6.016 in	1.504 in	15-800 psi	Steam	UV, V
8 NPS	10-12 NPS	28.5 in ²	[153] 6.024 in	1.507 in	15-800 psi	Steam	UV, V
10 NPS	14 NPS	52.82 in ²	[V] 8.201 in	2.051 in	15-300 psi	Steam	UV, V
12 NPS	16 NPS	76.03 in ²	[W] 9.839 in	2.461 in	15-300 psi	Steam	UV, V

Design Name: SL-xxxx PA		NBCert #	27199
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		V	09/30/2027

Design Type

[Power Actuated Relief Valve] SL-xxxx PA
 Capacity Tests: Sec. V at National Board Testing Lab on September 24, 2015
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Power Actuated
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Fukui Seisakusho Company, Limited {FKI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1-2 NPS	0.122 in ²	[D] 0.394 in	0.098 in	15-5500 psi	Steam	V
0.75-1 NPS	1-2 NPS	0.216 in ²	[E] 0.524 in	0.134 in	15-5500 psi	Steam	V
1-2 NPS	2-4 NPS	0.336 in ²	[F] 0.654 in	0.165 in	15-5500 psi	Steam	V
1-2 NPS	2-4 NPS	0.336 in ²	[F1] 0.654 in	0.096 in	15-5500 psi	Steam	V
1-2 NPS	2-4 NPS	0.439 in ²	[19] 0.748 in	0.189 in	15-5500 psi	Steam	V
1.25-2 NPS	2.5-4 NPS	0.548 in ²	[G] 0.835 in	0.209 in	15-5500 psi	Steam	V
1.25-2 NPS	2.5-4 NPS	0.548 in ²	[G1] 0.835 in	0.146 in	15-5500 psi	Steam	V
1.25-2 NPS	2.5-4 NPS	0.701 in ²	[24] 0.945 in	0.236 in	15-5500 psi	Steam	V
1.5-2 NPS	3-4 NPS	0.861 in ²	[H] 1.047 in	0.264 in	15-5500 psi	Steam	V
1.5-2 NPS	3-4 NPS	1.095 in ²	[30] 1.181 in	0.295 in	15-5500 psi	Steam	V
2-3 NPS	3-6 NPS	1.408 in ²	[J] 1.339 in	0.335 in	15-5500 psi	Steam	V
2-3 NPS	3-6 NPS	1.758 in ²	[38] 1.496 in	0.374 in	15-5500 psi	Steam	V
2-3 NPS	3-6 NPS	1.804 in ²	[J3] 1.515 in	0.38 in	15-5500 psi	Steam	V
2.5-4 NPS	4-8 NPS	2.006 in ²	[K] 1.598 in	0.402 in	15-5500 psi	Steam	V
2.5-4 NPS	4-8 NPS	2.676 in ²	[K2] 1.846 in	0.465 in	15-5500 psi	Steam	V
2.5-4 NPS	4-8 NPS	2.863 in ²	[K3] 1.909 in	0.477 in	15-5500 psi	Steam	V
2.5-4 NPS	4-8 NPS	2.922 in ²	[49] 1.929 in	0.484 in	15-5500 psi	Steam	V
2.5-4 NPS	4-8 NPS	3.117 in ²	[L] 1.992 in	0.5 in	15-5500 psi	Steam	V
3-4 NPS	4-6 NPS	3.819 in ²	[56] 2.205 in	0.551 in	15-5500 psi	Steam	V
3-4 NPS	4-6 NPS	3.927 in ²	[M] 2.236 in	0.559 in	15-5500 psi	Steam	V
3-4 NPS	6-8 NPS	4.008 in ²	[M2] 2.259 in	0.565 in	15-5500 psi	Steam	V
3.5-4 NPS	6-8 NPS	4.741 in ²	[N] 2.457 in	0.614 in	15-3000 psi	Steam	V
3.5-4 NPS	6-8 NPS	5.143 in ²	[65] 2.559 in	0.642 in	15-3000 psi	Steam	V
3.5-4 NPS	6-8 NPS	5.301 in ²	[N2] 2.598 in	0.65 in	15-3000 psi	Steam	V
4-6 NPS	6-8 NPS	6.487 in ²	[73] 2.874 in	0.72 in	15-3000 psi	Steam	V
4-6 NPS	6-8 NPS	6.793 in ²	[74.7] 2.941 in	0.736 in	15-3000 psi	Steam	V
4-6 NPS	6-8 NPS	6.975 in ²	[P] 2.98 in	0.748 in	15-3000 psi	Steam	V
4-6 NPS	6-8 NPS	7.388 in ²	[77.9] 3.067 in	0.768 in	15-3000 psi	Steam	V
4.5-6 NPS	8-10 NPS	8.184 in ²	[82] 3.228 in	0.807 in	15-3000 psi	Steam	V
4.5-6 NPS	8-10 NPS	8.465 in ²	[Q0] 3.283 in	0.823 in	15-3000 psi	Steam	V
5-6 NPS	8-10 NPS	9.43 in ²	[88] 3.465 in	0.866 in	15-2000 psi	Steam	V
5-6 NPS	8-10 NPS	9.948 in ²	[Q1] 3.559 in	0.89 in	15-1500 psi	Steam	V
5.5-6 NPS	8-10 NPS	12.07 in ²	[Q] 3.921 in	0.98 in	15-1500 psi	Steam	V

6 NPS	10 NPS	13.422 in ²	[105] 4.134 in	1.035 in	15-1500 psi	Steam	V
6 NPS	10 NPS	13.914 in ²	[106.9] 4.209 in	1.055 in	15-1500 psi	Steam	V
6 NPS	10 NPS	16.1 in ²	[115] 4.528 in	1.134 in	15-1500 psi	Steam	V
6 NPS	10 NPS	17.48 in ²	[R] 4.717 in	1.181 in	15-1500 psi	Steam	V
6 NPS	10 NPS	19.67 in ²	[RR] 5.004 in	1.251 in	15-1500 psi	Steam	V
8 NPS	10, 12 NPS	28.43 in ²	[T] 6.016 in	1.504 in	15-800 psi	Steam	V
8 NPS	10, 12 NPS	28.5 in ²	[153] 6.024 in	1.507 in	15-800 psi	Steam	V
10 NPS	14 NPS	52.82 in ²	[V] 8.201 in	2.051 in	15-300 psi	Steam	V
12 NPS	16 NPS	76.03 in ²	[W] 9.839 in	2.461 in	15-300 psi	Steam	V

GLM Energy Services, LLC (GCM)

Nameplate Abbreviation: GLM Energy Services

Kenai, AK 99611United States

This Company Manufactures or Assembles:

Design Name:	1700 & 2700	NBCert #	18100
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	V	07/31/2025
-----------	---	------------

Design Type

[Safety Valve] 1700 & 2700
Capacity Tests: Sec. UV, V at Dresser, Inc. on August 1, 1957
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	50-5800 psi	Steam	V
4 NPS	4 dual NPS	1.84 in ²	[K] 1.531 in	0.383 in	50-5800 psi	Steam	V
2-3 NPS	4, 6 NPS	2.545 in ²	[#3] 1.8 in	0.45 in	50-5800 psi	Steam	UV, V
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-2575 psi	Steam	UV
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	50-5800 psi	Steam	V
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	15-3100 psi	Steam	UV
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	50-5800 psi	Steam	V

4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	15-3100 psi	Steam	UV
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	15-1800 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	1.24 in	50-2200 psi	Steam	UV, V
8-10 NPS	10,12 NPS	28.3 in ²	[T] 6 in	1.5 in	50-1500 psi	Steam	UV, V

Design Name: 1900, 1900-30 1900-35 LA & DALA (Liquids) NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/10/2025

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V

12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V
-----------	--------	------------------------	---------------	----------	------------	-------	-----------

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	07/10/2025
-----------	----	------------

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV

8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/10/2025

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/10/2025

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2

NBCert #

18144

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/10/2025

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert #

18751

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/10/2025

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900E-2, 1900-30E-2 NBCert # 18166

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 07/10/2025

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 07/10/2025

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 1982 NBCert # 18379

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 07/10/2025

Design Type

[Safety Relief Valve] 1982
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at unknown lab on May 6, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Air	NV, UV
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Steam	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Air	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Steam	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Air	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Steam	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Air	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Air	NV, UV

Design Name: 3900 (39PV, 39MV pilots) NBCert # 18447

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/10/2025

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV

1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV

8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid) NBCert # 18458

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/10/2025

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Global Engg. Solutions FZCO (A Bliss Anand - India Group Company) (GES)

Dubai, United Arab Emirates

This Company Manufactures or Assembles:

Design Name: 28L Series		NBCert # 00987	
Manufacturer/Assembler		Designators	Expiration Date

Manufacturer

UV

10/30/2030

Design Type

[Relief Valve] 28L Series
Capacity Tests: Sec. UV at National Board Testing Lab on May 9, 2023
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.115 in ²	[D] 0.383 in	0.096 in	15-10000 psi	Water	UV
1-1.5 NPS	2, 3 NPS	0.208 in ²	[E] 0.514 in	0.129 in	15-10000 psi	Water	UV
1.5 NPS	2, 3 NPS	0.328 in ²	[F] 0.646 in	0.162 in	15-10000 psi	Water	UV
1.5-2 NPS	3 NPS	0.545 in ²	[G] 0.833 in	0.208 in	15-7000 psi	Water	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 1.043 in	0.261 in	15-6000 psi	Water	UV

2-3 NPS	3, 4 NPS	1.408 in ²	[J] 1.339 in	0.335 in	15-6000 psi	Water	UV
3 NPS	4, 6 NPS	2.013 in ²	[K] 1.601 in	0.4 in	15-5000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.136 in ²	[L] 1.998 in	0.5 in	15-4000 psi	Water	UV
4 NPS	6 NPS	3.959 in ²	[M] 2.245 in	0.561 in	15-3000 psi	Water	UV
4 NPS	6 NPS	4.777 in ²	[N] 2.466 in	0.617 in	15-2500 psi	Water	UV
4 NPS	6 NPS	7.037 in ²	[P] 2.993 in	0.748 in	15-2000 psi	Water	UV
6 NPS	8 NPS	12.2 in ²	[Q] 3.941 in	0.985 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	17.686 in ²	[R] 4.745 in	1.186 in	15-600 psi	Water	UV
8 NPS	10 NPS	28.761 in ²	[T] 6.051 in	1.513 in	15-500 psi	Water	UV
8-10 NPS	10-12 NPS	30.78 in ²	[U] 6.26 in	1.565 in	15-300 psi	Water	UV

Design Name: 28L Series (Air,Gas)

NBCert #

00998

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/30/2030

Design Type

[Safety Relief Valve] 28L Series (Air,Gas)
Capacity Tests: Sec. UV at National Board Testing Lab on September 21, 2022
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.849 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.115 in ²	[D] 0.383 in	0.096 in	15-10000 psi	Air	UV
1-1.5 NPS	2, 3 NPS	0.208 in ²	[E] 0.514 in	0.129 in	15-10000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.328 in ²	[F] 0.646 in	0.162 in	15-10000 psi	Air	UV
1.5-2 NPS	3 NPS	0.545 in ²	[G] 0.833 in	0.208 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 1.043 in	0.261 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.408 in ²	[J] 1.339 in	0.335 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.013 in ²	[K] 1.601 in	0.4 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.136 in ²	[L] 1.998 in	0.5 in	15-4000 psi	Air	UV
4 NPS	6 NPS	3.959 in ²	[M] 2.245 in	0.561 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.777 in ²	[N] 2.466 in	0.617 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.037 in ²	[P] 2.993 in	0.748 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.2 in ²	[Q] 3.941 in	0.985 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.686 in ²	[R] 4.745 in	1.186 in	15-600 psi	Air	UV
8 NPS	10 NPS	28.761 in ²	[T] 6.051 in	1.513 in	15-500 psi	Air	UV
8-10 NPS	10-12 NPS	30.78 in ²	[U] 6.26 in	1.565 in	15-300 psi	Air	UV

Design Name: 28V Series	NBCert # 00392
-------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/30/2030

Design Type

[Safety Relief Valve] 28V Series
Capacity Tests: Sec. UV at National Board Testing Lab on September 21, 2022
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.850 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.115 in ²	[D] 0.383 in	0.096 in	15-10000 psi	Air	UV
1-1.5 NPS	2, 3 NPS	0.208 in ²	[E] 0.514 in	0.129 in	15-10000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.328 in ²	[F] 0.646 in	0.162 in	15-10000 psi	Air	UV
1.5-2 NPS	3 NPS	0.545 in ²	[G] 0.833 in	0.208 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.855 in ²	[H] 1.043 in	0.261 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.408 in ²	[J] 1.339 in	0.335 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.013 in ²	[K] 1.601 in	0.4 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.136 in ²	[L] 1.998 in	0.5 in	15-4000 psi	Air	UV
4 NPS	6 NPS	3.959 in ²	[M] 2.245 in	0.561 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.777 in ²	[N] 2.466 in	0.617 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.037 in ²	[P] 2.993 in	0.748 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.2 in ²	[Q] 3.941 in	0.985 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.686 in ²	[R] 4.745 in	1.186 in	15-600 psi	Air	UV
8 NPS	10 NPS	28.761 in ²	[T] 6.051 in	1.513 in	15-500 psi	Air	UV
8-10 NPS	10-12 NPS	30.78 in ²	[U] 6.26 in	1.565 in	15-300 psi	Air	UV
10 NPS	14 NPS	48.945 in ²	[V] 7.894 in	1.973 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.848 in ²	[W] 9.016 in	2.254 in	15-1000 psi	Air	UV
16 NPS	18 NPS	104.524 in ²	[W2] 11.535 in	2.884 in	15-750 psi	Air	UV
16 NPS	20 NPS	114.004 in ²	[X] 12.047 in	3.012 in	15-750 psi	Air	UV
18 NPS	24 NPS	144.077 in ²	[Y] 13.543 in	3.386 in	15-750 psi	Air	UV
20 NPS	24 NPS	177.666 in ²	[Z] 15.039 in	3.76 in	15-750 psi	Air	UV

Design Name: 29L Series	NBCert # 01090
-------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/30/2030

Design Type

[Relief Valve] 29L Series
Capacity Tests: Sec. UV at National Board Testing Lab on May 9, 2023
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.646 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.071 in ²	[C] 0.3 in	0.075 in	15-10000 psi	Water	UV
0.5-1 NPS	1 NPS	0.129 in ²	[D] 0.405 in	0.101 in	15-10000 psi	Water	UV
1 NPS	1.5 NPS	0.227 in ²	[E] 0.538 in	0.135 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.356 in ²	[F] 0.673 in	0.168 in	15-7000 psi	Water	UV

Design Name: 29V Series NBCert # 01078

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

10/30/2030

Design Type

[Safety Relief Valve] 29V Series
Capacity Tests: Sec. UV at National Board Testing Lab on March 11, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.071 in ²	[C] 0.3 in	0.075 in	15-10000 psi	Air	UV
0.5-1 NPS	1 NPS	0.129 in ²	[D] 0.405 in	0.101 in	15-10000 psi	Air	UV
1 NPS	1.5 NPS	0.227 in ²	[E] 0.538 in	0.135 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.356 in ²	[F] 0.673 in	0.168 in	15-7000 psi	Air	UV

Design Name: 31L Series NBCert # 01180

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

10/30/2030

Design Type

[Pilot Operated Pressure Relief Valve] 31L Series
Capacity Tests: Sec. UV at National Board Testing Lab on January 11, 2023
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.738 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.156 in ²	[D] 0.445 in	0.111 in	15-6170 psi	Water	UV
1-1.5 NPS	2 NPS	0.232 in ²	[E] 0.543 in	0.136 in	15-6170 psi	Water	UV
1-1.5 NPS	2 NPS	0.379 in ²	[F] 0.695 in	0.174 in	15-6170 psi	Water	UV
1.5-2 NPS	3 NPS	0.57 in ²	[G] 0.852 in	0.213 in	15-6170 psi	Water	UV
1.5-2 NPS	3 NPS	0.886 in ²	[H] 1.062 in	0.266 in	15-6170 psi	Water	UV
2-3 NPS	3, 4 NPS	1.449 in ²	[J] 1.358 in	0.34 in	15-4620 psi	Water	UV
3 NPS	4 NPS	2.061 in ²	[K] 1.62 in	0.405 in	15-3705 psi	Water	UV
3-4 NPS	4, 6 NPS	3.196 in ²	[L] 2.017 in	0.504 in	15-3705 psi	Water	UV
4 NPS	6 NPS	4.03 in ²	[M] 2.265 in	0.566 in	15-3705 psi	Water	UV
4 NPS	6 NPS	4.855 in ²	[N] 2.486 in	0.622 in	15-3705 psi	Water	UV
4 NPS	6 NPS	7.126 in ²	[P] 3.012 in	0.753 in	15-3705 psi	Water	UV
6 NPS	8, 8 Dual NPS	12.318 in ²	[Q] 3.96 in	0.99 in	15-1480 psi	Water	UV
6 NPS	8, 8 Dual NPS	17.842 in ²	[R] 4.766 in	1.192 in	15-1020 psi	Water	UV
8 NPS	10, 10 Dual NPS	29.018 in ²	[T] 6.078 in	1.52 in	15-985 psi	Water	UV

Design Name: 31V Series

NBCert # 01168

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/30/2030

Design Type

[Pilot Operated Pressure Relief Valve] 31V Series
Capacity Tests: Sec. UV at National Board Testing Lab on June 15, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.857 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Bliss Anand Private Limited {BLS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.156 in ²	[D] 0.445 in	0.111 in	15-6170 psi	Air	UV
1-1.5 NPS	2 NPS	0.232 in ²	[E] 0.543 in	0.136 in	15-6170 psi	Air	UV
1-1.5 NPS	2 NPS	0.379 in ²	[F] 0.695 in	0.174 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.57 in ²	[G] 0.852 in	0.213 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.886 in ²	[H] 1.062 in	0.266 in	15-6170 psi	Air	UV
2-3 NPS	3, 4 NPS	1.449 in ²	[J] 1.358 in	0.34 in	15-4620 psi	Air	UV
3 NPS	4 NPS	2.061 in ²	[K] 1.62 in	0.405 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.196 in ²	[L] 2.017 in	0.504 in	15-3705 psi	Air	UV
4 NPS	6 NPS	4.03 in ²	[M] 2.265 in	0.566 in	15-3705 psi	Air	UV
4 NPS	6 NPS	4.855 in ²	[N] 2.486 in	0.622 in	15-3705 psi	Air	UV
4 NPS	6 NPS	7.126 in ²	[P] 3.012 in	0.753 in	15-3705 psi	Air	UV
6 NPS	8, 8 Dual NPS	12.318 in ²	[Q] 3.96 in	0.99 in	15-1480 psi	Air	UV
6 NPS	8, 8 Dual NPS	17.842 in ²	[R] 4.766 in	1.192 in	15-1020 psi	Air	UV

Goetze KG Armaturen (GTZ)

71636 Ludwigsburg, Germany

This Company Manufactures or Assembles:

Design Name:	2400 / 2480	NBCert #	96072
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/13/2029

Design Type

[Safety Relief Valve] 2400 / 2480
Capacity Tests: Sec. UV at National Board Testing Lab on July 14, 2016
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.798 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS	.375 NPS	0.0438 in ²	0.2362 in	0.0787 in	40-1015 psi	Air	UV
0.25 NPS	.375 NPS	0.0438 in ²	0.2362 in	0.0787 in	40-1015 psi	Steam	UV
0.375 NPS	.50 NPS	0.0685 in ²	0.2953 in	0.0984 in	40-1015 psi	Air	UV
0.375 NPS	.50 NPS	0.0685 in ²	0.2953 in	0.0984 in	40-1015 psi	Steam	UV
0.5 NPS	.75 NPS	0.1342 in ²	0.4134 in	0.1378 in	40-1015 psi	Air	UV
0.5 NPS	.75 NPS	0.1342 in ²	0.4134 in	0.1378 in	40-1015 psi	Steam	UV
0.75 NPS	1.0 NPS	0.2057 in ²	0.5118 in	0.1732 in	40-1015 psi	Air	UV
0.75 NPS	1.0 NPS	0.2057 in ²	0.5118 in	0.1732 in	40-1015 psi	Steam	UV
1.25 NPS	1.5 NPS	0.3944 in ²	0.7087 in	0.2362 in	40-725 psi	Air	UV
1.25 NPS	1.5 NPS	0.3944 in ²	0.7087 in	0.2362 in	40-725 psi	Steam	UV
1.5 NPS	2.0 NPS	0.644 in ²	0.9055 in	0.3071 in	40-725 psi	Air	UV
1.5 NPS	2.0 NPS	0.644 in ²	0.9055 in	0.3071 in	40-725 psi	Steam	UV

Design Name:	2400 / 2480 Liquids	NBCert #	96083
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/12/2029

Design Type

[Relief Valve] 2400 / 2480 Liquids
Capacity Tests: Sec. UV at National Board Testing Lab on July 12, 2016
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.571 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.1342 in ²	0.4134 in	0.1378 in	40-1015 psi	Water	UV
0.75 NPS	1.0 NPS	0.2057 in ²	0.5118 in	0.1732 in	40-1015 psi	Water	UV
1.25 NPS	1.5 NPS	0.3944 in ²	0.7087 in	0.2362 in	40-725 psi	Water	UV
1.5 NPS	2.0 NPS	0.644 in ²	0.9055 in	0.3071 in	40-725 psi	Water	UV

Design Name: 255, 455	NBCert # 96274
-----------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/13/2030

Design Type

[Safety Relief Valve] 255, 455
HolderDesignation:
Capacity Tests: Sec. UV at National Board Testing Lab on November 13, 2024
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.828 Unitless; (alternate medium): 0.000
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
20 DN	32 DN	0.3944 in ²	0.7087 in	0.189 in	15-580 psi	Air	UV
20 DN	32 DN	0.3944 in ²	0.7087 in	0.189 in	15-580 psi	Steam	UV
1 NPS	2 NPS	0.6163 in ²	0.8858 in	0.2362 in	15-290 psi	Air	UV
1 NPS	2 NPS	0.6163 in ²	0.8858 in	0.2362 in	15-290 psi	Steam	UV
25 DN	40 DN	0.6163 in ²	0.8858 in	0.2362 in	15-580 psi	Air	UV
25 DN	40 DN	0.6163 in ²	0.8858 in	0.2362 in	15-580 psi	Steam	UV
1.5 NPS	2 NPS	1.0451 in ²	1.1535 in	0.3071 in	15-290 psi	Air	UV
1.5 NPS	2 NPS	1.0451 in ²	1.1535 in	0.3071 in	15-290 psi	Steam	UV
32 DN	50 DN	1.0451 in ²	1.1535 in	0.3071 in	15-580 psi	Air	UV
32 DN	50 DN	1.0451 in ²	1.1535 in	0.3071 in	15-580 psi	Steam	UV
1.5 NPS	3 NPS	1.5777 in ²	1.4173 in	0.378 in	15-290 psi	Air	UV
1.5 NPS	3 NPS	1.5777 in ²	1.4173 in	0.378 in	15-290 psi	Steam	UV
40 DN	65 DN	1.5777 in ²	1.4173 in	0.378 in	15-580 psi	Air	UV
40 DN	65 DN	1.5777 in ²	1.4173 in	0.378 in	15-580 psi	Steam	UV
2 NPS	3 NPS	2.4652 in ²	1.7717 in	0.4921 in	15-290 psi	Air	UV
2 NPS	3 NPS	2.4652 in ²	1.7717 in	0.4921 in	15-290 psi	Steam	UV
50 DN	80 DN	2.4652 in ²	1.7717 in	0.4921 in	15-580 psi	Air	UV
50 DN	80 DN	2.4652 in ²	1.7717 in	0.4921 in	15-580 psi	Steam	UV
3 NPS	4 NPS	4.2377 in ²	2.3228 in	0.6181 in	15-290 psi	Air	UV
3 NPS	4 NPS	4.2377 in ²	2.3228 in	0.6181 in	15-290 psi	Steam	UV
65 DN	100 DN	4.2377 in ²	2.3228 in	0.6181 in	15-580 psi	Air	UV
65 DN	100 DN	4.2377 in ²	2.3228 in	0.6181 in	15-580 psi	Steam	UV

80 DN	125 DN	6.3108 in ²	2.8346 in	0.7559 in	15-580 psi	Air	UV
80 DN	125 DN	6.3108 in ²	2.8346 in	0.7559 in	15-580 psi	Steam	UV
100 DN	150 DN	9.8607 in ²	3.5433 in	0.9449 in	15-580 psi	Air	UV
100 DN	150 DN	9.8607 in ²	3.5433 in	0.9449 in	15-580 psi	Steam	UV
4 NPS	6 NPS	9.8607 in ²	3.5433 in	0.9449 in	15-290 psi	Air	UV
4 NPS	6 NPS	9.8607 in ²	3.5433 in	0.9449 in	15-290 psi	Steam	UV

Design Name:	255, 455 (DN15)	NBCert #	96296
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/13/2030

Design Type

[Safety Relief Valve] 255, 455 (DN15)
HolderDesignation:
Capacity Tests: Sec. UV at National Board Testing Lab on August 2, 2024
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.740 SCFM/PSIA; (alternate medium): 10.500 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.2739 in ²	0.5906 in	0.1575 in	15-290 psi	Air	UV
0.75 NPS	1 NPS	0.2739 in ²	0.5906 in	0.1575 in	15-290 psi	Steam	UV
15 DN	25 DN	0.2739 in ²	0.5906 in	0.1575 in	15-580 psi	Air	UV
15 DN	25 DN	0.2739 in ²	0.5906 in	0.1575 in	15-580 psi	Steam	UV

Design Name:	255, 455 (Liquid)	NBCert #	96285
--------------	-------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/13/2030

Design Type

[Relief Valve] 255, 455 (Liquid)
HolderDesignation:
Capacity Tests: Sec. UV at National Board Testing Lab on August 2, 2024
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.580 Unitless; (alternate medium): 0.000
Media - Test: Water/Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
20 DN	32 DN	0.3944 in ²	0.7087 in	0.189 in	15-580 psi	Water	UV
1 NPS	2 NPS	0.6163 in ²	0.8858 in	0.2362 in	15-290 psi	Water	UV
25 DN	40 DN	0.6163 in ²	0.8858 in	0.2362 in	15-580 psi	Water	UV
1.5 NPS	2 NPS	1.0451 in ²	1.1535 in	0.3071 in	15-290 psi	Water	UV
32 DN	50 DN	1.0451 in ²	1.1535 in	0.3071 in	15-580 psi	Water	UV

1.5 NPS	3 NPS	1.5777 in ²	1.4173 in	0.378 in	15-290 psi	Water	UV
40 DN	65 DN	1.5777 in ²	1.4173 in	0.378 in	15-580 psi	Water	UV
2 NPS	3 NPS	2.4652 in ²	1.7717 in	0.4921 in	15-290 psi	Water	UV
50 DN	80 DN	2.4652 in ²	1.7717 in	0.4921 in	15-580 psi	Water	UV
3 NPS	4 NPS	4.2377 in ²	2.3228 in	0.6181 in	15-290 psi	Water	UV
65 DN	100 DN	4.2377 in ²	2.3228 in	0.6181 in	15-580 psi	Water	UV
80 DN	125 DN	6.3108 in ²	2.8346 in	0.7559 in	15-580 psi	Water	UV
100 DN	150 DN	9.8607 in ²	3.5433 in	0.9449 in	15-580 psi	Water	UV
4 NPS	6 NPS	9.8607 in ²	3.5433 in	0.9449 in	15-290 psi	Water	UV

Design Name:	4000	NBCert #	96151
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/13/2029

Design Type

[Safety Relief Valve] 4000
Capacity Tests: Sec. UV at National Board Testing Lab on June 26, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.680 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
25 DN	40 DN	0.644 in ²	0.9055 in	0.2598 in	15-232 psi	Air	UV
25 DN	40 DN	0.644 in ²	0.9055 in	0.2598 in	15-232 psi	Steam	UV
40 DN	65 DN	1.666 in ²	1.457 in	0.374 in	15-232 psi	Air	UV
40 DN	65 DN	1.666 in ²	1.457 in	0.374 in	15-232 psi	Steam	UV
50 DN	80 DN	2.576 in ²	1.811 in	0.472 in	15-232 psi	Air	UV
50 DN	80 DN	2.576 in ²	1.811 in	0.472 in	15-232 psi	Steam	UV
65 DN	100 DN	4.3825 in ²	2.362 in	0.63 in	15-232 psi	Air	UV
65 DN	100 DN	4.3825 in ²	2.362 in	0.63 in	15-232 psi	Steam	UV
80 DN	125 DN	6.666 in ²	2.913 in	0.787 in	15-232 psi	Air	UV
80 DN	125 DN	6.666 in ²	2.913 in	0.787 in	15-232 psi	Steam	UV
100 DN	150 DN	10.3038 in ²	3.622 in	0.945 in	15-232 psi	Air	UV
100 DN	150 DN	10.3038 in ²	3.622 in	0.945 in	15-232 psi	Steam	UV

Design Name:	4000 (Liquids)	NBCert #	96162
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/13/2029

Design Type

[Relief Valve] 4000 (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on June 27, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.452 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
25 DN	40 DN	0.644 in ²	0.9055 in	0.2598 in	15-232 psi	Water	UV
40 DN	65 DN	1.666 in ²	1.457 in	0.374 in	15-232 psi	Water	UV
50 DN	80 DN	2.576 in ²	1.811 in	0.472 in	15-232 psi	Water	UV
65 DN	100 DN	4.3825 in ²	2.362 in	0.63 in	15-232 psi	Water	UV
80 DN	125 DN	6.666 in ²	2.913 in	0.787 in	15-232 psi	Water	UV
100 DN	150 DN	10.3038 in ²	3.622 in	0.945 in	15-232 psi	Water	UV

Design Name: 4020, 4040, 4060 NBCert # 96230

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

04/19/2028

Design Type

[Safety Relief Valve] 4020, 4040, 4060
Capacity Tests: Sec. UV at National Board Testing Lab on December 10, 2021
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 6.220 SCFM/PSIA; (alternate medium): 17.460 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
25 DN	25 DN	0.7307 in ²	0.9646 in	0.197 in	15-232 psi	Air	UV
25 DN	25 DN	0.7307 in ²	0.9646 in	0.197 in	15-232 psi	Steam	UV

Design Name: 4020, 4040, 4060 (Liquid) NBCert # 96241

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

08/25/2028

Design Type

[Relief Valve] 4020, 4040, 4060 (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on May 10, 2022
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 9.220 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
25 DN	25 DN	0.7307 in²	0.9646 in	0.197 in	15-232 psi	Water	UV
Design Name: 410, 810, 1809, 1810							
NBCert #				96094			
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			01/13/2029	
Design Type							
[Safety Relief Valve] 410, 810, 1809, 1810 Capacity Tests: Sec. UV at National Board Testing Lab on October 31, 2016 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.758 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Goetze KG Armaturen {GTZ}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS		0.0685 in ²	0.295 in	0.089 in	15-725 psi	Air	UV
0.375 NPS		0.1217 in ²	0.394 in	0.118 in	15-725 psi	Air	UV
0.5 NPS		0.1473 in ²	0.433 in	0.13 in	15-725 psi	Air	UV
0.75 NPS		0.3116 in ²	0.63 in	0.189 in	15-725 psi	Air	UV
1 NPS		0.4869 in ²	0.787 in	0.236 in	15-725 psi	Air	UV
1.25 NPS		0.7609 in ²	0.9843 in	0.2756 in	30-232 psi	Air	UV
1.5 NPS		1.2466 in ²	1.2598 in	0.3543 in	30-232 psi	Air	UV
2 NPS		1.9478 in ²	1.5748 in	0.3937 in	30-232 psi	Air	UV

Design Name: 451, 851		NBCert #	96038
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	05/05/2028
Design Type			
[Safety Relief Valve] 451, 851 Capacity Tests: Sec. UV at National Board Testing Lab on October 23, 2015 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.659 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Goetze KG Armaturen {GTZ}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-0.75 NPS	1.25 NPS	0.3944 in ²	0.7087 in	0.2087 in	15-1015 psi	Air	UV
1-1 NPS	1.5 NPS	0.644 in ²	0.9055 in	0.2402 in	15-1015 psi	Air	UV
1.25-1.25 NPS	2 NPS	1.1177 in ²	1.1929 in	0.311 in	15-1015 psi	Air	UV

Design Name:	451, 851 Liquids	NBCert #	96049
--------------	------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/12/2029

Design Type

[Relief Valve] 451, 851 Liquids
Capacity Tests: Sec. UV at National Board Testing Lab on July 12, 2016
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.492 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-0.75 NPS	1.25 NPS	0.3944 in²	0.7087 in	0.2087 in	15-1015 psi	Water	UV
1-1 NPS	1.5 NPS	0.644 in²	0.9055 in	0.2402 in	15-1015 psi	Water	UV
1.25-2 NPS	1.1177 NPS	1.1177 in²	1.1929 in	0.311 in	15-1015 psi	Water	UV

Design Name:	451-1/2", 851-1/2"	NBCert #	96050
--------------	--------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/03/2028

Design Type

[Safety Relief Valve] 451-1/2", 851-1/2"
Capacity Tests: Sec. UV at National Board Testing Lab on October 21, 2015
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.470 SCFM/PSIA; (alternate medium): 6.940 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.5 NPS	1 NPS	0.3039 in²	0.622 in	0.0866 in	15-1015 psi	Air	UV

Design Name:	451-1/2", 851-1/2" (Liquids)	NBCert #	96061
--------------	------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/04/2028

Design Type

[Relief Valve] 451-1/2", 851-1/2" (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on October 21, 2015
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.046 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.5 NPS	1 NPS	0.3039 in²	0.622 in	0.0866 in	15-1015 psi	Water	UV
Design Name: 460NBCert # 96218							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			05/27/2027	
Design Type							
[Safety Relief Valve] 460 Capacity Tests: Sec. UV at National Board Testing Lab on November 5, 2019 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.549 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Goetze KG Armaturen {GTZ}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375 NPS	0.375 NPS	0.986 in ²	0.3543 in	0.0886 in	30-362 psi	Air	UV
0.375 NPS	0.375 NPS	0.986 in ²	0.3543 in	0.0886 in	30-362 psi	Steam	UV
0.5 NPS	0.5 NPS	0.2057 in ²	0.5118 in	0.128 in	30-362 psi	Air	UV
0.5 NPS	0.5 NPS	0.2057 in ²	0.5118 in	0.128 in	30-362 psi	Steam	UV
0.75 NPS	0.75 NPS	0.2739 in ²	0.5906 in	0.1476 in	30-362 psi	Air	UV
0.75 NPS	0.75 NPS	0.2739 in ²	0.5906 in	0.1476 in	30-362 psi	Steam	UV
1 NPS	1 NPS	0.3944 in ²	0.7087 in	0.177 in	30-362 psi	Air	UV
1 NPS	1 NPS	0.3944 in ²	0.7087 in	0.177 in	30-362 psi	Steam	UV

Design Name: 460 (Liquid)		NBCert #	96229
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	12/03/2026
Design Type			
[Relief Valve] 460 (Liquid) Capacity Tests: Sec. UV at National Board Testing Lab on December 13, 2019 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.410 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Goetze KG Armaturen {GTZ}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	0.5 NPS	0.2057 in ²	0.5118 in	0.128 in	43-362 psi	Water	UV
0.75 NPS	0.75 NPS	0.2739 in ²	0.5906 in	0.1476 in	43-362 psi	Water	UV
1 NPS	1 NPS	0.3944 in ²	0.7087 in	0.177 in	43-362 psi	Water	UV

Design Name:	492	NBCert #	96252
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/19/2028

Design Type

[Safety Relief Valve] 492
Capacity Tests: Sec. UV at National Board Testing Lab on January 10, 2022
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas; Certified: Air/Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.75 NPS	0.5-1 NPS	0.011 in ²	0.1181 in	0.0866 in	2175-21750 psi	Air	UV
0.25-1 NPS	0.5-1 NPS	0.0247 in ²	0.1772 in	0.0866 in	1450-14500 psi	Air	UV
0.25-1 NPS	0.5-1 NPS	0.0438 in ²	0.2362 in	0.1181 in	725-9135 psi	Air	UV
0.375-1 NPS	0.5-1 NPS	0.0986 in ²	0.3543 in	0.1181 in	725-3625 psi	Air	UV

Design Name:	642/6420 (1-1/2" to 2-1/2"), 645/6450 (1-1/4" to 2")	NBCert #	96195
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/16/2030

Design Type

[Safety Relief Valve] 642/6420 (1-1/2" to 2-1/2"), 645/6450 (1-1/4" to 2")
Capacity Tests: Sec. UV at National Board Testing Lab on November 8, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.546 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.25 NPS	1.0956 in ²	1.1811 in	0.2756 in	15-232 psi	Air	UV
1.25-1.5 NPS	1.25 NPS	1.0956 in ²	1.1811 in	0.2756 in	15-232 psi	Steam	UV
1.5-2 NPS	2 NPS	1.8516 in ²	1.5354 in	0.3543 in	15-232 psi	Air	UV
1.5-2 NPS	2 NPS	1.8516 in ²	1.5354 in	0.3543 in	15-232 psi	Steam	UV
2-2.5 NPS	2.5 NPS	2.8048 in ²	1.8898 in	0.4449 in	15-232 psi	Air	UV
2-2.5 NPS	2.5 NPS	2.8048 in ²	1.8898 in	0.4449 in	15-232 psi	Steam	UV

Design Name:	642/6420 (1-1/2" to 2-1/2"), 645/6450 (1-1/4" to 2") (Liquid)	NBCert #	96207
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/15/2030

Design Type

[Relief Valve] 642/6420 (1-1/2" to 2-1/2"), 645/6450 (1-1/4" to 2") (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on November 7, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.359 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	1.096 in ²	1.181 in	0.276 in	15-232 psi	Water	UV
1.5-2 NPS	2 NPS	1.8516 in ²	1.5354 in	0.3543 in	15-232 psi	Water	UV
2-2.5 NPS	2.5 NPS	2.8048 in ²	1.8898 in	0.4449 in	15-232 psi	Water	UV

Design Name: 642/6420/4420 (1/2" to 1-1/4"),
645/6450/4450 (1/2" to 1") NBCert # 96139

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	05/16/2030
--------------	----	------------

Design Type

[Safety Relief Valve] 642/6420/4420 (1/2" to 1-1/4"), 645/6450/4450 (1/2" to 1")
Capacity Tests: Sec. UV at National Board Testing Lab on November 6, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.650 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	0.5, 0.75 NPS	0.2057 in ²	0.5118 in	0.13 in	15-232 psi	Air	UV
0.5 NPS	0.5, 0.75 NPS	0.2057 in ²	0.5118 in	0.13 in	15-232 psi	Steam	UV
0.75 NPS	0.75 NPS	0.2739 in ²	0.5906 in	0.1457 in	15-232 psi	Air	UV
0.75 NPS	0.75 NPS	0.2739 in ²	0.5906 in	0.1457 in	15-232 psi	Steam	UV
0.75-1 NPS	1 NPS	0.3944 in ²	0.7087 in	0.1693 in	15-232 psi	Air	UV
0.75-1 NPS	1 NPS	0.3944 in ²	0.7087 in	0.1693 in	15-232 psi	Steam	UV
1-1.25 NPS	1.25 NPS	0.644 in ²	0.9055 in	0.2323 in	15-232 psi	Air	UV
1-1.25 NPS	1.25 NPS	0.644 in ²	0.9055 in	0.2323 in	15-232 psi	Steam	UV

Design Name: 642/6420/4420 (1/2" to 1-1/4"),
645/6450/4450 (1/2" to 1") (Liquid) NBCert # 96140

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	05/15/2030
--------------	----	------------

Design Type

[Relief Valve] 642/6420/4420 (1/2" to 1-1/4"), 645/6450/4450 (1/2" to 1") (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on November 7, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.429 Unitless
Media - Test: Air/Gas, Steam; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.5, .75 NPS	0.2057 in ²	0.5118 in	0.13 in	15-232 psi	Water	UV
0.75 NPS	.75 NPS	0.2739 in ²	0.5906 in	0.1457 in	15-232 psi	Water	UV
0.75-1 NPS	1 NPS	0.3944 in ²	0.7087 in	0.1693 in	15-232 psi	Water	UV
1-1.25 NPS	1.25 NPS	0.644 in ²	0.9055 in	0.2323 in	15-232 psi	Water	UV

Design Name: 812, 412, 1812 NBCert # 96005

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

11/20/2025

Design Type

[Safety Relief Valve] 812, 412, 1812
Capacity Tests: Sec. UV at National Board Testing Lab on August 14, 2013
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.774 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.238 in ²	0.551 in	0.138 in	15-725 psi	Air	UV
0.75 NPS		0.486 in ²	0.787 in	0.197 in	15-725 psi	Air	UV
1 NPS		0.701 in ²	0.945 in	0.236 in	15-725 psi	Air	UV
1.25-1.5 NPS		1.17 in ²	1.22 in	0.305 in	15-725 psi	Air	UV

Design Name: 812-2", 412-2" NBCert # 96106

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

01/12/2029

Design Type

[Safety Relief Valve] 812-2", 412-2"
Capacity Tests: Sec. UV at National Board Testing Lab on July 13, 2016
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 30.116 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Goetze KG Armaturen {GTZ}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		2.8005 in ²	1.8883 in	0.315 in	15-435 psi	Air	UV

GRISS S.A. (SPG)

Armentieres, 59428France

This Company Manufactures or Assembles:

Design Name: 8100			NBCert # 49047		
Manufacturer/Assembler		Designators		Expiration Date	
Manufacturer		UV		06/23/2027	

Design Type

[Safety Valve] 8100
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on April 5, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.867 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: GRISS S.A. {SPG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 NPS	6 NPS	4.6951 in ²	[N] 0.2445 in	0.733 in	15-1000 psi	Air	UV
4 NPS	6 NPS	4.6951 in ²	[N] 0.2445 in	0.733 in	15-1000 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.1219 in ²	[D] 0.394 in	0.118 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.1219 in ²	[D] 0.394 in	0.118 in	15-6000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2157 in ²	[E] 0.524 in	0.145 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2157 in ²	[E] 0.524 in	0.145 in	15-6000 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3318 in ²	[F] 0.65 in	0.195 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3318 in ²	[F] 0.65 in	0.195 in	15-5000 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5476 in ²	[G] 0.835 in	0.25 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.5476 in ²	[G] 0.835 in	0.25 in	15-3500 psi	Air	UV
1.5-2 NPS	3 NPS	0.8544 in ²	[H] 1.043 in	0.314 in	15-2500 psi	Air	UV
1.5-2 NPS	3 NPS	0.8544 in ²	[H] 1.043 in	0.314 in	15-2500 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.3998 in ²	[J] 1.335 in	0.441 in	15-2500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.3998 in ²	[J] 1.335 in	0.441 in	15-2500 psi	Steam	UV
3 NPS	4, 6 NPS	1.9956 in ²	[K] 1.594 in	0.478 in	15-2000 psi	Air	UV
3 NPS	4, 6 NPS	1.9956 in ²	[K] 1.594 in	0.478 in	15-2000 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.0915 in ²	[L] 1.984 in	0.595 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.0915 in ²	[L] 1.984 in	0.595 in	15-1500 psi	Steam	UV
4 NPS	6 NPS	3.9127 in ²	[M] 2.232 in	0.671 in	15-1100 psi	Air	UV
4 NPS	6 NPS	3.9127 in ²	[M] 2.232 in	0.671 in	15-1100 psi	Steam	UV

4 NPS	6 NPS	6.9046 in ²	[P] 2.965 in	0.89 in	15-1000 psi	Air	UV
4 NPS	6 NPS	6.9046 in ²	[P] 2.965 in	0.89 in	15-1000 psi	Steam	UV
6 NPS	8 NPS	11.9337 in ²	[Q] 3.898 in	1.169 in	15-600 psi	Air	UV
6 NPS	8 NPS	11.9337 in ²	[Q] 3.898 in	1.169 in	15-600 psi	Steam	UV
6 NPS	8, 10 NPS	16.7784 in ²	[R] 4.622 in	1.386 in	15-300 psi	Air	UV
6 NPS	8, 10 NPS	16.7784 in ²	[R] 4.622 in	1.386 in	15-300 psi	Steam	UV
8 NPS	10 NPS	28.2743 in ²	[T] 6 in	1.799 in	15-300 psi	Air	UV
8 NPS	10 NPS	28.2743 in ²	[T] 6 in	1.799 in	15-300 psi	Steam	UV
10 NPS	14 NPS	45.105 in ²	[V] 7.578 in	1.895 in	15-180 psi	Air	UV
10 NPS	14 NPS	45.105 in ²	[V] 7.578 in	1.895 in	15-180 psi	Steam	UV
12 NPS	12 x 2 NPS	67.2235 in ²	[W] 9.2516 in	2.313 in	15-160 psi	Air	UV
12 NPS	12 x 2 NPS	67.2235 in ²	[W] 9.2516 in	2.313 in	15-160 psi	Steam	UV

Design Name: 81P (Liquids) NBCert # 01102

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 04/27/2027

Design Type

[Relief Valve] 81P (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: 93% of pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name: 900 Series (Liquid), 7700, SNC NBCert # 15499

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 04/11/2027

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.661 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name: 900 Series, 7700, SNC

NBCert #

15411

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

04/12/2027

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV

1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name:	BP	NBCert #	15501
--------------	----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 04/27/2027

Design Type

[Safety Relief Valve] BP
Capacity Tests: Sec. UV at Crosby Valve, LLC on August 24, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.841 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.0539 in ²	[#4] 0.262 in	0.06 in	50-3000 psi	Air	UV
0.75-1 NPS	1 NPS	0.0929 in ²	[#5] 0.344 in	0.085 in	50-3000 psi	Air	UV
0.75-1 NPS	1 NPS	0.114 in ²	[#5A] 0.381 in	0.098 in	50-3000 psi	Air	UV
0.75-1 NPS	1 NPS	0.1364 in ²	[#6] 0.417 in	0.112 in	50-3000 psi	Air	UV

Design Name:	BP (Liquids)	NBCert #	15534
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 04/26/2027

Design Type

[Relief Valve] BP (Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on September 15, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.631 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.0539 in ²	[#4] 0.262 in	0.06 in	50-3000 psi	Water	UV, V
0.75-1 NPS	1 NPS	0.0929 in ²	[#5] 0.344 in	0.085 in	50-3000 psi	Water	UV, V
0.75-1 NPS	1 NPS	0.114 in ²	[#5A] 0.381 in	0.098 in	50-3000 psi	Water	UV, V
0.75-1 NPS	1 NPS	0.1364 in ²	[#6] 0.417 in	0.112 in	50-3000 psi	Water	UV, V

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Liquids)	NBCert #	15095
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 04/26/2027

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.656 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/27/2027

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
 Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.870 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Gulf Valve Service Co., LLC (GVS)

Baton Rouge, LA 70817United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3NBCert # 18032

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	08/16/2027

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1811, 1511

NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	08/26/2028

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA
(Liquids)

NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	08/16/2027

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V

1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/16/2027

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV

3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201) NBCert # 18223

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/13/2027

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV

1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name: 19000 Series

NBCert #

18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

08/16/2027

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

11/14/2028

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/29/2028

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/26/2028

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/29/2028

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV

1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV
-----------	---------	------------------------	--------------	----------	-------------	-----	--------

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 08/16/2027

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 1982 NBCert # 18379

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/29/2028

Design Type

[Safety Relief Valve] 1982
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at unknown lab on May 6, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Air	NV, UV
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Steam	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Air	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Steam	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Air	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Steam	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Air	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Air	NV, UV

Hansen Technologies Corporation (HTL)

Nameplate Abbreviation: HANSEN

Commerce, GA 30529United States

This Company Manufactures or Assembles:

Design Name: EZB		NBCert # 70108	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	11/23/2029
Design Type			
[Safety Relief Valve] EZB Capacity Tests: Sec. UV at National Board Testing Lab on October 31, 2011 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.781 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Hansen Technologies Corporation {HTL}			
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia. Lift Set Pressure Range Media Designator
0.5-0.75 NPS	.75, 1 NPS	0.083 in ²	0.326 in 0.082 in 150-600 psi Air UV
Design Name: EZC		NBCert # 70096	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	09/16/2029
Design Type			
[Safety Relief Valve] EZC Capacity Tests: Sec. UV at National Board Testing Lab on May 9, 2011 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.630 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Hansen Technologies Corporation {HTL}			
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia. Lift Set Pressure Range Media Designator
0.75 NPS	1 NPS	0.169 in ²	0.464 in 150-600 psi Air UV
Design Name: EZE		NBCert # 70120	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	08/07/2029

Design Type

[Safety Relief Valve] EZE
Capacity Tests: Sec. UV at National Board Testing Lab on January 12, 2012
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.100 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Hansen Technologies Corporation {HTL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.25 NPS	1.25, 1.5 NPS	0.224 in ²	0.534 in	0.134 in	150-400 psi	Air	UV

Design Name: EZF	NBCert # 70131
------------------	----------------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

08/07/2029

Design Type

[Safety Relief Valve] EZF
Capacity Tests: Sec. UV at National Board Testing Lab on February 16, 2012
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.500 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Hansen Technologies Corporation {HTL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.25 NPS	1.25, 1.5 NPS	0.267 in ²	0.583 in	0.146 in	150-400 psi	Air	UV

Design Name: EZLQ	NBCert # 70085
-------------------	----------------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

09/16/2029

Design Type

[Safety Relief Valve] EZLQ
Capacity Tests: Sec. UV at National Board Testing Lab on October 31, 2011
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.790 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Hansen Technologies Corporation {HTL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.102 in ²	0.36 in	0.09 in	50-125 psi	Water	UV

Design Name: H5600, H5601 & H5602	NBCert # 70018
-----------------------------------	----------------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

09/02/2026

Design Type

[Safety Relief Valve] H5600, H5601 & H5602
Capacity Tests: Sec. UV at National Board Testing Lab on March 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.650 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Hansen Technologies Corporation {HTL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1 NPS	0.208 in ²	0.515 in	0.125 in	150-350 psi	Air	UV

Design Name:	H5600A	NBCert #	70030
--------------	--------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

09/24/2026

Design Type

[Safety Relief Valve] H5600A
Capacity Tests: Sec. UV at National Board Testing Lab on March 23, 2000
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.320 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Hansen Technologies Corporation {HTL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.172 in ²	0.515 in	0.125 in	150-400 psi	Air	UV

Design Name:	H5600R, H5602R	NBCert #	70041
--------------	----------------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

09/24/2026

Design Type

[Safety Relief Valve] H5600R, H5602R
Capacity Tests: Sec. UV at National Board Testing Lab on January 17, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.781 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Hansen Technologies Corporation {HTL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 - 1 NPS	0.0498 in ²	0.515 in	0.125 in	150-400 psi	Air	UV

Design Name:	H5604	NBCert #	70029
--------------	-------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

09/04/2026

Design Type

[Safety Relief Valve] H5604
Capacity Tests: Sec. UV at National Board Testing Lab on August 25, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.330 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Hansen Technologies Corporation {HTL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS		0.441 in ²	0.75 in	0.125 in	150-400 psi	Air	UV

Design Name:	H5613	NBCert #	70007
--------------	-------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

09/04/2026

Design Type

[Safety Relief Valve] H5613
Capacity Tests: Sec. UV at National Board Testing Lab on July 7, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.920 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Hansen Technologies Corporation {HTL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.25 NPS	0.312 in ²	0.75 in	0.125 in	100-400 psi	Air	UV

Design Name:	H5632R	NBCert #	70052
--------------	--------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

09/24/2026

Design Type

[Safety Relief Valve] H5632R
Capacity Tests: Sec. UV at National Board Testing Lab on April 22, 2003
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.630 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Hansen Technologies Corporation {HTL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.102 in ²	0.515 in	0.125 in	150-400 psi	Air	UV

Design Name:	H5633R	NBCert #	70063
--------------	--------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

09/24/2026

Design Type

[Safety Relief Valve] H5633R
Capacity Tests: Sec. UV at National Board Testing Lab on January 17, 2003
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.100 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Hansen Technologies Corporation {HTL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.25 NPS	0.138 in ²	0.75 in	0.125 in	150-400 psi	Air	UV

Design Name: H5634R NBCert # 70074

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

09/04/2026

Design Type

[Safety Relief Valve] H5634R
Capacity Tests: Sec. UV at National Board Testing Lab on April 29, 2003
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.500 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Hansen Technologies Corporation {HTL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.162 in ²	0.75 in	0.125 in	150-400 psi	Air	UV

Hansom (Nanjing) Technologies Co., Ltd. (JRM)

Nameplate Abbreviation: HANSOM

Nanjing, Jiangsu Province, 211316People's Republic of China

This Company Manufactures or Assembles:

Design Name: IN-P, HO-F Series (12"-100" NPS) NBCert # 01540

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

08/28/2030

Design Type

[Buckling Pin Non-reclosing Device] IN-P, HO-F Series (12"-100" NPS)
Capacity Tests: Sec. UD at National Board Testing Lab on August 14, 2017
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 1.120 Unitless
Media - Test: Air/Gas; Certified: Compressible and Incompressible (KrgI)
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: MNFA
Designed by: Hansom (Nanjing) Technologies Co., Ltd. {JRM}
Comments: The flow areas published are for Class 150 flanges. Please consult manufacturer for flow area of other flange classes.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
12 NPS	12 NPS	78.776 in ²			0.5-2250 psi	Air	UD
14 NPS	14 NPS	97.342 in ²			0.5-2250 psi	Air	UD
16 NPS	16 NPS	143.464 in ²			0.5-2250 psi	Air	UD
18 NPS	18 NPS	178.071 in ²			0.5-2250 psi	Air	UD
20 NPS	20 NPS	224.149 in ²			0.5-2250 psi	Air	UD
22 NPS	22 NPS	275.579 in ²			0.5-2250 psi	Air	UD
24 NPS	24 NPS	330.358 in ²			0.5-2250 psi	Air	UD
26 NPS	26 NPS	381.907 in ²			0.5-1440 psi	Air	UD
28 NPS	28 NPS	450.438 in ²			0.5-1440 psi	Air	UD
30 NPS	30 NPS	524.62 in ²			0.5-1440 psi	Air	UD
32 NPS	32 NPS	604.455 in ²			0.5-1440 psi	Air	UD
34 NPS	34 NPS	689.941 in ²			0.5-1440 psi	Air	UD
36 NPS	36 NPS	781.08 in ²			0.5-1440 psi	Air	UD
38 NPS	38 NPS	877.87 in ²			0.5-1440 psi	Air	UD
40 NPS	40 NPS	980.313 in ²			0.5-1440 psi	Air	UD
42 NPS	42 NPS	1088.41 in ²			0.5-1440 psi	Air	UD
44 NPS	44 NPS	1202.15 in ²			0.5-1440 psi	Air	UD
46 NPS	46 NPS	1321.55 in ²			0.5-1440 psi	Air	UD
48 NPS	48 NPS	1446.6 in ²			0.5-1440 psi	Air	UD
50 NPS	50 NPS	1577.31 in ²			0.5-720 psi	Air	UD
52 NPS	52 NPS	1713.66 in ²			0.5-720 psi	Air	UD
54 NPS	54 NPS	1855.67 in ²			0.5-720 psi	Air	UD
56 NPS	56 NPS	2003.33 in ²			0.5-720 psi	Air	UD
58 NPS	58 NPS	2156.64 in ²			0.5-720 psi	Air	UD
60 NPS	60 NPS	2315.6 in ²			0.5-720 psi	Air	UD
64 NPS	64 NPS	2650.48 in ²			0.5-720 psi	Air	UD
68 NPS	68 NPS	3007.97 in ²			0.5-720 psi	Air	UD
72 NPS	72 NPS	3388.07 in ²			0.5-720 psi	Air	UD
78 NPS	78 NPS	3670.33 in ²			0.5-720 psi	Air	UD
100 NPS	100 NPS	6405.6 in ²		0 in	0.5-720 psi	Air	UD
80 NPS	80 NPS	3888.58 in ²		0 in	0.5-720 psi	Air	UD
82 NPS	82 NPS	4122.38 in ²		0 in	0.5-720 psi	Air	UD
84 NPS	84 NPS	4353.62 in ²		0 in	0.5-720 psi	Air	UD
86 NPS	86 NPS	4592.44 in ²		0 in	0.5-720 psi	Air	UD
88 NPS	88 NPS	4832.84 in ²		0 in	0.5-720 psi	Air	UD
90 NPS	90 NPS	5080.44 in ²		0 in	0.5-720 psi	Air	UD
92 NPS	92 NPS	5335.32 in ²		0 in	0.5-720 psi	Air	UD
94 NPS	94 NPS	5597.56 in ²		0 in	0.5-720 psi	Air	UD
96 NPS	96 NPS	5859.99 in ²		0 in	0.5-720 psi	Air	UD

98 NPS	98 NPS	6129.32 in²	0 in	0.5-720 psi	Air	UD
--------	--------	-------------	------	-------------	-----	----

Design Name:

IN-P, HO-F Series (2"-10" NPS)

NBCert #

00897

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	03/31/2029

Design Type
[Buckling Pin Non-reclosing Device] IN-P, HO-F Series (2"-10" NPS) Capacity Tests: Sec. UD at National Board Testing Lab on April 22, 2016 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value:21.360 Unitless Media - Test: Air/Gas; Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Buckling Pressure Flow Area Configuration: MNFA Designed by: Hansom (Nanjing) Technologies Co., Ltd. {JRM} Comments: The flow areas published are for Class 150 flanges. Please consult manufacturer for flow area of other flange classes.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS	10 NPS	53.385 in²			0.5-2250 psi	Air	UD
2 NPS	2 NPS	1.557 in²			0.5-2250 psi	Air	UD
2.5 NPS	2.5 NPS	2.097 in²			0.5-2250 psi	Air	UD
3 NPS	3 NPS	3.816 in²			0.5-2250 psi	Air	UD
4 NPS	4 NPS	6.458 in²			0.5-2250 psi	Air	UD
6 NPS	6 NPS	17.441 in²			0.5-2250 psi	Air	UD
8 NPS	8 NPS	32.375 in²			0.5-2250 psi	Air	UD

Henghua Valve Co., Ltd. (HNG)

Nameplate Abbreviation: HHSV

Wenzhou City, Zhejiang Province, 325105People's Republic of China

This Company Manufactures or Assembles:

Design Name: HFO		NBCert # 01898
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/02/2031

Design Type
[Safety Relief Valve] HFO Capacity Tests: Sec. UV at National Board Testing Lab on March 20, 2023 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.867 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Henghua Valve Co., Ltd. {HNG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.239 in²	[E] 0.5512 in	0.138 in	15-6000 psi	Air	UV
1.5-1.5 NPS	2, 3 NPS	0.352 in²	[F] 0.6693 in	0.167 in	15-5000 psi	Air	UV

1.5-2 NPS	2.5, 3 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.266 in	15-2750 psi	Air	UV
2-3 NPS	3, 4 NPS	1.448 in ²	[J] 1.358 in	0.34 in	15-2700 psi	Air	UV
3-3 NPS	4, 6 NPS	2.097 in ²	[K] 1.634 in	0.409 in	15-2220 psi	Air	UV
3-4 NPS	4, 6 NPS	2.849 in ²	[L] 1.905 in	0.476 in	50-1500 psi	Air	UV
4-4 NPS	6 NPS	4.097 in ²	[M] 2.284 in	0.571 in	50-1100 psi	Air	UV
4-4 NPS	6 NPS	4.988 in ²	[N] 2.52 in	0.63 in	50-1000 psi	Air	UV
4-4 NPS	6 NPS	7.22 in ²	[P] 3.032 in	0.758 in	50-1000 psi	Air	UV
6-6 NPS	8 NPS	12.667 in ²	[Q] 4.016 in	1.004 in	50-600 psi	Air	UV
6-6 NPS	8, 10 NPS	18.118 in ²	[R] 4.803 in	1.201 in	50-300 psi	Air	UV
8-8 NPS	10 NPS	29.628 in ²	[T] 6.142 in	1.536 in	50-300 psi	Air	UV
10-10 NPS	14 NPS	43.943 in ²	[V] 7.48 in	1.87 in	50-285 psi	Air	UV
12-12 NPS	16 NPS	61.626 in ²	[W] 8.858 in	2.215 in	50-285 psi	Air	UV

Henry Technologies Ltd (HNL)

Nameplate Abbreviation: HENRY

Glasgow, Scotland, G52 4XZUnited Kingdom

This Company Manufactures or Assembles:

Design Name: 5230A-S, 5231A-S, 5231B-S		NBCert #	01911
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	05/08/2031
Design Type			
[Safety Relief Valve] 5230A-S, 5231A-S, 5231B-S Capacity Tests: Sec. UV at National Board Testing Lab on October 1, 2018 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.626 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Henry Technologies Ltd {HNL}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
	.50 - .625 NPS	0.0491 in ²	0.25 in	0.157 in	203-449.6 psi	Air	UV

Design Name: 5230AX, 5231AX, 5231BX, 5233AX, 5234AX, 5235AX			NBCert # 29180	
Manufacturer/Assembler		Designators		Expiration Date
Manufacturer		UV		10/03/2030

Design Type

[Safety Relief Valve] 5230AX, 5231AX, 5231BX, 5233AX, 5234AX, 5235AX
Capacity Tests: Sec. UV at National Board Testing Lab on December 1, 2014
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.847 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Henry Technologies Ltd {HNL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.5 NPS		0.06 in ²		0.157 in ²	150-675 psi	Air	UV

Design Name: 5232A-S, 5240-S, 5242-S, 5340-S, 5342-S NBCert # 01922

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

08/28/2030

Design Type

[Safety Relief Valve] 5232A-S, 5240-S, 5242-S, 5340-S, 5342-S
Capacity Tests: Sec. UV at National Board Testing Lab on October 2, 2018
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.375 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Henry Technologies Ltd {HNL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
	.75 NPS	0.1104 in ²	0.375 in	0.197 in	149.4-449.6 psi	Air	UV

Design Name: 5244S, 5244A-S, 5344S, 5344A-S, 5244P NBCert # 01696

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

01/23/2031

Design Type

[Safety Relief Valve] 5244S, 5244A-S, 5344S, 5344A-S, 5244P
Capacity Tests: Sec. UV at National Board Testing Lab on May 9, 2019
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.530 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Henry Technologies Ltd {HNL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.196 in ²	0.5 in	0.197 in	149.4-449.6 psi	Air	UV

Design Name: 5245-S, 5246-S, 5345-S, 5346-S, B5246 NBCert # 01933

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

08/29/2030

Design Type

[Safety Relief Valve] 5245-S, 5246-S, 5345-S, 5346-S, B5246
Capacity Tests: Sec. UV at National Board Testing Lab on October 3, 2018
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.456 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Henry Technologies Ltd {HNL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.25 NPS	1.250 NPS	0.3883 in ²	0.703 in	0.197 in	149.4-449.6 psi	Air	UV

Design Name:	5600	NBCert #	29146
--------------	------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer	UV	05/08/2031
--------------	----	------------

Design Type

[Safety Relief Valve] 5600
Capacity Tests: Sec. UV at National Board Testing Lab on June 12, 1992
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.290 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Henry Technologies Ltd {HNL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.196 in ²	0.5 in		150-450 psi	Air	UV

Design Name:	5601 & 5602	NBCert #	29113
--------------	-------------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer	UV	05/08/2031
--------------	----	------------

Design Type

[Safety Relief Valve] 5601 & 5602
Capacity Tests: Sec. UV at unknown lab on April 12, 1965
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.650 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Henry Technologies Ltd {HNL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1 NPS	0.196 in ²	0.5 in	0.125 in	150-450 psi	Air	UV

Design Name:	5603	NBCert #	29124
--------------	------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer	UV	10/29/2030
--------------	----	------------

Design Type

[Safety Relief Valve] 5603
Capacity Tests: Sec. UV at unknown lab on July 20, 1989
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.773 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Henry Technologies Ltd {HNL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.25 NPS	0.196 in ²	0.5 in		150-450 psi	Air	UV

Design Name: 5604, 5604-YM, 5604-YP NBCert # 29135

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

08/29/2030

Design Type

[Safety Relief Valve] 5604, 5604-YM, 5604-YP
Capacity Tests: Sec. UV at unknown lab on July 20, 1989
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.330 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Henry Technologies Ltd {HNL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.625 NPS	1.5, 1-7/8 NPS	0.388 in ²	0.703 in		150-450 psi	Air	UV

Design Name: 5701AX, 5701GX NBCert # 01775

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

08/28/2030

Design Type

[Safety Relief Valve] 5701AX, 5701GX
Capacity Tests: Sec. UV at National Board Testing Lab on October 2, 2018
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.808 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Henry Technologies Ltd {HNL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	0.75 NPS	0.0614 in ²	0.2795 in	0.0984 in	667-1885 psi	Air	UV

Design Name: 5702, 5702A, 5702B, 5702C NBCert # 01764

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

08/29/2030

Design Type

[Safety Relief Valve] 5702, 5702A, 5702B, 5702C
Capacity Tests: Sec. UV at National Board Testing Lab on October 3, 2018
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.016 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Henry Technologies Ltd {HNL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.25 NPS	1 NPS	0.134 in ²	0.4134 in	0.157 in	449.5-1885 psi	Air	UV

HEROSE G.M.B.H. ARMATUREN UND METALLE (HEG)

Bad Oldesloe, 23843Germany

This Company Manufactures or Assembles:

Design Name: 06002/06012 gas tight NBCert # 91246

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

05/27/2027

Design Type

[Safety Relief Valve] 06002/06012 gas tight
Capacity Tests: Sec. UV at National Board Testing Lab on April 9, 2015
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.302 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.5 NPS	.375 NPS	28.3 mm ²	6 mm	0.8 mm	74-798 psi	Air	UV

Design Name: 06002/06012/06006/06016 NBCert # 91213

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

05/27/2027

Design Type

[Safety Relief Valve] 06002/06012/06006/06016
Capacity Tests: Sec. UV at National Board Testing Lab on February 26, 2015
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.337 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.5 NPS	.375 NPS	28.3 mm²	6 mm	0.9 mm	72-798 psi	Air	UV
Design Name: 06216/06217.0400NBCert # 91178							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			10/23/2029	
Design Type							
[Safety Relief Valve] 06216/06217.0400 Capacity Tests: Sec. UV at National Board Testing Lab on October 23, 2007 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.590 SCFM/PSIA Media - ; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		113.1 mm²	12 mm	3.6 mm	15-363 psi	Air	UV
Design Name: 06216/06217.0600NBCert # 91112							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			05/15/2030	
Design Type							
[Safety Relief Valve] 06216/06217.0600 Capacity Tests: Sec. UV at unknown lab on August 26, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 4.100 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		177 mm²	15 mm	5.5 mm	15-290 psi	Air	UV
Design Name: 06216/06217.1000NBCert # 91123							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			04/18/2030	
Design Type							
[Safety Relief Valve] 06216/06217.1000 Capacity Tests: Sec. UV at unknown lab on August 26, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 6.790 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	Side NPS	315 mm²	20 mm	7 mm	15-435 psi	Air	UV
Design Name: 06216/06217.1200NBCert #91134							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			04/18/2030	
Design Type							
[Safety Relief Valve] 06216/06217.1200 Capacity Tests: Sec. UV at unknown lab on August 26, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:10.150 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS		492 mm²	25 mm	9 mm	15-319 psi	Air	UV
Design Name: 06216/06217.1400NBCert #91145							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			04/18/2030	
Design Type							
[Safety Relief Valve] 06216/06217.1400 Capacity Tests: Sec. UV at unknown lab on August 26, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:16.500 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		805 mm²	32 mm²	12.5 mm	15-232 psi	Air	UV
Design Name: 06216/06217.2000NBCert #91156							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			04/18/2030	
Design Type							
[Safety Relief Valve] 06216/06217.2000 Capacity Tests: Sec. UV at unknown lab on August 26, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:24.800 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		1258 mm²	40 mm	15.1 mm	15-174 psi	Air	UV
Design Name: 06381/06386/06416			NBCert #		91224		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		05/27/2027		
Design Type							
[Safety Relief Valve] 06381/06386/06416 Capacity Tests: Sec. UV at National Board Testing Lab on February 26, 2015 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.700 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1 NPS	86.6 mm²	10.5 mm	2.1 mm	30-363 psi	Air	UV
Design Name: 06388./06418./06383./06413.2312/2314/2320			NBCert #		91101		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		04/18/2030		
Design Type							
[Safety Relief Valve] 06388./06418./06383./06413.2312/2314/2320 Capacity Tests: Sec. UV at unknown lab on August 27, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 7.550 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	2 NPS	389.1 mm²	23 mm	4.8 mm	29-725 psi	Air	UV
Design Name: 06388/06418/06383/06413.0704/0706			NBCert #		91011		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		12/09/2026		
Design Type							
[Safety Relief Valve] 06388/06418/06383/06413.0704/0706 Capacity Tests: Sec. UV at unknown lab on July 30, 1999 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.862 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1 NPS	38.5 mm²	7 mm	1.5 mm	48-725 psi	Air	UV
Design Name: 06388/06418/06383/06413.1004/1006					NBCert #	91088	
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			12/09/2026	
Design Type							
[Safety Relief Valve] 06388/06418/06383/06413.1004/1006 Capacity Tests: Sec. UV at unknown lab on July 30, 1999 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.517 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1 NPS	86.6 mm²	10.5 mm	2.2 mm	42-725 psi	Air	UV
Design Name: 06388/06418/06383/06413.1510					NBCert #	91077	
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			12/09/2026	
Design Type							
[Safety Relief Valve] 06388/06418/06383/06413.1510 Capacity Tests: Sec. UV at unknown lab on July 30, 1999 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.769 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.25 NPS	176.6 mm²	15 mm	2.6 mm	48-725 psi	Air	UV
Design Name: 06420/06421/06425/06426/06440/06441/06445/06446.0704/0706					NBCert #	91189	
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			05/01/2027	
Design Type							
[Safety Relief Valve] 06420/06421/06425/06426/06440/06441/06445/06446.0704/0706 Capacity Tests: Sec. UV at National Board Testing Lab on October 1, 2014 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.892 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1 NPS	38.5 mm²	7 mm	3 mm	29-725 psi	Air	UV
Design Name: 06420/06421/06425/06426/06440/06441/06445/06446.1004/1006 (10.5mm orifice) NBCert # 91190							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			01/07/2028	
Design Type							
[Safety Relief Valve] 06420/06421/06425/06426/06440/06441/06445/06446.1004/1006 (10.5mm orifice) Capacity Tests: Sec. UV at National Board Testing Lab on September 18, 2015 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.698 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1 NPS	86.6 mm²	10.5 mm	3 mm	35-725 psi	Air	UV
Design Name: 06420/06421/06425/06426/06440/06441/06445/06446.1406/.1410 (14 mm orifice) NBCert # 91279							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			01/07/2028	
Design Type							
[Safety Relief Valve] 06420/06421/06425/06426/06440/06441/06445/06446.1406/.1410 (14 mm orifice) Capacity Tests: Sec. UV at National Board Testing Lab on September 18, 2015 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.887 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1.25 NPS		14 mm	4 mm	35-580 psi	Air	UV
Design Name: 06420/06421/06425/06426/06440/06441/06445/06446.1406/1410 (14 mm orifice 15-34 psi) NBCert # 91257							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			05/27/2027	
Design Type							
[Safety Relief Valve] 06420/06421/06425/06426/06440/06441/06445/06446.1406/1410 (14 mm orifice 15-34 psi) Capacity Tests: Sec. UV at National Board Testing Lab on February 27, 2015 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.820 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1.25 NPS	153.9 mm²	14 mm	4 mm	15-34 psi	Air	UV
Design Name:			06420/06421/06425/06426/06440/06441/06445/06446.1810/.1812 (18 mm orifice)		NBCert #	91280	
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			01/07/2028	
Design Type							
[Safety Relief Valve] 06420/06421/06425/06426/06440/06441/06445/06446.1810/.1812 (18 mm orifice)							
Capacity Tests: Sec. UV at National Board Testing Lab on September 18, 2015							
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method							
Certified Value: 4.773 SCFM/PSIA							
Media - Test: Air/Gas; Certified: Air, Gas							
Set Pressure Definition: Initial Audible Discharge							
Blowdown Characteristics: Fixed							
Flow Area Configuration: Nozzle/Full Lift							
Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.25 NPS	1.5 NPS	245.5 mm²	18 mm	5 mm	38-580 psi	Air	UV
Design Name:		06420/06421/06425/06426/06440/06441/06445/06446.2312 (23 mm orifice)			NBCert #	91202	
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			05/27/2027	
Design Type							
[Safety Relief Valve] 06420/06421/06425/06426/06440/06441/06445/06446.2312 (23 mm orifice) Capacity Tests: Sec. UV at National Board Testing Lab on February 27, 2015 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 6.510 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	415.5 mm ²	23 mm	6 mm	20-145 psi	Air	UV

Hui Bao Enterprise Co., Ltd. (HBO)

Nameplate Abbreviation: THB

Ho Mei, Chang Hua Hsien, 508Taiwan

This Company Manufactures or Assembles:

Design Name: T102N					NBCert # 95037		
Manufacturer/Assembler				Designators		Expiration Date	
Manufacturer				UV		11/24/2026	

Design Type

[Safety Relief Valve] T102N
Capacity Tests: Sec. UV at National Board Testing Lab on January 31, 2005
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.269 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Hui Bao Enterprise Co., Ltd. {HBO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.25 NPS		12.57 mm ²	4 mm	4.8 mm	50-275 psi	Air	UV

IDC Plumbing & Heating Technology (Beijing) Co., Ltd. (IDC)

Nameplate Abbreviation: IDC

Zhuhai, Guangdong, 519170People's Republic of China

This Company Manufactures or Assembles:

Design Name: EUP3/4-125

NBCert # 02697

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

HV

11/26/2030

Design Type

[Safety Relief Valve] EUP3/4-125
HolderDesignation:
Capacity Tests: Sec. HV at National Board Testing Lab on August 8, 2023
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:763000 BTU/HR; (alternate medium): 0.000
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: 40 CC Method
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: IDC Plumbing & Heating Technology (Beijing) Co., Ltd. {IDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	0.75 NPS	0.19 in ²	0.492 in	0.123 in	125-125 psi	Steam	HV

Design Name: EUP3/4-150, EUPQ3/4-150

NBCert # 00291

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

HV

09/20/2027

Design Type

[Safety Relief Valve] EUP3/4-150, EUPQ3/4-150
Capacity Tests: Sec. HV at National Board Testing Lab on December 8, 2020
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:630000 BTU/HR
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: 40 CC Method
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: IDC Plumbing & Heating Technology (Beijing) Co., Ltd. {IDC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	0.75 NPS	0.19 in²	0.492 in	0.118 in	150-150 psi	Steam	HV
Design Name: EUP3/4-30, EUPQ3/4-30NBCert #00280							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			HV			06/01/2027	
Design Type							
[Safety Relief Valve] EUP3/4-30, EUPQ3/4-30 Capacity Tests: Sec. HV at National Board Testing Lab on December 8, 2020 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:419000 BTU/HR Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: IDC Plumbing & Heating Technology (Beijing) Co., Ltd. {IDC}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	0.75 NPS	0.312 in²	0.63 in	0.118 in	30-30 psi	Steam	HV
Design Name: EUP3/4-75NBCert #02686							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			HV			11/26/2030	
Design Type							
[Safety Relief Valve] EUP3/4-75 HolderDesignation: Capacity Tests: Sec. HV at National Board Testing Lab on August 8, 2023 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:519000 BTU/HR; (alternate medium): 0.000 Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: IDC Plumbing & Heating Technology (Beijing) Co., Ltd. {IDC}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	0.75 NPS	0.19 in²	0.492 in	0.123 in	75-75 psi	Steam	HV
Design Name: EUTP3/4-150NBCert #02495							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			HV			08/25/2028	
Design Type							
[Temperature Actuated Pressure Relief Valve] EUTP3/4-150 Capacity Tests: Sec. HV at National Board Testing Lab on April 13, 2022 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:662600 BTU/HR Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: IDC Plumbing & Heating Technology (Beijing) Co., Ltd. {IDC}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	0.75 NPS	0.182 in ²	0.492 in	0.118 in	150-150 psi	Steam	HV

IDC Plumbing & Heating Technology (Beijing) Co., Ltd. (IDP)

Nameplate Abbreviation: IDC

HaiYan, 314300People's Republic of China

This Company Manufactures or Assembles:

Design Name: EUP3/4-150, EUPQ3/4-150		NBCert #	00291
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	HV	08/12/2030	
Design Type			
[Safety Relief Valve] EUP3/4-150, EUPQ3/4-150 Capacity Tests: Sec. HV at National Board Testing Lab on December 8, 2020 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:630000 BTU/HR Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: IDC Plumbing & Heating Technology (Beijing) Co., Ltd. {IDC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	0.75 NPS	0.19 in ²	0.492 in	0.118 in	150-150 psi	Steam	HV

Industrial Service Solutions, LLC (BAY)

Nameplate Abbreviation: Industrial
Service Solutions

Tukwila, WA 98168United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3		NBCert # 18032
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	06/14/2029
Design Type		
[Safety Valve] 1541, 1543, 1541-3, 1543-3 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1811, 1511	NBCert # 18122
-------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 02/07/2029

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V

1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 02/06/2029

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V

6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35 NBCert # 18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/06/2029

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series	NBCert # 18706
---------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	02/06/2029
-----------	----	------------

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/06/2029

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/21/2028

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 11/28/2028

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 3.256 GPM/SQ. RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM

NBCert # 19066

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

08/23/2028

Design Type

[Safety Relief Valve] 1900-DM
 Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
 Set Pressure Definition(1): Pop; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D NBCert # 19088

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/23/2028

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E NBCert # 19099

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/23/2028

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2		NBCert #	18166
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	02/07/2029
Design Type			
[Safety Relief Valve] 1900E-2, 1900-30E-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids)		NBCert #	18762
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV, V	11/28/2028
Design Type			
[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids) Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.798 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids)		NBCert #	19077
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	08/22/2028
Design Type			
[Relief Valve] 19110M & 19110H (Liquids) Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.264 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name:	2900 (39PV & 39MV pilots - Liquid)	NBCert #	18874
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 02/03/2031

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots - Liquid)
Capacity Tests: Sec. UV, V at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.127 in	15-6250 psi	Water	UV, V
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	UV, V
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.205 in	15-6250 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-6250 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-6000 psi	Water	UV, V
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-6000 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-3750 psi	Water	UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-2250 psi	Water	UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-1500 psi	Water	UV, V
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.738 in	15-1500 psi	Water	UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-905 psi	Water	UV, V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV, V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.93 in	15-675 psi	Water	UV, V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-535 psi	Water	UV, V

Design Name:	2900 (39PV & 39MV pilots)	NBCert #	18863
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/03/2031

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
 Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV

12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
--------	--------	------------------------	---------------	----------	------------	-------	----

Design Name:	2900-TM (39PV & 39MV pilots)	NBCert #	01427
--------------	------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	02/03/2031
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 2900-TM (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Water	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Water	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Water	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2000 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Water	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Water	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-300 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Water	UV

Design Name: 3900 (39PV, 39MV pilots)

NBCert #

18447

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

11/21/2028

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV

1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV

6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid) NBCert # 18458

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/23/2028

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV

2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Industrial Service Solutions, LLC (BYS)

Nameplate Abbreviation: Industrial
Service Solutions

Ferndale, WA 98248United States

This Company Manufactures or Assembles:

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	10/20/2026	
Design Type			
[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids) Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.670 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V

1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/20/2026

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV

3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/19/2026

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert #

18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

10/19/2026

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2

NBCert #

18144

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

02/14/2029

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert # 18751

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/14/2029

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900E-2, 1900-30E-2 NBCert # 18166

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/14/2029

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/14/2029

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ. RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Industrial Service Solutions, LLC (CRS)Nameplate Abbreviation: Industrial Service Solutions

Benicia, CA 94510United States

This Company Manufactures or Assembles:

Design Name: 1811, 1511		NBCert # 18122
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	11/30/2029

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV

4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/30/2029

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/29/2029

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV

10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/29/2029

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/29/2029

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/29/2029

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/29/2029

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM	NBCert # 19066
----------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/30/2029

Design Type

[Safety Relief Valve] 1900-DM
Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV

12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name:	1900-DM-D	NBCert #	19088
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/30/2029

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name:	1900-DM-E	NBCert #	19099
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/20/2029

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/29/2029

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/30/2029

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Industrial Service Solutions, LLC (MLV)

Nameplate Abbreviation: Industrial
Service Solutions

Odessa, TX 79764 United States

This Company Manufactures or Assembles:

Design Name:	1541, 1543, 1541-3, 1543-3	NBCert #	18032
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	01/10/2029

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V

0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name:	1811, 1511	NBCert #	18122
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV, V	09/07/2031
-----------	-------	------------

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV

2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV, V	09/09/2031	

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35	NBCert # 18201
-------------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/07/2031

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV

8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/19/2031

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/18/2031

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2

NBCert #

18144

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

09/07/2031

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert #

18751

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV, V

09/25/2031

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 3.256 GPM/SQ. RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM

NBCert # 19066

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

06/21/2029

Design Type

[Safety Relief Valve] 1900-DM
 Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
 Set Pressure Definition(1): Pop; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D NBCert # 19088

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/27/2028

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E NBCert # 19099

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/27/2028

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/07/2031

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name:	1900E-2, 1900-30E-2 LA & DALA (Liquids)	NBCert #	18762
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	08/13/2031

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name:	3900 (39PV, 39MV pilots)	NBCert #	18447
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/10/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV

1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid)

NBCert #

18458

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

10/27/2028

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)

Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.743 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV

2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Industrial Service Solutions, LLC (WAR)

Nameplate Abbreviation: Industrial
Service Solutions

Brighton, CO 80601United States

This Company Manufactures or Assembles:

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	03/19/2026

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/06/2026

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV

1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series			NBCert # 18706	
Manufacturer/Assembler		Designators		Expiration Date
Assembler		UV		05/05/2026

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/09/2029

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV

1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/09/2029

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/09/2029

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ. RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/09/2029

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/09/2029

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Industrial Service Solutions, LLC (WSL)

Nameplate Abbreviation: Industrial
Service Solutions

Salt Lake City, UT 84119United States

This Company Manufactures or Assembles:

Design Name: 1811, 1511 NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	03/13/2031

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V

1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA (Liquids)

NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV, V

03/13/2031

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V

8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

03/13/2031

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV

6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201) NBCert # 18223

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/12/2031

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/02/2028

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV

1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/02/2028

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2 NBCert # 18144

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/12/2031

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert # 18751

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	03/12/2031

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 3.256 GPM/SQ.RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM NBCert # 19066

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/08/2028

Design Type

[Safety Relief Valve] 1900-DM
 Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
 Set Pressure Definition(1): Pop; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D

NBCert #

19088

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

01/12/2029

Design Type

[Safety Relief Valve] 1900-DM-D

Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Curtain Area

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E

NBCert #

19099

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

02/08/2028

Design Type

[Safety Relief Valve] 1900-DM-E

Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Curtain Area

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name:	1900-DM-RL, 1900-30DM-RL (Restricted Lift Version of Cert 19066)	NBCert #	19101
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/12/2031

Design Type

[Safety Relief Valve] 1900-DM-RL, 1900-30DM-RL (Restricted Lift Version of Cert 19066)

HolderDesignation:

Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Restricted Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.119 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.119 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.152 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.152 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.182 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.182 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.226 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.226 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.254 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.254 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.279 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.279 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.338 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.338 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.445 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.445 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.535 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.535 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	0.682 in	15-408 psi	Air	UV

8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	0.682 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.728 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.728 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.879 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.879 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	1.103 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	1.103 in	15-300 psi	Water	UV

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/12/2031

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name:	1900E-2, 1900-30E-2 LA & DALA (Liquids)	NBCert #	18762
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 03/12/2031

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ. RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name:	19110M & 19110H (Liquids)	NBCert #	19077
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/09/2031

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
 Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 2.264 GPM/SQ.RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Industrial Steel & Boiler Services, Inc. (ISB)

Chicopee, MA 01013-2893 United States

This Company Manufactures or Assembles:

Design Name: Kunkle 6000, 6252 Series NBCert # 36324

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	11/26/2026

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
 Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV

1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 910 to 919

NBCert #

36100

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

05/07/2027

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV

0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name: Reyco R, RB & RO (Fig. 971, 973, 974) NBCert # 73000

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/26/2027

Design Type

[Safety Relief Valve] Reyco R, RB & RO (Fig. 971, 973, 974)
Capacity Tests: Sec. UV at National Board Testing Lab on March 19, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.122 in ²	[D] 0.394 in	0.12 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.122 in ²	[D] 0.394 in	0.12 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.217 in ²	[E] 0.526 in	0.16 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.217 in ²	[E] 0.526 in	0.16 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.34 in ²	[F] 0.658 in	0.2 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.34 in ²	[F] 0.658 in	0.2 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.558 in ²	[G] 0.843 in	0.26 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.558 in ²	[G] 0.843 in	0.26 in	15-4905 psi	Air	UV
1.5-2 NPS	3 NPS	0.869 in ²	[H] 1.052 in	0.32 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.869 in ²	[H] 1.052 in	0.32 in	15-3300 psi	Air	UV
2-3 NPS	3, 4 NPS	1.427 in ²	[J] 1.348 in	0.41 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.427 in ²	[J] 1.348 in	0.41 in	15-3300 psi	Air	UV
3 NPS	4, 6 NPS	2.036 in ²	[K] 1.61 in	0.49 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.036 in ²	[K] 1.61 in	0.49 in	15-3300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.16 in ²	[L] 2.006 in	0.61 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.16 in ²	[L] 2.006 in	0.61 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	3.987 in ²	[M] 2.253 in	0.69 in	15-1600 psi	Air	UV
4 NPS	6 NPS	3.987 in ²	[M] 2.253 in	0.69 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.807 in ²	[N] 2.474 in	0.75 in	15-1600 psi	Air	UV

4 NPS	6 NPS	4.807 in ²	[N] 2.474 in	0.75 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.07 in ²	[P] 3 in	0.92 in	15-1600 psi	Air	UV
4 NPS	6 NPS	7.07 in ²	[P] 3 in	0.92 in	15-1600 psi	Steam	UV
6 NPS	8 NPS	12.24 in ²	[Q] 3.948 in	1.2 in	15-925 psi	Air	UV
6 NPS	8 NPS	12.24 in ²	[Q] 3.948 in	1.2 in	15-925 psi	Steam	UV
6 NPS	8, 10 NPS	17.72 in ²	[R] 4.75 in	1.45 in	15-350 psi	Air	UV
6 NPS	8, 10 NPS	17.72 in ²	[R] 4.75 in	1.45 in	15-350 psi	Steam	UV
8 NPS	10 NPS	29.75 in ²	[T] 6.155 in	1.84 in	15-325 psi	Air	UV
8 NPS	10 NPS	29.75 in ²	[T] 6.155 in	1.84 in	15-325 psi	Steam	UV

Design Name:	Reyco R, RB, RO, RBO (Fig. 971, 973, 974) (liquid)	NBCert #	73011
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/26/2027

Design Type

[Relief Valve] Reyco R, RB, RO, RBO (Fig. 971, 973, 974) (liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on September 27, 2001
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.724 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 2.5, 3 NPS	0.122 in ²	[D] 0.394 in	0.12 in	15-6250 psi	Water	UV
1-1.5 NPS	2, 2.5, 3 NPS	0.217 in ²	[E] 0.526 in	0.16 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.34 in ²	[F] 0.658 in	0.2 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5, 3 NPS	0.558 in ²	[G] 0.843 in	0.26 in	15-4905 psi	Water	UV
1.5-2 NPS	3 NPS	0.869 in ²	[H] 1.052 in	0.32 in	15-3300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.427 in ²	[J] 1.348 in	0.41 in	15-3300 psi	Water	UV
3 NPS	4, 6 NPS	2.036 in ²	[K] 1.61 in	0.49 in	15-3300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.16 in ²	[L] 2.006 in	0.61 in	15-2900 psi	Water	UV
4 NPS	6 NPS	3.987 in ²	[M] 2.253 in	0.69 in	15-1600 psi	Water	UV
4 NPS	6 NPS	4.807 in ²	[N] 2.474 in	0.75 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.07 in ²	[P] 3 in	0.92 in	15-1600 psi	Water	UV
6 NPS	8 NPS	12.24 in ²	[Q] 3.948 in	1.2 in	15-925 psi	Water	UV
6 NPS	8, 10 NPS	17.72 in ²	[R] 4.75 in	1.45 in	15-350 psi	Water	UV
8 NPS	10 NPS	29.75 in ²	[T] 6.155 in	1.84 in	15-325 psi	Water	UV

Design Name:	RL-14 & RLO-14 (0.315 in. orifice)	NBCert #	73044
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/26/2027

Design Type

[Safety Relief Valve] RL-14 & RLO-14 (0.315 in. orifice)
Capacity Tests: Sec. UV at National Board Testing Lab on June 8, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.230 SCFM/PSIA; (alternate medium): 3.460 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.078 in ²	0.315 in	0.078 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.078 in ²	0.315 in	0.078 in	15-5000 psi	Air	UV

Design Name: RL-14 & RLO-14 (0.315 in. orifice) (Liquids) NBCert # 73055

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

04/26/2027

Design Type

[Relief Valve] RL-14 & RLO-14 (0.315 in. orifice) (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on June 4, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.880 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.078 in ²	0.315 in	0.078 in	15-5000 psi	Water	UV

Design Name: RL14 & RLO14 (0.394 in. orifice) NBCert # 73202

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

04/26/2027

Design Type

[Safety Relief Valve] RL14 & RLO14 (0.394 in. orifice)
Capacity Tests: Sec. UV at National Board Testing Lab on September 30, 2014
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.637 SCFM/PSIA; (alternate medium): 4.600 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.122 in ²	0.394 in	0.0985 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.122 in ²	0.394 in	0.0985 in	15-5000 psi	Air	UV

Design Name:		RL14 & RLO14 (0.394 in. orifice) (Liquid)	NBCert #	73213			
Manufacturer/Assembler		Designators		Expiration Date			
Assembler		UV		04/26/2027			
Design Type							
[Relief Valve] RL14 & RLO14 (0.394 in. orifice) (Liquid) Capacity Tests: Sec. UV at National Board Testing Lab on September 30, 2014 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.021 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: ARI-Armaturen USA LP {TAR}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.122 in²	0.394 in	0.0985 in	15-5000 psi	Water	UV

Industrial Valve Sales & Service, LLC (IVE)

Mobile, AL 36613United States

This Company Manufactures or Assembles:

Design Name: 1890, 1892, 1895, 1896				NBCert #	57013		
Manufacturer/Assembler			Designators		Expiration Date		
Assembler			UV		05/29/2031		
Design Type							
[Safety Relief Valve] 1890, 1892, 1895, 1896 Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 19, 1988 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 4.410 PPH/PSIA; (alternate medium): 1.570 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.11 in²	0.375 in	0.094 in	15-800 psi	Air	UV
0.5-0.75 NPS	.75, 1 NPS	0.11 in²	0.375 in	0.094 in	15-800 psi	Air	NV
0.5-0.75 NPS	.75, 1 NPS	0.11 in²	0.375 in	0.094 in	15-800 psi	Steam	UV
0.5-0.75 NPS	.75, 1 NPS	0.11 in²	0.375 in	0.094 in	15-800 psi	Steam	NV

Design Name: 1890L, 1892L, 1895L, 1896L (Liquids)		NBCert #	57192
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	05/29/2031

Design Type

[Relief Valve] 1890L, 1892L, 1895L, 1896L (Liquids)
Capacity Tests: Sec. UV at unknown lab on January 14, 1993
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.210 GPM/SQ. RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	3/4, 1 NPS	0.11 in ²	0.375 in	0.08 in	15-800 psi	Water	UV

Design Name: 2400 NBCert # 57451

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 03/06/2031

Design Type

[Safety Relief Valve] 2400
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on August 28, 2019
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.817 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75-1 NPS	0.049 in ²	[B] 0.25 in	0.08 in	20-2000 psi	Air	UV
0.5-1 NPS	1-2 NPS	0.11 in ²	[D] 0.375 in	0.12 in	20-1410 psi	Air	UV
0.75-1 NPS	1-2 NPS	0.196 in ²	[E] 0.5 in	0.175 in	20-600 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.295 in	20-4000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.365 in	20-3000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.435 in	20-2500 psi	Air	UV

Design Name: 2600 & 2600S NBCert # 57057

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 05/29/2031

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV

1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name:	2600 Series Restricted Lift version of Cert Number 57057	NBCert #	57406
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	05/29/2031
-----------	----	------------

Design Type

[Safety Relief Valve] 2600 Series Restricted Lift version of Cert Number 57057
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 10, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Air	UV
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Steam	UV
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Air	UV
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Steam	UV
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Air	UV
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Steam	UV
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.08 in	15-7000 psi	Air	UV
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.08 in	15-7000 psi	Steam	UV
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.095 in	15-6000 psi	Air	UV
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.095 in	15-6000 psi	Steam	UV
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.122 in	15-6000 psi	Air	UV
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.122 in	15-6000 psi	Steam	UV
3 in	4, 6 in	2.042 in ²	[K] 1.612 in	0.145 in	15-5000 psi	Air	UV
3 in	4, 6 in	2.042 in ²	[K] 1.612 in	0.145 in	15-5000 psi	Steam	UV
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.181 in	15-4000 psi	Air	UV
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.181 in	15-4000 psi	Steam	UV
4 in	6 in	4 in ²	[M] 2.257 in	0.203 in	15-3000 psi	Air	UV
4 in	6 in	4 in ²	[M] 2.257 in	0.203 in	15-3000 psi	Steam	UV
4 in	6 in	4.822 in ²	[N] 2.478 in	0.223 in	15-3000 psi	Air	UV
4 in	6 in	4.822 in ²	[N] 2.478 in	0.223 in	15-3000 psi	Steam	UV
4 in	6 in	7.087 in ²	[P] 3.004 in	0.27 in	15-2500 psi	Air	UV
4 in	6 in	7.087 in ²	[P] 3.004 in	0.27 in	15-2500 psi	Steam	UV
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.356 in	15-2000 psi	Air	UV
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.356 in	15-2000 psi	Steam	UV
6 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.428 in	15-1500 psi	Air	UV
6 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.428 in	15-1500 psi	Steam	UV
8 in	10 in	28.94 in ²	[T] 6.07 in	0.546 in	15-1000 psi	Air	UV
8 in	10 in	28.94 in ²	[T] 6.07 in	0.546 in	15-1000 psi	Steam	UV
8 in	10 in	31.5 in ²	[U] 6.333 in	0.57 in	15-300 psi	Air	UV

8 in	10 in	31.5 in ²	[U] 6.333 in	0.57 in	15-300 psi	Steam	UV
10 in	14 in	49.4 in ²	[V] 7.93 in	0.714 in	15-1000 psi	Air	UV
10 in	14 in	49.4 in ²	[V] 7.93 in	0.714 in	15-1000 psi	Steam	UV
12 in	16 in	63.62 in ²	[W] 9 in	0.81 in	15-1000 psi	Air	UV
12 in	16 in	63.62 in ²	[W] 9 in	0.81 in	15-1000 psi	Steam	UV
16 in	18 in	104 in ²	[W2] 11.507 in	1.036 in	15-750 psi	Air	UV
16 in	18 in	104 in ²	[W2] 11.507 in	1.036 in	15-750 psi	Steam	UV
16 in	20 in	113.1 in ²	[X] 12 in	1.08 in	15-750 psi	Air	UV
16 in	20 in	113.1 in ²	[X] 12 in	1.08 in	15-750 psi	Steam	UV
18 in	24 in	143.1 in ²	[Y] 13.5 in	1.215 in	15-750 psi	Air	UV
18 in	24 in	143.1 in ²	[Y] 13.5 in	1.215 in	15-750 psi	Steam	UV
20 in	24 in	176.7 in ²	[Z] 15 in	1.35 in	15-750 psi	Air	UV
20 in	24 in	176.7 in ²	[Z] 15 in	1.35 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

05/29/2031

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV

4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Air & Steam) Series Restricted Lift version of Cert Number 57260 NBCert # 57439

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 05/29/2031

Design Type

[Safety Relief Valve] 2600L (Air & Steam) Series Restricted Lift version of Cert Number 57260
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 6, 2018
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.08 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.08 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.08 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.089 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.089 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.111 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.111 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.142 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.142 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.169 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.169 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.211 in	15-2900 psi	Steam	UV

3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.211 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.237 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.237 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.26 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.26 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.315 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.315 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.415 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.415 in	15-2000 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	0.5 in	15-1500 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	0.5 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	0.638 in	15-1000 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	0.638 in	15-1000 psi	Steam	UV
8 NPS	10 NPS	31.5 in ²	[U] 6.333 in	0.665 in	15-300 psi	Air	UV
8 NPS	10 NPS	31.5 in ²	[U] 6.333 in	0.665 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids)	NBCert # 57068
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 05/30/2031

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V

8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name:	2600L (Liquids) Series Restricted Lift version of Cert Number 57068.	NBCert #	57417
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 05/30/2031

Design Type

[Safety Relief Valve] 2600L (Liquids) Series Restricted Lift version of Cert Number 57068.
Capacity Tests: Sec. UV, V at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on January 23, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Water	UV, V
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-6000 psi	Water	UV, V
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-5000 psi	Water	UV, V
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.098 in	15-3600 psi	Water	UV, V
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.122 in	15-2750 psi	Water	UV, V
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.156 in	15-2700 psi	Water	UV, V
3 in	4, 6 in	2.041 in ²	[K] 1.612 in	0.187 in	15-2200 psi	Water	UV, V
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.232 in	15-1500 psi	Water	UV, V
4 in	6 in	4 in ²	[M] 2.257 in	0.261 in	15-1100 psi	Water	UV, V
4 in	6 in	4.822 in ²	[N] 2.478 in	0.287 in	15-1000 psi	Water	UV, V
4 in	6 in	7.087 in ²	[P] 3.004 in	0.348 in	15-1000 psi	Water	UV, V
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.458 in	15-900 psi	Water	UV, V
6-8 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.551 in	15-600 psi	Water	UV, V
8 in	10 in	28.94 in ²	[T] 6.07 in	0.702 in	15-300 psi	Water	UV, V
8 in	10 in	31.5 in ²	[U] 6.333 in	0.741 in	15-300 psi	Water	UV, V

Design Name:	2600M	NBCert #	57226
--------------	-------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/06/2031

Design Type

[Safety Relief Valve] 2600M
HolderDesignation:
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on November 7, 2024
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless; (alternate medium): 0.689 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Water/Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-3600 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-3600 psi	Water	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2750 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2750 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2700 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2700 psi	Water	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2200 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2200 psi	Water	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-1500 psi	Water	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-1100 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-1000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-1000 psi	Water	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-1000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-1000 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-600 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-600 psi	Water	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-300 psi	Water	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Water	UV

Design Name: 2700, 2700S, 3700, 3700S			NBCert # 57237	
Manufacturer/Assembler		Designators	Expiration Date	
Assembler		UV	05/29/2031	

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids)

NBCert #

57248

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/29/2031

Design Type

[Relief Valve] 2700L, 3700L (Liquids)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.676 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV

0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800	NBCert # 57024
-------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/29/2031

Design Type

[Pilot Operated Pressure Relief Valve] 3800
Capacity Tests: Sec. UV at unknown lab on May 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV

4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name:	3800FP	NBCert #	57035
--------------	--------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 05/29/2031

Design Type

[Pilot Operated Pressure Relief Valve] 3800FP
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on April 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-1050 psi	Steam	UV
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-11300 psi	Air	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-1050 psi	Steam	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-11300 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-1050 psi	Steam	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-11300 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-1050 psi	Steam	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-11300 psi	Air	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-6300 psi	Air	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-6300 psi	Air	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-2300 psi	Air	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1500 psi	Air	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-800 psi	Steam	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-1500 psi	Air	UV

Design Name: 3800L PCM	NBCert # 57394
------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	05/29/2031
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 3800L PCM
Capacity Tests: Sec. UV at unknown lab on May 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless; (alternate medium): 0.782 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Initial Audible Discharge; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV

4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Design Name: 3800L, PCL, PCM pilots

NBCert #

57215

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

05/30/2031

Design Type

[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.782 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV

4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Design Name: 4200 / 4400 NBCert # 57282

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	05/30/2031

Design Type

[Safety Valve] 4200 / 4400
Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.872 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

Design Name: 6400/6600 (previously 2500 & 4600) NBCert # 57046

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	05/30/2031

Design Type

[Safety Valve] 6400/6600 (previously 2500 & 4600)
Capacity Tests: Sec. UV, V at Ohio State University (Robinson Laboratory) on January 28, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	V
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	V
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	V
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Air	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	V
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Air	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	V
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	UV

8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	V
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	UV

Integrated Plant Services, Inc. (IPS)
Nameplate Abbreviation: Integrated Plant Services

Columbus, OH 43219United States

This Company Manufactures or Assembles:

Design Name:
1900, 1900-30 1900-35 LA & DALA (Liquids)
NBCert #
18784

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/23/2025

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35	NBCert # 18201
-------------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	09/23/2025
-----------	----	------------

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV

8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201) NBCert # 18223

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/23/2025

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name: 19000 Series

NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

10/17/2030

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/17/2030

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/23/2025

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/23/2025

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 3.256 GPM/SQ. RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM

NBCert # 19066

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

08/18/2029

Design Type

[Safety Relief Valve] 1900-DM
 Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
 Set Pressure Definition(1): Pop; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D NBCert # 19088

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/05/2029

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E NBCert # 19099

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/05/2029

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2		NBCert #	18166
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	09/23/2025
Design Type			
[Safety Relief Valve] 1900E-2, 1900-30E-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids)		NBCert #	18762
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	09/23/2025
Design Type			
[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids) Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.798 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids)		NBCert #	19077
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	09/23/2025
Design Type			
[Relief Valve] 19110M & 19110H (Liquids) Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.264 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 2900-TM (39PV & 39MV pilots) NBCert # 01427

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/06/2030

Design Type

[Pilot Operated Pressure Relief Valve] 2900-TM (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Water	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Water	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Water	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2000 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Water	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Water	UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Water	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-300 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Water	UV

Design Name: 3900-TM (39PV, 39MV pilots)

NBCert #

01438

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

09/06/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3900-TM (39PV, 39MV pilots)

Capacity Tests: Sec. UV at Dresser, Inc. on May 19, 1988

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless; (alternate medium): 0.743 Unitless; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Water	UV

1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Jiangsu Bafang Safety Device Co.,Ltd (XBA)	Nameplate Abbreviation: BasCo
---	--------------------------------------

Jiangsu Province, People's Republic of China

This Company Manufactures or Assembles:

Design Name:	9100 Series Buckling Pin Relief Valve	NBCert #	00965
--------------	---------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	10/13/2028
--------------	----	------------

Design Type

[Buckling Pin Non-reclosing Device] 9100 Series Buckling Pin Relief Valve
Capacity Tests: Sec. UD at National Board Testing Lab on June 2, 2016
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 1.685 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: Nozzle/Full Lift
Designed by: Jiangsu Bafang Safety Device Co.,Ltd {XBA}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	1.5 NPS	1.767 in ²	1.5 in	0.75 in	15-275 psi	Air	UD
2 NPS	2 NPS	3.301 in ²	2.05 in	1.02 in	15-275 psi	Air	UD
3 NPS	3 NPS	7.022 in ²	2.99 in	1.5 in	15-275 psi	Air	UD
4 NPS	4 NPS	12.692 in ²	4.02 in	1.97 in	15-275 psi	Air	UD

6 NPS	6 NPS	28.086 in ²	5.98 in	2.56 in	1-275 psi	Air	UD
8 NPS	8 NPS	50.14 in ²	8.99 in	2.95 in	1-275 psi	Air	UD
10 NPS	10 NPS	78.54 in ²	10 in	3.54 in	1-275 psi	Air	UD
12 NPS	12 NPS	113.286 in ²	12.01 in	3.94 in	1-275 psi	Air	UD
14 NPS	14 NPS	138.303 in ²	13.27 in	4.33 in	1-275 psi	Air	UD
16 NPS	16 NPS	182.415 in ²	15.24 in	4.92 in	1-275 psi	Air	UD
20 NPS	20 NPS	291.039 in ²	19.25 in	5.91 in	1-275 psi	Air	UD
24 NPS	24 NPS	425.288 in ²	23.27 in	6.89 in	1-275 psi	Air	UD
28 NPS	28 NPS	574.678 in ²	27.05 in	8.06 in	1-275 psi	Air	UD
32 NPS	32 NPS	750.391 in ²	30.91 in	9.06 in	1-145 psi	Air	UD
36 NPS	36 NPS	957.72 in ²	34.92 in	10.02 in	1-145 psi	Air	UD
40 NPS	40 NPS	1183.59 in ²	38.82 in	11.22 in	1-145 psi	Air	UD

Design Name: 9800 NBCert # 02259

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/23/2029

Design Type

[Buckling Pin Non-reclosing Device] 9800
Capacity Tests: Sec. UD at National Board Testing Lab on April 11, 2022
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value:14.030 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: MNFA
Designed by: Jiangsu Bafang Safety Device Co.,Ltd {XBA}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS		50.66 in ²			0.5-2250 psi		UD
12 NPS		78.76 in ²			0.5-2250 psi		UD
14 NPS		97.28 in ²			0.5-2250 psi		UD
16 NPS		132.12 in ²			0.5-2250 psi		UD
18 NPS		169.22 in ²			0.5-2250 psi		UD
20 NPS		232.6 in ²			0.5-2250 psi		UD
24 NPS		311.46 in ²			0.5-2250 psi		UD
26 NPS		360.9 in ²			0.5-1440 psi		UD
28 NPS		439.81 in ²			0.5-1440 psi		UD
3 NPS		3.2 in ²			0.5-2250 psi		UD
30 NPS		495.77 in ²			0.5-1440 psi		UD
32 NPS		618.39 in ²			0.5-1440 psi		UD
34 NPS		652 in ²			0.5-1440 psi		UD
36 NPS		738.12 in ²			0.5-1440 psi		UD
38 NPS		829.58 in ²			0.5-1440 psi		UD
4 NPS		6.82 in ²			0.5-2250 psi		UD
40 NPS		926.4 in ²			0.5-1440 psi		UD

42 NPS	1028.55 in ²	0.5-1440 psi	UD
44 NPS	1136.03 in ²	0.5-1440 psi	UD
46 NPS	1248.87 in ²	0.5-1440 psi	UD
48 NPS	1367.04 in ²	0.5-1440 psi	UD
50 NPS	1493.07 in ²	0.5-720 psi	UD
52 NPS	1619.41 in ²	0.5-720 psi	UD
54 NPS	1753.61 in ²	0.5-720 psi	UD
56 NPS	1893.14 in ²	0.5-720 psi	UD
58 NPS	2038.02 in ²	0.5-720 psi	UD
6 NPS	18.4 in ²	0.5-2250 psi	UD
60 NPS	2188.24 in ²	0.5-720 psi	UD
64 NPS	2504.7 in ²	0.5-720 psi	UD
72 NPS	3201.72 in ²	0.5-720 psi	UD
8 NPS	31.42 in ²	0.5-2250 psi	UD
80 NPS	4545.85 in ²	0.5-720 psi	UD

Design Name: FCD Series Rupture Disc NBCert # 00684

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/13/2028

Design Type

[Rupture Disk Device] FCD Series Rupture Disc
HolderDesignation: FH
Capacity Tests: Sec. UD at National Board Testing Lab on June 5, 2015
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.600 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Jiangsu Bafang Safety Device Co.,Ltd {XBA}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.68 in ²			88-1000 psi	Air	UD
1.5 NPS		1.61 in ²			62-700 psi	Air	UD
10 NPS		74.48 in ²			8-240 psi	Air	UD
12 NPS		105.69 in ²			6-200 psi	Air	UD
14 NPS		134.86 in ²			6-175 psi	Air	UD
16 NPS		175.9 in ²			6-150 psi	Air	UD
18 NPS		223.34 in ²			6-135 psi	Air	UD
2 NPS		2.94 in ²			30-550 psi	Air	UD
20 NPS		277.49 in ²			3-120 psi	Air	UD
24 NPS		397.05 in ²			3-100 psi	Air	UD
28 NPS		561.78 in ²			3-93 psi	Air	UD
3 NPS		6.44 in ²			22-450 psi	Air	UD
30 NPS		650.78 in ²			3-88 psi	Air	UD
36 NPS		906.69 in ²			3-75 psi	Air	UD

4 NPS	11.1 in ²	16-415 psi	Air	UD
6 NPS	25.77 in ²	12-320 psi	Air	UD
8 NPS	46.97 in ²	10-295 psi	Air	UD

Design Name: FGD NBCert # 02248

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 12/18/2025

Design Type

[Rupture Disk Device] FGD
HolderDesignation: FH
Capacity Tests: Sec. UD at National Board Testing Lab on August 21, 2019
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.600 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Blowdown Characteristics: Fixed
Flow Area Configuration: MNFA
Designed by: Jiangsu Bafang Safety Device Co.,Ltd {XBA}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.63 in ²			290-8700 psi	Air	UD
1.25 NPS		1.12 in ²			218-6525 psi	Air	UD
1.5 NPS		1.74 in ²			218-5075 psi	Air	UD
10 NPS		47.51 in ²			44-1160 psi	Air	UD
12 NPS		70.53 in ²			36-870 psi	Air	UD
14 NPS		87.9 in ²			36-508 psi	Air	UD
16 NPS		120.13 in ²			29-290 psi	Air	UD
2 NPS		2.35 in ²			174-4350 psi	Air	UD
2.5 NPS		4.24 in ²			145-2900 psi	Air	UD
3 NPS		5.4 in ²			145-2900 psi	Air	UD
4 NPS		9.55 in ²			102-2465 psi	Air	UD
5 NPS		13.67 in ²			87-1740 psi	Air	UD
6 NPS		18.08 in ²			73-1450 psi	Air	UD
8 NPS		31.05 in ²			58-1450 psi	Air	UD

Design Name: RCD Series Rupture Disc NBCert # 00954

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/13/2028

Design Type

[Rupture Disk Device] RCD Series Rupture Disc
HolderDesignation: RH
Capacity Tests: Sec. UD at National Board Testing Lab on June 1, 2016
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.970 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Jiangsu Bafang Safety Device Co.,Ltd {XBA}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.63 in ²			217-580 psi	Air	UD
1.5 NPS		1.74 in ²			174-435 psi	Air	UD
2 NPS		2.35 in ²			130-435 psi	Air	UD
3 NPS		5.4 in ²			116-435 psi	Air	UD
4 NPS		9.06 in ²			116-362 psi	Air	UD
6 NPS		17.41 in ²			72.5-217 psi	Air	UD
8 NPS		30.18 in ²			36-87 psi	Air	UD

Design Name: RSD NBCert # 02237

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	09/13/2028

Design Type

[Rupture Disk Device] RSD
HolderDesignation: RH
Capacity Tests: Sec. UD at National Board Testing Lab on January 22, 2020
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 4.800 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Blowdown Characteristics: Fixed
Flow Area Configuration: MNFA
Designed by: Jiangsu Bafang Safety Device Co.,Ltd {XBA}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.41 in ²			123-1015 psi	Air	UD
1 NPS		0.68 in ²			98-870 psi	Air	UD
1.25 NPS		1.3 in ²			75-870 psi	Air	UD
1.5 NPS		1.68 in ²			60-725 psi	Air	UD
10 NPS		67.42 in ²			6-131 psi	Air	UD
12 NPS		99.54 in ²			3-80 psi	Air	UD
14 NPS		129.92 in ²			3-65 psi	Air	UD
16 NPS		169.24 in ²			3-46 psi	Air	UD
2 NPS		3.24 in ²			45-580 psi	Air	UD
2.5 NPS		4.65 in ²			30-435 psi	Air	UD
3 NPS		7.23 in ²			22-406 psi	Air	UD
4 NPS		12.23 in ²			12-363 psi	Air	UD
5 NPS		18.33 in ²			9-305 psi	Air	UD
6 NPS		26.84 in ²			7.5-305 psi	Air	UD
8 NPS		42.92 in ²			7.5-189 psi	Air	UD

Yangsan-si, Gyeongsangnam-do, 50567 Republic of Korea

This Company Manufactures or Assembles:

Design Name: JSV-FF100		NBCert # 89030
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/21/2029

Design Type

[Safety Relief Valve] JSV-FF100
 Capacity Tests: Sec. UV at National Board Testing Lab on October 7, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.831 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: JOKWANG I.L.I. Co., Ltd. {JOK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	1 - 3 NPS	0.11 in ²	[D] 0.374 in	0.094 in	15-2900 psi	Steam	UV
0.75-1.5 NPS	1 - 3 NPS	0.11 in ²	[D] 0.374 in	0.094 in	15-6000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-6000 psi	Air	UV
0.75-1.5 NPS	1-3 NPS	0.206 in ²	[D1] 0.512 in	0.127 in	15-2900 psi	Steam	UV
0.75-1.5 NPS	1-3 NPS	0.206 in ²	[D1] 0.512 in	0.127 in	15-6000 psi	Air	UV
1-1.5 NPS	2-3 NPS	0.292 in ²	[E1] 0.61 in	0.152 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.292 in ²	[E1] 0.61 in	0.152 in	15-6000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.308 in ²	[F] 0.626 in	0.157 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.308 in ²	[F] 0.626 in	0.157 in	15-5000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.403 in ²	[F1] 0.717 in	0.179 in	15-2900 psi	Steam	UV
1.5-2 NPS	2-3 NPS	0.403 in ²	[F1] 0.717 in	0.179 in	15-5000 psi	Air	UV
1.5-3 NPS	3 NPS	0.506 in ²	[G] 0.803 in	0.201 in	15-2900 psi	Steam	UV
1.5-3 NPS	3 NPS	0.506 in ²	[G] 0.803 in	0.201 in	15-3700 psi	Air	UV
1.5-2 NPS	3 NPS	0.627 in ²	[G1] 0.894 in	0.223 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.627 in ²	[G1] 0.894 in	0.223 in	15-3700 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.25 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.25 in	15-2750 psi	Air	UV
1.5-2 NPS	3 NPS	0.982 in ²	[H1] 1.118 in	0.279 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.982 in ²	[H1] 1.118 in	0.279 in	15-2750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.293 in ²	[J] 1.283 in	0.321 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.293 in ²	[J] 1.283 in	0.321 in	15-2700 psi	Air	UV
2-3 NPS	3-4 NPS	1.56 in ²	[J1] 1.409 in	0.352 in	15-2500 psi	Steam	UV

2-3 NPS	3-4 NPS	1.56 in ²	[J1] 1.409 in	0.352 in	15-2750 psi	Air	UV
3 NPS	4 - 6 NPS	1.841 in ²	[K] 1.531 in	0.383 in	15-2000 psi	Steam	UV
3 NPS	4 - 6 NPS	1.841 in ²	[K] 1.531 in	0.383 in	15-2220 psi	Air	UV
3 NPS	4 - 6 NPS	2.177 in ²	[K1] 1.665 in	0.416 in	15-2000 psi	Steam	UV
3 NPS	4 - 6 NPS	2.177 in ²	[K1] 1.665 in	0.416 in	15-2200 psi	Air	UV
3-4 NPS	4 - 6 NPS	2.862 in ²	[L] 1.909 in	0.478 in	15-2500 psi	Air	UV
3-4 NPS	4 - 6 NPS	2.862 in ²	[L] 1.909 in	0.478 in	15-2500 psi	Steam	UV
3-4 NPS	4-6 NPS	3.484 in ²	[L1] 2.106 in	0.526 in	15-2500 psi	Air	UV
3-4 NPS	4-6 NPS	3.484 in ²	[L1] 2.106 in	0.526 in	15-2500 psi	Steam	UV
4 NPS	6 NPS	3.604 in ²	[M] 2.142 in	0.536 in	15-1100 psi	Air	UV
4 NPS	6 NPS	3.604 in ²	[M] 2.142 in	0.536 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	4.337 in ²	[N] 2.35 in	0.588 in	15-1000 psi	Air	UV
4 NPS	6 NPS	4.337 in ²	[N] 2.35 in	0.588 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	4.383 in ²	[M1] 2.362 in	0.59 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.383 in ²	[M1] 2.362 in	0.59 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	5.303 in ²	[N1] 2.598 in	0.649 in	15-1000 psi	Air	UV
4 NPS	6 NPS	5.303 in ²	[N1] 2.598 in	0.649 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	6.379 in ²	[P] 2.85 in	0.713 in	15-1000 psi	Air	UV
4 NPS	6 NPS	6.379 in ²	[P] 2.85 in	0.713 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	7.068 in ²	[P1] 3 in	0.75 in	15-1000 psi	Air	UV
4 NPS	6 NPS	7.068 in ²	[P1] 3 in	0.75 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	7.512 in ²	[P2] 3.095 in	0.774 in	15-1000 psi	Air	UV
4 NPS	6 NPS	7.512 in ²	[P2] 3.095 in	0.774 in	15-1000 psi	Steam	UV
6 NPS	8 NPS	11.056 in ²	[Q] 3.752 in	0.938 in	15-1100 psi	Air	UV
6 NPS	8 NPS	11.056 in ²	[Q] 3.752 in	0.938 in	15-1100 psi	Steam	UV
6 NPS	8 NPS	13.041 in ²	[Q1] 4.0748 in	1.018 in	15-1100 psi	Air	UV
6 NPS	8 NPS	13.041 in ²	[Q1] 4.0748 in	1.018 in	15-1100 psi	Steam	UV
6 NPS	8 - 10 NPS	16.018 in ²	[R] 4.516 in	1.129 in	15-400 psi	Air	UV
6 NPS	8 - 10 NPS	16.018 in ²	[R] 4.516 in	1.129 in	15-400 psi	Steam	UV
8 NPS	10 NPS	26.021 in ²	[T] 5.756 in	1.439 in	15-300 psi	Air	UV
8 NPS	10 NPS	26.021 in ²	[T] 5.756 in	1.439 in	15-300 psi	Steam	UV
8 NPS	10 NPS	28.274 in ²	[T1] 6 in	1.5 in	15-300 psi	Air	UV
8 NPS	10 NPS	28.274 in ²	[T1] 6 in	1.5 in	15-300 psi	Steam	UV
8 NPS	10 NPS	30.699 in ²	[T2] 6.252 in	1.563 in	15-300 psi	Air	UV
8 NPS	10 NPS	30.699 in ²	[T2] 6.252 in	1.563 in	15-300 psi	Steam	UV
10 NPS	14 NPS	39.447 in ²	[V] 7.087 in	1.772 in	15-300 psi	Air	UV
10 NPS	14 NPS	39.447 in ²	[V] 7.087 in	1.772 in	15-300 psi	Steam	UV
10 NPS	14 NPS	44.179 in ²	[V1] 7.5 in	1.875 in	15-300 psi	Air	UV
10 NPS	14 NPS	44.179 in ²	[V1] 7.5 in	1.875 in	15-300 psi	Steam	UV
12 NPS	16 NPS	55.748 in ²	[W] 8.425 in	2.107 in	15-300 psi	Air	UV
12 NPS	16 NPS	55.748 in ²	[W] 8.425 in	2.107 in	15-300 psi	Steam	UV

12 NPS	16 NPS	63.617 in ²	[W1] 9 in	2.25 in	15-300 psi	Air	UV
12 NPS	16 NPS	63.617 in ²	[W1] 9 in	2.25 in	15-300 psi	Steam	UV
14 NPS	18 NPS	76.078 in ²	[Y] 9.842 in	2.461 in	15-300 psi	Air	UV
14 NPS	18 NPS	76.078 in ²	[Y] 9.842 in	2.461 in	15-300 psi	Steam	UV
14 NPS	18 NPS	86.59 in ²	[Y1] 10.5 in	2.625 in	15-300 psi	Air	UV
14 NPS	18 NPS	86.59 in ²	[Y1] 10.5 in	2.625 in	15-300 psi	Steam	UV

Design Name: JSV-FF100 (Liquid) NBCert # 89041

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 03/21/2029

Design Type

[Safety Relief Valve] JSV-FF100 (Liquid)
Capacity Tests: Sec. UV, V at National Board Testing Lab on October 7, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.615 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: JOKWANG I.L.I. Co., Ltd. {JOK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	1 - 3 NPS	0.11 in ²	[D] 0.374 in	0.094 in	15-6000 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-6000 psi	Water	UV, V
0.75-1.5 NPS	1-3 NPS	0.206 in ²	[D1] 0.512 in	0.127 in	15-6000 psi	Water	UV, V
1-1.5 NPS	2-3 NPS	0.292 in ²	[E1] 0.612 in	0.152 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.308 in ²	[F] 0.626 in	0.157 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.403 in ²	[F1] 0.716 in	0.179 in	15-5000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.506 in ²	[G] 0.803 in	0.201 in	15-3700 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.595 in ²	[G1] 0.87 in	0.217 in	15-3700 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.25 in	15-2750 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.982 in ²	[H1] 1.1178 in	0.279 in	15-2750 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.293 in ²	[J] 1.283 in	0.321 in	15-2700 psi	Water	UV, V
2-3 NPS	3-4 NPS	1.56 in ²	[J1] 1.4088 in	0.352 in	15-2700 psi	Water	UV, V
3 NPS	4 - 6 NPS	1.841 in ²	[K] 1.531 in	0.383 in	15-2220 psi	Water	UV, V
3 NPS	4 - 6 NPS	2.177 in ²	[K1] 1.665 in	0.416 in	15-2200 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	2.862 in ²	[L] 1.909 in	0.478 in	15-2500 psi	Water	UV, V
3-4 NPS	4-6 NPS	3.484 in ²	[L1] 2.105 in	0.526 in	15-2500 psi	Water	UV, V
4 NPS	6 NPS	3.604 in ²	[M] 2.142 in	0.536 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.337 in ²	[N] 2.35 in	0.588 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	4.382 in ²	[M1] 2.361 in	0.59 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	5.302 in ²	[N1] 2.597 in	0.649 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	6.379 in ²	[P] 2.85 in	0.713 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.521 in ²	[P1] 3.0945 in	0.75 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	11.056 in ²	[Q] 3.752 in	0.938 in	15-600 psi	Water	UV, V

6 NPS	8 NPS	13.041 in ²	[Q1] 4.0748 in	1.018 in	15-600 psi	Water	UV, V
6 NPS	8 - 10 NPS	16.018 in ²	[R] 4.516 in	1.129 in	15-300 psi	Water	UV, V
8 NPS	10 NPS	26.021 in ²	[T] 5.756 in	1.439 in	15-300 psi	Water	UV, V
8 NPS	10 NPS	30.699 in ²	[T1] 6.252 in	1.562 in	15-300 psi	Water	UV, V
10 NPS	14 NPS	39.447 in ²	[V] 7.087 in	1.772 in	15-300 psi	Water	UV, V
10 NPS	14 NPS	44.179 in ²	[V1] 7.5 in	1.875 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	55.748 in ²	[W] 8.425 in	2.107 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.617 in ²	[W1] 9 in	2.25 in	15-300 psi	Water	UV, V
14 NPS	18 NPS	76.078 in ²	[Y] 9.842 in	2.461 in	15-300 psi	Water	UV, V
14 NPS	18 NPS	86.59 in ²	[Y1] 10.5 in	2.625 in	15-300 psi	Water	UV, V

Design Name: JSV-FF200		NBCert #	89074
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV, V	11/23/2027

Design Type
[Safety Valve] JSV-FF200 Capacity Tests: Sec. UV, V at National Board Testing Lab on June 25, 2014 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.869 Unitless Media - Test: Steam; Certified: Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: JOKWANG I.L.I. Co., Ltd. {JOK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.439 in ²	0.748 in	0.187 in	15-4750 psi	Steam	V
1.25-1.5 NPS	2.5, 3 NPS	0.701 in ²	0.945 in	0.236 in	15-4750 psi	Steam	V
1.5-2 NPS	2.5-4 NPS	1.095 in ²	1.181 in	0.295 in	15-4750 psi	Steam	V
2-3 NPS	3-6 NPS	1.758 in ²	1.496 in	0.374 in	15-5020 psi	Steam	V
2.5-3 NPS	4-6 NPS	2.922 in ²	1.929 in	0.482 in	15-4750 psi	Steam	V
3-4 NPS	5-8 NPS	4.531 in ²	2.402 in	0.601 in	15-3000 psi	Steam	V
4-4 NPS	6-8 NPS	7.031 in ²	2.992 in	0.748 in	15-3000 psi	Steam	V
5-6 NPS	8-10 NPS	10.986 in ²	3.74 in	0.935 in	15-2000 psi	Steam	V
6 NPS	8-10 NPS	12.566 in ²	4 in	1 in	15-2000 psi	Steam	V
6-8 NPS	8-10 NPS	16.103 in ²	4.528 in	1.132 in	15-2000 psi	Steam	V
8-8 NPS	10-12 NPS	27.395 in ²	5.906 in	1.477 in	15-1500 psi	Steam	V
10-10 NPS	14 NPS	39.447 in ²	7.087 in	1.772 in	15-500 psi	Steam	V
12-12 NPS	16 NPS	55.748 in ²	8.425 in	2.107 in	15-500 psi	Steam	V
14-14 NPS	18 NPS	76.078 in ²	9.842 in	2.461 in	15-500 psi	Steam	V

Design Name: JSV-FT100 (Liquid)		NBCert #	89096
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	03/22/2028

Design Type

[Relief Valve] JSV-FT100 (Liquid)
 Capacity Tests: Sec. UV at National Board Testing Lab on February 10, 2015
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 2.990 GPM/SQ. RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: JOKWANG I.L.I. Co., Ltd. {JOK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	[D] 0.374 in	0.094 in	15-4500 psi	Water	UV

Design Name: JSV-PF100 NBCert # 89052

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/27/2031

Design Type

[Pilot Operated Pressure Relief Valve] JSV-PF100
 Capacity Tests: Sec. UV at National Board Testing Lab on May 23, 2012
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.873 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: JOKWANG I.L.I. Co., Ltd. {JOK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-10000 psi	Air	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-10000 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-10000 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-7000 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-6000 psi	Air	UV
1.5-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-4000 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-4000 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.487 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.487 in	0.917 in	15-3000 psi	Air	UV

4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-2500 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-2000 psi	Air	UV
6 NPS	8 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-2000 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1480 psi	Air	UV
10 NPS	14 NPS	44.18 in ²	[V] 7.5 in	2.775 in	15-500 psi	Air	UV
10 NPS	14 NPS	44.18 in ²	[V] 7.5 in	2.775 in	15-500 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.33 in	15-500 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.33 in	15-500 psi	Steam	UV
14 NPS	18 NPS	86.59 in ²	[Y] 10.68 in	3.951 in	15-500 psi	Air	UV
14 NPS	18 NPS	86.59 in ²	[Y] 10.68 in	3.951 in	15-500 psi	Steam	UV
16 NPS	20 NPS	95.38 in ²	[Z] 11.02 in	4.077 in	15-500 psi	Air	UV
16 NPS	20 NPS	95.38 in ²	[Z] 11.02 in	4.077 in	15-500 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[Z2] 12 in	4.44 in	15-500 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[Z2] 12 in	4.44 in	15-500 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[A] 13.498 in	4.994 in	15-500 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[A] 13.498 in	4.994 in	15-500 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[B] 15 in	5.55 in	15-500 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[B] 15 in	5.55 in	15-500 psi	Steam	UV
20 NPS	24 NPS	227 in ²	[B2] 17 in	6.29 in	15-500 psi	Air	UV
20 NPS	24 NPS	227 in ²	[B2] 17 in	6.29 in	15-500 psi	Steam	UV

Design Name: JSV-PF100 (Liquid)

NBCert #

89063

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

02/27/2031

Design Type

[Pilot Operated Pressure Relief Valve] JSV-PF100 (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on May 23, 2012
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.795 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: JOKWANG I.L.I. Co., Ltd. {JOK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-6170 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-6170 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-6170 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-6170 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-6170 psi	Water	UV

2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-6170 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-3705 psi	Water	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-3705 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1480 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.487 in	0.917 in	15-1480 psi	Water	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1480 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1480 psi	Water	UV
6 NPS	8 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1480 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1480 psi	Water	UV
10 NPS	14 NPS	44.18 in ²	[V] 7.5 in	2.775 in	15-500 psi	Water	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.33 in	15-500 psi	Water	UV
14 NPS	18 NPS	86.59 in ²	[Y] 10.68 in	3.951 in	15-500 psi	Water	UV
16 NPS	20 NPS	95.38 in ²	[Z] 11.02 in	4.077 in	15-500 psi	Water	UV
16 NPS	20 NPS	113.1 in ²	[Z2] 12 in	4.44 in	15-500 psi	Water	UV
18 NPS	24 NPS	143.1 in ²	[A] 13.498 in	4.994 in	15-500 psi	Water	UV
20 NPS	24 NPS	176.7 in ²	[B] 15 in	5.55 in	15-500 psi	Water	UV
20 NPS	24 NPS	227 in ²	[B2] 17 in	6.29 in	15-500 psi	Water	UV

J-S Machine and Valve Inc. (JSM)

Nameplate Abbreviation: J-S Machine & Valve

Nowata, OK 74048United States

This Company Manufactures or Assembles:

Design Name: 9 Series			NBCert # 44019				
Manufacturer/Assembler		Designators		Expiration Date			
Assembler		UV		08/30/2029			
Design Type							
[Safety Relief Valve] 9 Series Capacity Tests: Sec. UV at National Board Testing Lab on July 24, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.823 Unitless Media - Test: Air/Gas; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: TRILLIUM Flow Technologies - France SAS {SAR}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in²	0.236 in	0.07 in	15-4700 psi	Air	UV
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in²	0.236 in	0.07 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.124 in²	0.398 in	0.1 in	14.5-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.124 in²	0.398 in	0.1 in	14.5-4700 psi	Air	UV
0.75-1 NPS	1 NPS	0.222 in²	0.531 in	0.13 in	14.5-2220 psi	Air	UV
0.75-1 NPS	1 NPS	0.222 in²	0.531 in	0.13 in	14.5-2220 psi	Steam	UV

1-1.5 NPS	1.5 NPS	0.352 in ²	0.669 in	0.17 in	14.5-740 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.669 in	0.17 in	14.5-740 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	0.85 in	0.21 in	14.5-285 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	0.85 in	0.21 in	14.5-285 psi	Steam	UV

Design Name: 9 Series (Liquids) NBCert # 44020

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/30/2029

Design Type

[Relief Valve] 9 Series (Liquids)
Capacity Tests: Sec. UV, V at National Board Testing Lab on July 24, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.632 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	[B] 0.236 in	0.07 in	15-6250 psi	Water	UV
0.5-1 NPS	1 NPS	0.124 in ²	[D] 0.398 in	0.1 in	14.5-6250 psi	Water	UV
0.75-1 NPS	1 NPS	0.222 in ²	[E] 0.531 in	0.13 in	14.5-2220 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	[F] 0.669 in	0.17 in	14.5-740 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	[G] 0.85 in	0.21 in	14.5-285 psi	Water	UV

Design Name: P3, P4 (liquids) NBCert # 92012

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/30/2029

Design Type

[Relief Valve] P3, P4 (liquids)
Capacity Tests: Sec. UV, V at National Board Testing Lab on December 7, 1993
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.631 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Water	UV, V
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Water	UV, V
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Water	UV, V
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Water	UV, V
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Water	UV, V

3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Water	UV, V
4 NPS	6 NPS	7.032 in ²	[P] 2.992 in	0.94 in	15-1300 psi	Water	UV, V
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Water	UV, V
6 NPS	8-10 NPS	15.267 in ²	[R] 4.409 in	1.477 in	15-500 psi	Water	UV, V
8 NPS	10 NPS	28.126 in ²	[T] 5.984 in	1.88 in	15-500 psi	Water	UV, V

Design Name: P3, P4, P5 NBCert # 92001

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/30/2030

Design Type

[Safety Relief Valve] P3, P4, P5
Capacity Tests: Sec. UV at unknown lab on June 5, 1986
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Air	UV
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Air	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-2900 psi	Steam	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Air	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-2900 psi	Steam	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Air	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-2900 psi	Steam	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Air	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Steam	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Air	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Steam	UV

6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Air	UV
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Steam	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Air	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Steam	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Air	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Steam	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Air	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Steam	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Air	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Steam	UV

Design Name:	STARFLOW-V	NBCert #	44110
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	V	10/30/2030

Design Type

[Safety Valve] STARFLOW-V
Capacity Tests: Sec. UV, V at National Board Testing Lab on April 26, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}
Comments: org. date added and V orif. area corrected from 38.548 to 38.485 JB 8-10-20
corrected H inlet to add 1.5" JB -8-2-21

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5-3 NPS	0.373 in ²	[F] 0.689 in	0.172 in	30-2250 psi	Steam	UV, V
1.25-2 NPS	1.5-3 NPS	0.589 in ²	[G] 0.8661 in	0.217 in	30-2250 psi	Steam	UV, V
1.5-2 NPS	2.5, 3 NPS	0.996 in ²	[H] 1.126 in	0.281 in	30-2250 psi	Steam	UV, V
1.5-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.3622 in	0.341 in	30-2250 psi	Steam	UV, V
2-3 NPS	3-6 NPS	1.667 in ²	[K] 1.457 in	0.364 in	30-2250 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.758 in ²	[L] 1.874 in	0.469 in	30-2250 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.983 in ²	[M] 2.252 in	0.563 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	5.303 in ²	[N] 2.5984 in	0.65 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	0.75 in	30-2250 psi	Steam	UV, V
6 NPS	8 NPS	10.148 in ²	[Q] 3.594 in	0.902 in	30-1494 psi	Steam	UV, V
6 NPS	8, 10 NPS	14.173 in ²	[R] 4.248 in	1.062 in	30-1494 psi	Steam	UV, V
8 NPS	10 NPS	23.997 in ²	[T] 5.528 in	1.382 in	30-740 psi	Steam	UV, V
10 NPS	14 NPS	38.485 in ²	[V] 7 in	1.75 in	30-740 psi	Steam	UV, V
12 NPS	2x12 NPS	55.438 in ²	[W] 8.402 in	2.1 in	30-740 psi	Steam	UV, V

Design Name: Starsteam V Series (Res. Lift)		NBCert #	92045
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	V	08/30/2029	

Design Type

[Safety Valve] Starsteam V Series (Res. Lift)
Capacity Tests: Sec. UV, V at National Board Testing Lab on August 6, 2012
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Restricted Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	3 NPS	0.996 in ²	[1] 1.125 in	0.156 in	15-6525 psi	Steam	UV, V
2 NPS	3 NPS	1.667 in ²	[2] 1.456 in	0.201 in	15-6525 psi	Steam	UV, V
2.5 NPS	6 NPS	2.758 in ²	[3] 1.874 in	0.258 in	15-6525 psi	Steam	UV, V
3 NPS	6 NPS	3.983 in ²	[4] 2.251 in	0.309 in	15-6525 psi	Steam	UV, V
4 NPS	6 NPS	5.303 in ²	[5] 2.598 in	0.357 in	15-6525 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[6] 3 in	0.414 in	15-3280 psi	Steam	UV, V
6 NPS	8 NPS	11.056 in ²	[Q] 3.571 in	0.517 in	15-2798 psi	Steam	UV, V
6 NPS	10 NPS	15.904 in ²	[R] 4.5 in	0.619 in	15-1580 psi	Steam	UV, V
6 NPS	10 NPS	19.299 in ²	[RR] 4.957 in	0.681 in	15-1580 psi	Steam	UV, V
8 NPS	10 NPS	27.391 in ²	[T] 5.905 in	0.812 in	15-1190 psi	Steam	UV, V

Kings Energy Services Ltd. (KES)

Nameplate Abbreviation: Kings Energy
Services

Sarnia, ON N7T 7H3Canada

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S		NBCert #	57057
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	06/09/2029	

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV

18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam) NBCert # 57260

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/09/2029

Design Type

[Safety Relief Valve] 2600L (Air & Steam)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV

8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name:	2600L (Liquids)	NBCert #	57068
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/09/2029

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/09/2029

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids)

NBCert #

57248

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/09/2029

Design Type

[Relief Valve] 2700L, 3700L (Liquids)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.676 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV

0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Korea Special Metal Co., Ltd. (KSM)

Nameplate Abbreviation: KSM

Incheon, 21634 Republic of Korea

This Company Manufactures or Assembles:

Design Name:	KSF	NBCert #	01944
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	11/16/2028
--------------	----	------------

Design Type

[Safety Relief Valve] KSF
Capacity Tests: Sec. UV at National Board Testing Lab on March 11, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.853 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Korea Special Metal Co., Ltd. {KSM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.5 NPS	0.75-3 NPS	0.122 in ²	[D] 0.394 in	0.0984 in	15-6000 psi	Air	UV
1-1.5 NPS	1.5-3 NPS	0.2057 in ²	[E] 0.512 in	0.128 in	15-6000 psi	Air	UV
1.5 NPS	2-3 NPS	0.3116 in ²	[F] 0.63 in	0.157 in	15-5000 psi	Air	UV
1 NPS	1.5-2 NPS	0.439 in ²	[F3] 0.748 in	0.187 in	15-6000 psi	Air	UV
1.5 NPS	2.5-3 NPS	0.5368 in ²	[G] 0.8267 in	0.207 in	15-3700 psi	Air	UV
1.5-2 NPS	2.5-3 NPS	0.8229 in ²	[H] 1.0236 in	0.256 in	15-2750 psi	Air	UV
1.5 NPS	2.5-3 NPS	1.0956 in ²	[H3] 1.181 in	0.295 in	15-2750 psi	Air	UV
2-3 NPS	3-4 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-2700 psi	Air	UV
2 NPS	3 NPS	1.7578 in ²	[J2] 1.496 in	0.374 in	15-2700 psi	Air	UV
3 NPS	4-6 NPS	1.852 in ²	[K] 1.535 in	0.384 in	15-2200 psi	Air	UV
2.5-4 NPS	4-6 NPS	2.923 in ²	[L] 1.929 in	0.482 in	15-2500 psi	Air	UV
4 NPS	6 NPS	3.682 in ²	[M] 2.165 in	0.541 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.382 in ²	[N] 2.362 in	0.591 in	15-1100 psi	Air	UV
3 NPS	4-6 NPS	4.53 in ²	[N2] 2.402 in	0.6 in	15-1100 psi	Air	UV
4 NPS	6 NPS	6.487 in ²	[P] 2.874 in	0.719 in	15-1000 psi	Air	UV
6 NPS	8 NPS	11.222 in ²	[Q] 3.78 in	0.945 in	15-600 psi	Air	UV
6 NPS	8-10 NPS	16.103 in ²	[R] 4.528 in	1.132 in	15-400 psi	Air	UV

8 NPS	10 NPS	27.395 in ²	[T] 5.906 in	1.476 in	15-300 psi	Air	UV
10 NPS	14 NPS	39.447 in ²	[V1] 7.087 in	1.772 in	15-300 psi	Air	UV
12 NPS	16 NPS	55.748 in ²	[W1] 8.425 in	2.106 in	15-300 psi	Air	UV
14 NPS	18 NPS	76.093 in ²	[Y] 9.843 in	2.461 in	15-300 psi	Air	UV

Design Name:	KST	NBCert #	01955
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/14/2028

Design Type

[Safety Relief Valve] KST
Capacity Tests: Sec. UV at National Board Testing Lab on October 14, 2020
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Korea Special Metal Co., Ltd. {KSM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	0.75-1 NPS	0.122 in ²	[D] 0.394 in	0.0984 in	15-300 psi	Air	UV
0.75-1 NPS	0.75-1 NPS	0.228 in ²	[E1] 0.539 in	0.1346 in	15-300 psi	Air	UV
1 NPS	1-1.25 NPS	0.352 in ²	[F2] 0.669 in	0.167 in	15-300 psi	Air	UV

Kunshan Xinxinpeng Mechanical Co. Ltd (KUN)

Nameplate Abbreviation: XXP

Jiangsu Province, 215323 People's Republic of China

This Company Manufactures or Assembles:

Design Name:	AX-15	NBCert #	14915
--------------	-------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/29/2029

Design Type

[Safety Relief Valve] AX-15
Capacity Tests: Sec. UV at National Board Testing Lab on August 31, 2006
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.328 SCFM/PSIA
Media - ; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Kunshan Xinxinpeng Mechanical Co. Ltd {KUN}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS		0.0214 in ²	4.2 mm	1.05 mm	70-270 psi	Air	UV

Lakeside Process Controls, Ltd. (TVA)

Nameplate Abbreviation: Lakeside
Process Controls

Sarnia, ON N7T 2S6Canada

This Company Manufactures or Assembles:

Design Name:	443/449/546/843/849/943/949/5046/5049 (Liquids)	NBCert #	01337
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	04/07/2027
Design Type			
[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids) Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.767 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids)			NBCert #	01326
Manufacturer/Assembler		Designators		Expiration Date
Assembler		UV		02/12/2027
Design Type				
[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids) Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.491 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Emerson Automation Solutions Final Control US LP {AGC}				

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV

1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name:	81, 81P, 83, 84	NBCert #	01089
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/12/2027

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV

1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 81P (Liquids) NBCert # 01102

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/12/2027

Design Type

[Relief Valve] 81P (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: 93% of pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name: 900 Series (Liquid), 7700, SNC NBCert # 15499

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/31/2029

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V

0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name: 900 Series, 7700, SNC NBCert # 15411

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/31/2029

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/12/2027

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.656 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name:	JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB	NBCert #	15208
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	07/31/2029
-----------	----	------------

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV

6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Design Name:	Kunkle 6000, 6252 Series	NBCert #	36324
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	11/01/2029

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V

1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name:	Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)	NBCert #	36111
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	02/12/2027
-----------	----	------------

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 , 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

LAM VALVES INC. (LMV)

Houston, TX 77023United States

This Company Manufactures or Assembles:

Design Name:	Kunkle 1, 2	NBCert #	36223
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	08/08/2030	
Design Type			
[Safety Valve] Kunkle 1, 2 Capacity Tests: Sec. UV at unknown lab on July 1, 1953 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.823 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, Top NPS	0.049 in ²	0.75 in	0.029 in	15-250 psi	Air	UV
0.5-0.75 NPS	.75, Top NPS	0.049 in ²	0.75 in	0.029 in	15-250 psi	Steam	UV
1 NPS	1, Top NPS	0.0844 in ²	1 in	0.038 in	15-250 psi	Air	UV
1 NPS	1, Top NPS	0.0844 in ²	1 in	0.038 in	15-250 psi	Steam	UV

Design Name:	Kunkle 264, 265, 266 & 267	NBCert #	36267
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	08/07/2030	
Design Type			
[Safety Relief Valve] Kunkle 264, 265, 266 & 267 Capacity Tests: Sec. UV at unknown lab on July 20, 1956 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.766 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.11 in²	0.375 in	0.115 in	15-2000 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.11 in²	0.375 in	0.115 in	15-3300 psi	Air	UV

Design Name: Kunkle 337 NBCert # 36278

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/08/2030

Design Type

[Safety Relief Valve] Kunkle 337
Capacity Tests: Sec. UV at unknown lab on February 22, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	1.916 in²	1.562 in	0.612 in	15-60 psi	Air	UV
2.5 NPS	2.5 NPS	2.786 in²	1.883 in	0.755 in	15-60 psi	Air	UV
3 NPS	3 NPS	4.037 in²	2.267 in	0.91 in	15-60 psi	Air	UV

Design Name: Kunkle 541-A/542-A (.295 orifice) NBCert # 36469

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/21/2030

Design Type

[Safety Relief Valve] Kunkle 541-A/542-A (.295 orifice)
Capacity Tests: Sec. UV at unknown lab on December 14, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.000 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS		0.068 in²	0.295 in	0.126 in	15-200 psi	Air	UV

Design Name: Kunkle 541-C/542-C/548-C (.422 Orifice) NBCert # 36302

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/21/2030

Design Type

[Safety Relief Valve] Kunkle 541-C/542-C/548-C (.422 Orifice)
Capacity Tests: Sec. UV at unknown lab on May 20, 1988
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.000 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	Side NPS	0.14 in ²	0.422 in	0.2 in	15-400 psi	Air	UV

Design Name: Kunkle 548-A (.295 Orifice) NBCert # 36290

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 05/21/2030

Design Type

[Safety Relief Valve] Kunkle 548-A (.295 Orifice)
Capacity Tests: Sec. UV at unknown lab on May 20, 1988
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.000 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.375 NPS	Side NPS	0.068 in ²	0.295 in	0.126 in	15-400 psi	Air	UV

Design Name: Kunkle 6000, 6252 Series NBCert # 36324

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV, V 05/21/2030

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV

1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 910 to 919			NBCert # 36100	
Manufacturer/Assembler		Designators	Expiration Date	
Assembler		UV	08/07/2030	

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name: Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid) NBCert # 36111

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	08/07/2030

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

Laurentide Controls Limited (SIE)

Kirkland, QC H9J 4A1Canada

This Company Manufactures or Assembles:

Design Name: 81, 81P, 83, 84		NBCert # 01089
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/19/2029

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 81P (Liquids)		NBCert # 01102
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	06/19/2029

Design Type

[Relief Valve] 81P (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: 93% of pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name:	900 Series (Liquid), 7700, SNC	NBCert #	15499
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV, V	06/19/2029
-----------	-------	------------

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name:	900 Series, 7700, SNC	NBCert #	15411
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	06/19/2029
-----------	----	------------

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: C776

NBCert # 36425

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/19/2029

Design Type

[Safety Relief Valve] C776
 Capacity Tests: Sec. UV at Crosby Valve, LLC on July 15, 2002
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.790 Unitless
 Media - Test: Air/Gas; Certified: Gas
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Regulator Technologies - Fromex S.A. de C.V. {FCF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.169 in ²	0.465 in	0.116 in	15-600 psi	Air	UV
1 NPS	1.25 NPS	0.34 in ²	0.658 in	0.164 in	15-500 psi	Air	UV
0.75-1 NPS	1.25 NPS	0.486 in ²	0.787 in	0.197 in	15-600 psi	Air	UV
1.25 NPS	1.5 NPS	0.645 in ²	0.906 in	0.227 in	15-500 psi	Air	UV
1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.286 in	15-500 psi	Air	UV
2-2.5 NPS	2.5 NPS	1.667 in ²	1.457 in	0.364 in	15-500 psi	Air	UV

Design Name:	HL, HSL	NBCert #	15589
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 03/10/2029

Design Type

[Safety Valve] HL, HSL
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on November 3, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.869 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	1.5 NPS	0.339 in ²	[F] 0.657 in	0.164 in	15-725 psi	Steam	UV, V
1.25-2 NPS	1.5 NPS	0.553 in ²	[G] 0.839 in	0.21 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.868 in ²	[H] 1.051 in	0.263 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.327 in ²	[J] 1.3 in	0.325 in	15-725 psi	Steam	UV, V
2-3 NPS	3-4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-725 psi	Steam	UV, V
2.5-4 NPS	4-6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-725 psi	Steam	UV, V
3 NPS	4-6 NPS	3.955 in ²	[M] 2.244 in	0.561 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	4.831 in ²	[N] 2.48 in	0.62 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	7.031 in ²	[P] 2.992 in	0.748 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[QQ] 3.75 in	0.937 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	0.984 in	15-725 psi	Steam	UV, V

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Liquids)	NBCert #	15095
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 09/15/2029

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV

1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/19/2029

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV

0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV

8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Design Name:	Kunkle 337	NBCert #	36278
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/19/2029

Design Type

[Safety Relief Valve] Kunkle 337
Capacity Tests: Sec. UV at unknown lab on February 22, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	1.916 in ²	1.562 in	0.612 in	15-60 psi	Air	UV
2.5 NPS	2.5 NPS	2.786 in ²	1.883 in	0.755 in	15-60 psi	Air	UV
3 NPS	3 NPS	4.037 in ²	2.267 in	0.91 in	15-60 psi	Air	UV

Design Name:	Kunkle 6000, 6252 Series	NBCert #	36324
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	06/19/2029

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V

0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 910 to 919

NBCert # 36100

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/19/2029

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name: Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid) NBCert # 36111

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	06/19/2029

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

LCM Industries, Inc. (LCL)

Longview, TX 75604United States

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S		NBCert # 57057
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/22/2030

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV

6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name:	2600L (Liquids)	NBCert #	57068
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/22/2030

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V

4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700L, 3700L (Liquids) NBCert # 57248

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/22/2030

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800 NBCert # 57024

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/22/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3800
Capacity Tests: Sec. UV at unknown lab on May 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV

1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name:	3800FP	NBCert #	57035
--------------	--------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	05/10/2031
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 3800FP
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on April 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-1050 psi	Steam	UV
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-11300 psi	Air	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-1050 psi	Steam	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-11300 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-1050 psi	Steam	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-11300 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-1050 psi	Steam	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-11300 psi	Air	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-6300 psi	Air	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-6300 psi	Air	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-2300 psi	Air	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1500 psi	Air	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-800 psi	Steam	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-1500 psi	Air	UV

Design Name:	3800L, PCL, PCM pilots	NBCert #	57215
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/22/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.782 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV

3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

LCM Industries, Inc. (LCM)

Odessa, TX 79763United States

This Company Manufactures or Assembles:

Design Name:	2600 & 2600S	NBCert #	57057
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	09/07/2030
-----------	----	------------

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV

4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/03/2030

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV

1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids)	NBCert # 57068
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/03/2030

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V

1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S NBCert # 57237

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/07/2030

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV

2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids) NBCert # 57248

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/07/2030

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800 NBCert # 57024

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/07/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3800
Capacity Tests: Sec. UV at unknown lab on May 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV

1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name: 3800FP

NBCert # 57035

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/14/2031

Design Type

[Pilot Operated Pressure Relief Valve] 3800FP
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on April 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-1050 psi	Steam	UV

1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-11300 psi	Air	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-1050 psi	Steam	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-11300 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-1050 psi	Steam	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-11300 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-1050 psi	Steam	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-11300 psi	Air	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-6300 psi	Air	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-6300 psi	Air	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-2300 psi	Air	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1500 psi	Air	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-800 psi	Steam	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-1500 psi	Air	UV

Design Name: 3800L, PCL, PCM pilots

NBCert #

57215

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

09/07/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.782 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV

6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

LESER - The Safety Valve (Tianjin) Ltd. (LST)

Nameplate Abbreviation: LESER CN

Tianjin, 301700People's Republic of China

This Company Manufactures or Assembles:

Design Name: 237, 237IC, 237CC

NBCert #

37325

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/12/2029

Design Type

[Safety Relief Valve] 237, 237IC, 237CC
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on August 14, 2017
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.987 SCFM/PSIA; (alternate medium): 2.773 PPH/PSIA
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1 NPS	0.5-1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Air	UV
0.375-1 NPS	0.5-1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Steam	UV

Design Name: 237, 237IC, 237CC (Liquid)

NBCert #

37336

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/13/2029

Design Type

[Relief Valve] 237, 237IC, 237CC (Liquid)
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on August 14, 2017
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.591 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.058 in ²	0.394 in	0.039 in	15-2610 psi	Water	UV

Design Name: 441/442/444	NBCert # 37044
--------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	12/13/2029
--------------	----	------------

Design Type

[Safety Relief Valve] 441/442/444
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on February 17, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.699 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Air	UV
1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Steam	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Air	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Steam	UV
1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Air	UV
1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Steam	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Air	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Steam	UV
2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Air	UV
2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Steam	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Air	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Steam	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Air	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Steam	UV
5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Air	UV
5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Steam	UV
6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Air	UV
6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Steam	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Air	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Steam	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Air	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Steam	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Air	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Steam	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Air	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Steam	UV

Design Name:	441/442/444 liquids	NBCert #	37055
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/12/2029

Design Type

[Relief Valve] 441/442/444 liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on September 6, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.521 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Water	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Water	UV
1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Water	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Water	UV
2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Water	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Water	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Water	UV
5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Water	UV
6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Water	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Water	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Water	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Water	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Water	UV

Design Name:	459/462	NBCert #	37112
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/12/2029

Design Type

[Safety Relief Valve] 459/462
Capacity Tests: Sec. UV at National Board Testing Lab on February 17, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.811 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Air	UV
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-2900 psi	Steam	UV

0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Air	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Steam	UV

Design Name:	459/462 liquids	NBCert #	37101
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/13/2029

Design Type

[Relief Valve] 459/462 liquids
Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.566 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Water	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Water	UV
0.5-1.5 NPS	1-2.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Water	UV
1-2 NPS	1.5-2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Water	UV

Design Name:	526	NBCert #	37224
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/13/2029

Design Type

[Safety Relief Valve] 526
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 22, 2001
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Air	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-2900 psi	Steam	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Air	UV

1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Air	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-2900 psi	Steam	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Steam	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Air	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Steam	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Air	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Steam	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Air	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Steam	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Air	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Steam	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Air	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Steam	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Air	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Steam	UV

Design Name: 526 (Liquids)	NBCert # 37235
----------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/12/2029

Design Type

[Relief Valve] 526 (Liquids)
 Capacity Tests: Sec. UV at Leser GmbH & Co., KG on January 2, 2002
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.579 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Water	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Water	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Water	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Water	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Water	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Water	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.6698 in	15-1850 psi	Water	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Water	UV

4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Water	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Water	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.249 in	15-1038.5 psi	Water	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Water	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-914 psi	Water	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Water	UV

Design Name:	526D	NBCert #	37246
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/05/2031

Design Type
[Safety Relief Valve] 526D Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on March 4, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.990 SCFM/PSIA; (alternate medium): 5.590 PPH/PSIA Media - ; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Adjustable Flow Area Configuration: Curtain Area Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-10878 psi	Air	UV

Design Name:	526D Liquids	NBCert #	37257
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/12/2029

Design Type
[Relief Valve] 526D Liquids Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on March 4, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.110 GPM/SQ. RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-10878 psi	Water	UV

LESER GmbH & Co. KG (LES)	Nameplate Abbreviation: LESER
--------------------------------------	-------------------------------

Hohenwestedt, 24594Germany

This Company Manufactures or Assembles:

Design Name:	237, 237IC, 237CC	NBCert #	37325
--------------	-------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/23/2030

Design Type

[Safety Relief Valve] 237, 237IC, 237CC
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on August 14, 2017
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.987 SCFM/PSIA; (alternate medium): 2.773 PPH/PSIA
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1 NPS	0.5-1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Air	UV
0.375-1 NPS	0.5-1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Steam	UV

Design Name:	237, 237IC, 237CC (Liquid)	NBCert #	37336
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/07/2029

Design Type

[Relief Valve] 237, 237IC, 237CC (Liquid)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on August 14, 2017
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.591 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.058 in ²	0.394 in	0.039 in	15-2610 psi	Water	UV

Design Name:	437	NBCert #	37213
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/05/2030

Design Type

[Safety Relief Valve] 437
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 8, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.020 SCFM/PSIA; (alternate medium): 2.870 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Air	UV

0.375-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Steam	UV
-------------	---------------	-----------------------	----------	----------	-------------	-------	----

Design Name: 437 (Liquids)		NBCert #	37189
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	02/05/2030
Design Type			
[Relief Valve] 437 (Liquids) Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on November 22, 2001 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.540 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: LESER GmbH & Co. KG {LES}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Water	UV

Design Name: 438 Sub Types 481, 439		NBCert #	37190
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	02/05/2030
Design Type			
[Safety Relief Valve] 438 Sub Types 481, 439 Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on November 12, 2001 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.904 SCFM/PSIA; (alternate medium): 2.530 PPH/PSIA Media - Test: Air/Gas; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: LESER GmbH & Co. KG {LES}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1 NPS	0.5 - 1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Air	UV
0.375-1 NPS	0.5 - 1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Steam	UV

Design Name:		438 Sub Types 481, 439, Liquids	NBCert #	37202
Manufacturer/Assembler		Designators		Expiration Date
Manufacturer		UV		02/05/2030
Design Type				
[Safety Relief Valve] 438 Sub Types 481, 439, Liquids Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on November 23, 2001 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.490 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: LESER GmbH & Co. KG {LES}				

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.064 in²	0.394 in	0.043 in	15-2610 psi	Water	UV
Design Name: 441/442/444NBCert # 37044							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			02/05/2030	
Design Type							
[Safety Relief Valve] 441/442/444 Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on February 17, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.699 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5,2 NPS	0.644 in²	0.906 in	0.277 in	15-715 psi	Air	UV
1 NPS	1.5,2 NPS	0.644 in²	0.906 in	0.277 in	15-715 psi	Steam	UV
1.25-1.5 NPS	2 NPS	1.024 in²	1.142 in	0.349 in	15-715 psi	Air	UV
1.25-1.5 NPS	2 NPS	1.024 in²	1.142 in	0.349 in	15-715 psi	Steam	UV
1.5 NPS	2.5,3 NPS	1.667 in²	1.457 in	0.446 in	15-715 psi	Air	UV
1.5 NPS	2.5,3 NPS	1.667 in²	1.457 in	0.446 in	15-715 psi	Steam	UV
2 NPS	3 NPS	2.576 in²	1.811 in	0.554 in	15-715 psi	Air	UV
2 NPS	3 NPS	2.576 in²	1.811 in	0.554 in	15-715 psi	Steam	UV
2.5-3 NPS	4 NPS	4.383 in²	2.362 in	0.723 in	15-500 psi	Air	UV
2.5-3 NPS	4 NPS	4.383 in²	2.362 in	0.723 in	15-500 psi	Steam	UV
3 NPS	5 NPS	6.666 in²	2.913 in	0.891 in	15-500 psi	Air	UV
3 NPS	5 NPS	6.666 in²	2.913 in	0.891 in	15-500 psi	Steam	UV
4 NPS	6 NPS	10.304 in²	3.622 in	1.108 in	15-418 psi	Air	UV
4 NPS	6 NPS	10.304 in²	3.622 in	1.108 in	15-418 psi	Steam	UV
5 NPS	8 NPS	11.692 in²	3.858 in	1.181 in	15-315 psi	Air	UV
5 NPS	8 NPS	11.692 in²	3.858 in	1.181 in	15-315 psi	Steam	UV
6 NPS	10 NPS	19.021 in²	4.921 in	1.506 in	15-290 psi	Air	UV
6 NPS	10 NPS	19.021 in²	4.921 in	1.506 in	15-290 psi	Steam	UV
8 NPS	12 NPS	33.143 in²	6.496 in	1.988 in	15-430 psi	Air	UV
8 NPS	12 NPS	33.143 in²	6.496 in	1.988 in	15-430 psi	Steam	UV
10 NPS	14 NPS	48.695 in²	7.874 in	2.409 in	15-300 psi	Air	UV
10 NPS	14 NPS	48.695 in²	7.874 in	2.409 in	15-300 psi	Steam	UV
12 NPS	16 NPS	67.229 in²	9.252 in	2.831 in	15-310 psi	Air	UV
12 NPS	16 NPS	67.229 in²	9.252 in	2.831 in	15-310 psi	Steam	UV
16 NPS	20 NPS	105.94 in²	11.614 in	3.554 in	15-175 psi	Air	UV
16 NPS	20 NPS	105.94 in²	11.614 in	3.554 in	15-175 psi	Steam	UV

Design Name:	441/442/444 liquids	NBCert #	37055
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/05/2030

Design Type

[Relief Valve] 441/442/444 liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on September 6, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.521 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Water	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Water	UV
1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Water	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Water	UV
2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Water	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Water	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Water	UV
5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Water	UV
6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Water	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Water	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Water	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Water	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Water	UV

Design Name:	447 Air/Gas	NBCert #	37123
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/05/2030

Design Type

[Safety Relief Valve] 447 Air/Gas
Capacity Tests: Sec. UV at National Board Testing Lab on May 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.617 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.644 in ²	0.905 in	0.19 in	15-240 psi	Air	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.44 in	15-240 psi	Air	UV
3 NPS	4 NPS	4.383 in ²	2.362 in	0.52 in	15-240 psi	Air	UV

4 NPS	6 NPS	10.304 in ²	3.622 in	0.91 in	15-240 psi	UV
-------	-------	------------------------	----------	---------	------------	----

Design Name:	447 Liquid	NBCert #	37134
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/05/2030

Design Type

[Relief Valve] 447 Liquid
Capacity Tests: Sec. UV at National Board Testing Lab on May 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.431 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.644 in ²	0.906 in	0.19 in	15-240 psi	Water	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.44 in	15-240 psi	Water	UV
3 NPS	4 NPS	4.383 in ²	2.362 in	0.52 in	15-240 psi	Water	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	0.91 in	15-240 psi	Water	UV

Design Name:	455/456/457/458 Group 1	NBCert #	37066
--------------	-------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/05/2030

Design Type

[Safety Relief Valve] 455/456/457/458 Group 1
Capacity Tests: Sec. UV at National Board Testing Lab on February 17, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.798 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.274 in ²	0.591 in	0.197 in	35-1928 psi	Steam	UV
1 NPS	2 NPS	0.274 in ²	0.591 in	0.197 in	35-5715 psi	Air	UV
1 NPS	2 NPS	0.487 in ²	0.787 in	0.256 in	35-2571 psi	Steam	UV
1 NPS	2 NPS	0.487 in ²	0.787 in	0.256 in	35-3571 psi	Air	UV
2 NPS	3 NPS	1.096 in ²	1.181 in	0.354 in	35-2392 psi	Steam	UV
2 NPS	3 NPS	1.096 in ²	1.181 in	0.354 in	35-3571 psi	Air	UV
2 NPS	3 NPS	1.948 in ²	1.575 in	0.551 in	35-1630 psi	Air	UV
2 NPS	3 NPS	1.948 in ²	1.575 in	0.551 in	35-1630 psi	Steam	UV
3 NPS	4 NPS	3.043 in ²	1.969 in	0.709 in	35-2115 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	1.969 in	0.709 in	35-2115 psi	Steam	UV
4 NPS	6 NPS	3.043 in ²	1.969 in	0.866 in	35-2205 psi	Steam	UV

4 NPS	6 NPS	3.043 in ²	1.969 in	0.866 in	35-3290 psi	Air	UV
4 NPS	6 NPS	6.666 in ²	2.362 in	0.866 in	35-2130 psi	Air	UV
4 NPS	6 NPS	6.666 in ²	2.362 in	0.866 in	35-2130 psi	Steam	UV
4 NPS	6 NPS	6.666 in ²	2.913 in	0.827 in	35-1100 psi	Air	UV
4 NPS	6 NPS	6.666 in ²	2.913 in	0.827 in	35-1100 psi	Steam	UV

Design Name: 455/456/457/458 Group 1 (Liq) NBCert # 37077

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/05/2030

Design Type

[Relief Valve] 455/456/457/458 Group 1 (Liq)
Capacity Tests: Sec. UV at National Board Testing Lab on January 30, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.572 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.274 in ²	0.591 in	0.197 in	35-5715 psi	Water	UV
1 NPS	2 NPS	0.487 in ²	0.787 in	0.256 in	35-2571 psi	Water	UV
2 NPS	3 NPS	1.096 in ²	1.181 in	0.354 in	35-3571 psi	Water	UV
2 NPS	3 NPS	1.948 in ²	1.575 in	0.551 in	35-1630 psi	Water	UV
3 NPS	4 NPS	3.043 in ²	1.969 in	0.709 in	35-2115 psi	Water	UV
4 NPS	6 NPS	3.043 in ²	1.969 in	0.866 in	35-3290 psi	Water	UV
4 NPS	6 NPS	4.383 in ²	2.362 in	0.866 in	35-2130 psi	Water	UV
4 NPS	6 NPS	6.666 in ²	2.913 in	0.827 in	35-1100 psi	Water	UV

Design Name: 455/456/457/458 Group 2 NBCert # 37088

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/05/2030

Design Type

[Safety Relief Valve] 455/456/457/458 Group 2
Capacity Tests: Sec. UV at National Board Testing Lab on February 17, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.754 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS	4 NPS	4.383 in ²	2.362 in	0.866 in	35-1232 psi	Air	UV
3 NPS	4 NPS	4.383 in ²	2.362 in	0.866 in	35-1232 psi	Steam	UV
4 NPS	6 NPS	9.427 in ²	3.465 in	1.299 in	35-700 psi	Air	UV

4 NPS	6 NPS	9.427 in²	3.465 in	1.299 in	35-700 psi	Steam	UV
6 NPS	10 NPS	14.73 in²	4.331 in	1.22 in	35-575 psi	Air	UV
6 NPS	10 NPS	14.73 in²	4.331 in	1.22 in	35-575 psi	Steam	UV

Design Name: 455/456/457/458 Group 2 (Liq)				NBCert # 37099		
Manufacturer/Assembler			Designators		Expiration Date	
Manufacturer			UV		02/05/2030	
Design Type						
[Relief Valve] 455/456/457/458 Group 2 (Liq) Capacity Tests: Sec. UV at National Board Testing Lab on January 30, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.479 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}						

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS	4 NPS	4.383 in²	2.362 in	0.866 in	35-1232 psi	Water	UV
4 NPS	6 NPS	9.427 in²	3.465 in	1.299 in	35-700 psi	Water	UV
6 NPS	10 NPS	14.73 in²	4.331 in	1.22 in	35-575 psi	Water	UV

Design Name: 459/462				NBCert # 37112		
Manufacturer/Assembler			Designators		Expiration Date	
Manufacturer			UV		02/05/2030	
Design Type						
[Safety Relief Valve] 459/462 Capacity Tests: Sec. UV at National Board Testing Lab on February 17, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.811 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}						

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in²	0.236 in	0.043 in	15-13780 psi	Air	UV
0.5-1.8125 NPS	1-2 NPS	0.0438 in²	0.236 in	0.043 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in²	0.354 in	0.08 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in²	0.354 in	0.08 in	15-6175 psi	Air	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in²	0.512 in	0.118 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in²	0.512 in	0.118 in	15-2940 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in²	0.689 in	0.159 in	15-1470 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in²	0.689 in	0.159 in	15-1470 psi	Steam	UV

Design Name:	459/462 liquids	NBCert #	37101
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/05/2030

Design Type

[Relief Valve] 459/462 liquids
Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.566 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Water	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Water	UV
0.5-1.5 NPS	1-2.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Water	UV
1-2 NPS	1.5-2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Water	UV

Design Name:	483, 484, 485 (0.512 orifice)	NBCert #	37145
--------------	-------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/09/2029

Design Type

[Safety Relief Valve] 483, 484, 485 (0.512 orifice)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on January 4, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.960 SCFM/PSIA; (alternate medium): 5.500 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	1.5 NPS	0.127 in ²	0.512 in	0.079 in	15-232 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.127 in ²	0.512 in	0.079 in	15-232 psi	Steam	UV

Design Name:	483, 484, 485 (0.512 orifice) Liquids	NBCert #	37156
--------------	---------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/01/2029

Design Type

[Relief Valve] 483, 484, 485 (0.512 orifice) Liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on January 8, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.960 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	1.5 NPS	0.157 in²	0.512 in	0.098 in	15-232 psi	Water	UV
Design Name: 483, 484, 485 (0.984 orifice)NBCert #37167							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			05/14/2029	
Design Type							
[Safety Relief Valve] 483, 484, 485 (0.984 orifice) Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on February 1, 2001 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 4.960 SCFM/PSIA; (alternate medium): 13.930 PPH/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: LESER GmbH & Co. KG {LES}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2 NPS	0.427 in²	0.984 in	0.139 in	15-232 psi	Air	UV
1.5-2 NPS	2 NPS	0.427 in²	0.984 in	0.139 in	15-232 psi	Steam	UV
Design Name: 483, 484, 485 (0.984 orifice) LiquidsNBCert #37178							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			03/01/2029	
Design Type							
[Relief Valve] 483, 484, 485 (0.984 orifice) Liquids Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on May 1, 2001 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 7.460 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: LESER GmbH & Co. KG {LES}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2 NPS	0.485 in²	0.984 in	0.157 in	15-232 psi	Water	UV
Design Name: 488NBCert #37022							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			03/07/2029	
Design Type							
[Safety Relief Valve] 488 Capacity Tests: Sec. UV at National Board Testing Lab on May 31, 1990 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.721 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5 NPS	0.644 in ²	0.906 in	0.256 in	20-232 psi	Air	UV
1 NPS	1.5 NPS	0.644 in ²	0.906 in	0.256 in	20-232 psi	Steam	UV
1.5 NPS	2.5 NPS	1.667 in ²	1.457 in	0.416 in	20-232 psi	Air	UV
1.5 NPS	2.5 NPS	1.667 in ²	1.457 in	0.416 in	20-232 psi	Steam	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.512 in	20-232 psi	Air	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.512 in	20-232 psi	Steam	UV
2.5 NPS	4 NPS	4.383 in ²	2.362 in	0.674 in	20-232 psi	Air	UV
2.5 NPS	4 NPS	4.383 in ²	2.362 in	0.674 in	20-232 psi	Steam	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.832 in	20-232 psi	Air	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.832 in	20-232 psi	Steam	UV
4 NPS	6 NPS	10.3 in ²	3.622 in	1.035 in	20-232 psi	Air	UV
4 NPS	6 NPS	10.3 in ²	3.622 in	1.035 in	20-232 psi	Steam	UV

Design Name: 488 (Liquids)		NBCert # 37033	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	03/07/2029
Design Type			
[Relief Valve] 488 (Liquids) Capacity Tests: Sec. UV at National Board Testing Lab on June 1, 1990 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.472 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5 NPS	0.644 in ²	0.906 in	0.216 in	15-232 psi	Water	UV
1.5 NPS	2.5 NPS	1.667 in ²	1.457 in	0.347 in	15-232 psi	Water	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.431 in	15-232 psi	Water	UV
2.5 NPS	4 NPS	4.383 in ²	2.362 in	0.562 in	15-232 psi	Water	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.693 in	15-232 psi	Water	UV
4 NPS	6 NPS	10.3 in ²	3.622 in	0.862 in	15-232 psi	Water	UV

Design Name: 526		NBCert # 37224	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	02/05/2030

Design Type

[Safety Relief Valve] 526
 Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 22, 2001
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.801 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Air	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-2900 psi	Steam	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Air	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-2900 psi	Steam	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Steam	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Air	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Steam	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Air	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Steam	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Air	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Steam	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Air	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Steam	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Air	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Steam	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Air	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Steam	UV

Design Name: 526 (Liquids) NBCert # 37235

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/05/2030

Design Type

[Relief Valve] 526 (Liquids)
 Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on January 2, 2002
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.579 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Water	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Water	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Water	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Water	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Water	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Water	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.6698 in	15-1850 psi	Water	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Water	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Water	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Water	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.249 in	15-1038.5 psi	Water	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Water	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-914 psi	Water	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Water	UV

Design Name: 526D

NBCert # 37246

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/05/2030

Design Type

[Safety Relief Valve] 526D
 Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on March 4, 2002
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 1.990 SCFM/PSIA; (alternate medium): 5.590 PPH/PSIA
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Curtain Area
 Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-10878 psi	Air	UV

Design Name: 526D Liquids

NBCert # 37257

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/05/2030

Design Type

[Relief Valve] 526D Liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on March 4, 2002
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.110 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-10878 psi	Water	UV

Design Name: 526FB

NBCert # 37314

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

09/18/2026

Design Type

[Safety Relief Valve] 526FB
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on September 5, 2014
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - ; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 3 in	0.239 in ²	[E] 0.551 in	0.138 in	15-7758 psi	Air	UV
1.5-2 in	3 in	0.616 in ²	[G] 0.616 in	0.268 in	15-3705 psi	Air	UV
1.5 in	2, 3 in	0.394 in ²	[F] 0.709 in	0.216 in	15-9210 psi	Air	UV
1.5-2 in	3 in	0.975 in ²	[H] 1.114 in	0.323 in	15-2750 psi	Air	UV
2-3 in	3, 4 in	1.578 in ²	[J] 1.417 in	0.453 in	15-2700 psi	Air	UV
3 in	4, 6 in	2.251 in ²	[K] 1.693 in	0.531 in	15-2220 psi	Air	UV
3-4 in	4, 6 in	3.484 in ²	[L] 2.106 in	0.669 in	15-1500 psi	Air	UV
4 in	6 in	4.426 in ²	[M] 2.374 in	0.846 in	15-1100 psi	Air	UV
4 in	6 in	5.302 in ²	[N] 2.598 in	0.826 in	15-2760 psi	Air	UV
4 in	6 in	7.79 in ²	[P] 3.15 in	1.035 in	15-1000 psi	Air	UV
6 in	8 in	13.548 in ²	[Q] 4.154 in	1.248 in	15-914 psi	Air	UV
6 in	8, 10 in	19.325 in ²	[R] 4.961 in	1.496 in	15-522 psi	Air	UV
8 in	10 in	31.749 in ²	[T] 6.358 in	1.929 in	15-522 psi	Air	UV

Design Name: 526FB (Liquid)

NBCert # 37303

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

09/18/2026

Design Type

[Safety Relief Valve] 526FB (Liquid)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on April 14, 2014
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.579 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 3 in	0.239 in ²	[E] 0.551 in	0.138 in	15-7758 psi	Water	UV
1.5 in	2, 3 in	0.394 in ²	[F] 0.709 in	0.217 in	15-9210 psi	Water	UV
1.5-2 in	3 in	0.616 in ²	[G] 0.886 in	0.267 in	15-3705 psi	Water	UV
1.5-2 in	3 in	0.975 in ²	[H] 1.114 in	0.323 in	15-2750 psi	Water	UV
2-3 in	3, 4 in	1.578 in ²	[J] 1.417 in	0.453 in	15-2700 psi	Water	UV
3 in	4, 6 in	2.251 in ²	[K] 1.693 in	0.531 in	15-2220 psi	Water	UV
3-4 in	4, 6 in	3.484 in ²	[L] 2.106 in	0.669 in	15-1500 psi	Water	UV
4 in	6 in	4.426 in ²	[M] 2.374 in	0.846 in	15-1100 psi	Water	UV
4 in	6 in	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Water	UV
4 in	6 in	7.79 in ²	[P] 3.15 in	1.035 in	15-1000 psi	Water	UV
6 in	8 in	13.548 in ²	[Q] 4.154 in	1.248 in	15-914 psi	Water	UV
6 in	8,10 in	19.325 in ²	[R] 4.961 in	1.496 in	15-522 psi	Water	UV
8 in	10 in	31.749 in ²	[T] 6.358 in	1.929 in	15-522 psi	Water	UV

Design Name: 810/820 (811/814/821/824) NBCert # 37280

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	11/11/2026

Design Type

[Pilot Operated Pressure Relief Valve] 810/820 (811/814/821/824)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on October 31, 2009
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.820 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.394 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.394 in	15-740 psi	Steam	UV
1-1 NPS	2 NPS	0.147 in ²	[D] 0.433 mm	0.315 in	15-10000 psi	Air	UV
1-1 NPS	2 NPS	0.147 in ²	[D] 0.433 mm	0.315 in	15-740 psi	Steam	UV
1 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.315 in	15-10000 psi	Air	UV
1 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.315 in	15-740 psi	Steam	UV
1.5 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.394 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.394 in	15-740 psi	Steam	UV

1 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.315 in	15-10000 psi	Air	UV
1 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.315 in	15-740 psi	Steam	UV
1.5 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.394 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.394 in	15-740 psi	Steam	UV
1 NPS	2 NPS	0.644 in ²	[FB] 0.906 in	0.453 in	15-10000 psi	Air	UV
1 NPS	2 NPS	0.644 in ²	[FB] 0.906 in	0.453 in	15-740 psi	Steam	UV
1.5 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.472 in	15-10000 psi	Air	UV
1.5 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.472 in	15-740 psi	Steam	UV
2 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.591 in	15-10000 psi	Air	UV
2 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.591 in	15-740 psi	Steam	UV
1.5 NPS	2 NPS	1.024 in ²	[FB] 1.142 in	0.571 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	1.024 in ²	[FB] 1.142 in	0.571 in	15-740 psi	Steam	UV
1.5 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.472 in	15-10000 psi	Air	UV
1.5 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.472 in	15-740 psi	Steam	UV
2 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.591 in	15-10000 psi	Air	UV
2 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.591 in	15-740 psi	Steam	UV
1.5 NPS	3 NPS	1.552 in ²	[FB] 1.406 in	0.709 in	15-10000 psi	Air	UV
1.5 NPS	3 NPS	1.552 in ²	[FB] 1.406 in	0.709 in	15-740 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.758 in ²	[J] 1.496 in	0.591 in	15-10000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.758 in ²	[J] 1.496 in	0.591 in	15-740 psi	Steam	UV
3 NPS	4 NPS	2.465 in ²	[K] 1.772 in	0.866 in	15-10000 psi	Air	UV
3 NPS	4 NPS	2.465 in ²	[K] 1.772 in	0.866 in	15-740 psi	Steam	UV
2 NPS	3 NPS	2.805 in ²	[FB] 1.89 in	0.866 in	15-10000 psi	Air	UV
2 NPS	3 NPS	2.805 in ²	[FB] 1.89 in	0.866 in	15-740 psi	Steam	UV
3 NPS	4 NPS	3.818 in ²	[L] 2.205 in	0.866 in	15-10000 psi	Air	UV
3 NPS	4 NPS	3.818 in ²	[L] 2.205 in	0.866 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	3.818 in ²	[L] 2.205 in	0.787 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	3.818 in ²	[L] 2.205 in	0.787 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	4.832 in ²	[M] 2.48 in	0.787 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	4.832 in ²	[M] 2.48 in	0.787 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	5.796 in ²	[N] 2.717 in	0.787 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	5.796 in ²	[N] 2.717 in	0.787 in	15-740 psi	Steam	UV
3 NPS	4 NPS	6.848 in ²	[FB] 2.953 in	1.339 in	15-10000 psi	Air	UV
3 NPS	4 NPS	6.848 in ²	[FB] 2.953 in	1.339 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	8.386 in ²	[P] 3.268 in	1.339 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	8.386 in ²	[P] 3.268 in	1.339 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	10.987 in ²	[FB] 3.74 in	1.693 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	10.987 in ²	[FB] 3.74 in	1.693 in	15-740 psi	Steam	UV
6 NPS	8, 8 Dual NPS	14.73 in ²	[Q] 4.331 in	2.165 in	15-1500 psi	Air	UV
6 NPS	8, 8 Dual NPS	14.73 in ²	[Q] 4.331 in	2.165 in	15-740 psi	Steam	UV
6 NPS	8, 8 Dual NPS	21.534 in ²	[R] 5.236 in	2.165 in	15-1500 psi	Air	UV

6 NPS	8, 8 Dual NPS	21.534 in ²	[R] 5.236 in	2.165 in	15-740 psi	Steam	UV
6 NPS	8, 8 Dual NPS	24.547 in ²	[FB] 5.591 in	2.559 in	15-1500 psi	Air	UV
6 NPS	8, 8 Dual NPS	24.547 in ²	[FB] 5.591 in	2.559 in	15-740 psi	Steam	UV
8 NPS	10, 10 Dual NPS	34.359 in ²	[T] 6.614 in	3.15 in	15-1500 psi	Air	UV
8 NPS	10, 10 Dual NPS	34.359 in ²	[T] 6.614 in	3.15 in	15-740 psi	Steam	UV
8 NPS	10, 10 Dual NPS	39.443 in ²	[FB] 7.087 in	3.15 in	15-1500 psi	Air	UV
8 NPS	10, 10 Dual NPS	39.443 in ²	[FB] 7.087 in	3.15 in	15-740 psi	Steam	UV

Design Name: 820 (liquid) (821/824) NBCert # 37268

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 11/11/2026

Design Type

[Pilot Operated Pressure Relief Valve] 820 (liquid) (821/824)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 6, 2009
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.689 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.315 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.394 in	15-10000 psi	Water	UV
1 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.315 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.394 in	15-10000 psi	Water	UV
1 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.315 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.394 in	15-10000 psi	Water	UV
1 NPS	2 NPS	0.644 in ²	[FB] 0.906 in	0.453 in	15-10000 psi	Water	UV
1.5 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.472 in	15-10000 psi	Water	UV
2 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.591 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	1.142 in ²	[FB] 1.142 in	0.571 in	15-10000 psi	Water	UV
1.5 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.472 in	15-10000 psi	Water	UV
2 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.591 in	15-10000 psi	Water	UV
1.5 NPS	3 NPS	1.552 in ²	[FB] 1.406 in	0.709 in	15-10000 psi	Water	UV
2-3 NPS	3, 4 NPS	1.758 in ²	[J] 1.496 in	0.591 in	15-10000 psi	Water	UV
3 NPS	4 NPS	2.465 in ²	[K] 1.772 in	0.866 in	15-10000 psi	Water	UV
2 NPS	3 NPS	2.805 in ²	[FB] 1.89 in	0.866 in	15-10000 psi	Water	UV
3 NPS	4 NPS	3.818 in ²	[L] 2.205 in	0.866 in	15-10000 psi	Water	UV
4 NPS	6, 6 Dual NPS	3.818 in ²	[L] 2.205 in	0.787 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	4.832 in ²	[M] 2.48 in	0.787 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	5.796 in ²	[N] 2.717 in	0.787 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.848 in ²	[FB] 2.953 in	1.339 in	15-10000 psi	Water	UV
4 NPS	6, 6 Dual NPS	8.386 in ²	[P] 3.268 in	1.339 in	15-3750 psi	Water	UV

4 NPS	6, 6 Dual NPS	10.987 in ²	[FB] 3.74 in	1.693 in	15-3750 psi	Water	UV
6 NPS	8, 8 Dual NPS	14.73 in ²	[Q] 4.331 in	2.165 in	15-1500 psi	Water	UV
6 NPS	8, 8 Dual NPS	21.534 in ²	[R] 5.236 in	2.165 in	15-1500 psi	Water	UV
6 NPS	8, 8 Dual NPS	24.547 in ²	[FB] 5.591 in	2.559 in	15-1500 psi	Water	UV
8 NPS	10, 10 Dual NPS	34.359 in ²	[T] 6.614 in	3.15 in	15-1500 psi	Water	UV
8 NPS	10, 10 Dual NPS	39.443 in ²	[FB] 7.087 in	3.15 in	15-1500 psi	Water	UV

Design Name: 820/821/824 Air/Gas/Liquid NBCert # 37279

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/28/2031

Design Type

[Pilot Operated Pressure Relief Valve] 820/821/824 Air/Gas/Liquid
HolderDesignation:
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on November 6, 2009
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.820 Unitless; (alternate medium): 0.689 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Water/Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Initial Audible Discharge; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.315 in	15-10000 psi	Water	UV
1-1.5 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.315 in	15-10000 psi	Air	UV
1-1.5 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.315 in	15-10000 psi	Water	UV
1-1.5 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.315 in	15-10000 psi	Air	UV
1-1.5 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.315 in	15-10000 psi	Water	UV
1-1.5 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.315 in	15-10000 psi	Air	UV
1 NPS	2 NPS	0.644 in ²	[FB] 0.906 in	0.453 in	15-10000 psi	Water	UV
1 NPS	2 NPS	0.644 in ²	[FB] 0.906 in	0.453 in	15-10000 psi	Air	UV
1.5-2 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.472 in	15-10000 psi	Water	UV
1.5-2 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.472 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	1.142 in ²	[FB] 1.142 in	0.571 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	1.142 in ²	[FB] 1.142 in	0.571 in	15-10000 psi	Water	UV
1.5-2 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.472 in	15-10000 psi	Water	UV
1.5-2 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.472 in	15-10000 psi	Air	UV
1.5 NPS	3 NPS	1.552 in ²	[FB] 1.406 in	0.709 in	15-10000 psi	Water	UV
1.5 NPS	3 NPS	1.552 in ²	[FB] 1.406 in	0.709 in	15-10000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.758 in ²	[J] 1.496 in	0.591 in	15-10000 psi	Water	UV
2-3 NPS	3, 4 NPS	1.758 in ²	[J] 1.496 in	0.591 in	15-10000 psi	Air	UV
3 NPS	4 NPS	2.465 in ²	[K] 1.772 in	0.866 in	15-10000 psi	Water	UV
3 NPS	4 NPS	2.465 in ²	[K] 1.772 in	0.866 in	15-10000 psi	Air	UV
2 NPS	3 NPS	2.805 in ²	[FB] 1.89 in	0.866 in	15-10000 psi	Water	UV
2 NPS	3 NPS	2.805 in ²	[FB] 1.89 in	0.866 in	15-10000 psi	Air	UV

3-4 NPS	4, 6, 6 Dual NPS	3.818 in ²	[L] 2.205 in	0.866 in	15-10000 psi	Water	UV
3-4 NPS	4, 6, 6 Dual NPS	3.818 in ²	[L] 2.205 in	0.866 in	15-10000 psi	Air	UV
4 NPS	6, 6 Dual NPS	4.832 in ²	[M] 2.48 in	0.787 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	4.832 in ²	[M] 2.48 in	0.787 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	5.796 in ²	[N] 2.717 in	0.787 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	5.796 in ²	[N] 2.717 in	0.787 in	15-3750 psi	Air	UV
3 NPS	4 NPS	6.848 in ²	[FB] 2.953 in	1.339 in	15-10000 psi	Water	UV
3 NPS	4 NPS	6.848 in ²	[FB] 2.953 in	1.339 in	15-10000 psi	Air	UV
4 NPS	6, 6 Dual NPS	8.386 in ²	[P] 3.268 in	1.339 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	8.386 in ²	[P] 3.268 in	1.339 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	10.987 in ²	[FB] 3.74 in	1.693 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	10.987 in ²	[FB] 3.74 in	1.693 in	15-3750 psi	Air	UV
6 NPS	8, 8 Dual NPS	14.73 in ²	[Q] 4.331 in	2.165 in	15-1500 psi	Water	UV
6 NPS	8, 8 Dual NPS	14.73 in ²	[Q] 4.331 in	2.165 in	15-1500 psi	Air	UV
6 NPS	8, 8 Dual NPS	21.534 in ²	[R] 5.236 in	2.165 in	15-1500 psi	Water	UV
6 NPS	8, 8 Dual NPS	21.534 in ²	[R] 5.236 in	2.165 in	15-1500 psi	Air	UV
6 NPS	8, 8 Dual NPS	24.547 in ²	[FB] 5.591 in	2.559 in	15-1500 psi	Water	UV
6 NPS	8, 8 Dual NPS	24.547 in ²	[FB] 5.591 in	2.559 in	15-1500 psi	Air	UV
8 NPS	10, 10 Dual NPS	34.359 in ²	[T] 6.614 in	3.15 in	15-1500 psi	Water	UV
8 NPS	10, 10 Dual NPS	34.359 in ²	[T] 6.614 in	3.15 in	15-1500 psi	Air	UV
8 NPS	10, 10 Dual NPS	39.443 in ²	[FB] 7.087 in	3.15 in	15-1500 psi	Water	UV
8 NPS	10, 10 Dual NPS	39.443 in ²	[FB] 7.087 in	3.15 in	15-1500 psi	Air	UV

LESER INDIA PRIVATE LIMITED (FLV)

Nameplate Abbreviation: LESER INDIA

Maharashtra, 431 148India

This Company Manufactures or Assembles:

Design Name: 237, 237IC, 237CC		NBCert # 37325
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/21/2030
Design Type		
<p>[Safety Relief Valve] 237, 237IC, 237CC Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on August 14, 2017 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.987 SCFM/PSIA; (alternate medium): 2.773 PPH/PSIA Media - ; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: LESER GmbH & Co. KG {LES}</p>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1 NPS	0.5-1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Air	UV

0.375-1 NPS	0.5-1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Steam	UV
-------------	-----------	-----------------------	----------	----------	-------------	-------	----

Design Name: 237, 237IC, 237CC (Liquid)		NBCert # 37336
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/21/2030
Design Type		
<div>[Relief Valve] 237, 237IC, 237CC (Liquid) Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on August 14, 2017 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.591 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: LESER GmbH & Co. KG {LES}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.058 in ²	0.394 in	0.039 in	15-2610 psi	Water	UV

Design Name: 447 Air/Gas		NBCert # 37123
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	09/11/2029
Design Type		
<div>[Safety Relief Valve] 447 Air/Gas Capacity Tests: Sec. UV at National Board Testing Lab on May 5, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.617 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.644 in ²	0.905 in	0.19 in	15-240 psi	Air	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.44 in	15-240 psi	Air	UV
3 NPS	4 NPS	4.383 in ²	2.362 in	0.52 in	15-240 psi	Air	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	0.91 in	15-240 psi		UV

Design Name: 447 Liquid		NBCert #	37134
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	09/11/2029
Design Type			
[Relief Valve] 447 Liquid Capacity Tests: Sec. UV at National Board Testing Lab on May 5, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.431 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.644 in ²	0.906 in	0.19 in	15-240 psi	Water	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.44 in	15-240 psi	Water	UV
3 NPS	4 NPS	4.383 in ²	2.362 in	0.52 in	15-240 psi	Water	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	0.91 in	15-240 psi	Water	UV

Design Name: 459/462	NBCert # 37112
----------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 06/15/2027

Design Type

[Safety Relief Valve] 459/462
Capacity Tests: Sec. UV at National Board Testing Lab on February 17, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.811 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Air	UV
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Air	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Steam	UV

Design Name: 459/462 liquids	NBCert # 37101
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 06/15/2027

Design Type

[Relief Valve] 459/462 liquids
Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.566 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Water	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Water	UV

0.5-1.5 NPS	1-2.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Water	UV
1-2 NPS	1.5-2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Water	UV

Design Name: 526	NBCert # 37224
------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 06/15/2027

Design Type

[Safety Relief Valve] 526
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 22, 2001
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Air	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-2900 psi	Steam	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Air	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-2900 psi	Steam	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Steam	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Air	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Steam	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Air	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Steam	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Air	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Steam	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Air	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Steam	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Air	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Steam	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Air	UV

8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Steam	UV
-------	--------	------------------------	--------------	----------	------------	-------	----

Design Name:	526 (Liquids)	NBCert #	37235
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 06/15/2027

Design Type

[Relief Valve] 526 (Liquids)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on January 2, 2002
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.579 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Water	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Water	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Water	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Water	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Water	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Water	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.6698 in	15-1850 psi	Water	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Water	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Water	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Water	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.249 in	15-1038.5 psi	Water	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Water	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-914 psi	Water	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Water	UV

Design Name:	526D	NBCert #	37246
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 06/15/2027

Design Type

[Safety Relief Valve] 526D
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on March 4, 2002
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.990 SCFM/PSIA; (alternate medium): 5.590 PPH/PSIA
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-2900 psi	Steam	UV

1-1.5 NPS	2,3 NPS	0.121 in²	[D] 0.551 in	0.0551 in	15-10878 psi	Air	UV
Design Name: 526D Liquids							
NBCert #				37257			
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			06/15/2027	
Design Type							
[Relief Valve] 526D Liquids Capacity Tests: Sec. UV at Leser GmbH & Co., KG on March 4, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.110 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: LESER GmbH & Co. KG {LES}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-10878 psi	Water	UV

Design Name: 810/820 (811/814/821/824)		NBCert #	37280
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	06/08/2028
Design Type			
[Pilot Operated Pressure Relief Valve] 810/820 (811/814/821/824) Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on October 31, 2009 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.820 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.394 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.394 in	15-740 psi	Steam	UV
1-1 NPS	2 NPS	0.147 in ²	[D] 0.433 mm	0.315 in	15-10000 psi	Air	UV
1-1 NPS	2 NPS	0.147 in ²	[D] 0.433 mm	0.315 in	15-740 psi	Steam	UV
1 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.315 in	15-10000 psi	Air	UV
1 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.315 in	15-740 psi	Steam	UV
1.5 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.394 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.394 in	15-740 psi	Steam	UV
1 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.315 in	15-10000 psi	Air	UV
1 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.315 in	15-740 psi	Steam	UV
1.5 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.394 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.394 in	15-740 psi	Steam	UV
1 NPS	2 NPS	0.644 in ²	[FB] 0.906 in	0.453 in	15-10000 psi	Air	UV
1 NPS	2 NPS	0.644 in ²	[FB] 0.906 in	0.453 in	15-740 psi	Steam	UV

1.5 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.472 in	15-10000 psi	Air	UV
1.5 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.472 in	15-740 psi	Steam	UV
2 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.591 in	15-10000 psi	Air	UV
2 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.591 in	15-740 psi	Steam	UV
1.5 NPS	2 NPS	1.024 in ²	[FB] 1.142 in	0.571 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	1.024 in ²	[FB] 1.142 in	0.571 in	15-740 psi	Steam	UV
1.5 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.472 in	15-10000 psi	Air	UV
1.5 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.472 in	15-740 psi	Steam	UV
2 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.591 in	15-10000 psi	Air	UV
2 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.591 in	15-740 psi	Steam	UV
1.5 NPS	3 NPS	1.552 in ²	[FB] 1.406 in	0.709 in	15-10000 psi	Air	UV
1.5 NPS	3 NPS	1.552 in ²	[FB] 1.406 in	0.709 in	15-740 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.758 in ²	[J] 1.496 in	0.591 in	15-10000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.758 in ²	[J] 1.496 in	0.591 in	15-740 psi	Steam	UV
3 NPS	4 NPS	2.465 in ²	[K] 1.772 in	0.866 in	15-10000 psi	Air	UV
3 NPS	4 NPS	2.465 in ²	[K] 1.772 in	0.866 in	15-740 psi	Steam	UV
2 NPS	3 NPS	2.805 in ²	[FB] 1.89 in	0.866 in	15-10000 psi	Air	UV
2 NPS	3 NPS	2.805 in ²	[FB] 1.89 in	0.866 in	15-740 psi	Steam	UV
3 NPS	4 NPS	3.818 in ²	[L] 2.205 in	0.866 in	15-10000 psi	Air	UV
3 NPS	4 NPS	3.818 in ²	[L] 2.205 in	0.866 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	3.818 in ²	[L] 2.205 in	0.787 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	3.818 in ²	[L] 2.205 in	0.787 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	4.832 in ²	[M] 2.48 in	0.787 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	4.832 in ²	[M] 2.48 in	0.787 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	5.796 in ²	[N] 2.717 in	0.787 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	5.796 in ²	[N] 2.717 in	0.787 in	15-740 psi	Steam	UV
3 NPS	4 NPS	6.848 in ²	[FB] 2.953 in	1.339 in	15-10000 psi	Air	UV
3 NPS	4 NPS	6.848 in ²	[FB] 2.953 in	1.339 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	8.386 in ²	[P] 3.268 in	1.339 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	8.386 in ²	[P] 3.268 in	1.339 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	10.987 in ²	[FB] 3.74 in	1.693 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	10.987 in ²	[FB] 3.74 in	1.693 in	15-740 psi	Steam	UV
6 NPS	8, 8 Dual NPS	14.73 in ²	[Q] 4.331 in	2.165 in	15-1500 psi	Air	UV
6 NPS	8, 8 Dual NPS	14.73 in ²	[Q] 4.331 in	2.165 in	15-740 psi	Steam	UV
6 NPS	8, 8 Dual NPS	21.534 in ²	[R] 5.236 in	2.165 in	15-1500 psi	Air	UV
6 NPS	8, 8 Dual NPS	21.534 in ²	[R] 5.236 in	2.165 in	15-740 psi	Steam	UV
6 NPS	8, 8 Dual NPS	24.547 in ²	[FB] 5.591 in	2.559 in	15-1500 psi	Air	UV
6 NPS	8, 8 Dual NPS	24.547 in ²	[FB] 5.591 in	2.559 in	15-740 psi	Steam	UV
8 NPS	10, 10 Dual NPS	34.359 in ²	[T] 6.614 in	3.15 in	15-1500 psi	Air	UV
8 NPS	10, 10 Dual NPS	34.359 in ²	[T] 6.614 in	3.15 in	15-740 psi	Steam	UV
8 NPS	10, 10 Dual NPS	39.443 in ²	[FB] 7.087 in	3.15 in	15-1500 psi	Air	UV

8 NPS	10, 10 Dual NPS	39.443 in ²	[FB] 7.087 in	3.15 in	15-740 psi	Steam	UV
-------	-----------------	------------------------	---------------	---------	------------	-------	----

Design Name: 820 (liquid) (821/824)				NBCert # 37268			
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			06/08/2028	
Design Type							
[Pilot Operated Pressure Relief Valve] 820 (liquid) (821/824) Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 6, 2009 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.689 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.147 in²	[D] 0.433 in	0.315 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.147 in²	[D] 0.433 in	0.394 in	15-10000 psi	Water	UV
1 NPS	2 NPS	0.263 in²	[E] 0.579 in	0.315 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.263 in²	[E] 0.579 in	0.394 in	15-10000 psi	Water	UV
1 NPS	2 NPS	0.412 in²	[F] 0.724 in	0.315 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.412 in²	[F] 0.724 in	0.394 in	15-10000 psi	Water	UV
1 NPS	2 NPS	0.644 in²	[FB] 0.906 in	0.453 in	15-10000 psi	Water	UV
1.5 NPS	3 NPS	0.678 in²	[G] 0.929 in	0.472 in	15-10000 psi	Water	UV
2 NPS	3 NPS	0.678 in²	[G] 0.929 in	0.591 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	1.142 in²	[FB] 1.142 in	0.571 in	15-10000 psi	Water	UV
1.5 NPS	3 NPS	1.052 in²	[H] 1.157 in	0.472 in	15-10000 psi	Water	UV
2 NPS	3 NPS	1.052 in²	[H] 1.157 in	0.591 in	15-10000 psi	Water	UV
1.5 NPS	3 NPS	1.552 in²	[FB] 1.406 in	0.709 in	15-10000 psi	Water	UV
2-3 NPS	3, 4 NPS	1.758 in²	[J] 1.496 in	0.591 in	15-10000 psi	Water	UV
3 NPS	4 NPS	2.465 in²	[K] 1.772 in	0.866 in	15-10000 psi	Water	UV
2 NPS	3 NPS	2.805 in²	[FB] 1.89 in	0.866 in	15-10000 psi	Water	UV
3 NPS	4 NPS	3.818 in²	[L] 2.205 in	0.866 in	15-10000 psi	Water	UV
4 NPS	6, 6 Dual NPS	3.818 in²	[L] 2.205 in	0.787 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	4.832 in²	[M] 2.48 in	0.787 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	5.796 in²	[N] 2.717 in	0.787 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.848 in²	[FB] 2.953 in	1.339 in	15-10000 psi	Water	UV
4 NPS	6, 6 Dual NPS	8.386 in²	[P] 3.268 in	1.339 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	10.987 in²	[FB] 3.74 in	1.693 in	15-3750 psi	Water	UV
6 NPS	8, 8 Dual NPS	14.73 in²	[Q] 4.331 in	2.165 in	15-1500 psi	Water	UV
6 NPS	8, 8 Dual NPS	21.534 in²	[R] 5.236 in	2.165 in	15-1500 psi	Water	UV
6 NPS	8, 8 Dual NPS	24.547 in²	[FB] 5.591 in	2.559 in	15-1500 psi	Water	UV
8 NPS	10, 10 Dual NPS	34.359 in²	[T] 6.614 in	3.15 in	15-1500 psi	Water	UV
8 NPS	10, 10 Dual NPS	39.443 in²	[FB] 7.087 in	3.15 in	15-1500 psi	Water	UV

LESER LLC (LSR)

Nameplate Abbreviation: LESER LLC

Charlotte, NC 28273United States

This Company Manufactures or Assembles:

Design Name:	437	NBCert #	37213
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/12/2030

Design Type

[Safety Relief Valve] 437
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on November 8, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.020 SCFM/PSIA; (alternate medium): 2.870 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Air	UV
0.375-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Steam	UV

Design Name:	437 (Liquids)	NBCert #	37189
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/12/2030

Design Type

[Relief Valve] 437 (Liquids)
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on November 22, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.540 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Water	UV

Design Name:	438 Sub Types 481, 439	NBCert #	37190
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/05/2030

Design Type

[Safety Relief Valve] 438 Sub Types 481, 439
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 12, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.904 SCFM/PSIA; (alternate medium): 2.530 PPH/PSIA
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1 NPS	0.5 - 1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Air	UV
0.375-1 NPS	0.5 - 1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Steam	UV

Design Name: 438 Sub Types 481, 439, Liquids NBCert # 37202

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/12/2030

Design Type

[Safety Relief Valve] 438 Sub Types 481, 439, Liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 23, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.490 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Water	UV

Design Name: 441/442/444 NBCert # 37044

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/12/2030

Design Type

[Safety Relief Valve] 441/442/444
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on February 17, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.699 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Air	UV
1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Steam	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Air	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Steam	UV
1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Air	UV

1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Steam	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Air	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Steam	UV
2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Air	UV
2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Steam	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Air	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Steam	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Air	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Steam	UV
5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Air	UV
5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Steam	UV
6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Air	UV
6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Steam	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Air	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Steam	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Air	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Steam	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Air	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Steam	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Air	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Steam	UV

Design Name: 441/442/444 liquids NBCert # 37055

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/12/2030

Design Type

[Relief Valve] 441/442/444 liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on September 6, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.521 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Water	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Water	UV
1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Water	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Water	UV
2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Water	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Water	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Water	UV
5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Water	UV

6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Water	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Water	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Water	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Water	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Water	UV

Design Name: 447 Air/Gas

NBCert # 37123

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

07/12/2030

Design Type

[Safety Relief Valve] 447 Air/Gas
Capacity Tests: Sec. UV at National Board Testing Lab on May 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.617 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.644 in ²	0.905 in	0.19 in	15-240 psi	Air	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.44 in	15-240 psi	Air	UV
3 NPS	4 NPS	4.383 in ²	2.362 in	0.52 in	15-240 psi	Air	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	0.91 in	15-240 psi		UV

Design Name: 447 Liquid

NBCert # 37134

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

07/12/2030

Design Type

[Relief Valve] 447 Liquid
Capacity Tests: Sec. UV at National Board Testing Lab on May 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.431 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.644 in ²	0.906 in	0.19 in	15-240 psi	Water	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.44 in	15-240 psi	Water	UV
3 NPS	4 NPS	4.383 in ²	2.362 in	0.52 in	15-240 psi	Water	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	0.91 in	15-240 psi	Water	UV

Design Name: 459/462		NBCert # 37112
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/12/2030
Design Type		
[Safety Relief Valve] 459/462 Capacity Tests: Sec. UV at National Board Testing Lab on February 17, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.811 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Air	UV
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Air	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Steam	UV

Design Name: 459/462 liquids		NBCert # 37101
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/12/2030
Design Type		
[Relief Valve] 459/462 liquids Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.566 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Water	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Water	UV
0.5-1.5 NPS	1-2.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Water	UV
1-2 NPS	1.5-2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Water	UV

Design Name:	483, 484, 485 (0.512 orifice)	NBCert #	37145
--------------	-------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/06/2030

Design Type

[Safety Relief Valve] 483, 484, 485 (0.512 orifice)
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on January 4, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.960 SCFM/PSIA; (alternate medium): 5.500 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	1.5 NPS	0.127 in ²	0.512 in	0.079 in	15-232 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.127 in ²	0.512 in	0.079 in	15-232 psi	Steam	UV

Design Name:	483, 484, 485 (0.512 orifice) Liquids	NBCert #	37156
--------------	---------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/12/2030

Design Type

[Relief Valve] 483, 484, 485 (0.512 orifice) Liquids
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on January 8, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.960 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	1.5 NPS	0.157 in ²	0.512 in	0.098 in	15-232 psi	Water	UV

Design Name:	483, 484, 485 (0.984 orifice)	NBCert #	37167
--------------	-------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/12/2030

Design Type

[Safety Relief Valve] 483, 484, 485 (0.984 orifice)
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on February 1, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 4.960 SCFM/PSIA; (alternate medium): 13.930 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2 NPS	0.427 in ²	0.984 in	0.139 in	15-232 psi	Air	UV

1.5-2 NPS	2 NPS	0.427 in ²	0.984 in	0.139 in	15-232 psi	Steam	UV
-----------	-------	-----------------------	----------	----------	------------	-------	----

Design Name:	483, 484, 485 (0.984 orifice) Liquids	NBCert #	37178
--------------	---------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/12/2030

Design Type

[Relief Valve] 483, 484, 485 (0.984 orifice) Liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on May 1, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 7.460 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2 NPS	0.485 in ²	0.984 in	0.157 in	15-232 psi	Water	UV

Design Name:	488	NBCert #	37022
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/12/2030

Design Type

[Safety Relief Valve] 488
Capacity Tests: Sec. UV at National Board Testing Lab on May 31, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.721 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5 NPS	0.644 in ²	0.906 in	0.256 in	20-232 psi	Air	UV
1 NPS	1.5 NPS	0.644 in ²	0.906 in	0.256 in	20-232 psi	Steam	UV
1.5 NPS	2.5 NPS	1.667 in ²	1.457 in	0.416 in	20-232 psi	Air	UV
1.5 NPS	2.5 NPS	1.667 in ²	1.457 in	0.416 in	20-232 psi	Steam	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.512 in	20-232 psi	Air	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.512 in	20-232 psi	Steam	UV
2.5 NPS	4 NPS	4.383 in ²	2.362 in	0.674 in	20-232 psi	Air	UV
2.5 NPS	4 NPS	4.383 in ²	2.362 in	0.674 in	20-232 psi	Steam	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.832 in	20-232 psi	Air	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.832 in	20-232 psi	Steam	UV
4 NPS	6 NPS	10.3 in ²	3.622 in	1.035 in	20-232 psi	Air	UV
4 NPS	6 NPS	10.3 in ²	3.622 in	1.035 in	20-232 psi	Steam	UV

Design Name:	488 (Liquids)	NBCert #	37033
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/12/2030

Design Type
[Relief Valve] 488 (Liquids) Capacity Tests: Sec. UV at National Board Testing Lab on June 1, 1990 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.472 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5 NPS	0.644 in ²	0.906 in	0.216 in	15-232 psi	Water	UV
1.5 NPS	2.5 NPS	1.667 in ²	1.457 in	0.347 in	15-232 psi	Water	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.431 in	15-232 psi	Water	UV
2.5 NPS	4 NPS	4.383 in ²	2.362 in	0.562 in	15-232 psi	Water	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.693 in	15-232 psi	Water	UV
4 NPS	6 NPS	10.3 in ²	3.622 in	0.862 in	15-232 psi	Water	UV

Design Name:	526	NBCert #	37224
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/12/2030

Design Type
[Safety Relief Valve] 526 Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 22, 2001 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.801 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Air	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-2900 psi	Steam	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Air	UV

3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-2900 psi	Steam	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Steam	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Air	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Steam	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Air	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Steam	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Air	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Steam	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Air	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Steam	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Air	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Steam	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Air	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Steam	UV

Design Name: 526 (Liquids) NBCert # 37235

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/12/2030

Design Type

[Relief Valve] 526 (Liquids)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on January 2, 2002
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.579 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Water	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Water	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Water	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Water	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Water	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Water	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Water	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Water	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Water	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Water	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.249 in	15-1038.5 psi	Water	UV

6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Water	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-914 psi	Water	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Water	UV

Design Name: 526D NBCert # 37246

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/30/2030

Design Type

[Safety Relief Valve] 526D
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on March 4, 2002
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.990 SCFM/PSIA; (alternate medium): 5.590 PPH/PSIA
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-10878 psi	Air	UV

Design Name: 526D Liquids NBCert # 37257

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/12/2030

Design Type

[Relief Valve] 526D Liquids
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on March 4, 2002
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.110 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-10878 psi	Water	UV

Design Name: 810/820 (811/814/821/824) NBCert # 37280

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/06/2027

Design Type

[Pilot Operated Pressure Relief Valve] 810/820 (811/814/821/824)
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on October 31, 2009
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.820 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.394 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.394 in	15-740 psi	Steam	UV
1-1 NPS	2 NPS	0.147 in ²	[D] 0.433 mm	0.315 in	15-10000 psi	Air	UV
1-1 NPS	2 NPS	0.147 in ²	[D] 0.433 mm	0.315 in	15-740 psi	Steam	UV
1 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.315 in	15-10000 psi	Air	UV
1 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.315 in	15-740 psi	Steam	UV
1.5 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.394 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.394 in	15-740 psi	Steam	UV
1 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.315 in	15-10000 psi	Air	UV
1 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.315 in	15-740 psi	Steam	UV
1.5 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.394 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.394 in	15-740 psi	Steam	UV
1 NPS	2 NPS	0.644 in ²	[FB] 0.906 in	0.453 in	15-10000 psi	Air	UV
1 NPS	2 NPS	0.644 in ²	[FB] 0.906 in	0.453 in	15-740 psi	Steam	UV
1.5 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.472 in	15-10000 psi	Air	UV
1.5 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.472 in	15-740 psi	Steam	UV
2 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.591 in	15-10000 psi	Air	UV
2 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.591 in	15-740 psi	Steam	UV
1.5 NPS	2 NPS	1.024 in ²	[FB] 1.142 in	0.571 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	1.024 in ²	[FB] 1.142 in	0.571 in	15-740 psi	Steam	UV
1.5 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.472 in	15-10000 psi	Air	UV
1.5 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.472 in	15-740 psi	Steam	UV
2 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.591 in	15-10000 psi	Air	UV
2 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.591 in	15-740 psi	Steam	UV
1.5 NPS	3 NPS	1.552 in ²	[FB] 1.406 in	0.709 in	15-10000 psi	Air	UV
1.5 NPS	3 NPS	1.552 in ²	[FB] 1.406 in	0.709 in	15-740 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.758 in ²	[J] 1.496 in	0.591 in	15-10000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.758 in ²	[J] 1.496 in	0.591 in	15-740 psi	Steam	UV
3 NPS	4 NPS	2.465 in ²	[K] 1.772 in	0.866 in	15-10000 psi	Air	UV
3 NPS	4 NPS	2.465 in ²	[K] 1.772 in	0.866 in	15-740 psi	Steam	UV
2 NPS	3 NPS	2.805 in ²	[FB] 1.89 in	0.866 in	15-10000 psi	Air	UV
2 NPS	3 NPS	2.805 in ²	[FB] 1.89 in	0.866 in	15-740 psi	Steam	UV
3 NPS	4 NPS	3.818 in ²	[L] 2.205 in	0.866 in	15-10000 psi	Air	UV
3 NPS	4 NPS	3.818 in ²	[L] 2.205 in	0.866 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	3.818 in ²	[L] 2.205 in	0.787 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	3.818 in ²	[L] 2.205 in	0.787 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	4.832 in ²	[M] 2.48 in	0.787 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	4.832 in ²	[M] 2.48 in	0.787 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	5.796 in ²	[N] 2.717 in	0.787 in	15-3750 psi	Air	UV

4 NPS	6, 6 Dual NPS	5.796 in ²	[N] 2.717 in	0.787 in	15-740 psi	Steam	UV
3 NPS	4 NPS	6.848 in ²	[FB] 2.953 in	1.339 in	15-10000 psi	Air	UV
3 NPS	4 NPS	6.848 in ²	[FB] 2.953 in	1.339 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	8.386 in ²	[P] 3.268 in	1.339 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	8.386 in ²	[P] 3.268 in	1.339 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	10.987 in ²	[FB] 3.74 in	1.693 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	10.987 in ²	[FB] 3.74 in	1.693 in	15-740 psi	Steam	UV
6 NPS	8, 8 Dual NPS	14.73 in ²	[Q] 4.331 in	2.165 in	15-1500 psi	Air	UV
6 NPS	8, 8 Dual NPS	14.73 in ²	[Q] 4.331 in	2.165 in	15-740 psi	Steam	UV
6 NPS	8, 8 Dual NPS	21.534 in ²	[R] 5.236 in	2.165 in	15-1500 psi	Air	UV
6 NPS	8, 8 Dual NPS	21.534 in ²	[R] 5.236 in	2.165 in	15-740 psi	Steam	UV
6 NPS	8, 8 Dual NPS	24.547 in ²	[FB] 5.591 in	2.559 in	15-1500 psi	Air	UV
6 NPS	8, 8 Dual NPS	24.547 in ²	[FB] 5.591 in	2.559 in	15-740 psi	Steam	UV
8 NPS	10, 10 Dual NPS	34.359 in ²	[T] 6.614 in	3.15 in	15-1500 psi	Air	UV
8 NPS	10, 10 Dual NPS	34.359 in ²	[T] 6.614 in	3.15 in	15-740 psi	Steam	UV
8 NPS	10, 10 Dual NPS	39.443 in ²	[FB] 7.087 in	3.15 in	15-1500 psi	Air	UV
8 NPS	10, 10 Dual NPS	39.443 in ²	[FB] 7.087 in	3.15 in	15-740 psi	Steam	UV

Design Name: 820 (liquid) (821/824)

NBCert #

37268

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

04/29/2027

Design Type

[Pilot Operated Pressure Relief Valve] 820 (liquid) (821/824)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 6, 2009
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.689 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.315 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.394 in	15-10000 psi	Water	UV
1 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.315 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.394 in	15-10000 psi	Water	UV
1 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.315 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.394 in	15-10000 psi	Water	UV
1 NPS	2 NPS	0.644 in ²	[FB] 0.906 in	0.453 in	15-10000 psi	Water	UV
1.5 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.472 in	15-10000 psi	Water	UV
2 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.591 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	1.142 in ²	[FB] 1.142 in	0.571 in	15-10000 psi	Water	UV
1.5 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.472 in	15-10000 psi	Water	UV
2 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.591 in	15-10000 psi	Water	UV

1.5 NPS	3 NPS	1.552 in ²	[FB] 1.406 in	0.709 in	15-10000 psi	Water	UV
2-3 NPS	3, 4 NPS	1.758 in ²	[J] 1.496 in	0.591 in	15-10000 psi	Water	UV
3 NPS	4 NPS	2.465 in ²	[K] 1.772 in	0.866 in	15-10000 psi	Water	UV
2 NPS	3 NPS	2.805 in ²	[FB] 1.89 in	0.866 in	15-10000 psi	Water	UV
3 NPS	4 NPS	3.818 in ²	[L] 2.205 in	0.866 in	15-10000 psi	Water	UV
4 NPS	6, 6 Dual NPS	3.818 in ²	[L] 2.205 in	0.787 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	4.832 in ²	[M] 2.48 in	0.787 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	5.796 in ²	[N] 2.717 in	0.787 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.848 in ²	[FB] 2.953 in	1.339 in	15-10000 psi	Water	UV
4 NPS	6, 6 Dual NPS	8.386 in ²	[P] 3.268 in	1.339 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	10.987 in ²	[FB] 3.74 in	1.693 in	15-3750 psi	Water	UV
6 NPS	8, 8 Dual NPS	14.73 in ²	[Q] 4.331 in	2.165 in	15-1500 psi	Water	UV
6 NPS	8, 8 Dual NPS	21.534 in ²	[R] 5.236 in	2.165 in	15-1500 psi	Water	UV
6 NPS	8, 8 Dual NPS	24.547 in ²	[FB] 5.591 in	2.559 in	15-1500 psi	Water	UV
8 NPS	10, 10 Dual NPS	34.359 in ²	[T] 6.614 in	3.15 in	15-1500 psi	Water	UV
8 NPS	10, 10 Dual NPS	39.443 in ²	[FB] 7.087 in	3.15 in	15-1500 psi	Water	UV

LESER Valvulas de Seguranca Ltda. (PLB)

Nameplate Abbreviation: LESER BR

Rio de Janeiro, CEP 22713-460Brazil

This Company Manufactures or Assembles:

Design Name: 437		NBCert # 37213
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/12/2030
Design Type		
<p>[Safety Relief Valve] 437 Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on November 8, 2001 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.020 SCFM/PSIA; (alternate medium): 2.870 PPH/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: LESER GmbH & Co. KG {LES}</p>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Air	UV
0.375-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Steam	UV

Design Name: 437 (Liquids)		NBCert # 37189	
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	11/13/2030	

Design Type

[Relief Valve] 437 (Liquids)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 22, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.540 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Water	UV

Design Name: 438 Sub Types 481, 439 NBCert # 37190

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 11/12/2030

Design Type

[Safety Relief Valve] 438 Sub Types 481, 439
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 12, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.904 SCFM/PSIA; (alternate medium): 2.530 PPH/PSIA
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1 NPS	0.5 - 1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Air	UV
0.375-1 NPS	0.5 - 1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Steam	UV

Design Name: 438 Sub Types 481, 439, Liquids NBCert # 37202

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 11/13/2030

Design Type

[Safety Relief Valve] 438 Sub Types 481, 439, Liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 23, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.490 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Water	UV

Design Name: 441/442/444 NBCert # 37044

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 11/13/2030

Design Type

[Safety Relief Valve] 441/442/444
 Capacity Tests: Sec. UV at Leser GmbH & Co., KG on February 17, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.699 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Air	UV
1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Steam	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Air	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Steam	UV
1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Air	UV
1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Steam	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Air	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Steam	UV
2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Air	UV
2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Steam	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Air	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Steam	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Air	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Steam	UV
5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Air	UV
5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Steam	UV
6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Air	UV
6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Steam	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Air	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Steam	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Air	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Steam	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Air	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Steam	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Air	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Steam	UV

Design Name: 441/442/444 liquids NBCert # 37055

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/13/2030

Design Type

[Relief Valve] 441/442/444 liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on September 6, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.521 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Water	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Water	UV
1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Water	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Water	UV
2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Water	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Water	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Water	UV
5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Water	UV
6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Water	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Water	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Water	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Water	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Water	UV

Design Name: 459/462

NBCert # 37112

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/13/2030

Design Type

[Safety Relief Valve] 459/462
Capacity Tests: Sec. UV at National Board Testing Lab on February 17, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.811 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Air	UV
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Air	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Air	UV

1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Steam	UV
---------	-------------	-----------------------	----------	----------	-------------	-------	----

Design Name:	459/462 liquids	NBCert #	37101
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/13/2030

Design Type

[Relief Valve] 459/462 liquids
Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.566 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Water	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Water	UV
0.5-1.5 NPS	1-2.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Water	UV
1-2 NPS	1.5-2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Water	UV

Design Name:	526	NBCert #	37224
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/12/2030

Design Type

[Safety Relief Valve] 526
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 22, 2001
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Air	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-2900 psi	Steam	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Air	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-2900 psi	Steam	UV

3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Steam	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Air	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Steam	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Air	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Steam	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Air	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Steam	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Air	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Steam	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Air	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Steam	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Air	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Steam	UV

Design Name: 526 (Liquids)

NBCert #

37235

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/12/2030

Design Type

[Relief Valve] 526 (Liquids)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on January 2, 2002
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.579 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Water	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Water	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Water	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Water	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Water	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Water	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Water	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Water	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Water	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Water	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.249 in	15-1038.5 psi	Water	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Water	UV

6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-914 psi	Water	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Water	UV

Design Name:	526D	NBCert #	37246
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/12/2030

Design Type
[Safety Relief Valve] 526D Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on March 4, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.990 SCFM/PSIA; (alternate medium): 5.590 PPH/PSIA Media - ; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Adjustable Flow Area Configuration: Curtain Area Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-10878 psi	Air	UV

Design Name:	526D Liquids	NBCert #	37257
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/12/2030

Design Type
[Relief Valve] 526D Liquids Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on March 4, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.110 GPM/SQ. RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-10878 psi	Water	UV

Design Name:	810/820 (811/814/821/824)	NBCert #	37280
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/13/2027

Design Type
[Pilot Operated Pressure Relief Valve] 810/820 (811/814/821/824) Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on October 31, 2009 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.820 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.394 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.394 in	15-740 psi	Steam	UV
1-1 NPS	2 NPS	0.147 in ²	[D] 0.433 mm	0.315 in	15-10000 psi	Air	UV
1-1 NPS	2 NPS	0.147 in ²	[D] 0.433 mm	0.315 in	15-740 psi	Steam	UV
1 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.315 in	15-10000 psi	Air	UV
1 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.315 in	15-740 psi	Steam	UV
1.5 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.394 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.394 in	15-740 psi	Steam	UV
1 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.315 in	15-10000 psi	Air	UV
1 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.315 in	15-740 psi	Steam	UV
1.5 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.394 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.394 in	15-740 psi	Steam	UV
1 NPS	2 NPS	0.644 in ²	[FB] 0.906 in	0.453 in	15-10000 psi	Air	UV
1 NPS	2 NPS	0.644 in ²	[FB] 0.906 in	0.453 in	15-740 psi	Steam	UV
1.5 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.472 in	15-10000 psi	Air	UV
1.5 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.472 in	15-740 psi	Steam	UV
2 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.591 in	15-10000 psi	Air	UV
2 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.591 in	15-740 psi	Steam	UV
1.5 NPS	2 NPS	1.024 in ²	[FB] 1.142 in	0.571 in	15-10000 psi	Air	UV
1.5 NPS	2 NPS	1.024 in ²	[FB] 1.142 in	0.571 in	15-740 psi	Steam	UV
1.5 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.472 in	15-10000 psi	Air	UV
1.5 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.472 in	15-740 psi	Steam	UV
2 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.591 in	15-10000 psi	Air	UV
2 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.591 in	15-740 psi	Steam	UV
1.5 NPS	3 NPS	1.552 in ²	[FB] 1.406 in	0.709 in	15-10000 psi	Air	UV
1.5 NPS	3 NPS	1.552 in ²	[FB] 1.406 in	0.709 in	15-740 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.758 in ²	[J] 1.496 in	0.591 in	15-10000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.758 in ²	[J] 1.496 in	0.591 in	15-740 psi	Steam	UV
3 NPS	4 NPS	2.465 in ²	[K] 1.772 in	0.866 in	15-10000 psi	Air	UV
3 NPS	4 NPS	2.465 in ²	[K] 1.772 in	0.866 in	15-740 psi	Steam	UV
2 NPS	3 NPS	2.805 in ²	[FB] 1.89 in	0.866 in	15-10000 psi	Air	UV
2 NPS	3 NPS	2.805 in ²	[FB] 1.89 in	0.866 in	15-740 psi	Steam	UV
3 NPS	4 NPS	3.818 in ²	[L] 2.205 in	0.866 in	15-10000 psi	Air	UV
3 NPS	4 NPS	3.818 in ²	[L] 2.205 in	0.866 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	3.818 in ²	[L] 2.205 in	0.787 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	3.818 in ²	[L] 2.205 in	0.787 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	4.832 in ²	[M] 2.48 in	0.787 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	4.832 in ²	[M] 2.48 in	0.787 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	5.796 in ²	[N] 2.717 in	0.787 in	15-3750 psi	Air	UV

4 NPS	6, 6 Dual NPS	5.796 in ²	[N] 2.717 in	0.787 in	15-740 psi	Steam	UV
3 NPS	4 NPS	6.848 in ²	[FB] 2.953 in	1.339 in	15-10000 psi	Air	UV
3 NPS	4 NPS	6.848 in ²	[FB] 2.953 in	1.339 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	8.386 in ²	[P] 3.268 in	1.339 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	8.386 in ²	[P] 3.268 in	1.339 in	15-740 psi	Steam	UV
4 NPS	6, 6 Dual NPS	10.987 in ²	[FB] 3.74 in	1.693 in	15-3750 psi	Air	UV
4 NPS	6, 6 Dual NPS	10.987 in ²	[FB] 3.74 in	1.693 in	15-740 psi	Steam	UV
6 NPS	8, 8 Dual NPS	14.73 in ²	[Q] 4.331 in	2.165 in	15-1500 psi	Air	UV
6 NPS	8, 8 Dual NPS	14.73 in ²	[Q] 4.331 in	2.165 in	15-740 psi	Steam	UV
6 NPS	8, 8 Dual NPS	21.534 in ²	[R] 5.236 in	2.165 in	15-1500 psi	Air	UV
6 NPS	8, 8 Dual NPS	21.534 in ²	[R] 5.236 in	2.165 in	15-740 psi	Steam	UV
6 NPS	8, 8 Dual NPS	24.547 in ²	[FB] 5.591 in	2.559 in	15-1500 psi	Air	UV
6 NPS	8, 8 Dual NPS	24.547 in ²	[FB] 5.591 in	2.559 in	15-740 psi	Steam	UV
8 NPS	10, 10 Dual NPS	34.359 in ²	[T] 6.614 in	3.15 in	15-1500 psi	Air	UV
8 NPS	10, 10 Dual NPS	34.359 in ²	[T] 6.614 in	3.15 in	15-740 psi	Steam	UV
8 NPS	10, 10 Dual NPS	39.443 in ²	[FB] 7.087 in	3.15 in	15-1500 psi	Air	UV
8 NPS	10, 10 Dual NPS	39.443 in ²	[FB] 7.087 in	3.15 in	15-740 psi	Steam	UV

Design Name: 820 (liquid) (821/824)

NBCert #

37268

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

12/13/2027

Design Type

[Pilot Operated Pressure Relief Valve] 820 (liquid) (821/824)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 6, 2009
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.689 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.315 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.147 in ²	[D] 0.433 in	0.394 in	15-10000 psi	Water	UV
1 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.315 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.263 in ²	[E] 0.579 in	0.394 in	15-10000 psi	Water	UV
1 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.315 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	0.412 in ²	[F] 0.724 in	0.394 in	15-10000 psi	Water	UV
1 NPS	2 NPS	0.644 in ²	[FB] 0.906 in	0.453 in	15-10000 psi	Water	UV
1.5 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.472 in	15-10000 psi	Water	UV
2 NPS	3 NPS	0.678 in ²	[G] 0.929 in	0.591 in	15-10000 psi	Water	UV
1.5 NPS	2 NPS	1.142 in ²	[FB] 1.142 in	0.571 in	15-10000 psi	Water	UV
1.5 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.472 in	15-10000 psi	Water	UV
2 NPS	3 NPS	1.052 in ²	[H] 1.157 in	0.591 in	15-10000 psi	Water	UV

1.5 NPS	3 NPS	1.552 in ²	[FB] 1.406 in	0.709 in	15-10000 psi	Water	UV
2-3 NPS	3, 4 NPS	1.758 in ²	[J] 1.496 in	0.591 in	15-10000 psi	Water	UV
3 NPS	4 NPS	2.465 in ²	[K] 1.772 in	0.866 in	15-10000 psi	Water	UV
2 NPS	3 NPS	2.805 in ²	[FB] 1.89 in	0.866 in	15-10000 psi	Water	UV
3 NPS	4 NPS	3.818 in ²	[L] 2.205 in	0.866 in	15-10000 psi	Water	UV
4 NPS	6, 6 Dual NPS	3.818 in ²	[L] 2.205 in	0.787 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	4.832 in ²	[M] 2.48 in	0.787 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	5.796 in ²	[N] 2.717 in	0.787 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.848 in ²	[FB] 2.953 in	1.339 in	15-10000 psi	Water	UV
4 NPS	6, 6 Dual NPS	8.386 in ²	[P] 3.268 in	1.339 in	15-3750 psi	Water	UV
4 NPS	6, 6 Dual NPS	10.987 in ²	[FB] 3.74 in	1.693 in	15-3750 psi	Water	UV
6 NPS	8, 8 Dual NPS	14.73 in ²	[Q] 4.331 in	2.165 in	15-1500 psi	Water	UV
6 NPS	8, 8 Dual NPS	21.534 in ²	[R] 5.236 in	2.165 in	15-1500 psi	Water	UV
6 NPS	8, 8 Dual NPS	24.547 in ²	[FB] 5.591 in	2.559 in	15-1500 psi	Water	UV
8 NPS	10, 10 Dual NPS	34.359 in ²	[T] 6.614 in	3.15 in	15-1500 psi	Water	UV
8 NPS	10, 10 Dual NPS	39.443 in ²	[FB] 7.087 in	3.15 in	15-1500 psi	Water	UV

LORCH Sicherheitsventile GmbH & Co. KG, Member of Herose Group (LRH)

Nameplate Abbreviation: Lorch

Filderstadt, 70794Germany

This Company Manufactures or Assembles:

Design Name: 2108		NBCert # 00730	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	05/31/2029
Design Type			
[Safety Relief Valve] 2108 Capacity Tests: Sec. UV at National Board Testing Lab on December 8, 2016 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.911 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: LORCH Sicherheitsventile GmbH & Co. KG, Member of Herose Group {LRH}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.5 NPS		42.7 mm ²	8 mm	1.7 mm	15-681 psi	Air	UV

Design Name: 2110		NBCert # 00752	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	05/31/2029

Design Type

[Safety Relief Valve] 2110
Capacity Tests: Sec. UV at National Board Testing Lab on September 18, 2015
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.415 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LORCH Sicherheitsventile GmbH & Co. KG, Member of Herose Group {LRH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-0.75 NPS		62.8 mm ²	10 mm	2 mm	25-609 psi	Air	UV

Design Name:	2115	NBCert #	00707
--------------	------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

05/31/2029

Design Type

[Safety Relief Valve] 2115
Capacity Tests: Sec. UV at National Board Testing Lab on December 8, 2016
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 4.163 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LORCH Sicherheitsventile GmbH & Co. KG, Member of Herose Group {LRH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS		176.7 mm ²	15 mm	4.8 mm	20-435 psi	Air	UV

Design Name:	2120	NBCert #	00729
--------------	------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

05/02/2029

Design Type

[Safety Relief Valve] 2120
Capacity Tests: Sec. UV at National Board Testing Lab on September 18, 2015
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 7.330 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LORCH Sicherheitsventile GmbH & Co. KG, Member of Herose Group {LRH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.25 NPS		314.2 mm ²	20 mm	6.7 mm	19-435 psi	Air	UV

Design Name:	2125	NBCert #	00718
--------------	------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

05/02/2029

Design Type

[Safety Relief Valve] 2125
Capacity Tests: Sec. UV at National Board Testing Lab on December 9, 2016
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 8.456 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LORCH Sicherheitsventile GmbH & Co. KG, Member of Herose Group {LRH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS		490.9 mm ²	25 mm	8.7 mm	15-435 psi	Air	UV

Design Name:	2207	NBCert #	00774
--------------	------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

05/31/2029

Design Type

[Safety Relief Valve] 2207
Capacity Tests: Sec. UV at National Board Testing Lab on September 18, 2015
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.727 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LORCH Sicherheitsventile GmbH & Co. KG, Member of Herose Group {LRH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.5 NPS	1/4-3/4 NPS	38.5 mm ²	7 mm	2.3 mm	30-435 psi	Air	UV

Design Name:	2212	NBCert #	00785
--------------	------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

05/31/2029

Design Type

[Safety Relief Valve] 2212
Capacity Tests: Sec. UV at National Board Testing Lab on December 9, 2016
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.018 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LORCH Sicherheitsventile GmbH & Co. KG, Member of Herose Group {LRH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-0.5 NPS	1/2-3/4 NPS	113.1 mm ²	12 mm	3.5 mm	35-635 psi	Air	UV

Design Name:	2215	NBCert #	00796
--------------	------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

05/02/2029

Design Type

[Safety Relief Valve] 2215
Capacity Tests: Sec. UV at National Board Testing Lab on December 9, 2016
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.214 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LORCH Sicherheitsventile GmbH & Co. KG, Member of Herose Group {LRH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	3/4-1 1/4 NPS	176.7 mm ²	15 mm	3.5 mm	35-435 psi	Air	UV

Luofu Valve Group Co., Ltd (LVG)

Zhejiang, 325105People's Republic of China

This Company Manufactures or Assembles:

Design Name: LF Series

NBCert # 23050

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

08/15/2028

Design Type

[Safety Relief Valve] LF Series
Capacity Tests: Sec. UV at National Board Testing Lab on May 7, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Luofu Valve Group Co., Ltd {LVG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.134 in ²	[D] 0.4134 in	0.124 in	43.5-6000 psi	Air	UV
1-1.5 NPS	2-3 NPS	0.187 in ²	[.488] 0.488 in	0.151 in	43.5-6000 psi	Air	UV
1-1.5 NPS	2-3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	43.5-6000 psi	Air	UV
1-1.5 NPS	2-3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	43.5-6000 psi	Air	UV
1.5-2 NPS	2.5,3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	43.5-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	43.5-6000 psi	Air	UV
2-3 NPS	3,4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	43.5-6000 psi	Air	UV
3-3 NPS	4,6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	43.5-6000 psi	Air	UV
4-4 NPS	6 NPS	2.714 in ²	[1.859] 1.895 in	0.601 in	43.5-3000 psi	Air	UV
3-4 NPS	4,6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	43.5-5000 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	43.5-5000 psi	Air	UV
4-4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	43.5-3000 psi	Air	UV
4-4 NPS	6 NPS	5.444 in ²	[2.633] 2.633 in	0.85 in	43.5-2250 psi	Air	UV
4-4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	43.5-3000 psi	Air	UV

6-6 NPS	8 NPS	11.045 in ²	[3.75] 3.75 in	1.243 in	43.5-3750 psi	Air	UV
6-6 NPS	8 NPS	12.174 in ²	[3.937] 3.937 in	1.243 in	43.5-2250 psi	Air	UV
6-6 NPS	10 NPS	12.236 in ²	[3.947] 3.947 in	1.496 in	43.5-2250 psi	Air	UV
6-6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	43.5-3000 psi	Air	UV
6-6 NPS	8 NPS	15.288 in ²	[4.412] 4.412 in	1.414 in	43.5-2250 psi	Air	UV
6-6 NPS	8,10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	43.5-1480 psi	Air	UV
8-8 NPS	10 NPS	18.254 in ²	[4.821] 4.821 in	1.907 in	43.5-2250 psi	Air	UV
8-8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	43.5-740 psi	Air	UV
8-8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	43.5-740 psi	Air	UV
10 NPS	14 NPS	43.943 in ²	[V] 7.48 in	2.244 in	43.5-285 psi	Air	UV
12 NPS	16 NPS	61.626 in ²	[W] 8.858 in	2.658 in	43.5-285 psi	Air	UV
14 NPS	18 NPS	82.291 in ²	[Y] 10.236 in	3.071 in	43.5-145 psi	Air	UV
16 NPS	18 NPS	95.448 in ²	[Z] 11.024 in	3.307 in	43.5-145 psi	Air	UV
16 NPS	20 NPS	109.56 in ²	[Z1] 11.811 in	3.543 in	43.5-145 psi	Air	UV
18 NPS	24 NPS	140.73 in ²	[AA] 13.386 in	4.016 in	43.5-145 psi	Air	UV
20 NPS	24 NPS	166.66 in ²	[BB] 14.567 in	4.37 in	43.5-145 psi	Air	UV

Design Name: LFXD-0601C

NBCert # 23072

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/19/2030

Design Type

[Pilot Operated Pressure Relief Valve] LFXD-0601C
Capacity Tests: Sec. UV at National Board Testing Lab on August 3, 2023
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:7554.0 SCFM
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Luofu Valve Group Co., Ltd {LVG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	3 NPS	1.449 in ²	1.358 in	0.34 in	290-290 psi	Air	UV

Mec - Tric Control Company (MCT)

Nameplate Abbreviation: MCC

Charlotte, NC 28205United States

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S

NBCert # 57057

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/30/2029

Design Type

[Safety Relief Valve] 2600 & 2600S

Capacity Tests: Sec. UV at unknown lab on June 11, 1972

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable (Single Ring)

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV

12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name:	2600L (Liquids)	NBCert #	57068
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/05/2026

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/30/2029

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/14/2029

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 4200 / 4400	NBCert # 57282
--------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	V	03/30/2029
-----------	---	------------

Design Type

[Safety Valve] 4200 / 4400
Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.872 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

MEC Cryo, LLC. (LSH)

Nameplate Abbreviation: MEC

Tampa, FL 33605 United States

This Company Manufactures or Assembles:

Design Name: ME910		NBCert # 47067
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/05/2030
Design Type		
[Pilot Operated Pressure Relief Valve] ME910 HolderDesignation: Capacity Tests: Sec. UV at National Board Testing Lab on June 6, 2023 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:140.70 SCFM/PSIA; (alternate medium): 0.000 ; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: MEC Cryo, LLC. {LSH}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 NPS	4 NPS	14.94 in ²	4.38 in	2 in	250-265 psi	Air	UV

Design Name: MEV250		NBCert # 47045
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/04/2030
Design Type		
[Safety Relief Valve] MEV250 Capacity Tests: Sec. UV at National Board Testing Lab on December 15, 2022 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:31.200 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: MEC Cryo, LLC. {LSH}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2.5 NPS		2.112 in ²	1.64 in	0.44 in	303-358 psi	Air	UV

Design Name: MEV300		NBCert # 47056
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/03/2029
Design Type		
[Safety Relief Valve] MEV300 Capacity Tests: Sec. UV at National Board Testing Lab on November 21, 2022 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:26.230 SCFM/PSIA; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: MEC Cryo, LLC. {LSH}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS		2.492 in ²	1.85 in		300-350 psi	Air	UV

Design Name: RXSO and RXSO-S		NBCert # 47001
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/04/2027

Design Type

[Safety Relief Valve] RXSO and RXSO-S
Capacity Tests: Sec. UV at Louisiana State University on April 17, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.604 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: MEC Cryo, LLC. {LSH}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.059 in ²	0.75 in	0.025 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75, 1 NPS	0.118 in ²	0.75 in	0.05 in	15-400 psi	Air	UV
0.5-1 NPS	1, 1.25 NPS	0.204 in ²	1 in	0.065 in	15-400 psi	Air	UV
0.75-1.25 NPS	1.25, 1.5 NPS	0.326 in ²	1.25 in	0.083 in	15-400 psi	Air	UV
1-1.5 NPS	1.5, 2 NPS	0.424 in ²	1.5 in	0.09 in	15-400 psi	Air	UV
1.25-2 NPS	2, 2.5 NPS	0.628 in ²	2 in	0.1 in	15-400 psi	Air	UV
2.5 NPS	3 NPS	0.864 in ²	2.5 in	0.11 in	15-400 psi	Air	UV
3 NPS	3, 4 NPS	1.131 in ²	3 in	0.12 in	15-400 psi	Air	UV

Mecklenburg Valve Source, LLC (MCK)

Nameplate Abbreviation: Mecklenburg Valve

Charlotte, NC 28205United States

This Company Manufactures or Assembles:

Design Name: Kunkle 264, 265, 266 & 267		NBCert # 36267
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/20/2029

Design Type

[Safety Relief Valve] Kunkle 264, 265, 266 & 267
Capacity Tests: Sec. UV at unknown lab on July 20, 1956
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.766 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.115 in	15-2000 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.115 in	15-3300 psi	Air	UV

Design Name: Kunkle 300,600	NBCert # 36076
-----------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 04/19/2029

Design Type

[Safety Valve] Kunkle 300,600
Capacity Tests: Sec. UV, V at unknown lab on February 10, 1961
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	UV
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	V
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	V
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Air	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	V
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Air	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	V
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Air	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	V
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	V
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Air	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	V

6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	UV
-------	-------	------------------------	-------------	----------	------------	-------	----

Design Name:	Kunkle 337	NBCert #	36278
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/20/2029

Design Type

[Safety Relief Valve] Kunkle 337
Capacity Tests: Sec. UV at unknown lab on February 22, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	1.916 in ²	1.562 in	0.612 in	15-60 psi	Air	UV
2.5 NPS	2.5 NPS	2.786 in ²	1.883 in	0.755 in	15-60 psi	Air	UV
3 NPS	3 NPS	4.037 in ²	2.267 in	0.91 in	15-60 psi	Air	UV

Design Name:	Kunkle 6000, 6252 Series	NBCert #	36324
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 04/19/2029

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV

1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 910 to 919

NBCert #

36100

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

04/20/2029

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV

0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name:	Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)	NBCert #	36111
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	04/19/2029	

Design Type
[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 , 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

Mercer Valve Co., Inc. (MCO)

Mercer, WI 54547United States

This Company Manufactures or Assembles:

Design Name:	81-100000 Series	NBCert #	38001
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	06/14/2030	

Design Type

[Safety Relief Valve] 81-100000 Series
Capacity Tests: Sec. UV at unknown lab on November 21, 1984
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.100 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 - 2 NPS	0.212 in ²	0.52 in	0.19 in	15-3500 psi	Air	UV

Design Name: 81-200000 Series NBCert # 38023

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 06/14/2030

Design Type

[Safety Relief Valve] 81-200000 Series
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on February 25, 1985
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 7.210 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2 NPS	0.472 in ²	0.775 in	0.3 in	15-2500 psi	Air	UV

Design Name: 9100 NBCert # 38056

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 06/14/2030

Design Type

[Safety Relief Valve] 9100
Capacity Tests: Sec. UV at National Board Testing Lab on July 19, 1991
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.818 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.062 in ²	[C] 0.281 in	0.11 in	15-10000 psi	Air	UV
0.5-1.5 NPS	1 - 2 NPS	0.122 in ²	[D] 0.394 in	0.17 in	15-7500 psi	Air	UV
0.75-2 NPS	1 - 3 NPS	0.212 in ²	[E] 0.52 in	0.19 in	15-6000 psi	Air	UV
1-2 NPS	1-1/2 - 3 NPS	0.337 in ²	[F] 0.655 in	0.27 in	15-5000 psi	Air	UV
1.5-3 NPS	2 - 3 NPS	0.472 in ²	[G] 0.775 in	0.3 in	15-4000 psi	Air	UV
1.5-3 NPS	2 - 3 NPS	0.865 in ²	[H] 1.05 in	0.41 in	15-2750 psi	Air	UV

2-3 NPS	2-1/2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.58 in	15-2700 psi	Air	UV
2-3 NPS	3-4 NPS	1.622 in ²	[JO] 1.437 in	0.6 in	15-1800 psi	Air	UV
3-4 NPS	3,4,6 NPS	2.074 in ²	[K] 1.625 in	0.65 in	15-2200 psi	Air	UV
3-4 NPS	4, 6 NPS	3.205 in ²	[L] 2.02 in	0.8 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.08 in ²	[M] 2.28 in	0.9 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.909 in ²	[N] 2.5 in	0.985 in	15-740 psi	Air	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.2 in	15-525 psi	Air	UV

Mercer Valve Co., Inc. (MRB)

Bridgeport, TX 76426United States

This Company Manufactures or Assembles:

Design Name:	81-100000 Series	NBCert #	38001
--------------	------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/07/2026

Design Type

[Safety Relief Valve] 81-100000 Series
Capacity Tests: Sec. UV at unknown lab on November 21, 1984
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.100 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 - 2 NPS	0.212 in ²	0.52 in	0.19 in	15-3500 psi	Air	UV

Design Name:	81-200000 Series	NBCert #	38023
--------------	------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/07/2026

Design Type

[Safety Relief Valve] 81-200000 Series
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on February 25, 1985
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 7.210 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2 NPS	0.472 in ²	0.775 in	0.3 in	15-2500 psi	Air	UV

Design Name:	9100	NBCert #	38056
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/27/2026

Design Type

[Safety Relief Valve] 9100
Capacity Tests: Sec. UV at National Board Testing Lab on July 19, 1991
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.818 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.062 in ²	[C] 0.281 in	0.11 in	15-10000 psi	Air	UV
0.5-1.5 NPS	1 - 2 NPS	0.122 in ²	[D] 0.394 in	0.17 in	15-7500 psi	Air	UV
0.75-2 NPS	1 - 3 NPS	0.212 in ²	[E] 0.52 in	0.19 in	15-6000 psi	Air	UV
1-2 NPS	1-1/2 - 3 NPS	0.337 in ²	[F] 0.655 in	0.27 in	15-5000 psi	Air	UV
1.5-3 NPS	2 - 3 NPS	0.472 in ²	[G] 0.775 in	0.3 in	15-4000 psi	Air	UV
1.5-3 NPS	2 - 3 NPS	0.865 in ²	[H] 1.05 in	0.41 in	15-2750 psi	Air	UV
2-3 NPS	2-1/2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.58 in	15-2700 psi	Air	UV
2-3 NPS	3-4 NPS	1.622 in ²	[JO] 1.437 in	0.6 in	15-1800 psi	Air	UV
3-4 NPS	3,4,6 NPS	2.074 in ²	[K] 1.625 in	0.65 in	15-2200 psi	Air	UV
3-4 NPS	4, 6 NPS	3.205 in ²	[L] 2.02 in	0.8 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.08 in ²	[M] 2.28 in	0.9 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.909 in ²	[N] 2.5 in	0.985 in	15-740 psi	Air	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.2 in	15-525 psi	Air	UV

Mercer Valve Co., Inc. (MVC)

Oklahoma City, OK 73127United States

This Company Manufactures or Assembles:

Design Name:	1400 Series	NBCert #	38113
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/07/2026

Design Type

[Safety Relief Valve] 1400 Series
Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 2015
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.291 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5-1 NPS	0.02 in²		0.06 in	150-10000 psi	Air	UV
Design Name: 81-100000 Series			NBCert #		38001		
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			02/21/2030	
Design Type							
[Safety Relief Valve] 81-100000 Series Capacity Tests: Sec. UV at unknown lab on November 21, 1984 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.100 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mercer Valve Co., Inc. {MVC}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 - 2 NPS	0.212 in²	0.52 in	0.19 in	15-3500 psi	Air	UV
Design Name: 81-100000L Liquids			NBCert #		38012		
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			12/13/2029	
Design Type							
[Relief Valve] 81-100000L Liquids Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on July 20, 1990 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.150 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mercer Valve Co., Inc. {MVC}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.212 in²	0.52 in	0.19 in	15-3000 psi	Water	UV
Design Name: 81-200000 Series			NBCert #		38023		
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			12/13/2029	
Design Type							
[Safety Relief Valve] 81-200000 Series Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on February 25, 1985 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 7.210 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mercer Valve Co., Inc. {MVC}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2 NPS	0.472 in²	0.775 in	0.3 in	15-2500 psi	Air	UV
Design Name: 81-200000L Liquids			NBCert #		38034		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		07/13/2026		
Design Type							
[Relief Valve] 81-200000L Liquids Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on August 21, 1990 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:12.770 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mercer Valve Co., Inc. {MVC}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2 NPS	0.472 in²	0.775 in	0.3 in	30-4000 psi	Water	UV
Design Name: 8500 Series			NBCert #		38102		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		12/13/2029		
Design Type							
[Safety Relief Valve] 8500 Series Capacity Tests: Sec. UV at National Board Testing Lab on February 12, 2013 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.370 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mercer Valve Co., Inc. {MVC}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-2 NPS	1, 2 NPS	0.212 in²	0.52 in	0.24 in	15-2400 psi	Air	UV
Design Name: 87-110000 Series			NBCert #		38045		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		07/13/2026		
Design Type							
[Safety Relief Valve] 87-110000 Series Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on August 30, 1985 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.910 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mercer Valve Co., Inc. {MVC}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.122 in²	0.394 in	0.18 in	15-6000 psi	Air	UV
Design Name: 9100		NBCert #		38056			
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			07/13/2026	
Design Type							
[Safety Relief Valve] 9100 Capacity Tests: Sec. UV at National Board Testing Lab on July 19, 1991 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.818 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mercer Valve Co., Inc. {MVC}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.062 in ²	[C] 0.281 in	0.11 in	15-10000 psi	Air	UV
0.5-1.5 NPS	1 - 2 NPS	0.122 in ²	[D] 0.394 in	0.17 in	15-7500 psi	Air	UV
0.75-2 NPS	1 - 3 NPS	0.212 in ²	[E] 0.52 in	0.19 in	15-6000 psi	Air	UV
1-2 NPS	1-1/2 - 3 NPS	0.337 in ²	[F] 0.655 in	0.27 in	15-5000 psi	Air	UV
1.5-3 NPS	2 - 3 NPS	0.472 in ²	[G] 0.775 in	0.3 in	15-4000 psi	Air	UV
1.5-3 NPS	2 - 3 NPS	0.865 in ²	[H] 1.05 in	0.41 in	15-2750 psi	Air	UV
2-3 NPS	2-1/2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.58 in	15-2700 psi	Air	UV
2-3 NPS	3-4 NPS	1.622 in ²	[JO] 1.437 in	0.6 in	15-1800 psi	Air	UV
3-4 NPS	3,4,6 NPS	2.074 in ²	[K] 1.625 in	0.65 in	15-2200 psi	Air	UV
3-4 NPS	4, 6 NPS	3.205 in ²	[L] 2.02 in	0.8 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.08 in ²	[M] 2.28 in	0.9 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.909 in ²	[N] 2.5 in	0.985 in	15-740 psi	Air	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.2 in	15-525 psi	Air	UV

Design Name: 9100L (Liquids)			NBCert # 38067	
Manufacturer/Assembler		Designators		Expiration Date
Manufacturer		UV		07/13/2026
Design Type				

[Relief Valve] 9100L (Liquids)
 Capacity Tests: Sec. UV at National Board Testing Lab on June 9, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.707 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.062 in ²	[C] 0.281 in	0.11 in	15-10000 psi	Water	UV
0.5-1 NPS	1 - 2 NPS	0.122 in ²	[D] 0.394 in	0.17 in	15-6500 psi	Water	UV
0.75-2 NPS	1 - 2 NPS	0.212 in ²	[E] 0.52 in	0.25 in	15-3500 psi	Water	UV
1-2 NPS	1.5 - 2.5 NPS	0.337 in ²	[F] 0.655 in	0.32 in	15-5000 psi	Water	UV
1.5-3 NPS	2 - 3 NPS	0.472 in ²	[G] 0.775 in	0.35 in	15-4000 psi	Water	UV
1.5-3 NPS	2 - 3 NPS	0.865 in ²	[H] 1.05 in	0.52 in	15-2750 psi	Water	UV
2-4 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.62 in	15-2700 psi	Water	UV
2-3 NPS	3-4 NPS	1.622 in ²	[JO] 1.437 in	0.64 in	15-1800 psi	Water	UV
3-4 NPS	3, 4 NPS	2.074 in ²	[K] 1.625 in	0.76 in	15-2220 psi	Water	UV
3-4 NPS	4, 6 NPS	3.205 in ²	[L] 2.02 in	0.82 in	15-2000 psi	Water	UV
4-4 NPS	6 NPS	4.08 in ²	[M] 2.28 in	0.95 in	15-2000 psi	Water	UV
4 NPS	6 NPS	4.909 in ²	[N] 2.5 in	0.985 in	15-740 psi	Water	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.2 in	15-525 psi	Water	UV

Design Name:	9500 (Full Port), S, M, E Pilots	NBCert #	38089
--------------	----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/21/2030

Design Type

[Pilot Operated Pressure Relief Valve] 9500 (Full Port), S, M, E Pilots
Capacity Tests: Sec. UV at National Board Testing Lab on July 18, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.820 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2,3 NPS	1.767 in ²	1.5 in	0.65 in	15-6170 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	1.939 in	0.85 in	15-3705 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	2.9 in	1.25 in	15-3700 psi	Air	UV
4 NPS	6 NPS	11.491 in ²	3.825 in	1.675 in	15-1530 psi	Air	UV
6 NPS	8 NPS	26.067 in ²	5.761 in	2.531 in	15-1480 psi	Air	UV
8 NPS	10 NPS	45.664 in ²	7.625 in	3.35 in	15-1480 psi	Air	UV

Design Name:	9500 L Series	NBCert #	38090
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/14/2030

Design Type

[Pilot Operated Pressure Relief Valve] 9500 L Series
 Capacity Tests: Sec. UV at National Board Testing Lab on December 14, 2006
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.731 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.371 in ²	[f] 0.687 in	0.325 in	15-6170 psi	Water	UV
1.5 NPS	3 NPS	0.866 in ²	[h] 1.05 in	0.485 in	15-6170 psi	Water	UV
2 NPS	3 NPS	1.431 in ²	[J] 1.35 in	0.625 in	15-6170 psi	Water	UV
3 NPS	4 NPS	3.205 in ²	[L] 2.02 in	0.92 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.083 in ²	[M] 2.28 in	1.05 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.38 in	15-3750 psi	Water	UV
6 NPS	8 NPS	17.721 in ²	[R] 4.75 in	2.185 in	15-1480 psi	Water	UV
8 NPS	10 NPS	25.967 in ²	[T] 5.75 in	2.625 in	15-1480 psi	Water	UV

Design Name: 9500, S, M, E Pilots

NBCert # 38078

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/02/2030

Design Type

[Pilot Operated Pressure Relief Valve] 9500, S, M, E Pilots
 Capacity Tests: Sec. UV at National Board Testing Lab on July 9, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.870 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.151 in ²	[D] 0.439 in	0.2 in	15-6170 psi	Air	UV
1-1.5 NPS	2 NPS	0.223 in ²	[E] 0.533 in	0.25 in	15-6170 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.325 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.559 in ²	[G] 0.844 in	0.39 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.866 in ²	[H] 1.05 in	0.485 in	15-6170 psi	Air	UV
2-3 NPS	3,4 NPS	1.431 in ²	[J] 1.35 in	0.625 in	15-6170 psi	Air	UV
3 NPS	4 NPS	2.074 in ²	[K] 1.625 in	0.75 in	15-3705 psi	Air	UV
3-4 NPS	4,6 NPS	3.205 in ²	[L] 2.02 in	0.92 in	15-3705 psi	Air	UV
4 NPS	6 NPS	4.083 in ²	[M] 2.28 in	1.05 in	15-3705 psi	Air	UV
4 NPS	6 NPS	4.909 in ²	[N] 2.5 in	1.15 in	15-3705 psi	Air	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.38 in	15-3705 psi	Air	UV
6 NPS	8 NPS	12.566 in ²	[Q] 4 in	1.84 in	15-1480 psi	Air	UV
6 NPS	8 NPS	17.721 in ²	[R] 4.75 in	2.185 in	15-1480 psi	Air	UV

Mercer Valve Co., Inc. (MVV)Nameplate Abbreviation: MVC
HOUSTON DIVISION

Houston, TX 77087United States

This Company Manufactures or Assembles:

Design Name:	81-100000 Series	NBCert #	38001
--------------	------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

AssemblerUV11/20/2028

Design Type

[Safety Relief Valve] 81-100000 Series
Capacity Tests: Sec. UV at unknown lab on November 21, 1984
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.100 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 - 2 NPS	0.212 in²	0.52 in	0.19 in	15-3500 psi	Air	UV

Design Name:	81-200000 Series	NBCert #	38023
--------------	------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

AssemblerUV11/20/2028

Design Type

[Safety Relief Valve] 81-200000 Series
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on February 25, 1985
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 7.210 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	2 NPS	0.472 in²	0.775 in	0.3 in	15-2500 psi	Air	UV

Design Name:	9100	NBCert #	38056
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

AssemblerUV11/20/2028

Design Type

[Safety Relief Valve] 9100
Capacity Tests: Sec. UV at National Board Testing Lab on July 19, 1991
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.818 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.062 in ²	[C] 0.281 in	0.11 in	15-10000 psi	Air	UV
0.5-1.5 NPS	1 - 2 NPS	0.122 in ²	[D] 0.394 in	0.17 in	15-7500 psi	Air	UV
0.75-2 NPS	1 - 3 NPS	0.212 in ²	[E] 0.52 in	0.19 in	15-6000 psi	Air	UV
1-2 NPS	1-1/2 - 3 NPS	0.337 in ²	[F] 0.655 in	0.27 in	15-5000 psi	Air	UV
1.5-3 NPS	2 - 3 NPS	0.472 in ²	[G] 0.775 in	0.3 in	15-4000 psi	Air	UV
1.5-3 NPS	2 - 3 NPS	0.865 in ²	[H] 1.05 in	0.41 in	15-2750 psi	Air	UV
2-3 NPS	2-1/2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.58 in	15-2700 psi	Air	UV
2-3 NPS	3-4 NPS	1.622 in ²	[JO] 1.437 in	0.6 in	15-1800 psi	Air	UV
3-4 NPS	3,4,6 NPS	2.074 in ²	[K] 1.625 in	0.65 in	15-2200 psi	Air	UV
3-4 NPS	4, 6 NPS	3.205 in ²	[L] 2.02 in	0.8 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.08 in ²	[M] 2.28 in	0.9 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.909 in ²	[N] 2.5 in	0.985 in	15-740 psi	Air	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.2 in	15-525 psi	Air	UV

Design Name: 9100L (Liquids) NBCert # 38067

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/20/2028

Design Type

[Relief Valve] 9100L (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on June 9, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.707 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.062 in ²	[C] 0.281 in	0.11 in	15-10000 psi	Water	UV
0.5-1 NPS	1 - 2 NPS	0.122 in ²	[D] 0.394 in	0.17 in	15-6500 psi	Water	UV
0.75-2 NPS	1 - 2 NPS	0.212 in ²	[E] 0.52 in	0.25 in	15-3500 psi	Water	UV
1-2 NPS	1.5 - 2.5 NPS	0.337 in ²	[F] 0.655 in	0.32 in	15-5000 psi	Water	UV
1.5-3 NPS	2 - 3 NPS	0.472 in ²	[G] 0.775 in	0.35 in	15-4000 psi	Water	UV
1.5-3 NPS	2 - 3 NPS	0.865 in ²	[H] 1.05 in	0.52 in	15-2750 psi	Water	UV
2-4 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.62 in	15-2700 psi	Water	UV
2-3 NPS	3-4 NPS	1.622 in ²	[JO] 1.437 in	0.64 in	15-1800 psi	Water	UV

3-4 NPS	3, 4 NPS	2.074 in ²	[K] 1.625 in	0.76 in	15-2220 psi	Water	UV
3-4 NPS	4, 6 NPS	3.205 in ²	[L] 2.02 in	0.82 in	15-2000 psi	Water	UV
4-4 NPS	6 NPS	4.08 in ²	[M] 2.28 in	0.95 in	15-2000 psi	Water	UV
4 NPS	6 NPS	4.909 in ²	[N] 2.5 in	0.985 in	15-740 psi	Water	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.2 in	15-525 psi	Water	UV

Design Name: 9500 (Full Port), S, M, E Pilots

NBCert #

38089

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

06/03/2029

Design Type

[Pilot Operated Pressure Relief Valve] 9500 (Full Port), S, M, E Pilots
Capacity Tests: Sec. UV at National Board Testing Lab on July 18, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.820 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2,3 NPS	1.767 in ²	1.5 in	0.65 in	15-6170 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	1.939 in	0.85 in	15-3705 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	2.9 in	1.25 in	15-3700 psi	Air	UV
4 NPS	6 NPS	11.491 in ²	3.825 in	1.675 in	15-1530 psi	Air	UV
6 NPS	8 NPS	26.067 in ²	5.761 in	2.531 in	15-1480 psi	Air	UV
8 NPS	10 NPS	45.664 in ²	7.625 in	3.35 in	15-1480 psi	Air	UV

Design Name: 9500, S, M, E Pilots

NBCert #

38078

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

06/03/2029

Design Type

[Pilot Operated Pressure Relief Valve] 9500, S, M, E Pilots
Capacity Tests: Sec. UV at National Board Testing Lab on July 9, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.151 in ²	[D] 0.439 in	0.2 in	15-6170 psi	Air	UV
1-1.5 NPS	2 NPS	0.223 in ²	[E] 0.533 in	0.25 in	15-6170 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.325 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.559 in ²	[G] 0.844 in	0.39 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.866 in ²	[H] 1.05 in	0.485 in	15-6170 psi	Air	UV

2-3 NPS	3,4 NPS	1.431 in ²	[J] 1.35 in	0.625 in	15-6170 psi	Air	UV
3 NPS	4 NPS	2.074 in ²	[K] 1.625 in	0.75 in	15-3705 psi	Air	UV
3-4 NPS	4,6 NPS	3.205 in ²	[L] 2.02 in	0.92 in	15-3705 psi	Air	UV
4 NPS	6 NPS	4.083 in ²	[M] 2.28 in	1.05 in	15-3705 psi	Air	UV
4 NPS	6 NPS	4.909 in ²	[N] 2.5 in	1.15 in	15-3705 psi	Air	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.38 in	15-3705 psi	Air	UV
6 NPS	8 NPS	12.566 in ²	[Q] 4 in	1.84 in	15-1480 psi	Air	UV
6 NPS	8 NPS	17.721 in ²	[R] 4.75 in	2.185 in	15-1480 psi	Air	UV
8 NPS	10 NPS	25.967 in ²	[T] 5.75 in	2.625 in	15-1480 psi	Air	UV

Mercury Manufacturing Company (MMC)	Nameplate Abbreviation: MMC
--	-----------------------------

Wyandotte, MI 48192United States

This Company Manufactures or Assembles:

Design Name:	MMC00014, MMC00016	NBCert #	78049
--------------	--------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	02/06/2031
--------------	----	------------

Design Type

[Safety Relief Valve] MMC00014, MMC00016
Capacity Tests: Sec. UV at National Board Testing Lab on February 18, 2009
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:414.00 SCFM
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Mercury Manufacturing Company {MMC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	.875 NPS	0.0573 in ²	0.27 in	0.067 in	462.5-0 psi	Air	UV

Design Name:	MMC00346	NBCert #	78061
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	05/06/2026
--------------	----	------------

Design Type

[Safety Relief Valve] MMC00346
Capacity Tests: Sec. UV at National Board Testing Lab on January 15, 2013
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:2359.0 SCFM
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Bubble
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercury Manufacturing Company {MMC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.875 NPS	1.625 top NPS	0.357 in²	0.675 in	0.168 in	450 psi	Air	UV
Design Name:			MMC00521, MMC00522		NBCert #	78296	
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			09/12/2029	
Design Type							
[Safety Relief Valve] MMC00521, MMC00522 Capacity Tests: Sec. UV at National Board Testing Lab on July 10, 2017 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.638 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mercury Manufacturing Company {MMC}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
24 mm		0.101 in²	0.36 in	0.09 in	1305-1960 psi	Air	UV
Design Name:			MMC014XX		NBCert #	78083	
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			06/07/2031	
Design Type							
[Safety Relief Valve] MMC014XX Capacity Tests: Sec. UV at National Board Testing Lab on April 12, 2013 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.708 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mercury Manufacturing Company {MMC}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.044 in²	0.237 in		960-2150 psi	Air	UV
Design Name:			MMC-0270		NBCert #	78027	
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			05/12/2029	
Design Type							
[Safety Relief Valve] MMC-0270 Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on November 29, 2005 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:558.00 SCFM Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Mercury Manufacturing Company {MMC}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	Top NPS	0.113 in²	0.38 in	0.095 in	350-350 psi	Air	UV
Design Name: MMC-0453-X							
NBCert # 78016							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			02/07/2031	
Design Type							
[Safety Relief Valve] MMC-0453-X Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on October 5, 2004 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:1226.0 SCFM Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mercury Manufacturing Company {MMC}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.625 NPS		0.204 in²	0.51 in	0.128 in	400-400 psi	Air	UV
Mersen USA ACE Corp. (COA)							
Salem, VA 24153United States							
This Company Manufactures or Assembles:							
Design Name: Series 3							
NBCert # 90111							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			01/23/2027	
Design Type							
[Rupture Disk Device] Series 3 HolderDesignation: N/A Capacity Tests: Sec. UD at National Board Testing Lab on May 19, 1999 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 0.600 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Mersen USA ACE Corp. {COA}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.78 in²			50-400 psi		UD
1.5 NPS		1.77 in²			15-300 psi		UD
10 NPS		78.5 in²			15-100 psi		UD
12 NPS		113 in²			15-100 psi		UD
14 NPS		138 in²			15-75 psi		UD
16 NPS		183 in²			15-75 psi		UD

18 NPS	234 in ²	15-50 psi	UD
2 NPS	3.14 in ²	15-250 psi	UD
2.5 NPS	4.78 in ²	15-250 psi	UD
20 NPS	291 in ²	15-30 psi	UD
24 NPS	424.55 in ²	15-25 psi	UD
3 NPS	7.07 in ²	15-200 psi	UD
4 NPS	12.6 in ²	15-150 psi	UD
6 NPS	28.3 in ²	15-100 psi	UD
8 NPS	50 in ²	15-100 psi	UD

Design Name:	Series 3 w. Dial Vac. Support	NBCert #	90144
--------------	-------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/23/2027

Design Type

[Rupture Disk Device] Series 3 w. Dial Vac. Support
HolderDesignation: N/A
Capacity Tests: Sec. UD at National Board Testing Lab on January 14, 2003
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value:12.500 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Mersen USA ACE Corp. {COA}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.39 in ²			15-50 psi		UD
1.5 NPS		0.845 in ²			7-20 psi		UD
10 NPS		39.41 in ²			1-20 psi		UD
12 NPS		57.52 in ²			0.5-20 psi		UD
14 NPS		70.99 in ²			0.5-20 psi		UD
16 NPS		105.71 in ²			0.5-20 psi		UD
18 NPS		119.96 in ²			0.5-20 psi		UD
2 NPS		1.37 in ²			3-20 psi		UD
2.5 NPS		2.18 in ²			3-20 psi		UD
20 NPS		156.17 in ²			0.5-20 psi		UD
24 NPS		278.07 in ²			0.5-20 psi		UD
3 NPS		3.54 in ²			2-20 psi		UD
4 NPS		6.45 in ²			2-20 psi		UD
6 NPS		12.28 in ²			1-20 psi		UD
8 NPS		29.54 in ²			1-20 psi		UD

Design Name:	Series 3 w/Bar Vac. Support	NBCert #	90122
--------------	-----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 08/07/2026

Design Type

[Rupture Disk Device] Series 3 w/Bar Vac. Support
 HolderDesignation: N/A
 Capacity Tests: Sec. UD at National Board Testing Lab on January 14, 2003
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 6.440 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Mersen USA ACE Corp. {COA}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.405 in ²			15-50 psi		UD
1.5 NPS		1.02 in ²			7-20 psi		UD
10 NPS		58.5 in ²			1-20 psi		UD
12 NPS		89 in ²			0.5-20 psi		UD
14 NPS		110 in ²			0.5-20 psi		UD
16 NPS		151 in ²			0.5-20 psi		UD
18 NPS		198 in ²			0.5-20 psi		UD
2 NPS		2.14 in ²			3-20 psi		UD
2.5 NPS		3.66 in ²			3-20 psi		UD
20 NPS		251 in ²			0.5-20 psi		UD
24 NPS		377 in ²			0.5-20 psi		UD
3 NPS		5.57 in ²			2-20 psi		UD
4 NPS		8.6 in ²			2-20 psi		UD
6 NPS		19.3 in ²			1-20 psi		UD
8 NPS		36.3 in ²			1-20 psi		UD

Design Name: Series 6

NBCert # 90133

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	04/20/2030

Design Type

[Rupture Disk Device] Series 6
 HolderDesignation: N/A
 Capacity Tests: Sec. UD at National Board Testing Lab on January 14, 2003
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 0.500 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Mersen USA ACE Corp. {COA}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.78 in ²			15-400 psi		UD
1.5 NPS		1.77 in ²			7-300 psi		UD
10 NPS		78.5 in ²			1-100 psi		UD
12 NPS		113 in ²			0.5-100 psi		UD
14 NPS		138 in ²			0.5-75 psi		UD
16 NPS		183 in ²			0.5-75 psi		UD

18 NPS	234 in ²	0.5-50 psi	UD
2 NPS	3.14 in ²	3-250 psi	UD
2.5 NPS	4.91 in ²	3-250 psi	UD
20 NPS	291 in ²	0.5-30 psi	UD
24 NPS	425 in ²	0.5-25 psi	UD
3 NPS	7.07 in ²	2-200 psi	UD
4 NPS	12.6 in ²	2-150 psi	UD
6 NPS	28.3 in ²	1-100 psi	UD
8 NPS	50.3 in ²	1-100 psi	UD

Midwest Valve Services, LLC (MID)

Nameplate Abbreviation: Midwest Valve Services

Minooka, IL 60447United States

This Company Manufactures or Assembles:

Design Name:	243/249/443/449/546/843/849/943/5046/5049/8043/8049	NBCert #	01292
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/23/2029

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
Capacity Tests: Sec. UV at unknown lab on August 8, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name:	253/259/453/459/853/859/953/959/5059/8053/8059	NBCert #	01304
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/23/2029

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
Capacity Tests: Sec. UV at unknown lab on July 31, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.627 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name:	263/269/463/469/566/863/869/963/969/5066/5069	NBCert #	01315
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/23/2029

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069
Capacity Tests: Sec. UV at unknown lab on July 30, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV

3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/23/2029

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.767 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/23/2029

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids) NBCert # 01348

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/14/2029

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids)
 Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.712 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name:	81, 81P, 83, 84	NBCert #	01089
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/23/2029

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name:	81P (Liquids)	NBCert #	01102
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/23/2029

Design Type

[Relief Valve] 81P (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.720 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: 93% of pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name: 900 Series (Liquid), 7700, SNC NBCert # 15499

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV, V

08/23/2029

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.661 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV

1.5 NPS 2.5 NPS 0.5674 in² [#9] 0.85 in 0.274 in 15-5000 psi Water UV, V

Design Name: 900 Series, 7700, SNC				NBCert # 15411	
Manufacturer/Assembler			Designators		Expiration Date

Assembler UV 08/23/2029

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: HL, HSL				NBCert # 15589	
Manufacturer/Assembler			Designators		Expiration Date

Assembler V 08/09/2030

Design Type

[Safety Valve] HL, HSL
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on November 3, 1999
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.869 Unitless
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	1.5 NPS	0.339 in ²	[F] 0.657 in	0.164 in	15-725 psi	Steam	UV, V
1.25-2 NPS	1.5 NPS	0.553 in ²	[G] 0.839 in	0.21 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.868 in ²	[H] 1.051 in	0.263 in	15-725 psi	Steam	UV, V

1.5-2.5 NPS	2.5 NPS	1.327 in ²	[J] 1.3 in	0.325 in	15-725 psi	Steam	UV, V
2-3 NPS	3-4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-725 psi	Steam	UV, V
2.5-4 NPS	4-6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-725 psi	Steam	UV, V
3 NPS	4-6 NPS	3.955 in ²	[M] 2.244 in	0.561 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	4.831 in ²	[N] 2.48 in	0.62 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	7.031 in ²	[P] 2.992 in	0.748 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[QQ] 3.75 in	0.937 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	0.984 in	15-725 psi	Steam	UV, V

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 08/23/2029

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V

4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/23/2029

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/23/2029

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV

6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Midwest Valve Services, LLC (RSO)

Des Moines, IA 50313United States

This Company Manufactures or Assembles:

Design Name: 243/249/443/449/546/843/849/943/5046/5049/8043/8049 NBCert # 01292

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/27/2030

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
Capacity Tests: Sec. UV at unknown lab on August 8, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV

1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name: 253/259/453/459/853/859/953/959/5059/8053/8059 NBCert # 01304

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/27/2030

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
Capacity Tests: Sec. UV at unknown lab on July 31, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.627 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 263/269/463/469/566/863/869/963/969/5066/5069 NBCert # 01315

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/27/2030

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069
 Capacity Tests: Sec. UV at unknown lab on July 30, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.860 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/27/2030

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.767 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V

1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/08/2031

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.491 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 81, 81P, 83, 84		NBCert #	01089
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	08/27/2030
Design Type			
[Safety Relief Valve] 81, 81P, 83, 84 Capacity Tests: Sec. UV at unknown lab on July 8, 1965 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.816 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC} Comments: Type 81P and 84 have fixed blowdown.			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 81P (Liquids)		NBCert #	01102
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	08/27/2030
Design Type			
[Relief Valve] 81P (Liquids) Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.720 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: 93% of pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V

0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name: 900 Series (Liquid), 7700, SNC NBCert # 15499

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/30/2030

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name: 900 Series, 7700, SNC NBCert # 15411

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/27/2030

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Liquids)	NBCert #	15095
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/27/2030

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV

3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/27/2030

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV

6 NPS	8 NPS	12.472 in²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV
Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/ABNBCert # 15208							
Manufacturer/Assembler			Designators			Expiration Date	
Assembler			UV			07/30/2030	
Design Type							
[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.865 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV

4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Millennium Power Services (MON)

Westfield, MA 01085United States

This Company Manufactures or Assembles:

Design Name:	1541, 1543, 1541-3, 1543-3	NBCert #	18032
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/27/2030

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name:	1811, 1511	NBCert #	18122
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV, V	05/28/2030
-----------	-------	------------

Design Type

[Safety Valve] 1811, 1511
 Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.877 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V

1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/22/2030

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V

6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35 NBCert # 18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/29/2030

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series	NBCert # 18706
---------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	05/28/2030
-----------	----	------------

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid		NBCert # 18717
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/28/2030
Design Type		
[Relief Valve] 19000 Series, Liquid Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.673 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2		NBCert # 18144
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/27/2030
Design Type		
[Safety Relief Valve] 1900D-2, 1900-30D-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids)		NBCert # 18751
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/22/2030

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM-D NBCert # 19088

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

07/17/2030

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E NBCert # 19099

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

07/17/2030

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/27/2030

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name:	1900E-2, 1900-30E-2 LA & DALA (Liquids)	NBCert #	18762
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/23/2030

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name:	1982	NBCert #	18379
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/22/2030

Design Type

[Safety Relief Valve] 1982
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at unknown lab on May 6, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Air	NV, UV

0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Steam	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Air	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Steam	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Air	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Steam	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Air	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Air	NV, UV

Design Name: 1982 LS, 820000LS NBCert # 18380

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 05/28/2030

Design Type

[Relief Valve] 1982 LS, 820000LS
Capacity Tests: Sec. UV at Dresser, Inc. on December 19, 1984
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.758 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	NV
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	UV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	NV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	NV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	UV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	NV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	NV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	UV

Design Name: 2900-TM (39PV & 39MV pilots) NBCert # 01427

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/06/2030

Design Type

[Pilot Operated Pressure Relief Valve] 2900-TM (39PV & 39MV pilots)

Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Water	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Water	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Water	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2000 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Water	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Water	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Water	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-300 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Water	UV

Mobile Valve - Tracy (MVT)

Nameplate Abbreviation: MVT

Tracy, NB E5L 2W1Canada

This Company Manufactures or Assembles:

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	08/12/2028	

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V

2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/12/2028

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV

4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series

NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

08/12/2028

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV

1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

08/12/2028

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Mobile Valve, A Division of Source Atlantic (MVR)

Nameplate Abbreviation: MVR / Mobile Valve - NS

Mt. Uniacke, NS B0N 1Z0Canada

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3	NBCert # 18032
---	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV, V

08/17/2026

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1811, 1511

NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	07/10/2026

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

MOGAS Industries, Inc. (MII)

Nameplate Abbreviation: MOGAS

Houston, TX 77039United States

This Company Manufactures or Assembles:

Design Name: PORV-UD		NBCert # 64112
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	V	07/05/2026

Design Type

[Power Actuated Relief Valve] PORV-UD
Capacity Tests: Sec. V at National Board Testing Lab on July 5, 1994
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:94.800 PPH/PSIA
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Power Actuated
Flow Area Configuration: Nozzle/Full Lift
Designed by: MOGAS Industries, Inc. {MII}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2.5-4 NPS	3 - 4 NPS	2.01 in ²	1.6 in		500-4100 psi	Steam	V

Design Name: PORV-UK, PORV-UKC NBCert # 64145

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	V	08/07/2029

Design Type

[Power Actuated Relief Valve] PORV-UK, PORV-UKC
Capacity Tests: Sec. V at National Board Testing Lab on August 7, 1996
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:112.40 PPH/PSIA
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Power Actuated
Flow Area Configuration: Nozzle/Full Lift
Designed by: MOGAS Industries, Inc. {MII}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2.5-4 in	4 - 6 NPS	2.57 in ²	1.81 in		1000-5000 psi	Steam	V

Design Name: PORV-UL NBCert # 64123

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	V	03/14/2030

Design Type

[Power Actuated Relief Valve] PORV-UL
Capacity Tests: Sec. V at National Board Testing Lab on January 10, 1997
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:57.700 PPH/PSIA
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Power Actuated
Flow Area Configuration: Nozzle/Full Lift
Designed by: MOGAS Industries, Inc. {MII}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-3 NPS	2 - 4 NPS	1.327 in ²	1.3 in		1000-5000 psi	Steam	V

Design Name: PORV-UM, PORV-UMC NBCert # 64101

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	V	05/01/2027

Design Type

[Power Actuated Relief Valve] PORV-UM, PORV-UMC
Capacity Tests: Sec. V at National Board Testing Lab on October 21, 1994
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:138.30 PPH/PSIA
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Power Actuated
Flow Area Configuration: Nozzle/Full Lift
Designed by: MOGAS Industries, Inc. {MII}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3-4 NPS	4 - 6 NPS	3.14 in ²	2 in		500-5000 psi	Steam	V

Design Name: PORV-UN NBCert # 64134

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	V	11/26/2030

Design Type

[Power Actuated Relief Valve] PORV-UN
Capacity Tests: Sec. V at National Board Testing Lab on August 22, 1997
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:155.80 PPH/PSIA
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Power Actuated
Flow Area Configuration: Nozzle/Full Lift
Designed by: MOGAS Industries, Inc. {MII}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3.5-5 in	4 - 6 NPS	3.56 in ²	2.13 in		1000-5000 psi	Steam	V

Mt.H Control Valves Co., Ltd. (MHC)

Gangseo-gu, Busan, 46754Republic of Korea

This Company Manufactures or Assembles:

Design Name: SC 32 NBCert # 00549

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/05/2028

Design Type

[Safety Relief Valve] SC 32
Capacity Tests: Sec. UV at National Board Testing Lab on March 30, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.851 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mt.H Control Valves Co., Ltd. {MHC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	1-3 NPS	0.1368 in ²	[D] 0.4173 in	0.106 in	15-2900 psi	Steam	UV

0.75-1.5 NPS	1-3 NPS	0.1368 in ²	[D] 0.4173 in	0.106 in	15-6000 psi	Air	UV
1-1.5 NPS	2-3 NPS	0.2812 in ²	[E] 0.5984 in	0.15 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.2812 in ²	[E] 0.5984 in	0.15 in	15-6000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.3772 in ²	[F] 0.693 in	0.174 in	15-2900 psi	Steam	UV
1.5-2 NPS	2-3 NPS	0.3772 in ²	[F] 0.693 in	0.174 in	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	0.5945 in ²	[G] 0.87 in	0.221 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.5945 in ²	[G] 0.87 in	0.221 in	15-3600 psi	Air	UV
1.5-2 NPS	3 NPS	0.9212 in ²	[H] 1.083 in	0.272 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9212 in ²	[H] 1.083 in	0.272 in	15-3000 psi	Air	UV
2-3 NPS	3-4 NPS	1.491 in ²	[J] 1.378 in	0.346 in	15-2500 psi	Steam	UV
2-3 NPS	3-4 NPS	1.491 in ²	[J] 1.378 in	0.346 in	15-3000 psi	Air	UV
3 NPS	4-6 NPS	2.128 in ²	[K] 1.646 in	0.413 in	15-2000 psi	Steam	UV
3 NPS	4-6 NPS	2.128 in ²	[K] 1.646 in	0.413 in	15-2500 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.517 in	15-2000 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.517 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.165 in ²	[M] 2.303 in	0.579 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.165 in ²	[M] 2.303 in	0.579 in	15-1500 psi	Steam	UV
4 NPS	6 NPS	5.063 in ²	[N] 2.539 in	0.638 in	15-1500 psi	Air	UV
4 NPS	6 NPS	5.063 in ²	[N] 2.539 in	0.638 in	15-1500 psi	Steam	UV
4 NPS	6 NPS	7.407 in ²	[P] 2.992 in	0.748 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	7.407 in ²	[P] 2.992 in	0.748 in	15-1600 psi	Air	UV
6 NPS	8 NPS	13.042 in ²	[Q] 4.075 in	1.02 in	15-600 psi	Air	UV
6 NPS	8 NPS	13.042 in ²	[Q] 4.075 in	1.02 in	15-600 psi	Steam	UV
6 NPS	8-10 NPS	18.505 in ²	[R] 4.488 in	1.122 in	15-600 psi	Air	UV
6 NPS	8-10 NPS	18.505 in ²	[R] 4.488 in	1.122 in	15-600 psi	Steam	UV
8 NPS	10 NPS	29.244 in ²	[T] 5.984 in	1.496 in	15-300 psi	Air	UV
8 NPS	10 NPS	29.244 in ²	[T] 5.984 in	1.496 in	15-300 psi	Steam	UV
10 NPS	14 NPS	47.97 in ²	[U] 7.48 in	1.87 in	15-500 psi	Air	UV
10 NPS	14 NPS	47.97 in ²	[U] 7.48 in	1.87 in	15-500 psi	Steam	UV
12 NPS	16 NPS	68.96 in ²	[V] 9.055 in	2.264 in	15-500 psi	Air	UV
12 NPS	16 NPS	68.96 in ²	[V] 9.055 in	2.264 in	15-500 psi	Steam	UV
14 NPS	18 NPS	94.08 in ²	[W] 10.512 in	2.638 in	15-500 psi	Air	UV
14 NPS	18 NPS	94.08 in ²	[W] 10.512 in	2.638 in	15-500 psi	Steam	UV
16 NPS	18 NPS	103.8 in ²	[X] 11.496 in	2.753 in	15-500 psi	Air	UV
16 NPS	18 NPS	103.8 in ²	[X] 11.496 in	2.753 in	15-500 psi	Steam	UV
16 NPS	18 NPS	123.49 in ²	[Y] 12.008 in	3.102 in	15-500 psi	Air	UV
16 NPS	18 NPS	123.49 in ²	[Y] 12.008 in	3.102 in	15-500 psi	Steam	UV
18 NPS	24 NPS	155.15 in ²	[Z] 13.504 in	3.368 in	15-500 psi	Air	UV
18 NPS	24 NPS	155.15 in ²	[Z] 13.504 in	3.368 in	15-500 psi	Steam	UV
20 NPS	24 NPS	191.87 in ²	[Z1] 14.961 in	3.74 in	15-500 psi	Air	UV
20 NPS	24 NPS	191.87 in ²	[Z1] 14.961 in	3.74 in	15-500 psi	Steam	UV

Design Name: SC 32 (Liquid)		NBCert #	00550
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	09/29/2027
Design Type			
[Safety Relief Valve] SC 32 (Liquid) Capacity Tests: Sec. UV at National Board Testing Lab on March 30, 2015 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.631 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mt.H Control Valves Co., Ltd. {MHC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	1-3 NPS	0.1368 in ²	[D] 0.4173 in	0.106 in	15-6000 psi	Water	UV
1-1.5 NPS	2-3 NPS	0.2812 in ²	[E] 0.5984 in	0.15 in	15-6000 psi	Water	UV
1.5-2 NPS	2-3 NPS	0.3772 in ²	[F] 0.693 in	0.174 in	15-5000 psi	Water	UV
1.5-2 NPS	3 NPS	0.5945 in ²	[G] 0.87 in	0.221 in	15-3600 psi	Water	UV
1.5-2 NPS	3 NPS	0.9212 in ²	[H] 1.083 in	0.272 in	15-3000 psi	Water	UV
2-3 NPS	3-4 NPS	1.491 in ²	[J] 1.378 in	0.346 in	15-3000 psi	Water	UV
3 NPS	4-6 NPS	2.128 in ²	[K] 1.646 in	0.413 in	15-2500 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.517 in	15-2000 psi	Water	UV
4 NPS	6 NPS	4.165 in ²	[M] 2.303 in	0.579 in	15-1500 psi	Water	UV
4 NPS	6 NPS	5.063 in ²	[N] 2.539 in	0.638 in	15-1500 psi	Water	UV
4 NPS	6 NPS	7.407 in ²	[P] 2.992 in	0.748 in	15-1600 psi	Water	UV
6 NPS	8 NPS	13.042 in ²	[Q] 4.075 in	1.02 in	15-600 psi	Water	UV
6 NPS	8-10 NPS	18.505 in ²	[R] 4.488 in	1.122 in	15-600 psi	Water	UV
8 NPS	10 NPS	29.244 in ²	[T] 5.984 in	1.496 in	15-300 psi	Water	UV
10 NPS	14 NPS	47.97 in ²	[U] 7.48 in	1.87 in	15-500 psi	Water	UV
12 NPS	16 NPS	68.96 in ²	[V] 9.055 in	2.264 in	15-500 psi	Water	UV
14 NPS	18 NPS	94.08 in ²	[W] 10.512 in	2.638 in	15-500 psi	Water	UV

Design Name: SP 32		NBCert #	00561
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	04/05/2028
Design Type			
[Pilot Operated Pressure Relief Valve] SP 32 Capacity Tests: Sec. UV at National Board Testing Lab on October 15, 2014 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.869 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition(1): Pop; (3): Initial Audible Discharge Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot Flow Area Configuration: Nozzle/Full Lift Designed by: Mt.H Control Valves Co., Ltd. {MHC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-10000 psi	Air	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-10000 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-10000 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-2 NPS	2-3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2-3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-7000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2-3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-6000 psi	Air	UV
1.5-3 NPS	2-4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2-4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-6000 psi	Air	UV
2-3 NPS	3-4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3-4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-4000 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-4000 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-2500 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-2000 psi	Air	UV
6 NPS	8 NPS	15.821 in ²	[R] 4.488 in	1.66 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	15.821 in ²	[R] 4.488 in	1.66 in	15-2000 psi	Air	UV
8 NPS	10 NPS	28.126 in ²	[T] 5.984 in	2.214 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.126 in ²	[T] 5.984 in	2.214 in	15-1480 psi	Air	UV
10 NPS	14 NPS	44.18 in ²	[V] 7.5 in	2.775 in	15-500 psi	Air	UV
10 NPS	14 NPS	44.18 in ²	[V] 7.5 in	2.775 in	15-500 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.33 in	15-500 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.33 in	15-500 psi	Steam	UV
14 NPS	18 NPS	86.785 in ²	[Y] 10.512 in	3.889 in	15-500 psi	Air	UV
14 NPS	18 NPS	86.785 in ²	[Y] 10.512 in	3.889 in	15-500 psi	Steam	UV
16 NPS	20 NPS	95.38 in ²	[Z] 11.02 in	4.077 in	15-500 psi	Air	UV
16 NPS	20 NPS	95.38 in ²	[Z] 11.02 in	4.077 in	15-500 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[Z2] 12 in	4.44 in	15-500 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[Z2] 12 in	4.44 in	15-500 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[A] 13.498 in	4.994 in	15-500 psi	Air	UV

18 NPS	24 NPS	143.1 in ²	[A] 13.498 in	4.994 in	15-500 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[B] 15 in	5.55 in	15-500 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[B] 15 in	5.55 in	15-500 psi	Steam	UV

Design Name: SP 32 (Liquid) NBCert # 00572

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 09/29/2027

Design Type

[Pilot Operated Pressure Relief Valve] SP 32 (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on October 14, 2014
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.782 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mt.H Control Valves Co., Ltd. {MHC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-6170 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-6170 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-6170 psi	Water	UV
1.5-2 NPS	2-3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-6170 psi	Water	UV
1.5-2 NPS	2-3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-6170 psi	Water	UV
2-3 NPS	3-4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-6170 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-3705 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-3705 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1480 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1480 psi	Water	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1480 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1480 psi	Water	UV
6 NPS	8 NPS	15.821 in ²	[R] 4.488 in	1.66 in	15-1480 psi	Water	UV
8 NPS	10 NPS	28.126 in ²	[T] 5.984 in	2.214 in	15-1480 psi	Water	UV
10 NPS	14 NPS	44.18 in ²	[V] 7.5 in	2.775 in	15-500 psi	Water	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.33 in	15-500 psi	Water	UV
14 NPS	18 NPS	86.785 in ²	[Y] 10.512 in	3.889 in	15-500 psi	Water	UV
16 NPS	20 NPS	95.38 in ²	[Z] 11.02 in	4.077 in	15-500 psi	Water	UV
16 NPS	20 NPS	113.1 in ²	[Z2] 12 in	4.44 in	15-500 psi	Water	UV
18 NPS	24 NPS	143.1 in ²	[A] 13.498 in	4.994 in	15-500 psi	Water	UV
20 NPS	24 NPS	176.7 in ²	[B] 15 in	5.55 in	15-500 psi	Water	UV

Mueller Refrigeration, LLC (MBC)

Hartsville, TN 37074United States

This Company Manufactures or Assembles:

Design Name:	3000A (3000, 3001, 3001X2, 3002, 3012, 3014, 3015, 3212, 3214, 3215, 3217, 5980X1, 3000C, 3001C, 3002C, 3012C, 3014C, 3015C, 3212C, 3214C, 3215C, 3000C-4FFL)	NBCert #	41173
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/22/2029

Design Type

[Safety Relief Valve] 3000A (3000, 3001, 3001X2, 3002, 3012, 3014, 3015, 3212, 3214, 3215, 3217, 5980X1, 3000C, 3001C, 3002C, 3012C, 3014C, 3015C, 3212C, 3214C, 3215C, 3000C-4FFL)
Capacity Tests: Sec. UV at National Board Testing Lab on November 10, 2016
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.379 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mueller Refrigeration, LLC {MBC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.5625 NPS	3/8, 1/2, Top NPS	0.028 in ²	0.187 in		150-800 psi	Air	UV

Design Name:	3020A (3016, 3020, 3020X2, 3216, 3220, 5731AX9, 5733, 5733X2, 3016C, 3020C, 3216C, 3220C)	NBCert #	41184
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/22/2029

Design Type

[Safety Relief Valve] 3020A (3016, 3020, 3020X2, 3216, 3220, 5731AX9, 5733, 5733X2, 3016C, 3020C, 3216C, 3220C)
Capacity Tests: Sec. UV at National Board Testing Lab on November 10, 2016
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.727 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mueller Refrigeration, LLC {MBC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1.125 NPS		0.062 in ²	0.281 in		150-800 psi	Air	UV

Design Name:	3030A (3030, 3030C, 3031, 3031C, 3031X1, 3045, 3045C, 3045TR, 3045X1)	NBCert #	41195
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/22/2029

Design Type

[Safety Relief Valve] 3030A (3030, 3030C, 3031, 3031C, 3031X1, 3045, 3045C, 3045TR, 3045X1)
Capacity Tests: Sec. UV at National Board Testing Lab on November 10, 2016
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.698 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mueller Refrigeration, LLC {MBC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1/2, 3/4, Top NPS	0.15 in ²	0.437 in		150-700 psi	Air	UV

Design Name:	3060A (3060, 3060FL, 3060X1, 3060X7, 3061X1, 3070, 3075)	NBCert #	41207
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/22/2029

Design Type

[Safety Relief Valve] 3060A (3060, 3060FL, 3060X1, 3060X7, 3061X1, 3070, 3075)
Capacity Tests: Sec. UV at National Board Testing Lab on November 10, 2016
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 4.093 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mueller Refrigeration, LLC {MBC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.25 NPS	1, 1.25 NPS	0.405 in ²	0.718 in		150-450 psi	Air	UV

Design Name:	3080A (3075TR, 5730)	NBCert #	41162
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/22/2029

Design Type

[Safety Relief Valve] 3080A (3075TR, 5730)
Capacity Tests: Sec. UV at National Board Testing Lab on November 10, 2016
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.637 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mueller Refrigeration, LLC {MBC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.625 NPS		0.196 in ²	0.5 in		300-450 psi	Air	UV

Design Name:	3090	NBCert #	41218
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/26/2030

Design Type

[Safety Relief Valve] 3090
Capacity Tests: Sec. UV at National Board Testing Lab on January 22, 2018
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value: 774.10 SCFM
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Mueller Refrigeration, LLC {MBC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.875 in	1.5 NPS	1.227 in ²	1.25 in	0.389 in	50-50 psi	Air	UV

Design Name: A15502, A15503, A15512, A15513,
A17430, A18774, A18933, A18934, A-
19108, B33746, B33752, B33753, B33754, NBCert # 41016
B33755 & B34425, B35616

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/13/2029

Design Type

[Safety Relief Valve] A15502, A15503, A15512, A15513, A17430, A18774, A18933, A18934, A-19108, B33746, B33752, B33753, B33754, B33755 & B34425, B35616
Capacity Tests: Sec. UV at unknown lab on January 3, 1956
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.438 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mueller Refrigeration, LLC {MBC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
		0.028 in ²	0.19 in		150-700 psi	Air	UV
0.125-0.375 NPS	3/8, 1/2 NPS	0.0284 in ²	0.19 in		150-700 psi	Air	UV

Design Name: A15504, A15514, A15515, B35413,
A18736, A18737 A18762, A18783, A18784, NBCert # 41027
A18935, A19105, A19099

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

05/03/2027

Design Type

[Safety Relief Valve] A15504, A15514, A15515, B35413, A18736, A18737 A18762, A18783, A18784, A18935, A19105, A19099
Capacity Tests: Sec. UV at unknown lab on January 3, 1956
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.965 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Designed by: Mueller Refrigeration, LLC {MBC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-0.875 NPS	1/2, 5/8, 3/4 NPS	0.0616 in ²	0.28 in		150-700 psi	Air	UV

Design Name: A-15506 & B-34444		NBCert #	41049
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	05/22/2026
Design Type			
[Safety Relief Valve] A-15506 & B-34444 Capacity Tests: Sec. UV at Phillips Petroleum on May 22, 1956 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.124 lb/min/psia Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Designed by: Mueller Refrigeration, LLC {MBC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-0.875 NPS		0.1134 in ²	0.38 in		150-450 psi	Air	UV

Design Name: A-17834, B-34580, A-18387, A-18473		NBCert #	41061
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	03/31/2026
Design Type			
[Safety Relief Valve] A-17834, B-34580, A-18387, A-18473 Capacity Tests: Sec. UV at National Board Testing Lab on October 29, 1999 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 4.400 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Designed by: Mueller Refrigeration, LLC {MBC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.625 NPS	1, 1.25 NPS	0.4185 in ²	0.73 in	0.183 in	150-450 psi	Air	UV

Design Name: A-17840, A-18735, & B-34519		NBCert #	41050
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	12/17/2025
Design Type			
[Safety Relief Valve] A-17840, A-18735, & B-34519 Capacity Tests: Sec. UV at National Board Testing Lab on July 8, 1999 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.690 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Designed by: Mueller Refrigeration, LLC {MBC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.625 NPS	1 NPS	0.196 in ²	0.5 in		150-450 psi	Air	UV

Design Name: A-17970, A-18443		NBCert #	41072
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	05/03/2027
Design Type			
[Safety Relief Valve] A-17970, A-18443 Capacity Tests: Sec. UV at National Board Testing Lab on October 28, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.390 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mueller Refrigeration, LLC {MBC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
	1 NPS	0.093 in ²	0.375 in		150-450 psi	Air	UV

Design Name: A-18356, A-18357, A-18358, A-18540		NBCert #	41083
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	03/21/2030
Design Type			
[Safety Relief Valve] A-18356, A-18357, A-18358, A-18540 Capacity Tests: Sec. UV at National Board Testing Lab on August 7, 2007 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.870 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mueller Refrigeration, LLC {MBC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.875 NPS	.5, .75 NPS	0.151 in ²	0.438 in	0.109 in	150-450 psi	Air	UV

Design Name: A-18422		NBCert #	41106
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	04/09/2026
Design Type			
[Safety Relief Valve] A-18422 Capacity Tests: Sec. UV at National Board Testing Lab on March 16, 2009 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.730 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mueller Refrigeration, LLC {MBC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.1134 in ²	0.38 in		600-700 psi	Air	UV

Design Name: A-18424 (Teflon seat)		NBCert #	41128
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	12/17/2025
Design Type			
[Safety Relief Valve] A-18424 (Teflon seat) Capacity Tests: Sec. UV at National Board Testing Lab on January 20, 2009 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.906 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mueller Refrigeration, LLC {MBC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1 NPS	0.196 in ²	0.5 in		150-450 psi	Air	UV

Design Name: A-18425, A-18444 (Teflon seat)		NBCert #	41117
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	12/17/2025
Design Type			
[Safety Relief Valve] A-18425, A-18444 (Teflon seat) Capacity Tests: Sec. UV at National Board Testing Lab on October 16, 2008 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 4.330 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mueller Refrigeration, LLC {MBC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.25 NPS	1.25 NPS	0.4185 in ²	0.73 in		150-450 psi	Air	UV

NAKAKITA SEISAKUSHO CO.,LTD. (NKK)

Daito, Osaka, 574-8691Japan

This Company Manufactures or Assembles:

Design Name: NS 200JMR			NBCert # 42073	
Manufacturer/Assembler		Designators		Expiration Date
Manufacturer		UV		04/18/2030

Design Type

[Relief Valve] NS 200JMR
 Capacity Tests: Sec. UV at National Board Testing Lab on May 8, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.603 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: NAKAKITA SEISAKUSHO CO.,LTD. {NKK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.1217 in ²	0.3149 in	0.079 in	15-3000 psi	Water	UV
0.75-1 NPS	.75 - 1 NPS	0.1217 in ²	0.3937 in	0.098 in	15-2000 psi	Water	UV

Design Name: NS255

NBCert # 42039

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

06/17/2027

Design Type

[Safety Relief Valve] NS255
 Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on April 17, 1978
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: NAKAKITA SEISAKUSHO CO.,LTD. {NKK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	1 -2.5 NPS	0.133 in ²	[D] 0.413 in	0.125 in	15-2900 psi	Steam	UV
0.75-1.5 NPS	1 -2.5 NPS	0.133 in ²	[D] 0.413 in	0.125 in	15-3500 psi	Air	UV
0.75-1.5 NPS	1 - 2.5 NPS	0.221 in ²	[E] 0.531 in	0.161 in	15-2900 psi	Steam	UV
0.75-1.5 NPS	1 - 2.5 NPS	0.221 in ²	[E] 0.531 in	0.161 in	15-3500 psi	Air	UV
1-1.5 NPS	1.5 - 2.5 NPS	0.351 in ²	[F] 0.669 in	0.2 in	15-2900 psi	Steam	UV
1-1.5 NPS	1.5 - 2.5 NPS	0.351 in ²	[F] 0.669 in	0.2 in	15-3500 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.589 in ²	[G] 0.866 in	0.259 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.589 in ²	[G] 0.866 in	0.259 in	15-3500 psi	Air	UV
1.5-2 NPS	3 NPS	0.919 in ²	[H] 1.082 in	0.326 in	15-2500 psi	Air	UV
1.5-2 NPS	3 NPS	0.919 in ²	[H] 1.082 in	0.326 in	15-2500 psi	Steam	UV
2-3 NPS	3 , 4 NPS	1.448 in ²	[J] 1.358 in	0.409 in	15-2500 psi	Air	UV
2-3 NPS	3 , 4 NPS	1.448 in ²	[J] 1.358 in	0.409 in	15-2500 psi	Steam	UV
3 NPS	4, 6 NPS	2.094 in ²	[K] 1.633 in	0.452 in	15-2000 psi	Air	UV
3 NPS	4, 6 NPS	2.094 in ²	[K] 1.633 in	0.452 in	15-2000 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.226 in ²	[L] 2.027 in	0.559 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.226 in ²	[L] 2.027 in	0.559 in	15-1500 psi	Steam	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.629 in	15-1000 psi	Air	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.629 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	4.908 in ²	[N] 2.5 in	0.688 in	15-1000 psi	Air	UV

4 NPS	6 NPS	4.908 in ²	[N] 2.5 in	0.688 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.834 in	15-1000 psi	Air	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.834 in	15-1000 psi	Steam	UV
6 NPS	8 NPS	12.541 in ²	[Q] 3.996 in	1.102 in	15-600 psi	Air	UV
6 NPS	8 NPS	12.541 in ²	[Q] 3.996 in	1.102 in	15-600 psi	Steam	UV
6 NPS	8, 10 NPS	18.118 in ²	[R] 4.803 in	1.322 in	15-400 psi	Air	UV
6 NPS	8, 10 NPS	18.118 in ²	[R] 4.803 in	1.322 in	15-400 psi	Steam	UV
8 NPS	10 NPS	29.435 in ²	[T] 6.122 in	1.685 in	15-300 psi	Air	UV
8 NPS	10 NPS	29.435 in ²	[T] 6.122 in	1.685 in	15-300 psi	Steam	UV
10 NPS	12, 14 NPS	47.722 in ²	[V] 7.795 in	2.145 in	15-300 psi	Air	UV
10 NPS	12, 14 NPS	47.722 in ²	[V] 7.795 in	2.145 in	15-300 psi	Steam	UV
12 NPS	14, 16 NPS	68.368 in ²	[W] 9.33 in	2.566 in	15-300 psi	Air	UV
12 NPS	14, 16 NPS	68.368 in ²	[W] 9.33 in	2.566 in	15-300 psi	Steam	UV

Design Name:	NS255E (Liquids)	NBCert #	42040
--------------	------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 06/17/2027

Design Type

[Relief Valve] NS255E (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on November 3, 1986
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: NAKAKITA SEISAKUSHO CO.,LTD. {NKK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	.75 - 2.5 NPS	0.11 in ²	0.375 in	0.112 in	15-5000 psi	Water	UV
0.75-1.5 NPS	.75 - 2.5 NPS	0.133 in ²	0.413 in	0.125 in	15-5000 psi	Water	UV
0.75-1.5 NPS	.75 - 2.5 NPS	0.196 in ²	0.5 in	0.15 in	15-5000 psi	Water	UV
0.75-1.5 NPS	0.75 - 2.5 NPS	0.221 in ²	0.531 in	0.161 in	15-5000 psi	Water	UV
1-1.5 NPS	1.5 - 2.5 NPS	0.307 in ²	0.625 in	0.19 in	15-5000 psi	Water	UV
1-1.5 NPS	1.5 - 2.5 NPS	0.351 in ²	0.669 in	0.2 in	15-5000 psi	Water	UV
1.5-2 NPS	2 - 3 NPS	0.503 in ²	0.8 in	0.24 in	15-3500 psi	Water	UV
1.5-2 NPS	2 - 3 NPS	0.589 in ²	0.866 in	0.259 in	15-3500 psi	Water	UV
1.5-2 NPS	3 NPS	0.785 in ²	1 in	0.3 in	15-2500 psi	Water	UV
1.5-2 NPS	3 NPS	0.919 in ²	1.082 in	0.326 in	15-2500 psi	Water	UV
2-3 NPS	3 , 4 NPS	1.287 in ²	1.281 in	0.384 in	15-2500 psi	Water	UV
2-3 NPS	3 , 4 NPS	1.448 in ²	1.358 in	0.409 in	15-2500 psi	Water	UV
3 NPS	4 , 6 NPS	1.838 in ²	1.53 in	0.421 in	15-2000 psi	Water	UV
3 NPS	4, 6 NPS	2.094 in ²	1.633 in	0.452 in	15-2000 psi	Water	UV
3-4 NPS	4 , 6 NPS	2.853 in ²	1.906 in	0.524 in	15-1500 psi	Water	UV
3-4 NPS	4, 6 NPS	3.226 in ²	2.027 in	0.559 in	15-1500 psi	Water	UV

4 NPS	6 NPS	3.6 in ²	2.141 in	0.589 in	15-1000 psi	Water	UV
4 NPS	6 NPS	4.093 in ²	2.283 in	0.629 in	15-1000 psi	Water	UV
4 NPS	6 NPS	4.34 in ²	2.351 in	0.646 in	15-1000 psi	Water	UV
4 NPS	6 NPS	4.908 in ²	2.5 in	0.688 in	15-1000 psi	Water	UV
4 NPS	6 NPS	6.38 in ²	2.85 in	0.784 in	15-1000 psi	Water	UV
4 NPS	6 NPS	7.215 in ²	3.031 in	0.834 in	15-1000 psi	Water	UV
6 NPS	8 NPS	11.05 in ²	3.75 in	1.031 in	15-600 psi	Water	UV
6 NPS	8 NPS	12.541 in ²	3.996 in	1.102 in	15-600 psi	Water	UV
6 NPS	8, 10 NPS	16 in ²	4.514 in	1.241 in	15-400 psi	Water	UV
6 NPS	8, 10 NPS	18.118 in ²	4.803 in	1.322 in	15-400 psi	Water	UV
8 NPS	10 NPS	26 in ²	5.75 in	1.582 in	15-300 psi	Water	UV
8 NPS	10 NPS	29.435 in ²	6.122 in	1.685 in	15-300 psi	Water	UV
10 NPS	12, 14 NPS	44.734 in ²	7.547 in	2.075 in	15-300 psi	Water	UV
10 NPS	12, 14 NPS	47.722 in ²	7.795 in	2.145 in	15-300 psi	Water	UV
12 NPS	14, 16 NPS	64.397 in ²	9.055 in	2.49 in	15-300 psi	Water	UV
12 NPS	14, 16 NPS	68.368 in ²	9.33 in	2.566 in	15-300 psi	Water	UV

Design Name: NS256

NBCert # 42062

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

04/03/2027

Design Type

[Pilot Operated Pressure Relief Valve] NS256
Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on June 21, 1979
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: NAKAKITA SEISAKUSHO CO.,LTD. {NKK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 2.5 NPS	0.112 in ²	0.378 in	0.114 in	50-2300 psi	Water	UV
1-1.5 NPS	2, 2.5 NPS	0.196 in ²	0.5 in	0.154 in	50-2300 psi	Air	UV
1.5 NPS	2, 2.5 NPS	0.307 in ²	0.626 in	0.193 in	50-2300 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.506 in ²	0.8031 in	0.24 in	50-2300 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	1 in	0.303 in	50-2300 psi	Air	UV
2-3 NPS	3, 4 NPS	1.293 in ²	1.2835 in	0.386 in	50-2300 psi	Air	UV
3 NPS	4, 6 NPS	1.842 in ²	1.5315 in	0.421 in	50-2000 psi	Air	UV
3-4 NPS	4, 6 NPS	2.863 in ²	1.9094 in	0.524 in	50-2000 psi	Air	UV
4 NPS	6 NPS	3.602 in ²	2.1417 in	0.591 in	50-2000 psi	Air	UV
4 NPS	6 NPS	4.353 in ²	2.3543 in	0.646 in	50-2000 psi	Air	UV
4 NPS	6 NPS	6.381 in ²	2.8504 in	0.783 in	50-1500 psi	Air	UV
6 NPS	8 NPS	11.056 in ²	3.752 in	1.031 in	50-1500 psi	Air	UV
6 NPS	8, 10 NPS	16.015 in ²	4.5157 in	1.4 in	50-1100 psi	Air	UV

8 NPS10, 12 NPS26.02 in²5.7559 in1.583 in50-1000 psiAirUV

Neway Valve Group - Wujiang Dongwu Machinery Co., Ltd (DWM)

Nameplate Abbreviation: DWMC

Suzhou City, Jiangsu Province, People's Republic of China

This Company Manufactures or Assembles:

Design Name: WFO, WFB		NBCert #	03418
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	05/05/2031	
Design Type			
[Safety Relief Valve] WFO, WFB			
Capacity Tests: Sec. UV at National Board Testing Lab on February 1, 2023			
Method of Establishing Relieving Capacity: Flow Capacity, K			
Certified Value: 0.867 Unitless			
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam			
Set Pressure Definition: Initial Audible Discharge			
Blowdown Characteristics: Adjustable (Single Ring)			
Flow Area Configuration: Nozzle/Full Lift			
Designed by: Neway Valve Group - Wujiang Dongwu Machinery Co., Ltd {DWM}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	80.118 mm²	[D] 10.1 mm	3.4 mm	15-6000 psi	Air	UV
1-1.5 NPS	2, 3 NPS	143.139 mm²	[E] 13.5 mm	4.5 mm	15-6000 psi	Air	UV
1.5 NPS	2, 3 NPS	224.318 mm²	[F] 16.9 mm	5.6 mm	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	366.435 mm²	[G] 21.6 mm	7.2 mm	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	572.555 mm²	[H] 27 mm	9 mm	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	934.82 mm²	[J] 34.5 mm	11.5 mm	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	1339.65 mm²	[K] 41.3 mm	13.8 mm	15-3000 psi	Air	UV
3-4 NPS	4, 6 NPS	2074.99 mm²	[L] 51.4 mm	17.1 mm	15-3000 psi	Air	UV
4 NPS	6 NPS	2623.89 mm²	[M] 57.8 mm	19.3 mm	15-1100 psi	Air	UV
4 NPS	6 NPS	3156.95 mm²	[N] 63.4 mm	21.1 mm	15-1013 psi	Air	UV
4 NPS	6 NPS	4644.54 mm²	[P] 76.9 mm	25.6 mm	15-1013 psi	Air	UV
6 NPS	8 NPS	8043.61 mm²	[Q] 101.2 mm	33.7 mm	15-720 psi	Air	UV
6 NPS	8, 10 NPS	11651.6 mm²	[R] 121.8 mm	40.6 mm	15-300 psi	Air	UV
8 NPS	10 NPS	18942.3 mm²	[T] 155.3 mm	51.8 mm	15-300 psi	Air	UV
10 NPS	14 NPS	31415.9 mm²	[V] 200 mm	66.7 mm	15-300 psi	Air	UV
12 NPS	16 NPS	45238.9 mm²	[W] 240 mm	80 mm	15-300 psi	Air	UV
14 NPS	18 NPS	61575.2 mm²	[Y] 280 mm	93.3 mm	15-300 psi	Air	UV
16 NPS	18 NPS	70685.8 mm²	[Z] 300 mm	100 mm	15-300 psi	Air	UV
18 NPS	24 NPS	101788 mm²	[AA] 360 mm	120 mm	15-300 psi	Air	UV
20 NPS	24 NPS	125664 mm²	[BB] 400 mm	133.3 mm	15-300 psi	Air	UV

Design Name:	WFO-L, WFB-L	NBCert #	03429
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	10/30/2029
--------------	----	------------

Design Type

[Safety Relief Valve] WFO-L, WFB-L
Capacity Tests: Sec. UV at National Board Testing Lab on February 1, 2023
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.632 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Neway Valve Group - Wujiang Dongwu Machinery Co., Ltd {DWM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	80.118 mm ²	[D] 10.1 mm	3.4 mm	30-6000 psi	Water	UV
1-1.5 NPS	2, 3 NPS	143.139 mm ²	[E] 13.5 mm	4.5 mm	30-6000 psi	Water	UV
1.5 NPS	2, 3 NPS	224.318 mm ²	[F] 16.9 mm	5.6 mm	30-5000 psi	Water	UV
1.5-2 NPS	3 NPS	366.435 mm ²	[G] 21.6 mm	7.2 mm	30-5000 psi	Water	UV
1.5-2 NPS	3 NPS	572.555 mm ²	[H] 27 mm	9 mm	30-6000 psi	Water	UV
2-3 NPS	3, 4 NPS	934.82 mm ²	[J] 34.5 mm	11.5 mm	30-3000 psi	Water	UV
3 NPS	4, 6 NPS	1339.65 mm ²	[K] 41.3 mm	13.8 mm	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	2074.99 mm ²	[L] 51.4 mm	17.1 mm	15-3000 psi	Water	UV
4 NPS	6 NPS	2623.89 mm ²	[M] 57.8 mm	19.3 mm	15-1100 psi	Water	UV
4 NPS	6 NPS	3156.95 mm ²	[N] 63.4 mm	21.1 mm	15-1013 psi	Water	UV
4 NPS	6 NPS	4644.54 mm ²	[P] 76.9 mm	25.6 mm	15-1013 psi	Water	UV
6 NPS	8 NPS	8043.61 mm ²	[Q] 101.2 mm	33.7 mm	15-720 psi	Water	UV
6 NPS	8, 10 NPS	11651.6 mm ²	[R] 121.8 mm	40.6 mm	15-300 psi	Water	UV
8 NPS	10 NPS	18942.3 mm ²	[T] 155.3 mm	51.8 mm	15-300 psi	Water	UV
10 NPS	14 NPS	31415.9 mm ²	[V] 200 mm	66.7 mm	15-300 psi	Water	UV
12 NPS	16 NPS	45238.9 mm ²	[W] 240 mm	80 mm	15-300 psi	Water	UV
14 NPS	18 NPS	61575.2 mm ²	[Y] 280 mm	93.3 mm	15-300 psi	Water	UV
16 NPS	18 NPS	70685.8 mm ²	[Z] 300 mm	100 mm	15-300 psi	Water	UV
18 NPS	24 NPS	101788 mm ²	[AA] 360 mm	120 mm	15-300 psi	Water	UV
20 NPS	24 NPS	125664 mm ²	[BB] 400 mm	133.3 mm	15-300 psi	Water	UV

Ningbo Dynamic Flow Technology Co., Ltd (NDF)

Nameplate Abbreviation: DNK

Ningbo City, 315800 People's Republic of China

This Company Manufactures or Assembles:

Design Name: BPF	NBCert # 02507
------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	01/31/2029
--------------	----	------------

Design Type

[Buckling Pin Non-reclosing Device] BPF
Capacity Tests: Sec. UD at National Board Testing Lab on May 27, 2022
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value:44.710 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: MNFA
Designed by: Ningbo Dynamic Flow Technology Co., Ltd {NDF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS	10 NPS	44.9 in ²			1-285 psi		UD
12 NPS	12 NPS	63.6 in ²			1-285 psi		UD
14 NPS	14 NPS	85.58 in ²			1-285 psi		UD
16 NPS	16 NPS	113.46 in ²			1-285 psi		UD
18 NPS	18 NPS	155.86 in ²			1-285 psi		UD
2 NPS	2 NPS	1.53 in ²			10-285 psi		UD
2.5 NPS	2.5 NPS	2.02 in ²			10-285 psi		UD
20 NPS	20 NPS	208.99 in ²			1-285 psi		UD
22 NPS	22 NPS	254.83 in ²			1-285 psi		UD
24 NPS	24 NPS	305.23 in ²			1-285 psi		UD
26 NPS	26 NPS	343.71 in ²			1-285 psi		UD
28 NPS	28 NPS	415.98 in ²			1-285 psi		UD
3 NPS	3 NPS	3.9 in ²			10-285 psi		UD
30 NPS	30 NPS	498.39 in ²			1-285 psi		UD
32 NPS	32 NPS	592.17 in ²			1-285 psi		UD
34 NPS	34 NPS	655.44 in ²			1-285 psi		UD
36 NPS	36 NPS	763.12 in ²			1-285 psi		UD
38 NPS	38 NPS	833.68 in ²			1-285 psi		UD
4 NPS	4 NPS	6.35 in ²			10-285 psi		UD
40 NPS	40 NPS	930.99 in ²			1-285 psi		UD
42 NPS	42 NPS	1033.68 in ²			1-285 psi		UD
44 NPS	44 NPS	1142.54 in ²			1-285 psi		UD
46 NPS	46 NPS	1255.97 in ²			1-285 psi		UD
48 NPS	48 NPS	1374.77 in ²			1-285 psi		UD
50 NPS	50 NPS	1498.93 in ²			1-285 psi		UD
52 NPS	52 NPS	1628.47 in ²			1-285 psi		UD
54 NPS	54 NPS	1803.59 in ²			1-720 psi		UD
56 NPS	56 NPS	1954.2 in ²			1-720 psi		UD
58 NPS	58 NPS	2114.49 in ²			1-720 psi		UD

6 NPS	6 NPS	16.8 in ²	1-285 psi	UD
60 NPS	60 NPS	2282.77 in ²	1-720 psi	UD
64 NPS	64 NPS	2663.16 in ²	1-720 psi	UD
68 NPS	68 NPS	3027.43 in ²	1-720 psi	UD
72 NPS	72 NPS	3392.79 in ²	1-720 psi	UD
76 NPS	76 NPS	3784.87 in ²	1-720 psi	UD
8 NPS	8 NPS	29.28 in ²	1-285 psi	UD
80 NPS	80 NPS	4212.27 in ²	1-720 psi	UD

Nirmal Industrial Controls Pvt. Ltd. (NIC)

Nameplate Abbreviation: NIRMAL

Thane, Maharashtra, 421601India

This Company Manufactures or Assembles:

Design Name:	Securamax (SR-08 Series)	NBCert #	01595
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/15/2031

Design Type

[Safety Relief Valve] Securamax (SR-08 Series)
Capacity Tests: Sec. UV at National Board Testing Lab on October 31, 2018
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.793 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable (Single Ring)
Designed by: Nirmal Industrial Controls Pvt. Ltd. {NIC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.044 in ²	[B] 0.237 in	0.0374 in	15-6090 psi	Air	UV
0.5-1 NPS	0.5-1 NPS	0.124 in ²	[D] 0.397 in	0.094 in	15-3697 psi	Air	UV
0.75-1 NPS	.75-1 NPS	0.222 in ²	[E] 0.532 in	0.126 in	15-2218 psi	Air	UV
1-1.5 NPS	1-1.5 NPS	0.352 in ²	[F] 0.669 in	0.153 in	15-739 psi	Air	UV
1-1.5 NPS	1-1.5 NPS	0.568 in ²	[G] 0.85 in	0.177 in	15-284.2 psi	Air	UV

Design Name:	Securamax (SR-08 Series) (Liquid)	NBCert #	01607
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/15/2031

Design Type

[Safety Relief Valve] Securamax (SR-08 Series) (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on October 31, 2018
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.622 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Designed by: Nirmal Industrial Controls Pvt. Ltd. {NIC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.044 in ²	[B] 0.237 in	0.0374 in	15-6090 psi	Air	UV
0.5-1 NPS	0.5-1 NPS	0.124 in ²	[D] 0.397 in	0.0944 in	15-3697 psi	Air	UV
0.75-1 NPS	.75-1 NPS	0.222 in ²	[E] 0.532 in	0.126 in	15-2218 psi	Air	UV
1-1.5 NPS	1-1.5 NPS	0.352 in ²	[F] 0.669 in	0.1535 in	15-739 psi	Air	UV
1-1.5 NPS	1-1.5 NPS	0.568 in ²	[G] 0.85 in	0.177 in	15-284.2 psi	Air	UV

Design Name: Securamax SR-07 Series NBCert # 00819

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/26/2029

Design Type

[Safety Relief Valve] Securamax SR-07 Series
Capacity Tests: Sec. UV at National Board Testing Lab on March 7, 2016
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Nirmal Industrial Controls Pvt. Ltd. {NIC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.124 in ²	[D] 0.398 in	0.134 in	15-3697 psi	Air	UV
1-1.5 NPS	2 NPS	0.224 in ²	[E] 0.531 in	0.134 in	15-3697 psi	Air	UV
1.5 NPS	2, 3 NPS	0.352 in ²	[F] 0.669 in	0.17 in	15-3697 psi	Air	UV
1.5-2 NPS	3 NPS	0.567 in ²	[G] 0.85 in	0.213 in	15-3697 psi	Air	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.268 in	15-2755 psi	Air	UV
2-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.362 in	0.342 in	15-2697 psi	Air	UV
3 NPS	4, 6 NPS	2.096 in ²	[K] 1.634 in	0.394 in	15-2218 psi	Air	UV
3-4 NPS	4, 6 NPS	3.228 in ²	[L] 2.028 in	0.55 in	15-1493 psi	Air	UV
4 NPS	6 NPS	3.817 in ²	[M] 2.205 in	0.55 in	15-1102 psi	Air	UV
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	0.64 in	15-1000 psi	Air	UV
4 NPS	6 NPS	7.027 in ²	[P] 2.992 in	0.76 in	15-1000 psi	Air	UV
6 NPS	8 NPS	12.915 in ²	[Q] 4.055 in	1.02 in	15-609 psi	Air	UV
6 NPS	8, 10 NPS	15.882 in ²	[R] 4.488 in	1.2 in	15-304 psi	Air	UV
8 NPS	10 NPS	27.92 in ²	[T] 5.965 in	1.54 in	15-304 psi	Air	UV

Design Name: Securamax SR-07 Series (Liquid) NBCert # 00820

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/15/2031

Design Type

[Safety Relief Valve] Securamax SR-07 Series (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on October 31, 2018
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.677 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Nirmal Industrial Controls Pvt. Ltd. {NIC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.124 in ²	[D] 0.398 in	0.134 in	15-3697 psi	Water	UV
1-1.5 NPS	2 NPS	0.224 in ²	[E] 0.531 in	0.134 in	15-3697 psi	Water	UV
1.5 NPS	2, 3 NPS	0.352 in ²	[F] 0.669 in	0.17 in	15-3697 psi	Water	UV
1.5-2 NPS	3 NPS	0.567 in ²	[G] 0.85 in	0.213 in	15-3697 psi	Water	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.268 in	15-2755 psi	Water	UV
2-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.362 in	0.342 in	15-2697 psi	Water	UV
3 NPS	4, 6 NPS	2.096 in ²	[K] 1.634 in	0.394 in	15-2218 psi	Water	UV
3-4 NPS	4, 6 NPS	3.228 in ²	[L] 2.028 in	0.55 in	15-1493 psi	Water	UV
4 NPS	6 NPS	3.817 in ²	[M] 2.205 in	0.55 in	15-1102 psi	Water	UV
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	0.64 in	15-1000 psi	Water	UV
4 NPS	6 NPS	7.027 in ²	[P] 2.992 in	0.76 in	15-1000 psi	Water	UV
6 NPS	8 NPS	12.915 in ²	[Q] 4.055 in	1.02 in	15-609 psi	Water	UV
6 NPS	8, 10 NPS	15.882 in ²	[R] 4.488 in	1.2 in	15-304 psi	Water	UV
8 NPS	10 NPS	27.92 in ²	[T] 5.965 in	1.54 in	15-304 psi	Water	UV

Norriseal-Wellmark, Inc. (NWK)

Houston, TX 77041United States

This Company Manufactures or Assembles:

Design Name: 2600 (Liquid)		NBCert # 66079
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/04/2028

Design Type

[Safety Relief Valve] 2600 (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on May 4, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.628 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Norriseal-Wellmark, Inc. {NWK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.5 NPS	1-2 NPS	0.125 in ²	[D] 0.4 in	0.224 in	15-2500 psi	Water	UV

0.75-2 NPS	1-3 NPS	0.223 in ²	[E] 0.534 in	0.246 in	15-2500 psi	Water	UV
1.5-2 NPS	1.5-3 NPS	0.354 in ²	[F] 0.672 in	0.301 in	15-2500 psi	Water	UV
1.5-2 NPS	1.5-3 NPS	0.576 in ²	[G] 0.857 in	0.363 in	75-2500 psi	Water	UV

Design Name:	2600 Series	NBCert #	66068
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/04/2028

Design Type

[Safety Relief Valve] 2600 Series
Capacity Tests: Sec. UV at National Board Testing Lab on March 5, 2007
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless
Media - ; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Norriseal-Wellmark, Inc. {NWK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 - 2 NPS	0.068 in ²	[C] 0.295 in		15-2500 psi	Air	UV
0.5-1.5 NPS	1 - 2 NPS	0.125 in ²	[D] 0.4 in		15-2500 psi	Air	UV
0.75-2 NPS	1 - 3 NPS	0.223 in ²	[E] 0.534 in		15-2500 psi	Air	UV
1.5-2 NPS	1.5 - 3 NPS	0.354 in ²	[F] 0.672 in		15-2500 psi	Air	UV
1.5-2 NPS	1.5 - 3 NPS	0.576 in ²	[G] 0.857 in		75-2500 psi	Air	UV

Design Name:	W9503	NBCert #	66057
--------------	-------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/04/2028

Design Type

[Safety Relief Valve] W9503
Capacity Tests: Sec. UV at National Board Testing Lab on June 16, 1999
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:36.120 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Norriseal-Wellmark, Inc. {NWK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS	3 NPS	3.142 in ²	2 in		15-125 psi	Air	UV

North American Machine Works, Inc. (ANA)

Nameplate Abbreviation: NAMW

Folcroft, PA 19032United States

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S	NBCert # 57057
---------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	08/12/2025
-----------	----	------------

Design Type

[Safety Relief Valve] 2600 & 2600S
 Capacity Tests: Sec. UV at unknown lab on June 11, 1972
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.858 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV

8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/12/2025

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV

4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids) NBCert # 57068

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/12/2025

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V

12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V
--------	--------	-----------------------	----------	--------	------------	-------	-------

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	08/12/2025
-----------	----	------------

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	08/12/2025
-----------	----	------------

Design Type

[Relief Valve] 2700L, 3700L (Liquids)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.676 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 4200 / 4400

NBCert #

57282

Manufacturer/Assembler	Designators	Expiration Date
Assembler	V	09/26/2025

Design Type

[Safety Valve] 4200 / 4400

Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.872 Unitless

Media - Test: Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable (Dual Ring)

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

North American Safety Valve Industries, Inc. (NAS)

Nameplate Abbreviation: NASVI

North Kansas City, MO 64116United States

This Company Manufactures or Assembles:

Design Name:	19 Series	NBCert #	11282
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	08/22/2029

Design Type

[Safety Valve] 19 Series
 Capacity Tests: Sec. UV, V at unknown lab on March 27, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.826 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.129 in ²	[D] 0.406 in	0.101 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.129 in ²	[D] 0.406 in	0.101 in	15-300 psi	Steam	UV, V
0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Air	UV
0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Steam	UV, V
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Air	UV
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Steam	UV, V
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Air	UV
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Steam	UV, V

Design Name:	Kunkle 1, 2	NBCert #	36223
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/22/2026

Design Type

[Safety Valve] Kunkle 1, 2
 Capacity Tests: Sec. UV at unknown lab on July 1, 1953
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.823 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, Top NPS	0.049 in ²	0.75 in	0.029 in	15-250 psi	Air	UV
0.5-0.75 NPS	.75, Top NPS	0.049 in ²	0.75 in	0.029 in	15-250 psi	Steam	UV
1 NPS	1, Top NPS	0.0844 in ²	1 in	0.038 in	15-250 psi	Air	UV
1 NPS	1, Top NPS	0.0844 in ²	1 in	0.038 in	15-250 psi	Steam	UV

Design Name:	Kunkle 189, 363, 389	NBCert #	36043
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/22/2026

Design Type

[Safety Relief Valve] Kunkle 189, 363, 389
Capacity Tests: Sec. UV at unknown lab on April 15, 1958
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.874 Unitless
Media - ; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.034 in ²	0.5 in	0.031 in	50-2500 psi	Air	UV

Design Name:	Kunkle 264, 265, 266 & 267	NBCert #	36267
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/22/2029

Design Type

[Safety Relief Valve] Kunkle 264, 265, 266 & 267
Capacity Tests: Sec. UV at unknown lab on July 20, 1956
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.766 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.115 in	15-2000 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.115 in	15-3300 psi	Air	UV

Design Name:	Kunkle 30	NBCert #	36335
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/22/2026

Design Type

[Safety Relief Valve] Kunkle 30
Capacity Tests: Sec. UV at unknown lab on December 18, 1989
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.186 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS			0.157 in	0.1 in	60-4000 psi	Air	UV

Design Name: Kunkle 300,600 NBCert # 36076

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV, V

07/22/2026

Design Type

[Safety Valve] Kunkle 300,600
Capacity Tests: Sec. UV, V at unknown lab on February 10, 1961
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	UV
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	V
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	V
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Air	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	V
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Air	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	V
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Air	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	V

3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	V
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Air	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	UV

Design Name: Kunkle 330. 330S, 333S NBCert # 36087

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/22/2026

Design Type

[Safety Relief Valve] Kunkle 330. 330S, 333S
Capacity Tests: Sec. UV at unknown lab on June 14, 1972
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.026 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.5 NPS			0.047 in	0.05 in	1000-7500 psi	Air	UV

Design Name: Kunkle 337 NBCert # 36278

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/23/2026

Design Type

[Safety Relief Valve] Kunkle 337
Capacity Tests: Sec. UV at unknown lab on February 22, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	1.916 in ²	1.562 in	0.612 in	15-60 psi	Air	UV
2.5 NPS	2.5 NPS	2.786 in ²	1.883 in	0.755 in	15-60 psi	Air	UV
3 NPS	3 NPS	4.037 in ²	2.267 in	0.91 in	15-60 psi	Air	UV

Design Name:	Kunkle 541-A/542-A (.295 orifice)	NBCert #	36469
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/22/2026

Design Type

[Safety Relief Valve] Kunkle 541-A/542-A (.295 orifice)
Capacity Tests: Sec. UV at unknown lab on December 14, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.000 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS		0.068 in ²	0.295 in	0.126 in	15-200 psi	Air	UV

Design Name:	Kunkle 541-C/542-C/548-C (.422 Orifice)	NBCert #	36302
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/22/2026

Design Type

[Safety Relief Valve] Kunkle 541-C/542-C/548-C (.422 Orifice)
Capacity Tests: Sec. UV at unknown lab on May 20, 1988
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.000 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	Side NPS	0.14 in ²	0.422 in	0.2 in	15-400 psi	Air	UV

Design Name:	Kunkle 548-A (.295 Orifice)	NBCert #	36290
--------------	-----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/19/2026

Design Type

[Safety Relief Valve] Kunkle 548-A (.295 Orifice)
Capacity Tests: Sec. UV at unknown lab on May 20, 1988
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.000 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.375 NPS	Side NPS	0.068 in ²	0.295 in	0.126 in	15-400 psi	Air	UV

Design Name:	Kunkle 6000, 6252 Series	NBCert #	36324
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV, V	08/22/2029
-----------	-------	------------

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V

4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 910 to 919 NBCert # 36100

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/23/2026

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name: Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid) NBCert # 36111

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	07/22/2026

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 , 1 NPS	0.1213 in²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

Design Name:	Kunkle 920, 921, 927, Agco A (High Temp. water)	NBCert #	36098
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	V	07/22/2026	

Design Type

[Safety Valve] Kunkle 920, 921, 927, Agco A (High Temp. water)
Capacity Tests: Sec. V at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Forced Flow Steam Generator/High Temp Hot Water (10% BD)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	V
0.75-1.25 NPS	1.25 NPS	0.2157 in²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	V
1-1.5 NPS	1.5 NPS	0.3369 in²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	V
1.25-2 NPS	2 NPS	0.553 in²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	V
1.5-2 NPS	2.5 NPS	0.864 in²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	V
2-2.5 NPS	3 NPS	1.415 in²	[J] 1.342 in	0.363 in	15-800 psi	Steam	V

NUOVA GENERAL INSTRUMENTS S.R.L. (NGI)

Pianello Val Tidone, 29010Italy

This Company Manufactures or Assembles:

Design Name: A001	NBCert # 32500
-------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 12/02/2028

Design Type

[Safety Valve] A001
Capacity Tests: Sec. UV at National Board Testing Lab on May 20, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.712 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: NUOVA GENERAL INSTRUMENTS S.R.L. {NGI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.375 NPS		38.5 mm ²	7 mm	2.1 mm	15-240 psi	Steam	UV
0.25-0.375 NPS		38.5 mm ²	7 mm	2.1 mm	15-870 psi	Air	UV
0.375-0.75 NPS		78.5 mm ²	10 mm	3 mm	15-1537 psi	Air	UV
0.375-0.75 NPS		78.5 mm ²	10 mm	3 mm	15-240 psi	Steam	UV
0.5 NPS		113 mm ²	12 mm	3.6 mm	15-240 psi	Steam	UV
0.5 NPS		113 mm ²	12 mm	3.6 mm	15-435 psi	Air	UV
0.5-1 NPS		154 mm ²	14 mm	4.2 mm	15-1160 psi	Air	UV
0.5-1 NPS		154 mm ²	14 mm	4.2 mm	15-240 psi	Steam	UV
1 NPS		254 mm ²	18 mm	5.4 mm	15-240 psi	Steam	UV
1 NPS		254 mm ²	18 mm	5.4 mm	15-304 psi	Air	UV
1 NPS		314 mm ²	20 mm	6 mm	15-240 psi	Steam	UV
1 NPS		314 mm ²	20 mm	6 mm	15-870 psi	Air	UV
1-1.5 NPS		491 mm ²	25 mm	7.5 mm	15-240 psi	Steam	UV
1-1.5 NPS		491 mm ²	25 mm	7.5 mm	15-435 psi	Air	UV
1.5 NPS		804 mm ²	32 mm	9.6 mm	15-177 psi	Steam	UV
1.5 NPS		804 mm ²	32 mm	9.6 mm	15-203 psi	Air	UV
1.5-2 NPS		1134 mm ²	38 mm	11.4 mm	15-240 psi	Steam	UV
1.5-2 NPS		1134 mm ²	38 mm	11.4 mm	15-435 psi	Air	UV
1.5-2 NPS		1257 mm ²	40 mm	12 mm	15-240 psi	Steam	UV
1.5-2 NPS		1257 mm ²	40 mm	12 mm	15-435 psi	Air	UV

Design Name: A002	NBCert # 32511
-------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/09/2029

Design Type

[Safety Valve] A002
 Capacity Tests: Sec. UV at National Board Testing Lab on October 18, 2005
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.622 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: NUOVA GENERAL INSTRUMENTS S.R.L. {NGI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	19.6 mm ²	5 mm	1.5 mm	15-240 psi	Steam	UV
0.5-1 NPS	1 NPS	19.6 mm ²	5 mm	1.5 mm	15-8702 psi	Air	UV
0.25-0.375 NPS	.5 NPS	38.5 mm ²	7 mm	2.1 mm	15-240 psi	Steam	UV
0.25-0.375 NPS	.5 NPS	38.5 mm ²	7 mm	2.1 mm	15-870 psi	Air	UV
0.5-1 NPS	1 NPS	50.2 mm ²	8 mm	2.4 mm	15-4351 psi	Air	UV
0.5-1 NPS	1 NPS	50.2 mm ²	8 mm	2.4 mm	15-240 psi	Steam	UV
0.375-1 NPS	.75, 1 NPS	78.5 mm ²	10 mm	3 mm	15-2175 psi	Air	UV
0.375-1 NPS	.75, 1 NPS	78.5 mm ²	10 mm	3 mm	15-240 psi	Steam	UV
0.5-1 NPS	1 NPS	143 mm ²	13.5 mm	4.1 mm	15-240 psi	Steam	UV
0.5-1 NPS	1 NPS	143 mm ²	13.5 mm	4.1 mm	15-870 psi	Air	UV
0.5-1.25 NPS	1, 1.25 NPS	154 mm ²	14 mm	4.2 mm	15-2175 psi	Air	UV
0.5-1.25 NPS	1, 1.25 NPS	154 mm ²	14 mm	4.2 mm	15-240 psi	Steam	UV
1-1.25 NPS	1.25 NPS	314 mm ²	20 mm	6 mm	15-240 psi	Steam	UV
1-1.25 NPS	1.25 NPS	314 mm ²	20 mm	6 mm	15-870 psi	Air	UV
1-1.5 NPS	1.5 NPS	491 mm ²	25 mm	7.4 mm	15-240 psi	Steam	UV
1-1.5 NPS	1.5 NPS	491 mm ²	25 mm	7.4 mm	15-870 psi	Air	UV
1.5-1.5 NPS	1.5 NPS	804 mm ²	32 mm	9.6 mm	15-177 psi	Steam	UV
1.5-1.5 NPS	1.5 NPS	804 mm ²	32 mm	9.6 mm	15-203 psi	Air	UV
1.5-2 NPS	2 NPS	1134 mm ²	38 mm	11.4 mm	15-240 psi	Steam	UV
1.5-2 NPS	2 NPS	1134 mm ²	38 mm	11.4 mm	15-435 psi	Air	UV
1.5-2 NPS	2 NPS	1257 mm ²	40 mm	12 mm	15-203 psi	Air	UV
1.5-2 NPS	2 NPS	1257 mm ²	40 mm	12 mm	15-203 psi	Steam	UV

NYNE MECHANICAL LLC (NYM)

Auburn, MA 01501United States

This Company Manufactures or Assembles:

Design Name:	243/249/443/449/546/843/849/943/5046/5049/8043/8049	NBCert #	01292
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	07/24/2026	

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
 Capacity Tests: Sec. UV at unknown lab on August 8, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name: 253/259/453/459/853/859/953/959/5059/8053/8059 NBCert # 01304

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/24/2026

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
 Capacity Tests: Sec. UV at unknown lab on July 31, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.627 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV

4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 263/269/463/469/566/863/869/963/969/5066/5069 NBCert # 01315

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/24/2026

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069

Capacity Tests: Sec. UV at unknown lab on July 30, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.860 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/24/2026

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.767 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

07/24/2026

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV

4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 81, 81P, 83, 84 NBCert # 01089

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/14/2029

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 900 Series (Liquid), 7700, SNC NBCert # 15499

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/24/2026

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.661 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name: 900 Series, 7700, SNC

NBCert #

15411

Manufacturer/Assembler

Designators

Expiration Date

Assembler

UV

07/24/2026

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV

1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/24/2026

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V

4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/24/2026

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/ABNBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/24/2026

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.865 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV

6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Oklahoma Safety Equipment Company, Inc. (OSECO) (OSE)

Nameplate Abbreviation: OSECOELFAB

Broken Arrow, OK 74012United States

This Company Manufactures or Assembles:

Design Name: (F) COV, (F) COH		NBCert #	00033
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UD	08/27/2026	
Design Type			
<div>[Rupture Disk Device] (F) COV, (F) COH HolderDesignation: FRDI Capacity Tests: Sec. UD at National Board Testing Lab on July 1, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 2.370 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}</div>			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.6 in ²			44-2000 psi		UD
1.5 NPS		1.48 in ²			31-1400 psi		UD
10 NPS		72.7 in ²			4-480 psi		UD
12 NPS		101 in ²			3-400 psi		UD
14 NPS		135 in ²			3-350 psi		UD
16 NPS		176 in ²			3-300 psi		UD

18 NPS	230 in ²	3-270 psi	UD
2 NPS	2.85 in ²	15-1100 psi	UD
20 NPS	279 in ²	3-240 psi	UD
24 NPS	415 in ²	3-200 psi	UD
28 NPS	562 in ²	3-185 psi	UD
3 NPS	5.41 in ²	11-900 psi	UD
30 NPS	650 in ²	3-175 psi	UD
32 NPS	754 in ²	3-165 psi	UD
34 NPS	855 in ²	3-158 psi	UD
36 NPS	955 in ²	3-150 psi	UD
4 NPS	10.3 in ²	8-830 psi	UD
40 NPS	1194 in ²	3-143 psi	UD
42 NPS	1320 in ²	3-150 psi	UD
6 NPS	22.6 in ²	6-640 psi	UD
8 NPS	45.6 in ²	5-590 psi	UD

Design Name:	(F) STD-OTU	NBCert #	00279
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/25/2031

Design Type

[Rupture Disk Device] (F) STD-OTU
HolderDesignation: OTU Body
Capacity Tests: Sec. UD at National Board Testing Lab on July 9, 2002
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 2.870 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.196 in ²	0.5 in		200-8200 psi		UD
0.75 NPS		0.441 in ²	0.75 in		200-5200 psi		UD
1 NPS		0.785 in ²	1 in		200-3800 psi		UD

Design Name:	0.25" STD	NBCert #	02811
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD3 03/07/2030

Design Type

[Rupture Disk Device] 0.25" STD
HolderDesignation:
Capacity Tests: Sec. UD3 at Oklahoma Safety Equipment Company, Inc. (OSECO) on March 7, 2024
Certified Value: 0.000 Unitless; (alternate medium): 0.000
Media - ; Certified: Air, Gas, Liquid
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS		0.0492 in²			10000-100000 psi		UD3
Design Name: CO (F) Flat SeatNBCert #00190							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			04/27/2029	
Design Type							
[Rupture Disk Device] CO (F) Flat Seat HolderDesignation: FRDI Capacity Tests: Sec. UD at National Board Testing Lab on October 26, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 0.500 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in²			43-2000 psi		UD
1.5 NPS		2.036 in²			31-1400 psi		UD
10 NPS		75.74 in²			4-480 psi		UD
12 NPS		107.8 in²			3-400 psi		UD
14 NPS		137.8 in²			3-350 psi		UD
16 NPS		180.1 in²			3-300 psi		UD
18 NPS		233.7 in²			3-270 psi		UD
2 NPS		3.355 in²			15-1100 psi		UD
20 NPS		281.7 in²			3-240 psi		UD
24 NPS		405.9 in²			3-200 psi		UD
28 NPS		522.7 in²			3-185 psi		UD
3 NPS		7.393 in²			11-900 psi		UD
30 NPS		634.7 in²			3-175 psi		UD
32 NPS		722.2 in²			3-165 psi		UD
36 NPS		914.3 in²			3-150 psi		UD
4 NPS		12.73 in²			8-830 psi		UD
42 NPS		1244.9 in²			3-135 psi		UD
6 NPS		28.89 in²			6-640 psi		UD
8 NPS		50 in²			5-590 psi		UD
Design Name: FAS (Liquid)NBCert #00202							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			01/25/2031	

Design Type

[Rupture Disk Device] FAS (Liquid)
 HolderDesignation: FRDI, Safety Cartridge
 Capacity Tests: Sec. UD at National Board Testing Lab on August 24, 2000
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 0.190 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			70-6500 psi		UD
1.5 NPS		2.036 in ²			50-6500 psi		UD
10 NPS		78.9 in ²			35-1500 psi		UD
12 NPS		113.1 in ²			35-1300 psi		UD
14 NPS		137.9 in ²			40-1000 psi		UD
16 NPS		176.7 in ²			45-900 psi		UD
18 NPS		233.7 in ²			50-800 psi		UD
2 NPS		3.355 in ²			40-5500 psi		UD
24 NPS		424.6 in ²			40-600 psi		UD
3 NPS		7.393 in ²			25-5000 psi		UD
4 NPS		12.73 in ²			25-2000 psi		UD
6 NPS		28.89 in ²			25-1800 psi		UD
8 NPS		50 in ²			30-1500 psi		UD

Design Name: FAS, WDA/FAS NBCert # 00011

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/09/2026

Design Type

[Rupture Disk Device] FAS, WDA/FAS
 HolderDesignation: FRDI, Safety Cartridge
 Capacity Tests: Sec. UD at National Board Testing Lab on November 11, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.223 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			70-6500 psi		UD
1.5 NPS		2.036 in ²			50-6500 psi		UD
10 NPS		78.9 in ²			35-1500 psi		UD
12 NPS		113.1 in ²			35-1300 psi		UD
14 NPS		137.9 in ²			40-1000 psi		UD
16 NPS		176.7 in ²			45-900 psi		UD
18 NPS		233.7 in ²			50-800 psi		UD
2 NPS		3.355 in ²			40-5500 psi		UD

24 NPS	424.6 in ²	40-600 psi	UD
3 NPS	7.393 in ²	25-5000 psi	UD
4 NPS	12.73 in ²	25-2000 psi	UD
6 NPS	28.89 in ²	25-1800 psi	UD
8 NPS	50 in ²	30-1500 psi	UD

Design Name: FST, FSTL, SST, SSTL

NBCert #

00257

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UD

01/25/2031

Design Type

[Rupture Disk Device] FST, FSTL, SST, SSTL

HolderDesignation: FRDI

Capacity Tests: Sec. UD at National Board Testing Lab on October 6, 1999

Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl

Certified Value: 2.290 Unitless

Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)

Set Pressure Definition: Burst Pressure

Flow Area Configuration: MNFA

Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.304 in ²			95-400 psi		UD
1 NPS		0.864 in ²			55-400 psi		UD
1.5 NPS		2.036 in ²			45-400 psi		UD
2 NPS		3.355 in ²			40-400 psi		UD
3 NPS		7.393 in ²			35-400 psi		UD
4 NPS		12.73 in ²			30-400 psi		UD
6 NPS		28.94 in ²			25-400 psi		UD
8 NPS		50 in ²			25-400 psi		UD

Design Name: GR, GRO

NBCert #

00246

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UD

02/16/2029

Design Type

[Rupture Disk Device] GR, GRO

Capacity Tests: Sec. UD at National Board Testing Lab on September 20, 2001

Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl

Certified Value: 1.220 Unitless

Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)

Set Pressure Definition: Burst Pressure

Flow Area Configuration: MNFA

Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.714 in ²			20-150 psi		UD
1.5 NPS		1.606 in ²			13-150 psi		UD
10 NPS		71.4 in ²			2.5-150 psi		UD
2 NPS		2.856 in ²			10-150 psi		UD

3 NPS	6.426 in ²	7-150 psi	UD
4 NPS	11.42 in ²	5-150 psi	UD
6 NPS	25.7 in ²	3-150 psi	UD
8 NPS	45.7 in ²	2.5-150 psi	UD

Design Name: HPSR (Air & Gases) NBCert # 01731

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	08/30/2025

Design Type

[Rupture Disk Device] HPSR (Air & Gases)
 HolderDesignation: HPSR Insert Holder, HPSR Welded RF, HPSR Welded RTJ
 Capacity Tests: Sec. UD at Oklahoma Safety Equipment Company, Inc. (OSECO) on December 20, 2018
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 1.450 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.31 in ²			2500-6000 psi		UD
2 NPS		0.994 in ²			2500-6000 psi		UD
3 NPS		2.074 in ²			1000-6000 psi		UD
4 NPS		3.715 in ²			2500-6000 psi		UD
6 NPS		7.52 in ²			2500-6000 psi		UD
8 NPS		13.17 in ²			2500-6000 psi		UD

Design Name: HPSR-LP (Liquid) NBCert # 01843

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/16/2030

Design Type

[Rupture Disk Device] HPSR-LP (Liquid)
 HolderDesignation: WDA Welded Holder, HPRDI Insert Holder
 Capacity Tests: Sec. UD at Oklahoma Safety Equipment Company, Inc. (OSECO) on October 1, 2018
 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krl
 Certified Value:24.000 Unitless
 Media - Test: Air/Gas; Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.31 in ²			500-700 psi		UD

Design Name: LoKr NBCert # 02619

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	07/14/2028

Design Type

[Rupture Disk Device] LoKr
HolderDesignation: LKR, Safety Cartridge, Safety Cartridge DUO
Capacity Tests: Sec. UD at Oklahoma Safety Equipment Company, Inc. (OSECO) on May 11, 2022
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.220 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		2.04 in ²			10-2200 psi		UD
10 NPS		78.85 in ²			10-500 psi		UD
12 NPS		111.9 in ²			10-300 psi		UD
2 NPS		3.36 in ²			10-2200 psi		UD
3 NPS		7.39 in ²			10-2200 psi		UD
4 NPS		12.73 in ²			10-1500 psi		UD
6 NPS		28.89 in ²			10-750 psi		UD
8 NPS		50.02 in ²			10-750 psi		UD

Design Name: LoKr (1 in.) NBCert # 02620

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

07/14/2028

Design Type

[Rupture Disk Device] LoKr (1 in.)
HolderDesignation: LKR, Safety Cartridge
Capacity Tests: Sec. UD at Oklahoma Safety Equipment Company, Inc. (OSECO) on May 11, 2022
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl
Certified Value: 0.210 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			15-2500 psi		UD

Design Name: OPFTK+ NBCert # 00426

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

06/20/2027

Design Type

[Rupture Disk Device] OPFTK+
HolderDesignation: OPK, Safety Cartridge
Capacity Tests: Sec. UD at National Board Testing Lab on February 19, 2010
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 2.770 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.792 in ²			100-1160 psi		UD
1.5 NPS		1.709 in ²			100-1087 psi		UD
10 NPS		67.64 in ²			50-274 psi		UD
12 NPS		99.28 in ²			50-250 psi		UD
2 NPS		2.899 in ²			100-1015 psi		UD
3 NPS		7.029 in ²			100-600 psi		UD
4 NPS		11.17 in ²			100-363 psi		UD
6 NPS		24.18 in ²			75-320 psi		UD
8 NPS		45.46 in ²			50-300 psi		UD

Design Name:	OPFTR+	NBCert #	00437
--------------	--------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	06/29/2027
--------------	----	------------

Design Type

[Rupture Disk Device] OPFTR+
HolderDesignation: OPR, Safety Cartridge
Capacity Tests: Sec. UD at National Board Testing Lab on February 3, 2010
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 1.700 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.775 in ²			47-250 psi		UD
1.5 NPS		1.693 in ²			25-250 psi		UD
10 NPS		65.05 in ²			19-100 psi		UD
12 NPS		94.87 in ²			19-100 psi		UD
2 NPS		2.843 in ²			15-250 psi		UD
3 NPS		6.809 in ²			8-200 psi		UD
4 NPS		10.96 in ²			5-175 psi		UD
6 NPS		23.38 in ²			15-100 psi		UD
8 NPS		44.18 in ²			19-100 psi		UD

Design Name:	OPK+	NBCert #	00459
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	09/20/2028
--------------	----	------------

Design Type

[Rupture Disk Device] OPK+
HolderDesignation: OPK, Safety Cartridge
Capacity Tests: Sec. UD at National Board Testing Lab on February 3, 2010
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 1.500 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.792 in ²			100-1160 psi		UD
1.5 NPS		1.709 in ²			100-1087 psi		UD
10 NPS		67.64 in ²			50-274 psi		UD
12 NPS		99.28 in ²			50-250 psi		UD
2 NPS		2.899 in ²			100-1015 psi		UD
3 NPS		7.029 in ²			100-600 psi		UD
4 NPS		11.17 in ²			100-363 psi		UD
6 NPS		24.18 in ²			75-320 psi		UD
8 NPS		45.46 in ²			50-300 psi		UD

Design Name: OPK+ (3/4")NBCert #02901

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/10/2030

Design Type

[Rupture Disk Device] OPK+ (3/4")
HolderDesignation: OPK
Capacity Tests: Sec. UD at National Board Testing Lab on March 21, 2024
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl
Certified Value: 1.500 Unitless; (alternate medium): 0.000
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	NPS	0.533 in ²	0 in	0 in	100-1160 psi		UD

Design Name: OPR+NBCert #00448

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	06/29/2027

Design Type

[Rupture Disk Device] OPR+
HolderDesignation: OPR, Safety Cartridge
Capacity Tests: Sec. UD at National Board Testing Lab on October 30, 2009
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.780 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.775 in ²			47-250 psi		UD
1.5 NPS		1.693 in ²			25-250 psi		UD
10 NPS		65.05 in ²			13-100 psi		UD
12 NPS		94.87 in ²			13-100 psi		UD
2 NPS		2.843 in ²			15-250 psi		UD
3 NPS		6.809 in ²			8-200 psi		UD
4 NPS		10.96 in ²			5-175 psi		UD
6 NPS		23.38 in ²			13-100 psi		UD
8 NPS		44.18 in ²			13-100 psi		UD

Design Name:	PCR, PCRL	NBCert #	00055
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/09/2026

Design Type

[Rupture Disk Device] PCR, PCRL
HolderDesignation: PRDI, Safety Cartridge
Capacity Tests: Sec. UD at National Board Testing Lab on November 11, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 2.170 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.39 in ²			85-750 psi	Air	UD
1 NPS		0.6 in ²			95-1250 psi		UD
1.5 NPS		1.3 in ²			70-2500 psi		UD
10 NPS		51.25 in ²			30-700 psi		UD
12 NPS		73.4 in ²			25-500 psi		UD
2 NPS		2.5 in ²			45-1000 psi		UD
3 NPS		4.8 in ²			35-1000 psi		UD
4 NPS		8 in ²			30-870 psi		UD
6 NPS		18 in ²			25-800 psi		UD
8 NPS		32 in ²			35-700 psi		UD

Design Name:	PRO +, PRO+L, RPRO+, RPRO+L (air/gas)	NBCert #	00381
--------------	---------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/20/2028

Design Type

[Rupture Disk Device] PRO +, PRO+L, RPRO+, RPRO+L (air/gas)
HolderDesignation: PRDI
Capacity Tests: Sec. UD at National Board Testing Lab on October 7, 2005
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.290 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			21-1000 psi		UD
1.5 NPS		2.036 in ²			14-1000 psi		UD
10 NPS		78.9 in ²			4-250 psi	Air	UD
2 NPS		3.355 in ²			8-750 psi		UD
3 NPS		7.393 in ²			8-500 psi		UD
4 NPS		12.73 in ²			8-500 psi		UD
6 NPS		28.89 in ²			6-300 psi		UD
8 NPS		50 in ²			6-250 psi	Air	UD

Design Name: PRO+KRGL, PRO+KRGL-L NBCert # 00460

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

10/22/2028

Design Type

[Rupture Disk Device] PRO+KRGL, PRO+KRGL-L
HolderDesignation: PRDI, Safety Cartridge
Capacity Tests: Sec. UD at National Board Testing Lab on October 22, 2010
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.690 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			21-1000 psi	Water	UD
1.5 NPS		2.036 in ²			14-1000 psi		UD
10 NPS		78.9 in ²			4-250 psi	Water	UD
2 NPS		3.355 in ²			8-1000 psi		UD
3 NPS		7.393 in ²			8-900 psi		UD
4 NPS		12.73 in ²			8-800 psi		UD
6 NPS		28.89 in ²			6-750 psi		UD
8 NPS		50 in ²			6-500 psi	Water	UD

Design Name: PROS NBCert # 00235

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

02/26/2031

Design Type

[Rupture Disk Device] PROS
Capacity Tests: Sec. UD at National Board Testing Lab on November 19, 2001
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 5.070 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.441 in ²			38-150 psi		UD
1.5 NPS		1.227 in ²			32-135 psi		UD
2 NPS		2.405 in ²			27-115 psi		UD
3 NPS		5.939 in ²			20-75 psi		UD
4 NPS		10.78 in ²			16-70 psi		UD

Design Name: PSR, PSRL, SSR, SSRL NBCert # 00077

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/22/2027

Design Type

[Rupture Disk Device] PSR, PSRL, SSR, SSRL
HolderDesignation: PRDI
Capacity Tests: Sec. UD at National Board Testing Lab on March 31, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 2.130 Unitless
Media - Test: Air/Gas; Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.6 in ²			40-225 psi		UD
1.5 NPS		1.3 in ²			25-200 psi		UD
10 NPS		51.25 in ²			15-100 psi		UD
12 NPS		73.4 in ²			15-100 psi		UD
2 NPS		2.5 in ²			19-100 psi		UD
3 NPS		4.8 in ²			15-75 psi		UD
4 NPS		8 in ²			15-75 psi		UD
6 NPS		18 in ²			15-50 psi		UD
8 NPS		32 in ²			15-50 psi		UD

Design Name: STD NBCert # 00268

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	04/20/2027

Design Type

[Rupture Disk Device] STD
HolderDesignation: RDI
Capacity Tests: Sec. UD at National Board Testing Lab on May 11, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.880 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS		0.049 in ²			160-70000 psi		UD
0.5 NPS		0.19 in ²			80-30000 psi		UD
0.75 NPS		0.44 in ²			70-3000 psi		UD
1 NPS		0.6 in ²			40-12000 psi		UD
1.5 NPS		1.48 in ²			26-6000 psi		UD
10 NPS		72.7 in ²			4-1400 psi		UD
12 NPS		101 in ²			4-1000 psi		UD
14 NPS		135 in ²			3-750 psi		UD
16 NPS		176 in ²			3-500 psi		UD
18 NPS		230 in ²			3-475 psi		UD
2 NPS		2.85 in ²			16-6000 psi		UD
20 NPS		279 in ²			2-450 psi		UD
24 NPS		415 in ²			2-450 psi		UD
3 NPS		5.41 in ²			12-6000 psi		UD
4 NPS		10.3 in ²			9-6000 psi		UD
6 NPS		22.3 in ²			7-3600 psi		UD
8 NPS		45.6 in ²			5-2100 psi		UD

Design Name: STDV NBCert # 00022

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	12/18/2025

Design Type

[Rupture Disk Device] STDV
HolderDesignation: RDI
Capacity Tests: Sec. UD at National Board Testing Lab on December 18, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 1.980 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Oklahoma Safety Equipment Company, Inc. (OSECO) {OSE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.6 in ²			145-12000 psi		UD
1.5 NPS		1.48 in ²			95-6000 psi		UD
10 NPS		72.7 in ²			14-1400 psi		UD
12 NPS		101 in ²			12-1000 psi		UD

14 NPS	135 in ²	11-750 psi	UD
16 NPS	176 in ²	9-500 psi	UD
18 NPS	230 in ²	8-475 psi	UD
2 NPS	2.85 in ²	55-6000 psi	UD
20 NPS	279 in ²	8-450 psi	UD
24 NPS	415 in ²	37-450 psi	UD
3 NPS	5.41 in ²	41-6000 psi	UD
4 NPS	10.3 in ²	31-6000 psi	UD
6 NPS	22.6 in ²	23-3600 psi	UD
8 NPS	45.6 in ²	18-2100 psi	UD

PACIFIC CONTROLS PTY LTD (PAC)

Tingalpa, QLD 4173Australia

This Company Manufactures or Assembles:

Design Name:	900 Series (Liquid), 7700, SNC	NBCert #	15499
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/08/2025

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name:	900 Series, 7700, SNC	NBCert #	15411
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/08/2025

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Liquids)	NBCert #	15095
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/08/2025

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V

1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name:	JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB	NBCert #	15208
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	08/08/2025
-----------	----	------------

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV

6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Parker Hannifin Corporation (FVC)

Nameplate Abbreviation: Parker PGI

Houston, TX 77041 United States

This Company Manufactures or Assembles:

Design Name: AA1301A		NBCert # 24006	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	03/27/2031
Design Type			
[Safety Relief Valve] AA1301A Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on August 15, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value: 1884.0 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Parker Hannifin Corporation {FVC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.446 in ²	0.753 in		250-0 psi	Air	UV

Design Name: AA1301B		NBCert # 24017	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	03/27/2031
Design Type			

[Safety Relief Valve] AA1301B
 Capacity Tests: Sec. UV at Louisiana State University on October 27, 1977
 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
 Certified Value: 1937.0 SCFM; Certification Provisions: Cert. @ 20% OP
 Media - Test: Air/Gas; Certified: Gas
 Set Pressure Definition: Start-to-Leak
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Parker Hannifin Corporation {FVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.446 in²	0.7533 in		265-0 psi	Air	UV
Design Name: AA1310A		NBCert #		24028			
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			03/27/2031	
Design Type							
[Safety Relief Valve] AA1310A Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:5112.0 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Parker Hannifin Corporation {FVC}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS		1.009 in²	1.134 in		250-250 psi	Air	UV
Design Name:		AA1310B		NBCert #		24039	
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UV			06/19/2031	
Design Type							
[Safety Relief Valve] AA1310B Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on April 3, 1979 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:5405.0 SCFM; Certification Provisions: Cert. @ 20% OP Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Parker Hannifin Corporation {FVC}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS		1.009 in ²	1.134 in		265-265 psi	Air	UV

Parker Hannifin Corporation (RSP)										Nameplate Abbreviation: Parker	
Mauston, WI 53948United States											

This Company Manufactures or Assembles:

Design Name: H-2			NBCert #		45009		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		03/23/2027		

Design Type

[Safety Relief Valve] H-2

Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on May 4, 1983

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 4.340 SCFM/PSIA

Media - Test: Air/Gas; Certified: Gas

Set Pressure Definition: Initial Audible Discharge

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Parker Hannifin Corporation {RSP}

Comments: Valve assembly includes separate proprietary flange. Connection size listed is the valve base only and does not show customer connection to proprietary flange.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	1 NPS	0.3068 in ²	0.625 in	0.152 in	50-300 psi	Air	UV

Design Name: H-3

NBCert # 45010

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/13/2031

Design Type

[Safety Relief Valve] H-3

Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on May 4, 1983

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 7.140 SCFM/PSIA

Media - Test: Air/Gas; Certified: Gas

Set Pressure Definition: Initial Audible Discharge

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Parker Hannifin Corporation {RSP}

Comments: Valve assembly includes separate proprietary flange. Connection size listed is the valve base only and does not show customer connection to proprietary flange.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1.25 NPS	0.5384 in ²	0.828 in	0.186 in	50-300 psi	Air	UV

Design Name: H-4

NBCert # 45021

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	05/06/2031

Design Type

[Safety Relief Valve] H-4

Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on March 16, 1983

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 10.670 SCFM/PSIA

Media - Test: Air/Gas; Certified: Gas

Set Pressure Definition: Initial Audible Discharge

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Parker Hannifin Corporation {RSP}

Comments: Valve assembly includes separate proprietary flange. Connection size listed is the valve base only and does not show customer connection to proprietary flange.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5 NPS	0.8348 in ²	1.031 in	0.247 in	50-300 psi	Air	UV

Design Name: H-5		NBCert #	45032
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	04/13/2031
Design Type			
[Safety Relief Valve] H-5 Capacity Tests: Sec. UV at National Board Testing Lab (Picaway) on March 16, 1983 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 17.820 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Parker Hannifin Corporation {RSP} Comments: Valve assembly includes separate proprietary flange. Connection size listed is the valve base only and does not show customer connection to proprietary flange.			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	2 NPS	1.4849 in ²	1.375 in	0.31 in	50-300 psi	Air	UV

Design Name: SR Series (1/2 in. Liquid)		NBCert #	45111
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	02/01/2030
Design Type			
[Relief Valve] SR Series (1/2 in. Liquid) Capacity Tests: Sec. UV at National Board Testing Lab on October 25, 2011 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.240 GPM/SQ. RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Parker Hannifin Corporation {RSP}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.0412 in ²	0.229 in	0.056 in	50-100 psi	Water	UV

Design Name: SR Series (3/4 in. Liquid)		NBCert #	45122
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	02/01/2030
Design Type			
[Relief Valve] SR Series (3/4 in. Liquid) Capacity Tests: Sec. UV at National Board Testing Lab on October 25, 2011 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.060 GPM/SQ. RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Parker Hannifin Corporation {RSP}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.0731 in ²	0.305 in	0.056 in	50-100 psi	Water	UV

Design Name: SR1, CSR1		NBCert #	45043
Manufacturer/Assembler	Designators		Expiration Date
Manufacturer	UV		10/02/2030
Design Type			
[Safety Relief Valve] SR1, CSR1 Capacity Tests: Sec. UV at National Board Testing Lab on August 20, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.725 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Parker Hannifin Corporation {RSP}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.088 in ²	0.5 in	0.055 in	100-400 psi	Air	UV

Design Name: SR1R		NBCert #	45133
Manufacturer/Assembler	Designators		Expiration Date
Manufacturer	UV		03/17/2028
Design Type			
[Safety Relief Valve] SR1R Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 2016 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.329 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Parker Hannifin Corporation {RSP}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.088 in ²	0.5 in	0.056 in	150-400 psi	Air	UV

Design Name: SR2, CSR2		NBCert #	45054
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	10/02/2030	
Design Type			
[Safety Relief Valve] SR2, CSR2 Capacity Tests: Sec. UV at National Board Testing Lab on August 20, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.370 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Parker Hannifin Corporation {RSP}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	1 NPS	0.196 in ²	0.5 in	0.055 in	150-400 psi	Air	UV

Design Name: SR3, CSR3		NBCert #	45065
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	07/18/2030
Design Type			
[Safety Relief Valve] SR3, CSR3 Capacity Tests: Sec. UV at National Board Testing Lab on June 24, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.100 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Parker Hannifin Corporation {RSP}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1.25 NPS	0.1314 in ²	0.409 in	0.103 in	150-400 psi	Air	UV

Design Name: SR4, CSR4		NBCert #	45076
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	07/18/2030
Design Type			
[Safety Relief Valve] SR4, CSR4 Capacity Tests: Sec. UV at National Board Testing Lab on March 5, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.729 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Parker Hannifin Corporation {RSP}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1.5 NPS	0.1794 in ²	0.478 in	0.103 in	150-400 psi	Air	UV

Design Name: SRH1, SRH2, SRH3, CSRH1, CSRH2, CSRH3		NBCert #	45087
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	07/18/2030
Design Type			
[Safety Relief Valve] SRH1, SRH2, SRH3, CSRH1, CSRH2, CSRH3 Capacity Tests: Sec. UV at National Board Testing Lab on March 4, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.580 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Parker Hannifin Corporation {RSP}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.196 in ²	0.5 in	0.186 in	150-400 psi	Air	UV

Design Name: SRH1R		NBCert #	45144
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	06/17/2026
Design Type			
[Safety Relief Valve] SRH1R Capacity Tests: Sec. UV at National Board Testing Lab on March 9, 2020 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.280 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Parker Hannifin Corporation {RSP}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.181 in ²	0.5 in	0.115 in	150-400 psi	Air	UV

Design Name: SRH3R		NBCert #	45155
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	06/17/2026
Design Type			
[Safety Relief Valve] SRH3R Capacity Tests: Sec. UV at National Board Testing Lab on March 9, 2020 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.580 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Parker Hannifin Corporation {RSP}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1. in	0.196 in ²	0.5 in	0.211 in	150-400 psi	Air	UV

Design Name: SRH3UR		NBCert #	45166
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	06/17/2026
Design Type			
[Safety Relief Valve] SRH3UR Capacity Tests: Sec. UV at National Board Testing Lab on March 9, 2020 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.750 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Parker Hannifin Corporation {RSP}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.094 in ²	0.5 in	0.06 in	150-400 psi	Air	UV

Design Name: SRH4, CSRH4		NBCert #	45100
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	05/28/2031
Design Type			
[Safety Relief Valve] SRH4, CSRH4 Capacity Tests: Sec. UV at National Board Testing Lab on February 27, 2003 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 4.440 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Parker Hannifin Corporation {RSP}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.25 NPS	0.4418 in ²	0.75 in	0.223 in	150-350 psi	Air	UV

Design Name: SRH4R		NBCert #	45177
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	06/17/2026
Design Type			
[Safety Relief Valve] SRH4R Capacity Tests: Sec. UV at National Board Testing Lab on March 9, 2020 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.000 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Parker Hannifin Corporation {RSP}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.25 NPS	0.131 in ²	0.409 in	0.148 in	150-400 psi	Air	UV

Design Name: SRH5, CSRH5		NBCert #	45098
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	05/06/2031
Design Type			
[Safety Relief Valve] SRH5, CSRH5 Capacity Tests: Sec. UV at National Board Testing Lab on February 27, 2003 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.360 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Parker Hannifin Corporation {RSP}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.4418 in ²	0.75 in	0.348 in	150-350 psi	Air	UV

Permian Pump & Valve (PER)

Odessa, TX 79764 United States

This Company Manufactures or Assembles:

Design Name:	Reyco R, RB & RO (Fig. 971, 973, 974)	NBCert #	73000
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	04/07/2027	

Design Type

[Safety Relief Valve] Reyco R, RB & RO (Fig. 971, 973, 974)
 Capacity Tests: Sec. UV at National Board Testing Lab on March 19, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.860 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.122 in ²	[D] 0.394 in	0.12 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.122 in ²	[D] 0.394 in	0.12 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.217 in ²	[E] 0.526 in	0.16 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.217 in ²	[E] 0.526 in	0.16 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.34 in ²	[F] 0.658 in	0.2 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.34 in ²	[F] 0.658 in	0.2 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.558 in ²	[G] 0.843 in	0.26 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.558 in ²	[G] 0.843 in	0.26 in	15-4905 psi	Air	UV
1.5-2 NPS	3 NPS	0.869 in ²	[H] 1.052 in	0.32 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.869 in ²	[H] 1.052 in	0.32 in	15-3300 psi	Air	UV
2-3 NPS	3, 4 NPS	1.427 in ²	[J] 1.348 in	0.41 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.427 in ²	[J] 1.348 in	0.41 in	15-3300 psi	Air	UV
3 NPS	4, 6 NPS	2.036 in ²	[K] 1.61 in	0.49 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.036 in ²	[K] 1.61 in	0.49 in	15-3300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.16 in ²	[L] 2.006 in	0.61 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.16 in ²	[L] 2.006 in	0.61 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	3.987 in ²	[M] 2.253 in	0.69 in	15-1600 psi	Air	UV
4 NPS	6 NPS	3.987 in ²	[M] 2.253 in	0.69 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.807 in ²	[N] 2.474 in	0.75 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.807 in ²	[N] 2.474 in	0.75 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.07 in ²	[P] 3 in	0.92 in	15-1600 psi	Air	UV
4 NPS	6 NPS	7.07 in ²	[P] 3 in	0.92 in	15-1600 psi	Steam	UV
6 NPS	8 NPS	12.24 in ²	[Q] 3.948 in	1.2 in	15-925 psi	Air	UV

6 NPS	8 NPS	12.24 in ²	[Q] 3.948 in	1.2 in	15-925 psi	Steam	UV
6 NPS	8, 10 NPS	17.72 in ²	[R] 4.75 in	1.45 in	15-350 psi	Air	UV
6 NPS	8, 10 NPS	17.72 in ²	[R] 4.75 in	1.45 in	15-350 psi	Steam	UV
8 NPS	10 NPS	29.75 in ²	[T] 6.155 in	1.84 in	15-325 psi	Air	UV
8 NPS	10 NPS	29.75 in ²	[T] 6.155 in	1.84 in	15-325 psi	Steam	UV

Design Name:	Reyco R, RB, RO, RBO (Fig. 971, 973, 974) (liquid)	NBCert #	73011
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/07/2027

Design Type

[Relief Valve] Reyco R, RB, RO, RBO (Fig. 971, 973, 974) (liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on September 27, 2001
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.724 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 2.5, 3 NPS	0.122 in ²	[D] 0.394 in	0.12 in	15-6250 psi	Water	UV
1-1.5 NPS	2, 2.5, 3 NPS	0.217 in ²	[E] 0.526 in	0.16 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.34 in ²	[F] 0.658 in	0.2 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5, 3 NPS	0.558 in ²	[G] 0.843 in	0.26 in	15-4905 psi	Water	UV
1.5-2 NPS	3 NPS	0.869 in ²	[H] 1.052 in	0.32 in	15-3300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.427 in ²	[J] 1.348 in	0.41 in	15-3300 psi	Water	UV
3 NPS	4, 6 NPS	2.036 in ²	[K] 1.61 in	0.49 in	15-3300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.16 in ²	[L] 2.006 in	0.61 in	15-2900 psi	Water	UV
4 NPS	6 NPS	3.987 in ²	[M] 2.253 in	0.69 in	15-1600 psi	Water	UV
4 NPS	6 NPS	4.807 in ²	[N] 2.474 in	0.75 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.07 in ²	[P] 3 in	0.92 in	15-1600 psi	Water	UV
6 NPS	8 NPS	12.24 in ²	[Q] 3.948 in	1.2 in	15-925 psi	Water	UV
6 NPS	8, 10 NPS	17.72 in ²	[R] 4.75 in	1.45 in	15-350 psi	Water	UV
8 NPS	10 NPS	29.75 in ²	[T] 6.155 in	1.84 in	15-325 psi	Water	UV

Design Name:	RL-14 & RLO-14 (0.315 in. orifice)	NBCert #	73044
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/07/2027

Design Type

[Safety Relief Valve] RL-14 & RLO-14 (0.315 in. orifice)
Capacity Tests: Sec. UV at National Board Testing Lab on June 8, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.230 SCFM/PSIA; (alternate medium): 3.460 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.078 in ²	0.315 in	0.078 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.078 in ²	0.315 in	0.078 in	15-5000 psi	Air	UV

Design Name: RL-14 & RLO-14 (0.315 in. orifice) (Liquids) NBCert # 73055

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

04/07/2027

Design Type

[Relief Valve] RL-14 & RLO-14 (0.315 in. orifice) (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on June 4, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.880 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.078 in ²	0.315 in	0.078 in	15-5000 psi	Water	UV

Design Name: RL14 & RLO14 (0.394 in. orifice) NBCert # 73202

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

04/07/2027

Design Type

[Safety Relief Valve] RL14 & RLO14 (0.394 in. orifice)
Capacity Tests: Sec. UV at National Board Testing Lab on September 30, 2014
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.637 SCFM/PSIA; (alternate medium): 4.600 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ARI-Armaturen USA LP {TAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.122 in ²	0.394 in	0.0985 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.122 in ²	0.394 in	0.0985 in	15-5000 psi	Air	UV

Pioneer Industrial Corporation (PIC)

Calvert City, KY 42029United States

This Company Manufactures or Assembles:

Design Name:	1541, 1543, 1541-3, 1543-3	NBCert #	18032
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV, V	09/26/2028	

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V

2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV
-----------	---------	-----------------------	---------------	---------	------------	-----	--------

Design Name:	1811, 1511	NBCert #	18122
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 09/26/2028

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/26/2028

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/26/2028

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV

1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)		NBCert #	18223
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	09/08/2028	

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Restricted Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV

10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/26/2028

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/26/2028

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Pioneer Industrial Corporation (PLA)

Hastings, NE 68901United States

This Company Manufactures or Assembles:

Design Name:	1811, 1511	NBCert #	18122
Manufacturer/Assembler	Designators	Expiration Date	

Assembler

UV, V

08/02/2030

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV

3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA (Liquids) NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/02/2030

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	08/02/2030
-----------	----	------------

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV

8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/02/2030

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/02/2030

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2

NBCert #

18144

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/02/2030

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert #

18751

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/02/2030

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900E-2, 1900-30E-2 NBCert # 18166

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 08/02/2030

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 08/02/2030

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids) NBCert # 19077

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 08/02/2030

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ. RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 1982 NBCert # 18379

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/02/2030

Design Type

[Safety Relief Valve] 1982
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at unknown lab on May 6, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Air	NV, UV
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Steam	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Air	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Steam	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Air	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Steam	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Air	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Air	NV, UV

Design Name: 1982 LS, 820000LS NBCert # 18380

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/02/2030

Design Type

[Relief Valve] 1982 LS, 820000LS
 Capacity Tests: Sec. UV at Dresser, Inc. on December 19, 1984
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.758 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	NV
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	UV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	NV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	NV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	UV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	NV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	NV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	UV

Design Name: 3900-TM (39PV, 39MV pilots) NBCert # 01438

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/15/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3900-TM (39PV, 39MV pilots)
 Capacity Tests: Sec. UV at Dresser, Inc. on May 19, 1988
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless; (alternate medium): 0.743 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Air	UV

1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV

6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Pioneer Pump and Packing - DBA Pioneer Industrial Corporation (ZLT)

St. Louis, MO 63104United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3				NBCert # 18032			
Manufacturer/Assembler			Designators		Expiration Date		
Assembler			UV, V		02/07/2030		
Design Type							
[Safety Valve] 1541, 1543, 1541-3, 1543-3 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV

1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1700 & 2700

NBCert # 18100

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV, V

02/07/2030

Design Type

[Safety Valve] 1700 & 2700
Capacity Tests: Sec. UV, V at Dresser, Inc. on August 1, 1957
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	50-5800 psi	Steam	V
4 NPS	4 dual NPS	1.84 in ²	[K] 1.531 in	0.383 in	50-5800 psi	Steam	V
2-3 NPS	4, 6 NPS	2.545 in ²	[#3] 1.8 in	0.45 in	50-5800 psi	Steam	UV, V
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-2575 psi	Steam	UV
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	50-5800 psi	Steam	V
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	15-3100 psi	Steam	UV

3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	50-5800 psi	Steam	V
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	15-3100 psi	Steam	UV
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	15-1800 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	1.24 in	50-2200 psi	Steam	UV, V
8-10 NPS	10,12 NPS	28.3 in ²	[T] 6 in	1.5 in	50-1500 psi	Steam	UV, V

Design Name: 1700 & 2700 (Restricted Lift version of Cert. # 18100) NBCert # 18111

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	11/14/2028

Design Type

[Safety Valve] 1700 & 2700 (Restricted Lift version of Cert. # 18100)
Capacity Tests: Sec. UV, V at unknown lab on October 13, 1981
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	50-5800 psi	Steam	V
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	15-3100 psi	Steam	UV
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	50-5800 psi	Steam	V
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-2575 psi	Steam	UV
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	50-5800 psi	Steam	V
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	15-3100 psi	Steam	UV
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	50-5800 psi	Steam	V
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	15-3100 psi	Steam	UV
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	50-3100 psi	Steam	V

6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.946 in	0.296 in	15-2000 psi	Steam	UV, V
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	0.372 in	50-2200 psi	Steam	V
8-10 NPS	10, 12 NPS	28.3 in ²	[T] 6 in	0.45 in	50-1500 psi	Steam	UV, V

Design Name: 1900, 1900-30 1900-35 LA & DALA (Liquids) NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/12/2030

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	02/07/2030
-----------	----	------------

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV

8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201) NBCert # 18223

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/07/2030

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name: 19000 Series

NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

06/12/2030

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/12/2030

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/07/2030

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/07/2030

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 3.256 GPM/SQ. RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM

NBCert # 19066

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

03/30/2029

Design Type

[Safety Relief Valve] 1900-DM
 Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
 Set Pressure Definition(1): Pop; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D NBCert # 19088

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/30/2029

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E NBCert # 19099

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/30/2029

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2		NBCert #	18166
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	02/07/2030
Design Type			
[Safety Relief Valve] 1900E-2, 1900-30E-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids)		NBCert #	18762
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	06/12/2030
Design Type			
[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids) Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.798 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids)		NBCert #	19077
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	02/07/2030
Design Type			
[Relief Valve] 19110M & 19110H (Liquids) Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.264 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name:	2900 (39PV & 39MV pilots - Liquid)	NBCert #	18874
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/10/2027

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots - Liquid)
Capacity Tests: Sec. UV, V at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.127 in	15-6250 psi	Water	UV, V
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	UV, V
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.205 in	15-6250 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-6250 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-6000 psi	Water	UV, V
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-6000 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-3750 psi	Water	UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-2250 psi	Water	UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-1500 psi	Water	UV, V
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.738 in	15-1500 psi	Water	UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-905 psi	Water	UV, V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV, V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.93 in	15-675 psi	Water	UV, V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-535 psi	Water	UV, V

Design Name:	2900 (39PV & 39MV pilots)	NBCert #	18863
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/10/2027

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
 Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV

12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
--------	--------	------------------------	---------------	----------	------------	-------	----

Design Name:	3900 (39PV, 39MV pilots)	NBCert #	18447
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	02/10/2027
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV

4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid)			NBCert #	18458
Manufacturer/Assembler		Designators		Expiration Date
Assembler		UV		02/10/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.743 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV

8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Portersville PRD LLC (PRK)

Nameplate Abbreviation: Portersville PRD - SP

South Point, OH 45680United States

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S		NBCert # 57057
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/13/2028
Design Type		
<div>[Safety Relief Valve] 2600 & 2600S</div> <div>Capacity Tests: Sec. UV at unknown lab on June 11, 1972</div> <div>Method of Establishing Relieving Capacity: Flow Capacity, K</div> <div>Certified Value: 0.858 Unitless</div> <div>Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam</div> <div>Set Pressure Definition: Pop</div> <div>Blowdown Characteristics: Adjustable (Single Ring)</div> <div>Flow Area Configuration: Nozzle/Full Lift</div> <div>Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV

4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Liquids)	NBCert # 57068
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 12/13/2028

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V

3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name:	2600L (Liquids) Series Restricted Lift version of Cert Number 57068.	NBCert #	57417
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	10/11/2028	

Design Type

[Safety Relief Valve] 2600L (Liquids) Series Restricted Lift version of Cert Number 57068.
Capacity Tests: Sec. UV, V at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on January 23, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Water	UV, V
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-6000 psi	Water	UV, V
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-5000 psi	Water	UV, V
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.098 in	15-3600 psi	Water	UV, V
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.122 in	15-2750 psi	Water	UV, V
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.156 in	15-2700 psi	Water	UV, V
3 in	4, 6 in	2.041 in ²	[K] 1.612 in	0.187 in	15-2200 psi	Water	UV, V
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.232 in	15-1500 psi	Water	UV, V
4 in	6 in	4 in ²	[M] 2.257 in	0.261 in	15-1100 psi	Water	UV, V
4 in	6 in	4.822 in ²	[N] 2.478 in	0.287 in	15-1000 psi	Water	UV, V
4 in	6 in	7.087 in ²	[P] 3.004 in	0.348 in	15-1000 psi	Water	UV, V
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.458 in	15-900 psi	Water	UV, V
6-8 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.551 in	15-600 psi	Water	UV, V
8 in	10 in	28.94 in ²	[T] 6.07 in	0.702 in	15-300 psi	Water	UV, V
8 in	10 in	31.5 in ²	[U] 6.333 in	0.741 in	15-300 psi	Water	UV, V

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/25/2025

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/14/2028

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 4200 / 4400	NBCert # 57282
--------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	V	10/25/2025
-----------	---	------------

Design Type

[Safety Valve] 4200 / 4400
Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.872 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

Portersville PRD, LLC (PRV)

North Chesterfield, VA 23236United States

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S	NBCert # 57057
---------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	01/19/2030
-----------	----	------------

Design Type

[Safety Relief Valve] 2600 & 2600S
 Capacity Tests: Sec. UV at unknown lab on June 11, 1972
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.858 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV

8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Liquids)	NBCert # 57068
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	01/19/2030
-----------	----	------------

Design Type

[Relief Valve] 2600L (Liquids)
 Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.652 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/29/2030

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/17/2026

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Portersville PRD, LLC (PTI)

Tallmadge, OH 44278United States

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S		NBCert # 57057
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/21/2029
Design Type		
[Safety Relief Valve] 2600 & 2600S Capacity Tests: Sec. UV at unknown lab on June 11, 1972 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.858 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV

3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name:	2600 Series Restricted Lift version of Cert Number 57057	NBCert #	57406
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/26/2028

Design Type

[Safety Relief Valve] 2600 Series Restricted Lift version of Cert Number 57057
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 10, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Air	UV
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Steam	UV
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Air	UV
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Steam	UV
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Air	UV
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Steam	UV
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.08 in	15-7000 psi	Air	UV
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.08 in	15-7000 psi	Steam	UV
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.095 in	15-6000 psi	Air	UV
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.095 in	15-6000 psi	Steam	UV
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.122 in	15-6000 psi	Air	UV
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.122 in	15-6000 psi	Steam	UV
3 in	4, 6 in	2.042 in ²	[K] 1.612 in	0.145 in	15-5000 psi	Air	UV
3 in	4, 6 in	2.042 in ²	[K] 1.612 in	0.145 in	15-5000 psi	Steam	UV
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.181 in	15-4000 psi	Air	UV
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.181 in	15-4000 psi	Steam	UV
4 in	6 in	4 in ²	[M] 2.257 in	0.203 in	15-3000 psi	Air	UV
4 in	6 in	4 in ²	[M] 2.257 in	0.203 in	15-3000 psi	Steam	UV
4 in	6 in	4.822 in ²	[N] 2.478 in	0.223 in	15-3000 psi	Air	UV
4 in	6 in	4.822 in ²	[N] 2.478 in	0.223 in	15-3000 psi	Steam	UV
4 in	6 in	7.087 in ²	[P] 3.004 in	0.27 in	15-2500 psi	Air	UV
4 in	6 in	7.087 in ²	[P] 3.004 in	0.27 in	15-2500 psi	Steam	UV
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.356 in	15-2000 psi	Air	UV
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.356 in	15-2000 psi	Steam	UV
6 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.428 in	15-1500 psi	Air	UV
6 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.428 in	15-1500 psi	Steam	UV
8 in	10 in	28.94 in ²	[T] 6.07 in	0.546 in	15-1000 psi	Air	UV
8 in	10 in	28.94 in ²	[T] 6.07 in	0.546 in	15-1000 psi	Steam	UV
8 in	10 in	31.5 in ²	[U] 6.333 in	0.57 in	15-300 psi	Air	UV
8 in	10 in	31.5 in ²	[U] 6.333 in	0.57 in	15-300 psi	Steam	UV
10 in	14 in	49.4 in ²	[V] 7.93 in	0.714 in	15-1000 psi	Air	UV
10 in	14 in	49.4 in ²	[V] 7.93 in	0.714 in	15-1000 psi	Steam	UV
12 in	16 in	63.62 in ²	[W] 9 in	0.81 in	15-1000 psi	Air	UV
12 in	16 in	63.62 in ²	[W] 9 in	0.81 in	15-1000 psi	Steam	UV
16 in	18 in	104 in ²	[W2] 11.507 in	1.036 in	15-750 psi	Air	UV
16 in	18 in	104 in ²	[W2] 11.507 in	1.036 in	15-750 psi	Steam	UV
16 in	20 in	113.1 in ²	[X] 12 in	1.08 in	15-750 psi	Air	UV
16 in	20 in	113.1 in ²	[X] 12 in	1.08 in	15-750 psi	Steam	UV
18 in	24 in	143.1 in ²	[Y] 13.5 in	1.215 in	15-750 psi	Air	UV

18 in	24 in	143.1 in ²	[Y] 13.5 in	1.215 in	15-750 psi	Steam	UV
20 in	24 in	176.7 in ²	[Z] 15 in	1.35 in	15-750 psi	Air	UV
20 in	24 in	176.7 in ²	[Z] 15 in	1.35 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam) Series Restricted Lift version of Cert Number 57260 NBCert # 57439

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/09/2028

Design Type

[Safety Relief Valve] 2600L (Air & Steam) Series Restricted Lift version of Cert Number 57260
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 6, 2018
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.08 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.08 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.08 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.089 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.089 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.111 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.111 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.142 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.142 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.169 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.169 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.211 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.211 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.237 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.237 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.26 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.26 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.315 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.315 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.415 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.415 in	15-2000 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	0.5 in	15-1500 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	0.5 in	15-1500 psi	Steam	UV

8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	0.638 in	15-1000 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	0.638 in	15-1000 psi	Steam	UV
8 NPS	10 NPS	31.5 in ²	[U] 6.333 in	0.665 in	15-300 psi	Air	UV
8 NPS	10 NPS	31.5 in ²	[U] 6.333 in	0.665 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids) NBCert # 57068

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/28/2029

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2600M NBCert # 57226

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/14/2031

Design Type

[Safety Relief Valve] 2600M

HolderDesignation:

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on November 7, 2024

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless; (alternate medium): 0.689 Unitless; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Water/Liquid; Certified: Air, Gas, Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-3600 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-3600 psi	Water	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2750 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2750 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2700 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2700 psi	Water	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2200 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2200 psi	Water	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-1500 psi	Water	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-1100 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-1000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-1000 psi	Water	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-1000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-1000 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-600 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-600 psi	Water	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-300 psi	Water	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Water	UV

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/23/2029

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/20/2029

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800	NBCert # 57024
-------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	08/06/2026
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 3800
Capacity Tests: Sec. UV at unknown lab on May 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV

3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name: 3800L, PCL, PCM pilots NBCert # 57215

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/06/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.782 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV

10 NPS14 NPS49.02 in²[V] 7.9 in2.94 in15-1500 psiWaterUV

Portersville PRD, LLC. (PRT)

Blountville, TN 37617United States

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S		NBCert # 57057
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/15/2028
Design Type		
[Safety Relief Valve] 2600 & 2600S Capacity Tests: Sec. UV at unknown lab on June 11, 1972 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.858 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV

6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

04/15/2028

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV

1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids)	NBCert # 57068
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/15/2028

Design Type

[Relief Valve] 2600L (Liquids)
 Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.652 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V

4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S NBCert # 57237

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/15/2028

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids)		NBCert #	57248
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	04/15/2028
Design Type			
[Relief Valve] 2700L, 3700L (Liquids) Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.676 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Portersville PRD, LLC. (PVE)	
New Castle, PA 16101United States	

This Company Manufactures or Assembles:

Design Name: 2400		NBCert #	57451
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	08/13/2026
Design Type			
[Safety Relief Valve] 2400 Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on August 28, 2019 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.817 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75-1 NPS	0.049 in ²	[B] 0.25 in	0.08 in	20-2000 psi	Air	UV

0.5-1 NPS	1-2 NPS	0.11 in ²	[D] 0.375 in	0.12 in	20-1410 psi	Air	UV
0.75-1 NPS	1-2 NPS	0.196 in ²	[E] 0.5 in	0.175 in	20-600 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.295 in	20-4000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.365 in	20-3000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.435 in	20-2500 psi	Air	UV

Design Name: 2600 & 2600S

NBCert # 57057

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

07/10/2027

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV

6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

02/07/2026

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV

2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids)	NBCert # 57068
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 09/25/2030

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V

4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S NBCert # 57237

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/10/2027

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids) NBCert # 57248

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/04/2025

Design Type

[Relief Valve] 2700L, 3700L (Liquids)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.676 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800

NBCert #

57024

Manufacturer/Assembler

Designators

Expiration Date

Assembler

UV

02/07/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3800

Capacity Tests: Sec. UV at unknown lab on May 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.859 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (3): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV

2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name: 3800FP

NBCert # 57035

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

02/10/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3800FP
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on April 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-1050 psi	Steam	UV
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-11300 psi	Air	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-1050 psi	Steam	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-11300 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-1050 psi	Steam	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-11300 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-1050 psi	Steam	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-11300 psi	Air	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-1050 psi	Steam	UV

4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-6300 psi	Air	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-6300 psi	Air	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-2300 psi	Air	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1500 psi	Air	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-800 psi	Steam	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-1500 psi	Air	UV

Design Name: 3800L, PCL, PCM pilots NBCert # 57215

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/04/2025

Design Type

[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.782 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Design Name:	4200 / 4400	NBCert #	57282
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 07/10/2027

Design Type

[Safety Valve] 4200 / 4400
Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.872 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

Design Name:	6400/6600 (previously 2500 & 4600)	NBCert #	57046
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 07/10/2027

Design Type

[Safety Valve] 6400/6600 (previously 2500 & 4600)
Capacity Tests: Sec. UV, V at Ohio State University (Robinson Laboratory) on January 28, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV

1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	V
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	V
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	V
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Air	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	V
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Air	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	V
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	V
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	UV

Precision Pump & Valve Service, Inc. (PPV)

Cross Lanes, WV 25313United States

This Company Manufactures or Assembles:

Design Name:	1541, 1543, 1541-3, 1543-3	NBCert #	18032
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/14/2028

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name:	1811, 1511	NBCert #	18122
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	05/25/2030

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA
(Liquids)

NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/17/2031

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V

1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/14/2028

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV

3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/17/2031

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert #

18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

08/08/2025

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2

NBCert #

18144

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

04/14/2028

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert # 18751

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	05/25/2030

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900E-2, 1900-30E-2 NBCert # 18166

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/25/2030

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/14/2028

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids) NBCert # 19077

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

03/05/2030

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 1982 NBCert # 18379

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

05/25/2030

Design Type

[Safety Relief Valve] 1982
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at unknown lab on May 6, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Air	NV, UV
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Steam	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Air	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Steam	NV, UV

1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Air	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Steam	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Air	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Air	NV, UV

Design Name: 1982 LS, 820000LS NBCert # 18380

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/14/2028

Design Type

[Relief Valve] 1982 LS, 820000LS
Capacity Tests: Sec. UV at Dresser, Inc. on December 19, 1984
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.758 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	NV
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	UV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	NV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	NV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	UV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	NV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	NV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	UV

Precision Services, Inc. (PUM)

Louisville, KY 40299United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3 NBCert # 18032

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	09/07/2029

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1700 & 2700

NBCert # 18100

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	09/19/2029

Design Type

[Safety Valve] 1700 & 2700
 Capacity Tests: Sec. UV, V at Dresser, Inc. on August 1, 1957
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	50-5800 psi	Steam	V
4 NPS	4 dual NPS	1.84 in ²	[K] 1.531 in	0.383 in	50-5800 psi	Steam	V
2-3 NPS	4, 6 NPS	2.545 in ²	[#3] 1.8 in	0.45 in	50-5800 psi	Steam	UV, V
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-2575 psi	Steam	UV
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	50-5800 psi	Steam	V
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	15-3100 psi	Steam	UV
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	50-5800 psi	Steam	V
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	15-3100 psi	Steam	UV
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	15-1800 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	1.24 in	50-2200 psi	Steam	UV, V
8-10 NPS	10,12 NPS	28.3 in ²	[T] 6 in	1.5 in	50-1500 psi	Steam	UV, V

Design Name: 1811, 1511

NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	09/20/2029

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA
(Liquids)

NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	09/18/2029

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V

1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

09/19/2029

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV

3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201) NBCert # 18223

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/29/2029

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV

1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name: 19000 Series		NBCert # 18706
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/19/2029
Design Type		

[Safety Relief Valve] 19000 Series
 Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

09/18/2029

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/20/2029

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	09/18/2029

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name:	1900-DM	NBCert #	19066
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/24/2028

Design Type

[Safety Relief Valve] 1900-DM
Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV

1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D

NBCert #

19088

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

02/24/2028

Design Type

[Safety Relief Valve] 1900-DM-D

Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Curtain Area

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name:	1900-DM-E	NBCert #	19099
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/24/2028

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/20/2029

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name:	1900E-2, 1900-30E-2 LA & DALA (Liquids)	NBCert #	18762
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	09/18/2029

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids) NBCert # 19077

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 12/16/2029

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 1982 NBCert # 18379

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 09/19/2029

Design Type

[Safety Relief Valve] 1982
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at unknown lab on May 6, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Air	NV, UV
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Steam	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Air	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Steam	NV, UV

1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Air	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Steam	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Air	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Air	NV, UV

Design Name: 1982 LS, 820000LS NBCert # 18380

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/18/2029

Design Type

[Relief Valve] 1982 LS, 820000LS
Capacity Tests: Sec. UV at Dresser, Inc. on December 19, 1984
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.758 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	NV
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	UV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	NV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	NV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	UV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	NV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	NV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	UV

Design Name: 2900 (39PV & 39MV pilots - Liquid) NBCert # 18874

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/24/2028

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots - Liquid)
Capacity Tests: Sec. UV, V at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.127 in	15-6250 psi	Water	UV, V
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	UV, V
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.205 in	15-6250 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-6250 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-6000 psi	Water	UV, V
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-6000 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-3750 psi	Water	UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-2250 psi	Water	UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-1500 psi	Water	UV, V
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.738 in	15-1500 psi	Water	UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-905 psi	Water	UV, V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV, V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.93 in	15-675 psi	Water	UV, V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-535 psi	Water	UV, V

Design Name:	2900 (39PV & 39MV pilots)	NBCert #	18863
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	02/24/2028
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV

2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots) NBCert # 18447

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/20/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV

1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV

6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid)

NBCert #

18458

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

12/16/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)

Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.743 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV

3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Puffer-Sweiven, LP (PPC)

Nameplate Abbreviation: PSI-CC

Corpus Christi, TX 78408United States

This Company Manufactures or Assembles:

Design Name: 900 Series (Liquid), 7700, SNC NBCert # 15499

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/17/2028

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name:	900 Series, 7700, SNC	NBCert #	15411
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/17/2028

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Liquids)	NBCert #	15095
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	08/17/2028
-----------	----	------------

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V

8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/11/2029

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV

4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Puffer-Sweiven, LP (PPH)

Houston, TX 77034United States

This Company Manufactures or Assembles:

Design Name: 243/249/443/449/546/843/849/943/5046/5049/8043/8049 NBCert # 01292

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/11/2029

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
Capacity Tests: Sec. UV at unknown lab on August 8, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name: 253/259/453/459/853/859/953/959/5059/8053/8059 NBCert # 01304

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/11/2029

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
Capacity Tests: Sec. UV at unknown lab on July 31, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.627 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name:	263/269/463/469/566/863/869/963/969/5066/5069	NBCert #	01315
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/11/2029

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069
Capacity Tests: Sec. UV at unknown lab on July 30, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name:	443/449/546/843/849/943/949/5046/5049 (Liquids)	NBCert #	01337
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/18/2029

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.767 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

07/11/2029

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV

4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids) NBCert # 01348

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/14/2029

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids)
Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.712 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name: 81, 81P, 83, 84 NBCert # 01089

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/11/2029

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 81P (Liquids)			NBCert # 01102	
Manufacturer/Assembler		Designators		Expiration Date
Assembler		UV		07/11/2029

Design Type

[Relief Valve] 81P (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: 93% of pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name: 900 Series (Liquid), 7700, SNC			NBCert # 15499	
Manufacturer/Assembler		Designators		Expiration Date
Assembler		UV		07/12/2029

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.661 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name: 900 Series, 7700, SNC

NBCert #

15411

Manufacturer/Assembler

Designators

Expiration Date

Assembler

UV

07/11/2029

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV

1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name:	HL, HSL	NBCert #	15589
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 04/01/2031

Design Type

[Safety Valve] HL, HSL
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on November 3, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.869 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	1.5 NPS	0.339 in ²	[F] 0.657 in	0.164 in	15-725 psi	Steam	UV, V
1.25-2 NPS	1.5 NPS	0.553 in ²	[G] 0.839 in	0.21 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.868 in ²	[H] 1.051 in	0.263 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.327 in ²	[J] 1.3 in	0.325 in	15-725 psi	Steam	UV, V
2-3 NPS	3-4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-725 psi	Steam	UV, V
2.5-4 NPS	4-6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-725 psi	Steam	UV, V
3 NPS	4-6 NPS	3.955 in ²	[M] 2.244 in	0.561 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	4.831 in ²	[N] 2.48 in	0.62 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	7.031 in ²	[P] 2.992 in	0.748 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[QQ] 3.75 in	0.937 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	0.984 in	15-725 psi	Steam	UV, V

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Liquids)	NBCert #	15095
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 07/11/2029

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV

0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/11/2029

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/18/2029

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV

1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV

12-14 NPS	16. 20 NPS	78.08 in²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16. 20 NPS	78.08 in²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Qiyao Special Valve (Ningbo Ninghao Machinery Factory) (NYE)

Ningbo City, 315207People's Republic of China

This Company Manufactures or Assembles:

Design Name:	ARBP-F (12-52 NPS)	NBCert #	02462
Manufacturer/Assembler	Designators	Expiration Date	

Manufacturer	UD	08/21/2029
--------------	----	------------

Design Type

[Buckling Pin Non-reclosing Device] ARBP-F (12-52 NPS)
Capacity Tests: Sec. UD at National Board Testing Lab on July 13, 2021
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 7.520 Unitless; Certification Provisions: Exceeds Lab Limits (Prev. CC 2397)
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: Nozzle/Full Lift
Designed by: Qiyao Special Valve (Ningbo Ninghao Machinery Factory) {NYE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
12 NPS	12 NPS	63.6 in²		0 in	1-285 psi	Air	UD
14 NPS	14 NPS	85.58 in²		0 in	1-285 psi	Air	UD
16 NPS	16 NPS	113.46 in²		0 in	1-285 psi	Air	UD
18 NPS	18 NPS	155.86 in²		0 in	1-285 psi	Air	UD
20 NPS	20 NPS	208.99 in²		0 in	1-285 psi	Air	UD
22 NPS	22 NPS	254.83 in²		0 in	1-285 psi	Air	UD
24 NPS	24 NPS	305.23 in²		0 in	1-285 psi	Air	UD
26 NPS	26 NPS	343.71 in²		0 in	1-285 psi	Air	UD
28 NPS	28 NPS	415.98 in²		0 in	1-285 psi	Air	UD
30 NPS	30 NPS	498.39 in²		0 in	1-285 psi	Air	UD
32 NPS	32 NPS	592.17 in²		0 in	1-285 psi	Air	UD
34 NPS	34 NPS	655.44 in²		0 in	1-285 psi	Air	UD
36 NPS	36 NPS	763.12 in²		0 in	1-285 psi	Air	UD
38 NPS	38 NPS	833.68 in²		0 in	1-285 psi	Air	UD
40 NPS	40 NPS	930.99 in²		0 in	1-285 psi	Air	UD
42 NPS	42 NPS	1033.68 in²		0 in	1-285 psi	Air	UD
44 NPS	44 NPS	1142.54 in²		0 in	1-285 psi	Air	UD
46 NPS	46 NPS	1255.97 in²		0 in	1-285 psi	Air	UD
48 NPS	48 NPS	1374.77 in²		0 in	1-285 psi	Air	UD
50 NPS	50 NPS	1498.93 in²		0 in	1-285 psi	Air	UD
52 NPS	52 NPS	1628.47 in²		0 in	1-285 psi	Air	UD

Design Name: ARBP-F (2-10 NPS)		NBCert #	01786
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	08/21/2029
Design Type			
[Buckling Pin Non-reclosing Device] ARBP-F (2-10 NPS) Capacity Tests: Sec. UD at National Board Testing Lab on March 4, 2019 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value:36.820 Unitless; Certification Provisions: Exceeds Lab Limits (Prev. CC 2397) Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Buckling Pressure Flow Area Configuration: Nozzle/Full Lift Designed by: Qiyao Special Valve (Ningbo Ninghao Machinery Factory) {NYE}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS	10 NPS	44.9 in ²			1-285 psi	Air	UD
2 NPS	2 NPS	1.53 in ²			10-285 psi	Air	UD
2.5 NPS	2.5 NPS	2.02 in ²			10-285 psi	Air	UD
3 NPS	3 NPS	3.9 in ²			10-285 psi	Air	UD
4 NPS	4 NPS	6.35 in ²			10-285 psi	Air	UD
6 NPS	6 NPS	16.8 in ²			1-285 psi	Air	UD
8 NPS	8 NPS	29.28 in ²			1-285 psi	Air	UD

Quadco, LLC (QUA)	
Brighton, CO 80603United States	

This Company Manufactures or Assembles:

Design Name: 459/462		NBCert #	37112
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	04/15/2027
Design Type			
[Safety Relief Valve] 459/462 Capacity Tests: Sec. UV at National Board Testing Lab on February 17, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.811 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Air	UV
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Air	UV

0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Steam	UV

Design Name:	459/462 liquids	NBCert #	37101
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/14/2027

Design Type

[Relief Valve] 459/462 liquids
Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.566 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Water	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Water	UV
0.5-1.5 NPS	1-2.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Water	UV
1-2 NPS	1.5-2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Water	UV

Design Name:	526	NBCert #	37224
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/19/2027

Design Type

[Safety Relief Valve] 526
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 22, 2001
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Air	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-2900 psi	Steam	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-2900 psi	Steam	UV

2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Air	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-2900 psi	Steam	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Steam	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Air	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Steam	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Air	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Steam	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Air	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Steam	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Air	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Steam	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Air	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Steam	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Air	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Steam	UV

Design Name: 526 (Liquids)

NBCert #

37235

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

04/19/2027

Design Type

[Relief Valve] 526 (Liquids)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on January 2, 2002
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.579 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Water	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Water	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Water	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Water	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Water	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Water	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Water	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Water	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Water	UV

4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Water	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.249 in	15-1038.5 psi	Water	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Water	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-914 psi	Water	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Water	UV

Design Name: 526D

NBCert #

37246

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

04/19/2027

Design Type

[Safety Relief Valve] 526D
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on March 4, 2002
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.990 SCFM/PSIA; (alternate medium): 5.590 PPH/PSIA
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-10878 psi	Air	UV

Design Name: 526D Liquids

NBCert #

37257

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

04/19/2027

Design Type

[Relief Valve] 526D Liquids
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on March 4, 2002
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.110 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-10878 psi	Water	UV

R. Conrader Company (RCO)

Nameplate Abbreviation: R.CONRADER

Erie, PA 16506United States

This Company Manufactures or Assembles:

Design Name: SRH 250		NBCert #	13598
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/21/2027
Design Type			
[Safety Relief Valve] SRH 250 Capacity Tests: Sec. UV at National Board Testing Lab on March 11, 2005 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.720 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: R. Conrader Company {RCO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.375 NPS		0.049 in ²	0.25 in	0.138 in	25-350 psi	Air	UV

Design Name: SRH 375		NBCert #	13600
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/21/2027
Design Type			
[Safety Relief Valve] SRH 375 Capacity Tests: Sec. UV at National Board Testing Lab on March 11, 2005 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.670 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: R. Conrader Company {RCO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-0.5 NPS		0.11 in ²	0.375 in	0.15 in	50-350 psi	Air	UV

Design Name: SRH 580		NBCert #	13576
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/21/2027
Design Type			
[Safety Relief Valve] SRH 580 Capacity Tests: Sec. UV at National Board Testing Lab on March 11, 2005 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.330 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: R. Conrader Company {RCO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS		0.262 in ²	0.578 in	0.144 in	25-300 psi	Air	UV

Design Name: SRS250		NBCert #	13611
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/21/2027
Design Type			
[Safety Relief Valve] SRS250 Capacity Tests: Sec. UV at National Board Testing Lab on February 10, 2017 Certified Value: 2.206 PPH/PSIA Media - Test: Steam; Certified: Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: R. Conrader Company {RCO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.375 NPS		0.049 in ²	[N/A] 0.25 in	0.14 in	25-60 psi	Steam	UV

Design Name: SRV 187		NBCert #	13509
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	03/10/2027
Design Type			
[Safety Relief Valve] SRV 187 Capacity Tests: Sec. UV at National Board Testing Lab on January 28, 2003 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.410 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: R. Conrader Company {RCO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.25 NPS		0.027 in ²	0.187 in	0.08 in	25-250 psi	Air	UV

Design Name: SRV 250		NBCert #	13510
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	05/19/2027
Design Type			
[Safety Relief Valve] SRV 250 Capacity Tests: Sec. UV at National Board Testing Lab on January 28, 2003 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.737 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: R. Conrader Company {RCO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.375 NPS		0.049 in ²	0.25 in	0.14 in	25-450 psi	Air	UV

Design Name: SRV 390		NBCert #	13521
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/21/2027
Design Type			
[Safety Relief Valve] SRV 390 Capacity Tests: Sec. UV at National Board Testing Lab on January 28, 2003 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.550 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: R. Conrader Company {RCO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-0.5 NPS		0.119 in ²	0.39 in	0.12 in	25-300 psi	Air	UV

Design Name: SRV 530		NBCert #	13532
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/21/2027
Design Type			
[Safety Relief Valve] SRV 530 Capacity Tests: Sec. UV at National Board Testing Lab on April 29, 2003 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.350 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: R. Conrader Company {RCO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS		0.221 in ²	0.53 in	0.2 in	25-300 psi	Air	UV

Design Name: SRV 765		NBCert #	13543
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/21/2027
Design Type			
[Safety Relief Valve] SRV 765 Capacity Tests: Sec. UV at National Board Testing Lab on April 29, 2003 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 7.130 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: R. Conrader Company {RCO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.25 NPS		0.46 in ²	0.765 in	0.225 in	25-300 psi	Air	UV

Ratermann Cryogenics (RAT)

Humble, TX 77396United States

This Company Manufactures or Assembles:

Design Name: 06388./06418./06383./06413.2312/2314/2320		NBCert # 91101
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/26/2029
Design Type		
[Safety Relief Valve] 06388./06418./06383./06413.2312/2314/2320 Capacity Tests: Sec. UV at unknown lab on August 27, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 7.550 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	2 NPS	389.1 mm ²	23 mm	4.8 mm	29-725 psi	Air	UV

Design Name: 06388/06418/06383/06413.0704/0706		NBCert #	91011
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	04/26/2029	
Design Type			
[Safety Relief Valve] 06388/06418/06383/06413.0704/0706 Capacity Tests: Sec. UV at unknown lab on July 30, 1999 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.862 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1 NPS	38.5 mm ²	7 mm	1.5 mm	48-725 psi	Air	UV

Design Name:	06388/06418/06383/06413.1004/1006	NBCert #	91088
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	04/26/2029	

Design Type

[Safety Relief Valve] 06388/06418/06383/06413.1004/1006
Capacity Tests: Sec. UV at unknown lab on July 30, 1999
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.517 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	1 NPS	86.6 mm ²	10.5 mm	2.2 mm	42-725 psi	Air	UV

Design Name: 06388/06418/06383/06413.1510 NBCert # 91077

Manufacturer/Assembler

Designators

Expiration Date

Assembler UV 04/26/2029

Design Type

[Safety Relief Valve] 06388/06418/06383/06413.1510
Capacity Tests: Sec. UV at unknown lab on July 30, 1999
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.769 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.25 NPS	176.6 mm ²	15 mm	2.6 mm	48-725 psi	Air	UV

REMBE GmbH Safety+Control (REM)

Nameplate Abbreviation: REMBE

Brilon, 59929Germany

This Company Manufactures or Assembles:

Design Name: IG-UKB-LS-1 NBCert # 84035

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer UD 12/17/2030

Design Type

[Rupture Disk Device] IG-UKB-LS-1
Capacity Tests: Sec. UD at National Board Testing Lab on August 13, 2013
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 2.800 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: REMBE GmbH Safety+Control {REM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.7 in ²			55-1450 psi	Air	UD

Design Name: IKB			NBCert # 84024				
Manufacturer/Assembler		Designators		Expiration Date			
Manufacturer		UD		07/05/2029			
Design Type							
[Rupture Disk Device] IKB HolderDesignation: IG-KUB(-S), IG-KUB-PTU(-S), G-KUB(-S) Capacity Tests: Sec. UD at National Board Testing Lab on December 8, 2010 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.970 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: REMBE GmbH Safety+Control {REM}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.53 in²			116-1450 psi		UD
1 NPS		0.85 in²			50.8-1450 psi		UD
1.25 NPS		1.47 in²			43.5-1450 psi		UD
1.5 NPS		2.02 in²			29-928 psi		UD
10 NPS		78.28 in²			7.3-580 psi		UD
12 NPS		111.6 in²			7.3-580 psi		UD
2 NPS		3.33 in²			21.8-928 psi		UD
2.5 NPS		4.73 in²			18.9-928 psi		UD
3 NPS		7.36 in²			14.5-928 psi		UD
4 NPS		12.71 in²			11.6-928 psi		UD
5 NPS		19.84 in²			10.2-580 psi		UD
6 NPS		28.68 in²			7.3-580 psi		UD
8 NPS		49.6 in²			7.3-580 psi		UD
110 mm		6800 mm²	[SPL]		14-300 psi		UD
84 mm		4700 mm²	[SPL]		22-750 psi		UD
90.4 mm		5600 mm²	[SPL]		22-750 psi		UD

Design Name: KUB		NBCert #	84002
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	11/30/2027
Design Type			
[Rupture Disk Device] KUB HolderDesignation: IG-KUB(-S), IG-KUB-PTU(-S), G-KUB(-S) Capacity Tests: Sec. UD at National Board Testing Lab on July 24, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.700 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: REMBE GmbH Safety+Control {REM}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.418 in ²			116-4600 psi		UD
1 NPS		0.698 in ²			94.3-4600 psi		UD
1.25 NPS		1.32 in ²			72.5-4600 psi		UD
1.5 NPS		1.7 in ²			58-4600 psi		UD
10 NPS		68.2 in ²			5.8-725 psi		UD
12 NPS		100.7 in ²			2.9-435 psi		UD
14 NPS		133 in ²			2.9-363 psi		UD
16 NPS		171 in ²			2.9-363 psi		UD
18 NPS		230 in ²			1.5-363 psi		UD
2 NPS		3.29 in ²			43.5-4600 psi		UD
2.5 NPS		4.72 in ²			29-1740 psi		UD
20 NPS		288 in ²			1.5-290 psi		UD
24 NPS		420 in ²			0.7-290 psi		UD
26 NPS		480 in ²			0.7-247 psi		UD
28 NPS		570 in ²			0.7-218 psi		UD
3 NPS		7.33 in ²			21.8-1740 psi		UD
30 NPS		657 in ²			0.7-174 psi		UD
32 NPS		752 in ²			0.7-145 psi		UD
4 NPS		12.4 in ²			8.7-1595 psi		UD
5 NPS		18.6 in ²			8.7-1450 psi		UD
6 NPS		27.9 in ²			7.3-1160 psi		UD
8 NPS		43.4 in ²			7.3-870 psi		UD
84 mm		4700 mm ²	[SPL]		23-750 psi		UD
90.4 mm		5600 mm ²	[SPL]		22-750 psi		UD

Design Name:	KUB (Liquid)	NBCert #	84057
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 03/26/2027

Design Type

[Rupture Disk Device] KUB (Liquid)
HolderDesignation: IG-KUB (-S)
Capacity Tests: Sec. UD at National Board Testing Lab on November 24, 2014
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 3.510 Unitless
Media - Test: Air/Gas; Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: REMBE GmbH Safety+Control {REM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.418 in ²			116-4600 psi	Water	UD
1 NPS		0.698 in ²			94-4600 psi	Water	UD
1.25 NPS		1.32 in ²			72.5-4600 psi	Water	UD

1.5 NPS	1.7 in ²	58-4600 psi	Water	UD
10 NPS	68.2 in ²	5.8-725 psi	Water	UD
12 NPS	100.7 in ²	2.9-435 psi	Water	UD
14 NPS	133 in ²	2.9-363 psi	Water	UD
16 NPS	171 in ²	2.9-363 psi	Water	UD
18 NPS	230 in ²	1.5-363 psi	Water	UD
2 NPS	3.29 in ²	43.5-4600 psi	Water	UD
2.5 NPS	4.72 in ²	29-1740 psi	Water	UD
20 NPS	288 in ²	1.5-290 psi	Water	UD
24 NPS	420 in ²	0.7-290 psi	Water	UD
26 NPS	480 in ²	0.7-247 psi	Water	UD
28 NPS	570 in ²	0.7-218 psi	Water	UD
3 NPS	7.33 in ²	21.8-1740 psi	Water	UD
30 NPS	657 in ²	0.7-174 psi	Water	UD
32 NPS	752 in ²	0.7-145 psi	Water	UD
4 NPS	12.4 in ²	8.7-1595 psi	Water	UD
5 NPS	18.6 in ²	8.7-1450 psi	Water	UD
6 NPS	27.9 in ²	7.3-1160 psi	Water	UD
8 NPS	43.4 in ²	7.3-1160 psi	Water	UD

Design Name: ODV	NBCert # 84013
------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	06/01/2029
--------------	----	------------

Design Type

[Rupture Disk Device] ODV
HolderDesignation: IG(-S)
Capacity Tests: Sec. UD at National Board Testing Lab on June 6, 2000
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.900 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: REMBE GmbH Safety+Control {REM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.139 in ²			116-2900 psi		UD
0.75 NPS		0.418 in ²			87-2900 psi		UD
1 NPS		0.698 in ²			72.5-2610 psi		UD
1.25 NPS		1.32 in ²			72.5-2320 psi		UD
1.5 NPS		1.55 in ²			58-2175 psi		UD
10 NPS		68.2 in ²			1.5-1740 psi		UD
12 NPS		100.7 in ²			1.5-1450 psi		UD
14 NPS		137 in ²			1.5-1450 psi		UD
16 NPS		175 in ²			1.5-1160 psi		UD
18 NPS		234 in ²			1.5-1015 psi		UD

2 NPS	2.94 in ²	43.5-2175 psi	UD
2.5 NPS	4.72 in ²	29-2175 psi	UD
20 NPS	279 in ²	1.5-870 psi	UD
24 NPS	407 in ²	0.7-870 psi	UD
26 NPS	473 in ²	0.7-725 psi	UD
28 NPS	570 in ²	0.7-725 psi	UD
3 NPS	7.33 in ²	14.5-2175 psi	UD
30 NPS	651 in ²	0.7-580 psi	UD
32 NPS	752 in ²	0.7-580 psi	UD
4 NPS	12.4 in ²	5.8-2175 psi	UD
5 NPS	18.6 in ²	5.8-2175 psi	UD
6 NPS	24.8 in ²	4.4-1885 psi	UD
8 NPS	43.4 in ²	2.2-1740 psi	UD

Design Name:	SFD-HL(HP) (Air/Gas)	NBCert #	84079
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 02/25/2031

Design Type

[Rupture Disk Device] SFD-HL(HP) (Air/Gas)
 HolderDesignation: IG-HL(-S), IG-HP(-S), G-HL(-S), G-HP(-S), IG-PTU-HL(-S), IG-PTU-HP(-S)
 Capacity Tests: Sec. UD at National Board Testing Lab on November 6, 2018
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.420 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: REMBE GmbH Safety+Control {REM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
		100.8 in ²			29-6250 psi		UD
		24.8 in ²			29-6250 psi		UD
		43.4 in ²			29-6250 psi		UD
		68.2 in ²			29-6250 psi		UD
0.75 NPS		0.48 in ²			232-6250 psi		UD
1 NPS		0.81 in ²			145-6250 psi		UD
1.25 NPS		1.47 in ²			94.3-6250 psi		UD
1.5 NPS		1.75 in ²			92.8-6250 psi		UD
10 NPS		78.74 in ²			29-6250 psi		UD
12 NPS		113 in ²			29-6250 psi		UD
14 NPS		137.8 in ²			29-3750 psi		UD
16 NPS		182.6 in ²			29-3750 psi		UD
18 NPS		233.6 in ²			29-1500 psi		UD
2 NPS		3.26 in ²			46.4-6250 psi		UD
2.5 NPS		4.73 in ²			46.4-6250 psi		UD
20 NPS		290.9 in ²			29-1500 psi		UD

22 NPS	354.5 in ²	29-1500 psi	UD
24 NPS	418 in ²	29-1500 psi	UD
3 NPS	7.38 in ²	46.4-6250 psi	UD
4 NPS	12.71 in ²	29-6250 psi	UD
5 NPS	20 in ²	29-6250 psi	UD
6 NPS	28.91 in ²	29-6250 psi	UD
8 NPS	49.99 in ²	29-6250 psi	UD

Design Name:	SFD-HL(HP) (Liquid)	NBCert #	84080
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 02/25/2031

Design Type

[Rupture Disk Device] SFD-HL(HP) (Liquid)
 HolderDesignation: IG-HL(-S), IG-HP(-S), G-HL(-S), G-HP(-S), IG-PTU-HL(-S), IG-PTU-HP(-S)
 Capacity Tests: Sec. UD at National Board Testing Lab on November 6, 2018
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 0.790 Unitless
 Media - Test: Air/Gas; Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: REMBE GmbH Safety+Control {REM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
		24.8 in ²			29-6250 psi		UD
		43.4 in ²			29-6250 psi		UD
		100.8 in ²			29-6250 psi		UD
		68.2 in ²			29-6250 psi		UD
0.75 NPS		0.48 in ²			232-6250 psi		UD
1 NPS		0.81 in ²			145-6250 psi		UD
1.25 NPS		1.47 in ²			94.3-6250 psi		UD
1.5 NPS		1.75 in ²			92.8-6250 psi		UD
10 NPS		78.74 in ²			29-6250 psi		UD
12 NPS		113 in ²			29-6250 psi		UD
14 NPS		137.8 in ²			29-3750 psi		UD
16 NPS		182.6 in ²			29-3750 psi		UD
18 NPS		233.6 in ²			29-1500 psi		UD
2 NPS		3.26 in ²			46.4-6250 psi		UD
2.5 NPS		4.73 in ²			46.4-6250 psi		UD
20 NPS		290.9 in ²			29-1500 psi		UD
22 NPS		354.5 in ²			29-1500 psi		UD
24 NPS		418 in ²			29-1500 psi		UD
3 NPS		7.38 in ²			46.4-6250 psi		UD
4 NPS		12.71 in ²			29-6250 psi		UD
5 NPS		20 in ²			29-6250 psi		UD
6 NPS		28.91 in ²			29-6250 psi		UD

Design Name: STAR-HL (HP)		NBCert # 84068	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	03/17/2029
Design Type			
[Rupture Disk Device] STAR-HL (HP) HolderDesignation: IG-HL (HP) Capacity Tests: Sec. UD at National Board Testing Lab on October 25, 2016 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 2.000 Unitless Media - Test: Air/Gas; Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: REMBE GmbH Safety+Control {REM}			
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia. Lift Set Pressure Range Media Designator
		24.8 in ²	5.8-6250 psi UD
		43.4 in ²	2.9-6250 psi UD
		68.2 in ²	2.9-6250 psi UD
		100.75 in ²	2.2-6250 psi UD
0.75 NPS		0.48 in ²	43.5-6250 psi UD
1 NPS		0.81 in ²	36.3-6250 psi UD
1.25 NPS		1.47 in ²	36.3-6250 psi UD
1.5 NPS		1.75 in ²	29-6250 psi UD
10 NPS		78.74 in ²	2.9-6250 psi UD
12 NPS		113 in ²	2.2-6250 psi UD
14 NPS		137.8 in ²	2.2-3750 psi UD
16 NPS		182.59 in ²	1.5-3750 psi UD
18 NPS		233.59 in ²	1.5-1500 psi UD
2 NPS		3.26 in ²	14.5-6250 psi UD
2.5 NPS		4.73 in ²	14.5-6250 psi UD
20 NPS		290.94 in ²	1.5-1500 psi UD
22 NPS		354.49 in ²	1.5-1500 psi UD
24 NPS		418.04 in ²	1.5-1500 psi UD
26 NPS		500.65 in ²	0.7-1500 psi UD
28 NPS		574.59 in ²	0.6-1500 psi UD
3 NPS		7.38 in ²	8.7-6250 psi UD
30 NPS		671.77 in ²	0.6-1500 psi UD
32 NPS		757.8 in ²	0.4-1500 psi UD
34 NPS		868 in ²	0.4-750 psi UD
36 NPS		964.26 in ²	0.4-750 psi UD
38 NPS		1089.65 in ²	0.4-290 psi UD
4 NPS		12.71 in ²	7.3-6250 psi UD
40 NPS		1209.78 in ²	0.4-232 psi UD

42 NPS	1336.1 in ²	0.4-145 psi	UD
44 NPS	1468.94 in ²	0.4-145 psi	UD
46 NPS	1606.89 in ²	0.4-145 psi	UD
48 NPS	1749.95 in ²	0.4-87 psi	UD
5 NPS	20 in ²	5.8-6250 psi	UD
50 NPS	1883.87 in ²	0.4-87 psi	UD
52 NPS	2035.15 in ²	0.4-87 psi	UD
56 NPS	2352.75 in ²	0.4-87 psi	UD
6 NPS	28.91 in ²	5.8-6250 psi	UD
8 NPS	49.99 in ²	2.9-6250 psi	UD

Design Name: TCR-(SGK)KUB NBCert # 84091

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	07/29/2031

Design Type

[Rupture Disk Device] TCR-(SGK)KUB
HolderDesignation: N/A
Capacity Tests: Sec. UD at National Board Testing Lab on April 8, 2019
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 6.860 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: REMBE GmbH Safety+Control {REM}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.341 in ²	0.87 in		50.9-363 psi		UD
25 DN		0.341 in ²	0.89 in		50.9-363 psi		UD
26.9 DN		0.341 in ²	0.933 in		50.9-363 psi		UD
25 DN		0.465 in ²	1.02 in		50.9-363 psi		UD
33.7 DN		0.543 in ²	1.17 in		50.9-363 psi		UD
33.7 DN		0.775 in ²	1.23 in		29.1-363 psi		UD
32 DN		0.775 in ²	1.26 in		29.1-363 psi		UD
1.5 NPS		1.01 in ²	1.37 in		29.1-363 psi		UD
38 DN		1.01 in ²	1.4 in		29.1-363 psi		UD
40 DN		1.24 in ²	1.48 in		29.1-363 psi		UD
40 DN		1.24 in ²	1.5 in		29.1-363 psi		UD
42 DN		1.24 in ²	1.51 in		29.1-363 psi		UD
48.3 DN		1.55 in ²	1.74 in		29.1-232 psi		UD
2 NPS		2.02 in ²	1.87 in		21.8-232 psi		UD
51 DN		2.02 in ²	1.91 in		21.8-232 psi		UD
50 DN		2.17 in ²	1.97 in		21.8-232 psi		UD
60.3 DN		2.79 in ²	2.22 in		21.8-232 psi		UD
2.5 NPS		3.26 in ²	2.37 in		14.5-232 psi		UD
63.5 DN		3.26 in ²	2.37 in		14.5-232 psi		UD

65 DN	3.88 in ²	2.6 in	14.5-232 psi	UD
70 DN	3.88 in ²	2.63 in	14.5-232 psi	UD
76.1 DN	4.96 in ²	2.84 in	14.5-232 psi	UD
3 NPS	4.96 in ²	2.87 in	14.5-232 psi	UD
76.1 DN	4.96 in ²	2.87 in	14.5-232 psi	UD
80 DN	6.2 in ²	3.19 in	14.5-145 psi	UD
88.9 DN	6.51 in ²	3.32 in	14.5-145 psi	UD
88.9 DN	6.51 in ²	3.34 in	14.5-145 psi	UD
4 NPS	9.3 in ²	3.83 in	8.7-145 psi	UD
101.6 DN	9.3 in ²	3.84 in	8.7-145 psi	UD
100 DN	9.61 in ²	3.94 in	8.7-145 psi	UD
114.3 DN	11.9 in ²	4.32 in	7.3-145 psi	UD
114.3 DN	11.9 in ²	4.34 in	7.3-145 psi	UD

Renew Valve and Machine Co. (REN)

Carleton, MI 48117United States

This Company Manufactures or Assembles:

Design Name:	1541, 1543, 1541-3, 1543-3	NBCert #	18032
Manufacturer/Assembler	Designators	Expiration Date	

Assembler	UV, V	07/27/2026
-----------	-------	------------

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV

1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1811, 1511

NBCert #

18122

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV, V

09/15/2029

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V

4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 10/05/2029

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/27/2026

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV

10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 05/14/2031

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/27/2026

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/15/2029

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 09/15/2029

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900E-2, 1900-30E-2		NBCert #	18166
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	09/15/2029
Design Type			
[Safety Relief Valve] 1900E-2, 1900-30E-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids)		NBCert #	18762
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV, V	05/14/2031
Design Type			
[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids) Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.798 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids)		NBCert #	19077
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	11/18/2029
Design Type			
[Relief Valve] 19110M & 19110H (Liquids) Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.264 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

RICHARDS INDUSTRIALS (RIN)

Cincinnati, OH 45209United States

This Company Manufactures or Assembles:

Design Name: SSRV-81		NBCert #	02158
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	12/16/2026
Design Type			
[Safety Relief Valve] SSRV-81 Capacity Tests: Sec. UV at National Board Testing Lab on February 11, 2020 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.570 SCFM/PSIA; (alternate medium): 4.410 PPH/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: RICHARDS INDUSTRIALS {RIN}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 in	0.5-1 in	0.064 in ²	0.37 in	0.043 in	15-500 psi	Air	UV
0.5 in	0.5-1 in	0.064 in ²	0.37 in	0.043 in	15-500 psi	Steam	UV
0.5-1 NPS	0.5-1 NPS	0.064 in ²	0.394 in	0.043 in	15-500 psi	Air	UV
0.5-1 NPS	0.5-1 NPS	0.064 in ²	0.394 in	0.043 in	15-500 psi	Steam	UV
0.75-1 in	0.75-1 in	0.064 in ²	0.394 in	0.043 in	15-500 psi	Air	UV
0.75-1 in	0.75-1 in	0.064 in ²	0.394 in	0.043 in	15-500 psi	Steam	UV

Design Name: SSRV-81 (Liquid)		NBCert #	02169
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	04/15/2027	
Design Type			
[Safety Relief Valve] SSRV-81 (Liquid) Capacity Tests: Sec. UV at National Board Testing Lab on December 17, 2020 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.210 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: RICHARDS INDUSTRIALS {RIN}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 in	0.5-1 in	0.064 in ²	0.37 in	0.043 in	15-500 psi	Water	UV
0.5-1 NPS	0.5-1 NPS	0.064 in ²	0.394 in	0.043 in	15-500 psi	Water	UV

0.75-1 in 0.75-1 in 0.064 in² 0.394 in 0.043 in 15-500 psi Water UV

Design Name: SSRV-83		NBCert # 02192
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/15/2027
Design Type		
[Safety Relief Valve] SSRV-83 Capacity Tests: Sec. UV at National Board Testing Lab on December 17, 2020 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.690 SCFM/PSIA; (alternate medium): 15.990 PPH/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: RICHARDS INDUSTRIALS {RIN}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	0.427 in²	0.984 in	0.139 in	15-232 psi	Air	UV
1.5 NPS	2 NPS	0.427 in²	0.984 in	0.139 in	15-232 psi	Steam	UV

Design Name: SSRV-83 (Liquid)		NBCert # 02204
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/18/2028
Design Type		
[Safety Relief Valve] SSRV-83 (Liquid) Capacity Tests: Sec. UV at National Board Testing Lab on August 3, 2021 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 8.150 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: RICHARDS INDUSTRIALS {RIN}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	0.427 in²	0.984 in	0.139 in	15-232 psi	Water	UV

Design Name: SSRV-83X		NBCert # 02170
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/16/2026
Design Type		
[Safety Relief Valve] SSRV-83X Capacity Tests: Sec. UV at National Board Testing Lab on February 11, 2020 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.990 SCFM/PSIA; (alternate medium): 5.590 PPH/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: RICHARDS INDUSTRIALS {RIN}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	1.5 NPS	0.127 in ²	0.512 in	0.079 in	15-232 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.127 in ²	0.512 in	0.079 in	15-232 psi	Steam	UV

Design Name: SSRV-83X (Liquid) NBCert # 02181

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/18/2028

Design Type

[Safety Relief Valve] SSRV-83X (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on October 29, 2021
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.407 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: RICHARDS INDUSTRIALS {RIN}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	1.5 NPS	0.127 in ²	0.512 in	0.079 in	15-142 psi	Water	UV

Design Name: SSRV-88 NBCert # 02383

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/04/2028

Design Type

[Safety Relief Valve] SSRV-88
Capacity Tests: Sec. UV at National Board Testing Lab on June 9, 2022
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.747 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: RICHARDS INDUSTRIALS {RIN}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	0.644 in ²	0.906 in	0.256 in	15-90 psi	Steam	UV
1.5 NPS	2 NPS	0.644 in ²	0.906 in	0.256 in	15-232 psi	Air	UV
2 NPS	3 NPS	1.667 in ²	1.457 in	0.416 in	15-90 psi	Steam	UV
2 NPS	3 NPS	1.667 in ²	1.457 in	0.416 in	15-232 psi	Air	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.512 in	15-90 psi	Steam	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.512 in	15-232 psi	Air	UV

Design Name: SSRV-88 (Liquid) NBCert # 01449

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/18/2028

Design Type

[Safety Relief Valve] SSRV-88 (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on November 15, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.546 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: RICHARDS INDUSTRIALS {RIN}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	0.644 in ²	0.906 in	0.256 in	15-232 psi	Water	UV
2 NPS	3 NPS	1.667 in ²	1.457 in	0.416 in	15-232 psi	Water	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.512 in	15-232 psi	Water	UV

Robert E. Mason & Associates Inc. (MCS)

Charlotte, NC 28208United States

This Company Manufactures or Assembles:

Design Name: 81, 81P, 83, 84 NBCert # 01089

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/12/2030

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV

2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV
-------	-------	-----------------------	-------------	---------	-------------	-----	----

Design Name:	81P (Liquids)	NBCert #	01102
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 12/12/2030

Design Type

[Relief Valve] 81P (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: 93% of pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name:	900 Series (Liquid), 7700, SNC	NBCert #	15499
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 12/12/2030

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V

1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name: 900 Series, 7700, SNC		NBCert # 15411
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/08/2030
Design Type		
<div>[Safety Relief Valve] 900 Series, 7700, SNC</div> <div>Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990</div> <div>Method of Establishing Relieving Capacity: Flow Capacity, K</div> <div>Certified Value: 0.878 Unitless</div> <div>Media - ; Certified: Air, Gas, Steam</div> <div>Set Pressure Definition: Pop</div> <div>Blowdown Characteristics: Fixed</div> <div>Flow Area Configuration: Nozzle/Full Lift</div> <div>Designed by: Emerson Automation Solutions Final Control US LP {AGC}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids)				NBCert # 15095			
Manufacturer/Assembler				Designators		Expiration Date	
Assembler				UV		12/12/2030	

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.656 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name:	JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB	NBCert #	15208
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	03/21/2031
-----------	----	------------

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV

6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

S & S Valve Services, LLC (SSV)

Metuchen, NJ 08840United States

This Company Manufactures or Assembles:

Design Name: 119 Series			NBCert # 11361				
Manufacturer/Assembler		Designators		Expiration Date			
Assembler		UV, V		07/09/2031			
Design Type							
[Safety Valve] 119 Series Capacity Tests: Sec. UV, V at National Board Testing Lab on March 5, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5 NPS	1.358 in²	[J] 1.315 in	0.329 in	15-250 psi	Air	UV
1.5 NPS	2.5 NPS	1.358 in²	[J] 1.315 in	0.329 in	15-250 psi	Steam	UV

1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Steam	UV
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Steam	NV
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Steam	V
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Air	UV
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Steam	UV
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Steam	V
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Air	UV
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Steam	UV
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Steam	V
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Air	UV
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Steam	UV
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Steam	V

Design Name: 19 Series NBCert # 11282

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/04/2031

Design Type

[Safety Valve] 19 Series
Capacity Tests: Sec. UV, V at unknown lab on March 27, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.826 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.129 in ²	[D] 0.406 in	0.101 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.129 in ²	[D] 0.406 in	0.101 in	15-300 psi	Steam	UV, V
0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Air	UV
0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Steam	UV, V
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Air	UV
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Air	UV

1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Steam	UV, V
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Air	UV
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Steam	UV, V

Design Name:	500 Series	NBCert #	11462
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/01/2031

Design Type

[Safety Valve] 500 Series
Capacity Tests: Sec. UV at National Board Testing Lab on June 12, 2000
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.861 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.129 in ²	[D] 0.406 in	0.102 in	15-2000 psi	Air	UV
0.5-0.75 NPS	.75, 1 NPS	0.129 in ²	[D] 0.406 in	0.102 in	15-2000 psi	Steam	UV
0.75-1 NPS	1.25 NPS	0.229 in ²	[E] 0.539 in	0.135 in	15-2000 psi	Air	UV
0.75-1 NPS	1.25 NPS	0.229 in ²	[E] 0.539 in	0.135 in	15-2000 psi	Steam	UV
1-1.25 NPS	1.5 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-2000 psi	Air	UV
1-1.25 NPS	1.5 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-2000 psi	Steam	UV
1.25-1.5 NPS	2 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-2000 psi	Air	UV
1.25-1.5 NPS	2 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-2000 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-2000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-2000 psi	Steam	UV
2 NPS	3 NPS	1.504 in ²	[J] 1.384 in	0.346 in	15-2000 psi	Air	UV
2 NPS	3 NPS	1.504 in ²	[J] 1.384 in	0.346 in	15-2000 psi	Steam	UV

Design Name:	500 Series (Liquids)	NBCert #	11473
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/04/2031

Design Type

[Safety Relief Valve] 500 Series (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on February 25, 2000
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.689 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.129 in ²	[D] 0.406 in	0.102 in	15-1000 psi	Water	UV
0.75-1 NPS	1.25 NPS	0.229 in ²	[E] 0.539 in	0.135 in	15-1000 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-1000 psi	Water	UV
1.25-1.5 NPS	2 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-1000 psi	Water	UV
1.5-2 NPS	2.5 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-1000 psi	Water	UV
2 NPS	3 NPS	1.504 in ²	[J] 1.384 in	0.346 in	15-1000 psi	Water	UV

S.C. Emerson S.R.L. (EMN)

Nameplate Abbreviation: RCL

Cluj-Napoca, 400641Romania

This Company Manufactures or Assembles:

Design Name:	243/249/443/449/546/843/849/943/5046/5049/8043/8049	NBCert #	01292
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	05/02/2028
Design Type			
[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049			
Capacity Tests: Sec. UV at unknown lab on August 8, 1997			
Method of Establishing Relieving Capacity: Flow Capacity, K			
Certified Value: 0.878 Unitless			
Media - Test: Air/Gas; Certified: Air, Gas, Steam			
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge			
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot			
Flow Area Configuration: Nozzle/Full Lift			
Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name:	253/259/453/459/853/859/953/959/5059/8053/8059	NBCert #	01304
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/02/2028

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
Capacity Tests: Sec. UV at unknown lab on July 31, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.627 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name:	263/269/463/469/566/863/869/963/969/5066/5069	NBCert #	01315
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/02/2028

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069
Capacity Tests: Sec. UV at unknown lab on July 30, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV

3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/02/2028

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.767 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 05/02/2028

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids) NBCert # 01348

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	10/11/2028

Design Type

[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids)
 Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.712 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name:	81, 81P, 83, 84	NBCert #	01089
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/14/2028

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
Capacity Tests: Sec. UV at unknown lab on July 8, 1965
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.816 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}
Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name:	81P (Liquids)	NBCert #	01102
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 07/09/2027

Design Type

[Relief Valve] 81P (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.720 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: 93% of pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name: 900 Series (Liquid), 7700, SNC NBCert # 15499

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

04/07/2026

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.661 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV

1.5 NPS 2.5 NPS 0.5674 in² [#9] 0.85 in 0.274 in 15-5000 psi Water UV, V

Design Name: 900 Series, 7700, SNC

NBCert #

15411

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

04/07/2026

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: BP

NBCert #

15501

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

07/09/2027

Design Type

[Safety Relief Valve] BP
 Capacity Tests: Sec. UV at Crosby Valve, LLC on August 24, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.841 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.0539 in ²	[#4] 0.262 in	0.06 in	50-3000 psi	Air	UV
0.75-1 NPS	1 NPS	0.0929 in ²	[#5] 0.344 in	0.085 in	50-3000 psi	Air	UV
0.75-1 NPS	1 NPS	0.114 in ²	[#5A] 0.381 in	0.098 in	50-3000 psi	Air	UV

0.75-1 NPS	1 NPS	0.1364 in ²	[#6] 0.417 in	0.112 in	50-3000 psi	Air	UV
------------	-------	------------------------	---------------	----------	-------------	-----	----

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Liquids)	NBCert #	15095
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	04/07/2026
--------------	----	------------

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV

6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name:	JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Liquids) (Restricted lift version of Certification 15095)	NBCert #	01393
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/14/2028

Design Type

[Safety Relief Valve] JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Liquids) (Restricted lift version of Certification 15095)

Capacity Tests: Sec. NV, UV, V at unknown lab on October 14, 2015

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.656 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Restricted Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.137 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.137 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Water	NV

4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	0.493 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.616 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Water	UV, V

Design Name:	JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Restricted Lift version of Certification 15512)	NBCert #	01382
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/14/2028

Design Type

[Safety Relief Valve] JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Restricted Lift version of Certification 15512)
Capacity Tests: Sec. UV at unknown lab on October 13, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.6949 in ²	0.892 in	0.137 in	15-2500 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	0.493 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.616 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Air	UV

Design Name:	JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB	NBCert #	15208
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 04/07/2026

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.865 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV

6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Design Name: JOS-E-RL/JBS-E-RL/JDS-E-RL (Restricted Lift version of cert 15208) NBCert # 01045

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 01/14/2028

Design Type

[Safety Relief Valve] JOS-E-RL/JBS-E-RL/JDS-E-RL (Restricted Lift version of cert 15208)
Capacity Tests: Sec. UV at unknown lab on May 26, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-15000 psi	Air	UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.08 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.08 in	15-15000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.08 in	15-15000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.08 in	15-2000 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.08 in	15-15000 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.08 in	15-2000 psi	Steam	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.099 in	15-15000 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.099 in	15-2000 psi	Steam	UV

2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.127 in	15-10000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.127 in	15-2000 psi	Steam	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.152 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.152 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.18 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.18 in	15-3000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.189 in	15-2000 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.189 in	15-5000 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.213 in	15-2000 psi	Steam	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.213 in	15-5000 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.234 in	15-1480 psi	Steam	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.234 in	15-3000 psi	Air	UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.255 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.255 in	15-2250 psi	Steam	UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.284 in	15-1480 psi	Steam	UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.284 in	15-3000 psi	Air	UV
6 NPS	8 NPS	11.045 in ²	3.75 in	0.373 in	15-1000 psi	Steam	UV
6 NPS	8 NPS	11.045 in ²	3.75 in	0.373 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.174 in ²	3.937 in	0.373 in	15-2250 psi	Air	UV
6 NPS	8 NPS	12.174 in ²	3.937 in	0.373 in	15-2250 psi	Steam	UV
6 NPS	10 NPS	12.236 in ²	3.947 in	0.449 in	15-2250 psi	Air	UV
6 NPS	10 NPS	12.236 in ²	3.947 in	0.449 in	15-2250 psi	Steam	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.373 in	15-1480 psi	Steam	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.373 in	15-3000 psi	Air	UV
6 NPS	8 NPS	15.288 in ²	4.412 in	0.424 in	15-2250 psi	Air	UV
6 NPS	8 NPS	15.288 in ²	4.412 in	0.424 in	15-2250 psi	Steam	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.449 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.449 in	15-1480 psi	Steam	UV
8 NPS	10 NPS	18.254 in ²	4.821 in	0.572 in	15-2250 psi	Air	UV
8 NPS	10 NPS	18.254 in ²	4.821 in	0.572 in	15-2250 psi	Steam	UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	0.572 in	15-740 psi	Air	UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	0.572 in	15-740 psi	Steam	UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	0.592 in	15-740 psi	Air	UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	0.592 in	15-740 psi	Steam	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	0.731 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	0.731 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	0.933 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	0.933 in	15-325 psi	Steam	UV

Design Name: Kunkle 337		NBCert # 36278
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/17/2030
Design Type		
[Safety Relief Valve] Kunkle 337 Capacity Tests: Sec. UV at unknown lab on February 22, 1982 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.860 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	1.916 in ²	1.562 in	0.612 in	15-60 psi	Air	UV
2.5 NPS	2.5 NPS	2.786 in ²	1.883 in	0.755 in	15-60 psi	Air	UV
3 NPS	3 NPS	4.037 in ²	2.267 in	0.91 in	15-60 psi	Air	UV

Design Name: Kunkle 6000, 6252 Series		NBCert # 36324
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/17/2030
Design Type		
[Safety Valve] Kunkle 6000, 6252 Series Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV

1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Samshin Limited (SAL)

Cheonan-si, Chungcheongnam-do, 31061 Republic of Korea

This Company Manufactures or Assembles:

Design Name: 150SRV 03/04		NBCert # 58058
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 3	04/27/2028

Design Type

[Safety Relief Valve] 150SRV 03/04
Capacity Tests: Sec. NV, -Class 3 at National Board Testing Lab on April 27, 2022
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:330.00 SCFM
Media - Test: Air/Gas; Certified: Air
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Samshin Limited {SAL}
Comments: 2 valves tested - represents all valves produced for this type

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS	4 NPS				1.84-0 psi	Air	NV, -Class 3

Design Name:	150SRV04	NBCert #	58069
--------------	----------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer	NV, -Class 3	06/28/2029
--------------	--------------	------------

Design Type

[Vacuum Relief Valve] 150SRV04
Capacity Tests: Sec. NV, -Class 3 at National Board Testing Lab on July 26, 2022
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:290.00 SCFM
Media - Test: Air/Gas; Certified: Air
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Samshin Limited {SAL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
	4 NPS		4.02 in	0.6 in	-0.25-0 psi	Air	NV, -Class 3

Design Name:	SRNBF1401EH	NBCert #	58047
--------------	-------------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer	NV, -Class 3	12/11/2026
--------------	--------------	------------

Design Type

[Safety Relief Valve] SRNBF1401EH
Capacity Tests: Sec. NV, -Class 3 at National Board Testing Lab on December 11, 2020
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.681 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Start-to-Leak
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Samshin Limited {SAL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.5 NPS	2 NPS	0.308 in ²	0.626 in	0.187 in	130-130 psi	Water	NV, -Class 3

Design Name:	SRNDF1540GH	NBCert #	58036
--------------	-------------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer	NV, -Class 3	05/20/2027
--------------	--------------	------------

Design Type

[Safety Relief Valve] SRNDF1540GH
 Capacity Tests: Sec. NV, -Class 3 at National Board Testing Lab on May 20, 2021
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 1.760 SCFM/PSIA
 Media - Test: Air/Gas; Certified: Air
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Samshin Limited {SAL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-0.75 NPS	1 NPS	0.11 in ²	0.374 in	0.101 in	128-498 psi	Air	NV, -Class 3

Scallon Controls, Inc. (SCN)

Nameplate Abbreviation: SCI

Beaumont, TX 77705United States

This Company Manufactures or Assembles:

Design Name: 243/249/443/449/546/843/849/943/5046/5049/8043/8049 NBCert # 01292

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/27/2026

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
 Capacity Tests: Sec. UV at unknown lab on August 8, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name:	253/259/453/459/853/859/953/959/5059/8053/8059	NBCert #	01304
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/27/2026

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059

Capacity Tests: Sec. UV at unknown lab on July 31, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.627 Unitless

Media - Test: Air/Gas; Certified: Air, Gas

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Curtain Area

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name:	263/269/463/469/566/863/869/963/969/5066/5069	NBCert #	01315
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/27/2026

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069

Capacity Tests: Sec. UV at unknown lab on July 30, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.860 Unitless

Media - Test: Air/Gas; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV

3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/27/2026

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)

Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.767 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/27/2026

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 81, 81P, 83, 84 NBCert # 01089

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/27/2026

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
 Capacity Tests: Sec. UV at unknown lab on July 8, 1965
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.816 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}
 Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 81P (Liquids)		NBCert #	01102
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	06/27/2026
Design Type			
[Relief Valve] 81P (Liquids) Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.720 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: 93% of pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name: 900 Series (Liquid), 7700, SNC			NBCert # 15499	
Manufacturer/Assembler		Designators		Expiration Date
Assembler		UV		06/27/2026

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.661 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name: 900 Series, 7700, SNC

NBCert #

15411

Manufacturer/Assembler

Designators

Expiration Date

Assembler

UV

06/27/2026

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV

1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name:	H Series (HCI, HSJ, HCA, HA, HB, HC, HCB, HCP, HJO, HN, HNA, HNB, HNP, HS, NBCert # 15006 HSA, HSB, HSC, HSP)						
--------------	---	--	--	--	--	--	--

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 06/27/2026

Design Type

[Safety Valve] H Series (HCI, HSJ, HCA, HA, HB, HC, HCB, HCP, HJO, HN, HNA, HNB, HNP, HS, HSA, HSB, HSC, HSP)
Capacity Tests: Sec. UV, V at unknown lab on September 1, 1939
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1.5 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-500 psi	Steam	UV, V
0.75 NPS	1.5 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-500 psi	Steam	UV, V
1-1.5 NPS	2 - 3 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-3100 psi	Steam	UV, V
1-2 NPS	2.5, 3 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-3100 psi	Steam	UV, V
1.5-2 NPS	3, 4, 6 NPS	0.785 in ²	[H] 1 in	0.25 in	15-5000 psi	Steam	UV, V
1.5 NPS	3 NPS	0.865 in ²	1.05 in	0.262 in	15-3100 psi	Steam	UV, V
1.5 NPS	3 NPS	0.994 in ²	[H2] 1.125 in	0.281 in	15-3100 psi	Steam	UV, V
2-3 NPS	3, 4, 6 NPS	1.288 in ²	[J] 1.281 in	0.32 in	15-5000 psi	Steam	UV, V
2 NPS	4 NPS	1.431 in ²	[J2] 1.35 in	0.338 in	15-3100 psi	Steam	UV, V
2.5-3 NPS	4, 6 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-6000 psi	Steam	UV, V
2.5 NPS	6 NPS	2.545 in ²	[K2] 1.8 in	0.45 in	15-6800 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.476 in	15-3100 psi	Steam	UV, V
3 NPS	6 NPS	3.341 in ²	[L2] 2.062 in	0.516 in	15-3100 psi	Steam	UV, V
3-4 NPS	6, 8 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-6000 psi	Steam	UV, V
3 NPS	6, 8 NPS	3.976 in ²	[M2] 2.25 in	0.563 in	15-6000 psi	Steam	UV, V
4 NPS	6 NPS	4.341 in ²	[N] 2.351 in	0.588 in	15-3100 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.712 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	7.07 in ²	[P2] 3 in	0.75 in	15-3100 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.937 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	12.25 in ²	[Q2] 3.95 in	0.988 in	15-3100 psi	Steam	UV, V
6 NPS	8, 10 NPS	16 in ²	[R] 4.513 in	1.128 in	15-3100 psi	Steam	UV, V
6 NPS	10 NPS	19.29 in ²	[RR] 4.956 in	1.239 in	15-3100 psi	Steam	UV, V
8 NPS	10, 12 NPS	26 in ²	[T] 5.75 in	1.437 in	15-500 psi	Steam	UV, V
8 NPS	12, 14 NPS	28.274 in ²	6 in	1.5 in	15-2000 psi	Steam	UV, V

10 NPS	14 NPS	44.18 in ²	7.5 in	1.875 in	15-500 psi	Steam	UV, V
12 NPS	16 NPS	63.62 in ²	9 in	2.25 in	15-500 psi	Steam	UV, V
14 NPS	18 NPS	86.59 in ²	10.5 in	2.625 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	95.21 in ²	11.01 in	2.753 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	114.04 in ²	12.05 in	3.02 in	15-500 psi	Steam	UV, V
18 NPS	24 NPS	143.14 in ²	13.5 in	3.375 in	15-500 psi	Steam	UV, V
20 NPS	24 NPS	176.71 in ²	15 in	3.75 in	15-500 psi	Steam	UV, V

Design Name:	HL, HSL	NBCert #	15589
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 03/01/2029

Design Type

[Safety Valve] HL, HSL
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on November 3, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.869 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	1.5 NPS	0.339 in ²	[F] 0.657 in	0.164 in	15-725 psi	Steam	UV, V
1.25-2 NPS	1.5 NPS	0.553 in ²	[G] 0.839 in	0.21 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.868 in ²	[H] 1.051 in	0.263 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.327 in ²	[J] 1.3 in	0.325 in	15-725 psi	Steam	UV, V
2-3 NPS	3-4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-725 psi	Steam	UV, V
2.5-4 NPS	4-6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-725 psi	Steam	UV, V
3 NPS	4-6 NPS	3.955 in ²	[M] 2.244 in	0.561 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	4.831 in ²	[N] 2.48 in	0.62 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	7.031 in ²	[P] 2.992 in	0.748 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[QQ] 3.75 in	0.937 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	0.984 in	15-725 psi	Steam	UV, V

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Liquids)	NBCert #	15095
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/27/2026

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/27/2026

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name:	JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Liquids) (Restricted lift version of Certification 15095)	NBCert #	01393
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/27/2026

Design Type

[Safety Relief Valve] JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Liquids) (Restricted lift version of Certification 15095)
Capacity Tests: Sec. NV, UV, V at unknown lab on October 14, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Water	UV, V

1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.137 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.137 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	0.493 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.616 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Water	UV, V

Design Name:	JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Restricted Lift version of Certification 15512)	NBCert #	01382
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/27/2026

Design Type

[Safety Relief Valve] JLT-JOS-RL/JLT-JBS-RL/JLT-JDS-RL (Restricted Lift version of Certification 15512)
Capacity Tests: Sec. UV at unknown lab on October 13, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.082 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.103 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.131 in	15-6170 psi	Air	UV

1.5-2 NPS	3 NPS	0.6949 in ²	0.892 in	0.137 in	15-2500 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.164 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.21 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.251 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.313 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.351 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.386 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	0.468 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	0.493 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.616 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.741 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	0.944 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/27/2026

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV

4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Design Name: JOS-E-RL/JBS-E-RL/JDS-E-RL (Restricted Lift version of cert 15208)		NBCert #	01045
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	06/27/2026

Design Type

[Safety Relief Valve] JOS-E-RL/JBS-E-RL/JDS-E-RL (Restricted Lift version of cert 15208)

Capacity Tests: Sec. UV at unknown lab on May 26, 2015

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.865 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable (Single Ring)

Flow Area Configuration: Restricted Lift

Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-15000 psi	Air	UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.08 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.08 in	15-15000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.08 in	15-15000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.08 in	15-2000 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.08 in	15-15000 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.08 in	15-2000 psi	Steam	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.099 in	15-15000 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.099 in	15-2000 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.127 in	15-10000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.127 in	15-2000 psi	Steam	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.152 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.152 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.18 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.18 in	15-3000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.189 in	15-2000 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.189 in	15-5000 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.213 in	15-2000 psi	Steam	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.213 in	15-5000 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.234 in	15-1480 psi	Steam	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.234 in	15-3000 psi	Air	UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.255 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.255 in	15-2250 psi	Steam	UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.284 in	15-1480 psi	Steam	UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.284 in	15-3000 psi	Air	UV
6 NPS	8 NPS	11.045 in ²	3.75 in	0.373 in	15-1000 psi	Steam	UV
6 NPS	8 NPS	11.045 in ²	3.75 in	0.373 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.174 in ²	3.937 in	0.373 in	15-2250 psi	Air	UV
6 NPS	8 NPS	12.174 in ²	3.937 in	0.373 in	15-2250 psi	Steam	UV
6 NPS	10 NPS	12.236 in ²	3.947 in	0.449 in	15-2250 psi	Air	UV

6 NPS	10 NPS	12.236 in ²	3.947 in	0.449 in	15-2250 psi	Steam	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.373 in	15-1480 psi	Steam	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.373 in	15-3000 psi	Air	UV
6 NPS	8 NPS	15.288 in ²	4.412 in	0.424 in	15-2250 psi	Air	UV
6 NPS	8 NPS	15.288 in ²	4.412 in	0.424 in	15-2250 psi	Steam	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.449 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.449 in	15-1480 psi	Steam	UV
8 NPS	10 NPS	18.254 in ²	4.821 in	0.572 in	15-2250 psi	Air	UV
8 NPS	10 NPS	18.254 in ²	4.821 in	0.572 in	15-2250 psi	Steam	UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	0.572 in	15-740 psi	Air	UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	0.572 in	15-740 psi	Steam	UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	0.592 in	15-740 psi	Air	UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	0.592 in	15-740 psi	Steam	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	0.731 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	0.731 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	0.933 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	0.933 in	15-325 psi	Steam	UV

Seetru Limited (SEE)

Nameplate Abbreviation: SEE

Bristol, BS1 6UTUnited Kingdom

This Company Manufactures or Assembles:

Design Name: 10125, 10725		NBCert # 06679	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	02/14/2029
Design Type			
[Safety Relief Valve] 10125, 10725 Capacity Tests: Sec. UV at National Board Testing Lab on November 18, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 11.300 SCFM/PSIA Media - ; Certified: Air, Gas Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Seetru Limited {SEE}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2.5 NPS		490 mm ²	25 mm		1.1-12 bar	Air	UV

Design Name: 319 (In Line Type)		NBCert # 06590	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	02/14/2029

Design Type

[Safety Relief Valve] 319 (In Line Type)
Capacity Tests: Sec. UV at National Board Testing Lab on May 17, 2005
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.040 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Seetru Limited {SEE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-0.5 NPS		71 mm ²	0.373 in		195-725 psi	Air	UV

Design Name:	319000488	NBCert #	06703
--------------	-----------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/14/2029

Design Type

[Safety Relief Valve] 319000488
Capacity Tests: Sec. UV at National Board Testing Lab on March 29, 2012
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.230 SCFM/PSIA
Media - ; Certified: Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Seetru Limited {SEE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	.75, 1 NPS	133.6 mm ²	13.04 mm		16.2-26.8 bar	Air	UV

Design Name:	32931	NBCert #	06714
--------------	-------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/14/2029

Design Type

[Safety Relief Valve] 32931
Capacity Tests: Sec. UV at National Board Testing Lab on November 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.700 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Seetru Limited {SEE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-0.75 NPS	0.75 NPS	0.0438 in ²	0.236 in	0.059 in	768-5365 psi	Air	UV

Design Name:	61118, 61718, 62118, 62718	NBCert #	06646
--------------	----------------------------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/15/2029

Design Type

[Safety Relief Valve] 61118, 61718, 62118, 62718
Capacity Tests: Sec. UV at National Board Testing Lab on November 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 6.040 SCFM/PSIA
Media - ; Certified: Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Seetru Limited {SEE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS		254.5 mm ²	18 mm		2.1-36 bar	Air	UV

Design Name: 61120, 61720, 62120, 62720 NBCert # 06657

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/16/2029

Design Type

[Safety Relief Valve] 61120, 61720, 62120, 62720
Capacity Tests: Sec. UV at National Board Testing Lab on November 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 7.320 SCFM/PSIA
Media - ; Certified: Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Seetru Limited {SEE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS		314.1 mm ²	20 mm		28-256 psi	Air	UV

Design Name: 63110, 64110, 65110, 63710, 64710, 65710NBCert # 06523

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/14/2029

Design Type

[Safety Relief Valve] 63110, 64110, 65110, 63710, 64710, 65710
Capacity Tests: Sec. UV at National Board Testing Lab on August 17, 2005
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.710 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Seetru Limited {SEE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-0.75 NPS	.75 NPS	70.9 mm ²	9.5 mm	3.5 mm	22.5-800 psi	Air	UV

Design Name: 63113, 64113, 65113, 63713, 64713, 65713NBCert # 06545

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/14/2029

Design Type

[Safety Relief Valve] 63113, 64113, 65113, 63713, 64713, 65713
Capacity Tests: Sec. UV at National Board Testing Lab on May 13, 2005
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.470 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Seetru Limited {SEE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	147.4 mm ²	13.7 mm	5.7 mm	20-710 psi	Air	UV

Design Name: 63118, 64118, 65118, 65718 NBCert # 06556

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/14/2029

Design Type

[Safety Relief Valve] 63118, 64118, 65118, 65718
Capacity Tests: Sec. UV at National Board Testing Lab on August 17, 2005
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.600 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Seetru Limited {SEE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	1.5 NPS	227 mm ²	17 mm		34.8-507 psi	Air	UV

Design Name: 63120, 64120, 65120, 63720, 64720, 65720NBCert # 06567

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/14/2029

Design Type

[Safety Relief Valve] 63120, 64120, 65120, 63720, 64720, 65720
Capacity Tests: Sec. UV at National Board Testing Lab on May 12, 2005
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 7.770 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Seetru Limited {SEE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	2 NPS	314 mm ²	20 mm	5 mm	43-507.5 psi	Air	UV

Design Name: 63125, 64125, 65125, 63725, 64725, 65725NBCert # 06578

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/14/2029

Design Type

[Safety Relief Valve] 63125, 64125, 65125, 63725, 64725, 65725
Capacity Tests: Sec. UV at National Board Testing Lab on May 12, 2005
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 12.260 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Seetru Limited {SEE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	2 NPS	490.4 mm ²	25 mm	9.5 mm	82-435 psi	Air	UV

Design Name: 81106,81706,84106,84706,81108,81708,81188,81788,84188,84788 NBCert # 06501

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/14/2029

Design Type

[Safety Relief Valve] 81106,81706,84106,84706,81108,81708,81188,81788,84188,84788
Capacity Tests: Sec. UV at National Board Testing Lab on August 18, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.748 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Seetru Limited {SEE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-0.5 NPS		28.3 mm ²	6 mm	1.5 mm	40.6-522 psi	Air	UV
0.25-0.5 NPS		50.27 mm ²	8 mm	1.4 mm	43.5-634 psi	Air	UV

Design Name: 81110, 84110, 81710, 84710 NBCert # 06613

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/14/2029

Design Type

[Safety Relief Valve] 81110, 84110, 81710, 84710
Capacity Tests: Sec. UV at National Board Testing Lab on October 18, 2005
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.660 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Seetru Limited {SEE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS		78.54 mm ²	10 mm	2.1 mm	34.9-738 psi	Air	UV

Design Name: 81113, 84113, 81713, 84713 NBCert # 06602

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/14/2029

Design Type

[Safety Relief Valve] 81113, 84113, 81713, 84713
Capacity Tests: Sec. UV at National Board Testing Lab on August 17, 2005
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.940 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Seetru Limited {SEE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS		132.7 mm ²	13 mm	2.73 mm	40.6-580 psi	Air	UV

Design Name: 81115, 81715, 84115, 84715 NBCert # 06680

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

02/16/2029

Design Type

[Safety Relief Valve] 81115, 81715, 84115, 84715
Capacity Tests: Sec. UV at National Board Testing Lab on November 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 4.000 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Seetru Limited {SEE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS		0.281 in ²	0.598 in	0.15 in	36-580 psi	Air	UV

Sempell GmbH (SML)

Nameplate Abbreviation: SEMPELL

Korschenbroich, D-41352Germany

This Company Manufactures or Assembles:

Design Name: SC & SB (Liquids) NBCert # 64011

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

09/17/2025

Design Type

[Relief Valve] SC & SB (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on March 12, 1992
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.576 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Sempell GmbH {SML}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.134 in ²	[D] 0.413 in	0.124 in	15-6000 psi	Water	UV
1-1.5 NPS	2 NPS	0.239 in ²	[E] 0.551 in	0.165 in	15-6000 psi	Water	UV
1.5 NPS	2 NPS	0.373 in ²	[F] 0.689 in	0.207 in	15-6000 psi	Water	UV
1.5-2 NPS	2.5 NPS	0.616 in ²	[G] 0.886 in	0.266 in	15-5000 psi	Water	UV
1.5-2 NPS	3 NPS	0.954 in ²	[H] 1.102 in	0.331 in	15-5000 psi	Water	UV
2-3 NPS	3 NPS	1.578 in ²	[J] 1.417 in	0.425 in	15-5000 psi	Water	UV
3 NPS	4 NPS	2.251 in ²	[K] 1.693 in	0.508 in	15-5000 psi	Water	UV
3-4 NPS	4 NPS	3.42 in ²	[L] 2.087 in	0.626 in	15-5000 psi	Water	UV
4 NPS	6 NPS	4.382 in ²	[M] 2.362 in	0.709 in	15-3705 psi	Water	UV
4 NPS	6 NPS	5.303 in ²	[N] 2.598 in	0.78 in	15-3705 psi	Water	UV
4 NPS	6 NPS	7.598 in ²	[P] 3.11 in	0.993 in	15-3190 psi	Water	UV
6 NPS	8 NPS	13.167 in ²	[Q] 4.094 in	1.228 in	15-3190 psi	Water	UV
6 NPS	8 NPS	19.021 in ²	[R] 4.921 in	1.476 in	15-2470 psi	Water	UV
8 NPS	10 NPS	31.165 in ²	[T] 6.299 in	1.89 in	15-1455 psi	Water	UV
10-12 NPS	12, 14 NPS	41.664 in ²	[T1] 7.283 in	2.185 in	15-1455 psi	Water	UV
10-14 NPS	14, 16 NPS	51.66 in ²	[U] 8.11 in	2.433 in	15-1160 psi	Water	UV
12-14 NPS	16, 20 NPS	64.399 in ²	[V] 9.055 in	2.717 in	15-1160 psi	Water	UV
14-16 NPS	20, 24 NPS	88.746 in ²	[W] 10.63 in	3.189 in	15-915 psi	Water	UV
16-20 NPS	20, 24 NPS	127.007 in ²	[X] 12.717 in	3.815 in	15-290 psi	Water	UV
20-24 NPS	24, 28 NPS	172.107 in ²	[Y] 14.803 in	4.441 in	15-290 psi	Water	UV
24-28 NPS	28, 32 NPS	233.545 in ²	[Z] 17.244 in	5.173 in	15-235 psi	Water	UV

Design Name: SEP	NBCert # 64077
------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	V	04/04/2030
--------------	---	------------

Design Type

[Power Actuated Relief Valve] SEP
 Capacity Tests: Sec. V at National Board Testing Lab on April 15, 2013
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Power Actuated
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Sempell GmbH {SML}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2.5-4 NPS	4, 6 NPS	1.758 in ²	[J1] 1.496 in	0.524 in	15-6000 psi	Steam	V
2.5-4 NPS	4,6 NPS	2.465 in ²	[K1] 1.772 in	0.62 in	15-6000 psi	Steam	V
2.5-4 NPS	4, 6 NPS	3.42 in ²	[L] 2.087 in	0.73 in	15-6000 psi	Steam	V
4-6 NPS	6, 8 NPS	4.382 in ²	[M] 2.362 in	0.827 in	15-6000 psi	Steam	V
4-6 NPS	6, 8 NPS	5.303 in ²	[N] 2.598 in	0.909 in	15-6000 psi	Steam	V
4-6 NPS	6-10 NPS	7.598 in ²	[P] 3.071 in	1.075 in	15-2000 psi	Steam	V

6-8 NPS	8-12 NPS	10.987 in ²	[P1] 3.74 in	1.309 in	15-2000 psi	Steam	V
6-8 NPS	8-12 NPS	13.17 in ²	[Q] 4.094 in	1.433 in	15-2000 psi	Steam	V
6-8 NPS	8-12 NPS	19.07 in ²	[R] 4.921 in	1.722 in	15-2000 psi	Steam	V

Design Name: VS99NBCert # 64066

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV	09/30/2029

Design Type

[Pilot Operated Pressure Relief Valve] VS99
Capacity Tests: Sec. NV, -Class 1 at National Board Testing Lab on December 1, 2009
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Sempell GmbH {SML}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
7 NPS	7 NPS	3.292 in ²	[K52] 2.047 in	30 mm	2320-2828 psi	Steam	NV
7 NPS	7 NPS	3.42 in ²	[K53] 2.087 in	30 mm	2320-2828 psi	Steam	NV
7 NPS	7 NPS	3.55 in ²	[K54] 2.126 in	30 mm	2320-2828 psi	Steam	NV
7 NPS	7 NPS	3.683 in ²	[K55] 2.165 in	30 mm	2320-2828 psi	Steam	NV
7 NPS	7 NPS	3.818 in ²	[K56] 2.205 in	30 mm	2320-2828 psi	Steam	NV
7 NPS	7 NPS	3.955 in ²	[K57] 2.244 in	30 mm	2320-2828 psi	Steam	NV
7 NPS	7 NPS	4.095 in ²	[K58] 2.283 in	30 mm	2320-2828 psi	Steam	NV
7 NPS	7 NPS	4.238 in ²	[K59] 2.323 in	30 mm	2320-2828 psi	Steam	NV
7 NPS	7 NPS	4.383 in ²	[K60] 2.362 in	30 mm	2320-2828 psi	Steam	NV
8 NPS	8 NPS	4.383 in ²	[L60] 2.362 in	35 mm	2320-2828 psi	Steam	NV
8 NPS	8 NPS	4.53 in ²	[L61] 2.402 in	35 mm	2320-2828 psi	Steam	NV
8 NPS	8 NPS	4.68 in ²	[L62] 2.441 in	35 mm	2320-2828 psi	Steam	NV
8 NPS	8 NPS	4.832 in ²	[L63] 2.48 in	35 mm	2320-2828 psi	Steam	NV
8 NPS	8 NPS	4.986 in ²	[L64] 2.52 in	35 mm	2320-2828 psi	Steam	NV
8 NPS	8 NPS	5.143 in ²	[L65] 2.559 in	35 mm	2320-2828 psi	Steam	NV
8 NPS	8 NPS	5.303 in ²	[L66] 2.598 in	35 mm	2320-2828 psi	Steam	NV
8 NPS	8 NPS	5.465 in ²	[L67] 2.638 in	35 mm	2320-2828 psi	Steam	NV
8 NPS	8 NPS	5.629 in ²	[L68] 2.677 in	35 mm	2320-2828 psi	Steam	NV
8 NPS	8 NPS	5.796 in ²	[L69] 2.717 in	35 mm	2320-2828 psi	Steam	NV
8 NPS	8 NPS	5.965 in ²	[L70] 2.756 in	35 mm	2320-2828 psi	Steam	NV

SETPOINT Integrated Solutions Inc. (CPA)Nameplate Abbreviation: SETPOINT

Port Arthur, TX 77640United States

This Company Manufactures or Assembles:

Design Name:	1541, 1543, 1541-3, 1543-3	NBCert #	18032
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	07/20/2029

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name:	1700 & 2700	NBCert #	18100
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	07/19/2029

Design Type

[Safety Valve] 1700 & 2700
 Capacity Tests: Sec. UV, V at Dresser, Inc. on August 1, 1957
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	50-5800 psi	Steam	V
4 NPS	4 dual NPS	1.84 in ²	[K] 1.531 in	0.383 in	50-5800 psi	Steam	V
2-3 NPS	4, 6 NPS	2.545 in ²	[#3] 1.8 in	0.45 in	50-5800 psi	Steam	UV, V
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-2575 psi	Steam	UV
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	50-5800 psi	Steam	V
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	15-3100 psi	Steam	UV
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	50-5800 psi	Steam	V
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	15-3100 psi	Steam	UV
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	15-1800 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	1.24 in	50-2200 psi	Steam	UV, V
8-10 NPS	10,12 NPS	28.3 in ²	[T] 6 in	1.5 in	50-1500 psi	Steam	UV, V

Design Name: 1700 & 2700 (Restricted Lift version of Cert. # 18100) NBCert # 18111

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	07/27/2029

Design Type

[Safety Valve] 1700 & 2700 (Restricted Lift version of Cert. # 18100)
 Capacity Tests: Sec. UV, V at unknown lab on October 13, 1981
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Restricted Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	50-5800 psi	Steam	V
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	15-3100 psi	Steam	UV
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	50-5800 psi	Steam	V
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-2575 psi	Steam	UV
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	50-5800 psi	Steam	V
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	15-3100 psi	Steam	UV
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	50-5800 psi	Steam	V
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	15-3100 psi	Steam	UV
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.946 in	0.296 in	15-2000 psi	Steam	UV, V
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	0.372 in	50-2200 psi	Steam	V
8-10 NPS	10, 12 NPS	28.3 in ²	[T] 6 in	0.45 in	50-1500 psi	Steam	UV, V

Design Name: 1811, 1511

NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	07/19/2029

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA
(Liquids)

NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	07/19/2029

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V

1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/18/2029

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV

3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/22/2029

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert #

18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

07/20/2029

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2

NBCert #

18144

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

07/19/2029

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert # 18751

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	07/27/2029

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM NBCert # 19066

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/20/2029

Design Type

[Safety Relief Valve] 1900-DM
Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV

3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D

NBCert #

19088

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/30/2029

Design Type

[Safety Relief Valve] 1900-DM-D

Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Curtain Area

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E

NBCert #

19099

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/30/2029

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2 NBCert # 18166

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

07/20/2029

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV, V

07/19/2029

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name:	19110M & 19110H (Liquids)	NBCert #	19077
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/27/2029

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name:	3900 (39PV, 39MV pilots)	NBCert #	18447
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/18/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV

1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV

10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Setpoint Integrated Solutions, Inc. (CCM)

West Monroe, LA 71292United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3 NBCert # 18032

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/09/2030

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV

1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1811, 1511

NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/09/2030

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	03/14/2030

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/06/2030

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/14/2030

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/10/2030

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV

0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/09/2030

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 04/10/2030

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name:	1900-DM	NBCert #	19066
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/03/2028

Design Type

[Safety Relief Valve] 1900-DM

Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D		NBCert # 19088
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/03/2028
Design Type		
[Safety Relief Valve] 1900-DM-D Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787) Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid Set Pressure Definition(1): Pop; (2): First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E		NBCert # 19099
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/03/2028
Design Type		
[Safety Relief Valve] 1900-DM-E Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787) Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid Set Pressure Definition(1): Pop; (2): First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2		NBCert # 18166
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/09/2030
Design Type		
[Safety Relief Valve] 1900E-2, 1900-30E-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/10/2030

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ. RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 1982 LS, 820000LS NBCert # 18380

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/14/2030

Design Type

[Relief Valve] 1982 LS, 820000LS
Capacity Tests: Sec. UV at Dresser, Inc. on December 19, 1984
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.758 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	NV
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	UV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	NV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	NV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	UV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	NV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	NV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	UV

Design Name: 2900-TM (39PV & 39MV pilots)

NBCert #

01427

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/17/2029

Design Type

[Pilot Operated Pressure Relief Valve] 2900-TM (39PV & 39MV pilots)

Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Water	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Water	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Water	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2000 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Water	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Water	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-300 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Water	UV

Design Name:	3900 (39PV, 39MV pilots)	NBCert #	18447
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/18/2028

Design Type
[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots) Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - ; Certified: Air, Gas, Steam Set Pressure Definition(1): Pop; (2): Initial Audible Discharge Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV

1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV

6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid) NBCert # 18458

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/03/2028

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV

3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Design Name: 3900-TM (39PV, 39MV pilots)

NBCert #

01438

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/17/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3900-TM (39PV, 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; (alternate medium): 0.743 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Water	UV

1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV

6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Setpoint Integrated Solutions, Inc. (CCS)

Nameplate Abbreviation: Setpoint
Integrated Solutions

Luling, LA 70070United States

This Company Manufactures or Assembles:

Design Name:	1541, 1543, 1541-3, 1543-3	NBCert #	18032
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV, V	12/13/2028
-----------	-------	------------

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV

0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1700 & 2700 NBCert # 18100

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 03/23/2029

Design Type

[Safety Valve] 1700 & 2700
Capacity Tests: Sec. UV, V at Dresser, Inc. on August 1, 1957
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	50-5800 psi	Steam	V
4 NPS	4 dual NPS	1.84 in ²	[K] 1.531 in	0.383 in	50-5800 psi	Steam	V
2-3 NPS	4, 6 NPS	2.545 in ²	[#3] 1.8 in	0.45 in	50-5800 psi	Steam	UV, V
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-2575 psi	Steam	UV
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	15-3100 psi	Steam	UV

2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	50-5800 psi	Steam	V
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	15-3100 psi	Steam	UV
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	50-5800 psi	Steam	V
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	15-3100 psi	Steam	UV
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	15-1800 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	1.24 in	50-2200 psi	Steam	UV, V
8-10 NPS	10,12 NPS	28.3 in ²	[T] 6 in	1.5 in	50-1500 psi	Steam	UV, V

Design Name: 1700 & 2700 (Restricted Lift version of Cert. # 18100) NBCert # 18111

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 05/20/2028

Design Type

[Safety Valve] 1700 & 2700 (Restricted Lift version of Cert. # 18100)
Capacity Tests: Sec. UV, V at unknown lab on October 13, 1981
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	50-5800 psi	Steam	V
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	15-3100 psi	Steam	UV
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	50-5800 psi	Steam	V
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-2575 psi	Steam	UV
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	50-5800 psi	Steam	V
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	15-3100 psi	Steam	UV
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	50-5800 psi	Steam	V

4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	15-3100 psi	Steam	UV
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.946 in	0.296 in	15-2000 psi	Steam	UV, V
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	0.372 in	50-2200 psi	Steam	V
8-10 NPS	10, 12 NPS	28.3 in ²	[T] 6 in	0.45 in	50-1500 psi	Steam	UV, V

Design Name: 1811, 1511

NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV, V

09/07/2027

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV

6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 09/08/2027

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 12/15/2025

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV

10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201) NBCert # 18223

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/05/2030

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV

8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/29/2028

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/03/2030

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2

NBCert #

18144

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

12/15/2025

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert #

18751

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV, V

09/07/2027

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 3.256 GPM/SQ. RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM

NBCert # 19066

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

07/29/2028

Design Type

[Safety Relief Valve] 1900-DM
 Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
 Set Pressure Definition(1): Pop; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name:	1900-DM-D	NBCert #	19088
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/16/2027

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name:	1900-DM-E	NBCert #	19099
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/16/2027

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2		NBCert #	18166
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	12/15/2025
Design Type			
[Safety Relief Valve] 1900E-2, 1900-30E-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids)		NBCert #	18762
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV, V	10/20/2028
Design Type			
[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids) Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.798 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids)		NBCert #	19077
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	11/17/2027
Design Type			
[Relief Valve] 19110M & 19110H (Liquids) Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.264 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name:	1982	NBCert #	18379
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/23/2028

Design Type

[Safety Relief Valve] 1982
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at unknown lab on May 6, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Air	NV, UV
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Steam	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Air	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Steam	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Air	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Steam	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Air	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Air	NV, UV

Design Name:	1982 LS, 820000LS	NBCert #	18380
--------------	-------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/03/2025

Design Type

[Relief Valve] 1982 LS, 820000LS
Capacity Tests: Sec. UV at Dresser, Inc. on December 19, 1984
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.758 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	NV
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	UV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	NV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	UV

1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	NV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	UV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	NV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	NV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	UV

Design Name: 2900 (39PV & 39MV pilots - Liquid) NBCert # 18874

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	11/14/2029

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots - Liquid)
Capacity Tests: Sec. UV, V at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.127 in	15-6250 psi	Water	UV, V
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	UV, V
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.205 in	15-6250 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-6250 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-6000 psi	Water	UV, V
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-6000 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-3750 psi	Water	UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-2250 psi	Water	UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-1500 psi	Water	UV, V
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.738 in	15-1500 psi	Water	UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-905 psi	Water	UV, V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV, V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.93 in	15-675 psi	Water	UV, V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-535 psi	Water	UV, V

Design Name: 2900 (39PV & 39MV pilots) NBCert # 18863

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/14/2029

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
 Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV

12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
--------	--------	------------------------	---------------	----------	------------	-------	----

Design Name:	2900-TM (39PV & 39MV pilots)	NBCert #	01427
--------------	------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	02/10/2029
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 2900-TM (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Water	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Water	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Water	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2000 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Water	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Water	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-300 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Water	UV

Design Name: 3900 (39PV, 39MV pilots)

NBCert #

18447

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

10/13/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV

1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV

6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid) NBCert # 18458

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/05/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV

2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Design Name: 3900-TM (39PV, 39MV pilots) NBCert # 01438

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/10/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3900-TM (39PV, 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; (alternate medium): 0.743 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV

1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV

6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

SETPOINT Integrated Solutions, Inc. (CCT)

Nameplate Abbreviation: SETPOINT
INTEGRATED SOLUTIONS

Kilgore, TX 75662United States

This Company Manufactures or Assembles:

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	05/13/2031

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V

2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/13/2031

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV

4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/30/2026

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV

1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

04/30/2026

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2

NBCert # 18144

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

05/14/2031

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert # 18751		
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/14/2031
Design Type		
[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids) Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.256 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900E-2, 1900-30E-2 NBCert # 18166		
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/14/2031
Design Type		
[Safety Relief Valve] 1900E-2, 1900-30E-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762		
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/14/2031
Design Type		
[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids) Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.798 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name:	3900 (39PV, 39MV pilots)	NBCert #	18447
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	04/30/2026
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV

4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid)

NBCert #

18458

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/30/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.743 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV

8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Setpoint Integrated Solutions, Inc. (SET)

Nameplate Abbreviation: Setpoint
Integrated Solutions

Baton Rouge, LA 70809United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3 NBCert # 18032

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	09/04/2027

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V

1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name:	1700 & 2700	NBCert #	18100
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 09/04/2027

Design Type

[Safety Valve] 1700 & 2700
Capacity Tests: Sec. UV, V at Dresser, Inc. on August 1, 1957
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	50-5800 psi	Steam	V
4 NPS	4 dual NPS	1.84 in ²	[K] 1.531 in	0.383 in	50-5800 psi	Steam	V
2-3 NPS	4, 6 NPS	2.545 in ²	[#3] 1.8 in	0.45 in	50-5800 psi	Steam	UV, V
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-2575 psi	Steam	UV
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	50-5800 psi	Steam	V
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	15-3100 psi	Steam	UV
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	50-5800 psi	Steam	V
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	15-3100 psi	Steam	UV
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	15-1800 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	50-2000 psi	Steam	V

6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	1.24 in	50-2200 psi	Steam	UV, V
8-10 NPS	10,12 NPS	28.3 in ²	[T] 6 in	1.5 in	50-1500 psi	Steam	UV, V

Design Name: 1700 & 2700 (Restricted Lift version of Cert. # 18100) NBCert # 18111

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 06/18/2027

Design Type

[Safety Valve] 1700 & 2700 (Restricted Lift version of Cert. # 18100)
Capacity Tests: Sec. UV, V at unknown lab on October 13, 1981
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	50-5800 psi	Steam	V
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	15-3100 psi	Steam	UV
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	50-5800 psi	Steam	V
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-2575 psi	Steam	UV
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	50-5800 psi	Steam	V
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	15-3100 psi	Steam	UV
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	50-5800 psi	Steam	V
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	15-3100 psi	Steam	UV
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.946 in	0.296 in	15-2000 psi	Steam	UV, V
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	0.372 in	50-2200 psi	Steam	V
8-10 NPS	10, 12 NPS	28.3 in ²	[T] 6 in	0.45 in	50-1500 psi	Steam	UV, V

Design Name:	1811, 1511	NBCert #	18122
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	06/18/2027

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	06/19/2027

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/19/2027

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV

1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)		NBCert #	18223
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	03/16/2030	

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Restricted Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV

10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/21/2027

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/18/2027

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/19/2027

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 06/19/2027

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM	NBCert # 19066
----------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	10/08/2030
-----------	----	------------

Design Type

[Safety Relief Valve] 1900-DM
Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV

12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name:	1900-DM-D	NBCert #	19088
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/08/2030

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name:	1900-DM-E	NBCert #	19099
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/13/2030

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/19/2027

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	06/19/2027

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids) NBCert # 19077

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/08/2030

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 1982 NBCert # 18379

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/16/2030

Design Type

[Safety Relief Valve] 1982
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at unknown lab on May 6, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Air	NV, UV
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Steam	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Air	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Steam	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Air	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Steam	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Air	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Air	NV, UV

Design Name: 1982 LS, 820000LS

NBCert # 18380

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/16/2030

Design Type

[Relief Valve] 1982 LS, 820000LS
Capacity Tests: Sec. UV at Dresser, Inc. on December 19, 1984
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.758 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	NV
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	UV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	NV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	NV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	UV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	NV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	NV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	UV

Design Name:	2900 (39PV & 39MV pilots - Liquid)	NBCert #	18874
--------------	------------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	06/17/2027

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots - Liquid)
Capacity Tests: Sec. UV, V at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.127 in	15-6250 psi	Water	UV, V
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	UV, V
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.205 in	15-6250 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-6250 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-6000 psi	Water	UV, V
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-6000 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-3750 psi	Water	UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-2250 psi	Water	UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-1500 psi	Water	UV, V
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.738 in	15-1500 psi	Water	UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-905 psi	Water	UV, V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV, V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.93 in	15-675 psi	Water	UV, V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-535 psi	Water	UV, V

Design Name:	2900 (39PV & 39MV pilots)	NBCert #	18863
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/26/2027

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots)		NBCert # 18447
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/04/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid)

NBCert #

18458

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

09/04/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV

1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

La Porte, TX 77571 United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3

NBCert # 18032

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	05/09/2030

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V

2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV
-----------	---------	-----------------------	---------------	---------	------------	-----	--------

Design Name:	1700 & 2700	NBCert #	18100
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV, V	02/06/2030
-----------	-------	------------

Design Type

[Safety Valve] 1700 & 2700
Capacity Tests: Sec. UV, V at Dresser, Inc. on August 1, 1957
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	50-5800 psi	Steam	V
4 NPS	4 dual NPS	1.84 in ²	[K] 1.531 in	0.383 in	50-5800 psi	Steam	V
2-3 NPS	4, 6 NPS	2.545 in ²	[#3] 1.8 in	0.45 in	50-5800 psi	Steam	UV, V
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-2575 psi	Steam	UV
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	50-5800 psi	Steam	V
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	15-3100 psi	Steam	UV
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	50-5800 psi	Steam	V
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	15-3100 psi	Steam	UV
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	15-1800 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	1.24 in	50-2200 psi	Steam	UV, V
8-10 NPS	10,12 NPS	28.3 in ²	[T] 6 in	1.5 in	50-1500 psi	Steam	UV, V

Design Name:	1700 & 2700 (Restricted Lift version of Cert. # 18100)	NBCert #	18111
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	05/09/2030

Design Type

[Safety Valve] 1700 & 2700 (Restricted Lift version of Cert. # 18100)
Capacity Tests: Sec. UV, V at unknown lab on October 13, 1981
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	50-5800 psi	Steam	V
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	15-3100 psi	Steam	UV
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	50-5800 psi	Steam	V
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-2575 psi	Steam	UV
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	50-5800 psi	Steam	V
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	15-3100 psi	Steam	UV
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	50-5800 psi	Steam	V
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	15-3100 psi	Steam	UV
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.946 in	0.296 in	15-2000 psi	Steam	UV, V
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	0.372 in	50-2200 psi	Steam	V
8-10 NPS	10, 12 NPS	28.3 in ²	[T] 6 in	0.45 in	50-1500 psi	Steam	UV, V

Design Name:	1811, 1511	NBCert #	18122
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	02/06/2030

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	02/06/2030

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/06/2030

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV

1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)		NBCert #	18223
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	12/21/2026	

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Restricted Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV

10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/06/2030

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/08/2030

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/06/2030

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 02/08/2030

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM	NBCert # 19066
----------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/04/2028

Design Type

[Safety Relief Valve] 1900-DM
Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV

12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name:	1900-DM-D	NBCert #	19088
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/04/2028

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name:	1900-DM-E	NBCert #	19099
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/29/2027

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 05/09/2030

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	02/08/2030

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids) NBCert # 19077

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/21/2026

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 2900 (39PV & 39MV pilots - Liquid) NBCert # 18874

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/21/2026

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots - Liquid)
Capacity Tests: Sec. UV, V at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.127 in	15-6250 psi	Water	UV, V
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	UV, V
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.205 in	15-6250 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-6250 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-6000 psi	Water	UV, V
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-6000 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-3750 psi	Water	UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-2250 psi	Water	UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-1500 psi	Water	UV, V
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.738 in	15-1500 psi	Water	UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-905 psi	Water	UV, V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV, V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.93 in	15-675 psi	Water	UV, V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-535 psi	Water	UV, V

Design Name: 2900 (39PV & 39MV pilots) NBCert # 18863

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/21/2026

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV

1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV

Design Name: 2900 POSRV (39 PV, 39 MV Pilots) NBCert # 18964

Manufacturer/Assembler	Designators	Expiration Date
Assembler	V	12/04/2026

Design Type

[Pilot Operated Pressure Relief Valve] 2900 POSRV (39 PV, 39 MV Pilots)
Capacity Tests: Sec. V at Dresser, Inc. on November 2, 2005
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.851 Unitless; (alternate medium): 0.691 Unitless; Certification Provisions: Economizer Service (Prev. CC 2446)
Media - Test: Liquid, Steam; Certified: Steam and Water
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	50-5800 psi	Steam	V
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	50-5800 psi	Water	V
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	50-5800 psi	Steam	V
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	50-5800 psi	Water	V
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	50-5800 psi	Steam	V
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	50-5800 psi	Water	V
1.5-2 NPS	3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	50-5800 psi	Steam	V
1.5-2 NPS	3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	50-5800 psi	Water	V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	45-3750 psi	Steam	V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	45-3750 psi	Water	V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	50-5800 psi	Steam	V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	50-5800 psi	Water	V
3 NPS	4, 6 NPS	2.136 in ²	[K] 1.649 in	0.446 in	55-5800 psi	Steam	V
3 NPS	4, 6 NPS	2.136 in ²	[K] 1.649 in	0.446 in	55-5800 psi	Water	V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	60-6250 psi	Steam	V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	60-6250 psi	Water	V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	65-2250 psi	Steam	V
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.625 in	65-2250 psi	Water	V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	40-2250 psi	Steam	V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	40-2250 psi	Water	V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	75-2250 psi	Steam	V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	75-2250 psi	Water	V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	85-1500 psi	Steam	V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	85-1500 psi	Water	V
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	40-1500 psi	Steam	V
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	40-1500 psi	Water	V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	40-905 psi	Steam	V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	40-905 psi	Water	V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	40-905 psi	Steam	V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	40-905 psi	Water	V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	40-675 psi	Steam	V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	40-675 psi	Water	V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	40-535 psi	Steam	V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	40-535 psi	Water	V

Design Name: 2900-TM (39PV & 39MV pilots)			NBCert #	01427
Manufacturer/Assembler		Designators		Expiration Date
Assembler		UV		12/13/2028

Design Type

[Pilot Operated Pressure Relief Valve] 2900-TM (39PV & 39MV pilots)

Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Water	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Water	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Water	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2000 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Water	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Water	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Water	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-300 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Water	UV

Design Name: 3900 (39PV, 39MV pilots) NBCert # 18447

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/06/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV

1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV

8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid) NBCert # 18458

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/11/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Design Name: 3900-TM (39PV, 39MV pilots) NBCert # 01438

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/13/2028

Design Type

[Pilot Operated Pressure Relief Valve] 3900-TM (39PV, 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; (alternate medium): 0.743 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Water	UV

1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV

6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Setpoint Integrated Solutions, Inc. (STC)

Nameplate Abbreviation: Setpoint
Integrated Solutions

Corpus Christi, TX 78409United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3 NBCert # 18032

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	12/06/2029

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V

1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1811, 1511 NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 12/06/2029

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV

4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 12/06/2029

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 12/06/2029

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV

10 NPS	14 NPS	50.26 in²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV
Design Name:		1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)		NBCert #	18223		
Manufacturer/Assembler			Designators			Expiration Date	
Assembler			UV			12/06/2029	
Design Type							
[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)							
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985							
Method of Establishing Relieving Capacity: Flow Capacity, K							
Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)							
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam							
Set Pressure Definition: Pop							
Blowdown Characteristics: Adjustable (Single Ring)							
Flow Area Configuration: Restricted Lift							
Designed by: Dresser, LLC. {DPT}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV

8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/06/2029

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/06/2029

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2

NBCert #

18144

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/06/2029

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert #

18751

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	12/06/2029

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 3.256 GPM/SQ. RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM

NBCert # 19066

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

06/28/2028

Design Type

[Safety Relief Valve] 1900-DM
 Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
 Set Pressure Definition(1): Pop; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D NBCert # 19088

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/16/2027

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name: 1900-DM-E NBCert # 19099

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/16/2027

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2		NBCert # 18166
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/06/2029
Design Type		
[Safety Relief Valve] 1900E-2, 1900-30E-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids)		NBCert # 18762
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	12/06/2029
Design Type		
[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids) Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.798 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids)		NBCert # 19077
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/06/2029
Design Type		
[Relief Valve] 19110M & 19110H (Liquids) Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.264 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 2900-TM (39PV & 39MV pilots) NBCert # 01427

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/05/2029

Design Type

[Pilot Operated Pressure Relief Valve] 2900-TM (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-6250 psi	Water	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Water	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-6250 psi	Water	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Water	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Water	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2000 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Water	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Water	UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Water	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-300 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Water	UV

Design Name: 3900 (39PV, 39MV pilots) NBCert # 18447

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/06/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV

1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV

6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid)

NBCert #

18458

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

12/07/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)

Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.743 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV

3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Design Name: 3900-TM (39PV, 39MV pilots)

NBCert #

01438

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

08/15/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3900-TM (39PV, 39MV pilots)

Capacity Tests: Sec. UV at Dresser, Inc. on May 19, 1988

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless; (alternate medium): 0.743 Unitless; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam

Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV

1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Setpoint Integrated Solutions, Inc. (STR)

Nameplate Abbreviation: Setpoint
Integrated Solutions

Richwood, TX 77531United States

This Company Manufactures or Assembles:

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	12/04/2029
-----------	----	------------

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V

1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

12/04/2029

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV

3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201) NBCert # 18223

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/04/2029

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV

1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name: 19000 Series

NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

12/04/2029

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV

0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert #

18717

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/04/2029

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2

NBCert #

18144

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/04/2029

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert # 18751

Manufacturer/Assembler

Designators

Expiration Date

Assembler

UV

12/04/2029

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900E-2, 1900-30E-2 NBCert # 18166

Manufacturer/Assembler

Designators

Expiration Date

Assembler

UV

12/04/2029

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/04/2029

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 5.798 GPM/SQ.RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids) NBCert # 19077

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/04/2029

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
 Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 2.264 GPM/SQ.RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 2900 (39PV & 39MV pilots - Liquid) NBCert # 18874

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/31/2029

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots - Liquid)
 Capacity Tests: Sec. UV, V at Dresser, Inc. on June 25, 1999
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.670 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.127 in	15-6250 psi	Water	UV, V
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	UV, V
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.205 in	15-6250 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-6250 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-6000 psi	Water	UV, V
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-6000 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-3750 psi	Water	UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-2250 psi	Water	UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-1500 psi	Water	UV, V
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.738 in	15-1500 psi	Water	UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-905 psi	Water	UV, V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV, V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.93 in	15-675 psi	Water	UV, V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-535 psi	Water	UV, V

Design Name:	2900 (39PV & 39MV pilots)	NBCert #	18863
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	12/04/2029
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV

2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots) NBCert # 18447

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/04/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV

1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV

6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid)

NBCert #

18458

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

12/04/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)

Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.743 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV

3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Setpoint Integrated Solutions, Inc. (WLS)

Nameplate Abbreviation: Setpoint
Integrated Solutions

Sulphur, LA 70665United States

This Company Manufactures or Assembles:

Design Name:	1811, 1511	NBCert #	18122
Manufacturer/Assembler	Designators	Expiration Date	

Assembler

UV, V

09/02/2027

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/19/2030

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V

3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35 NBCert # 18201

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/19/2030

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/19/2030

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV

1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/19/2030

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2 NBCert # 18144

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/19/2030

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert # 18751

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/19/2030

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 3.256 GPM/SQ.RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900E-2, 1900-30E-2 NBCert # 18166

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/19/2030

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 2900 (39PV & 39MV pilots - Liquid) NBCert # 18874

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	05/25/2027

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots - Liquid)
 Capacity Tests: Sec. UV, V at Dresser, Inc. on June 25, 1999
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.670 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	UV, V

1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.127 in	15-6250 psi	Water	UV, V
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	UV, V
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.205 in	15-6250 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-6250 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-6000 psi	Water	UV, V
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-6000 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-3750 psi	Water	UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-2250 psi	Water	UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-1500 psi	Water	UV, V
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.738 in	15-1500 psi	Water	UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-905 psi	Water	UV, V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV, V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.93 in	15-675 psi	Water	UV, V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-535 psi	Water	UV, V

Design Name: 2900 (39PV & 39MV pilots)

NBCert #

18863

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/25/2027

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV

3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots) NBCert # 18447

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/24/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV

1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV

8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid) NBCert # 18458

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/04/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV

3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Shanghai AFS Valve Manufacturing Co.,Ltd. (SAV)

Nameplate Abbreviation: AFS

Shanghai, 201516People's Republic of China

This Company Manufactures or Assembles:

Design Name: AFSJZ-40		NBCert # 03014	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/14/2031
Design Type			
[Safety Relief Valve] AFSJZ-40			
HolderDesignation:			
Capacity Tests: Sec. UV at National Board Testing Lab on August 15, 2024			
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method			
Certified Value:13.600 SCFM/PSIA; (alternate medium): 0.000			
Media - Test: Air/Gas; Certified: Gas			
Set Pressure Definition: Initial Audible Discharge			
Blowdown Characteristics: Fixed			
Flow Area Configuration: Nozzle/Full Lift			
Designed by: Shanghai AFS Valve Manufacturing Co.,Ltd. {SAV}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		1.096 in ²	1.1811 in	0.295 in	50.8-196 psi	Air	UV

Shanghai Beiting Valve Co., Ltd. (SHB)

Shanghai, 201802People's Republic of China

This Company Manufactures or Assembles:

Design Name: BTA-22C300C (13 mm orifice)		NBCert #	02350
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	04/23/2027	
Design Type			
[Safety Relief Valve] BTA-22C300C (13 mm orifice) Capacity Tests: Sec. UV at National Board Testing Lab on June 16, 2020 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:1245.3 SCFM Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Shanghai Beiting Valve Co., Ltd. {SHB}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.625 in		132.73 mm ²	13 mm	3.25 mm	400-400 psi	Air	UV

Design Name: BTA-22C300C (17.5 mm orifice)		NBCert #	02361
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	04/23/2027	
Design Type			
[Safety Relief Valve] BTA-22C300C (17.5 mm orifice) Capacity Tests: Sec. UV at National Board Testing Lab on June 16, 2020 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:2320.3 SCFM Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Shanghai Beiting Valve Co., Ltd. {SHB}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.875 in		240.53 mm ²	17.5 mm	4.4 mm	450-450 psi	Air	UV

Design Name: BTA-22C300C (24 mm orifice)		NBCert #	02372
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	04/23/2027	

Design Type

[Safety Relief Valve] BTA-22C300C (24 mm orifice)
Capacity Tests: Sec. UV at National Board Testing Lab on June 16, 2020
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:2359.2 SCFM
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Shanghai Beiting Valve Co., Ltd. {SHB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 in		452.39 mm ²	24 mm	6 mm	235-235 psi	Air	UV

Design Name: BTA-22C300T (12 mm orifice) NBCert # 02338

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/23/2027

Design Type

[Safety Relief Valve] BTA-22C300T (12 mm orifice)
Capacity Tests: Sec. UV at National Board Testing Lab on June 16, 2020
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.540 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Shanghai Beiting Valve Co., Ltd. {SHB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 in	113.1 mm ²	12 mm	3 mm	150-500 psi	Air	UV

Design Name: BTA-22C300T (30 mm orifice) NBCert # 02518

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/02/2028

Design Type

[Safety Relief Valve] BTA-22C300T (30 mm orifice)
Capacity Tests: Sec. UV at National Board Testing Lab on August 9, 2022
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:14.900 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Shanghai Beiting Valve Co., Ltd. {SHB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	706.8 mm ²	30 mm	7.5 mm	50-150 psi	Air	UV

Design Name: BTA-22C300T (7.8 mm orifice) NBCert # 01832

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/23/2027

Design Type

[Safety Relief Valve] BTA-22C300T (7.8 mm orifice)
Capacity Tests: Sec. UV at National Board Testing Lab on June 16, 2020
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.980 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Shanghai Beiting Valve Co., Ltd. {SHB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	0.875 in	47.78 mm ²	7.8 mm	1.95 mm	150-500 psi	Air	UV

Design Name:	BTA-22C300T, BTA-22C300T1 (18 mm orifice)	NBCert #	02349
--------------	---	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

04/23/2027

Design Type

[Safety Relief Valve] BTA-22C300T, BTA-22C300T1 (18 mm orifice)
Capacity Tests: Sec. UV at National Board Testing Lab on June 16, 2020
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.490 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Shanghai Beiting Valve Co., Ltd. {SHB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5 in	254.47 mm ²	18 mm	4.5 mm	50-500 psi	Air	UV

Design Name:	BTA-22C300T1 (6.3 mm orifice)	NBCert #	02529
--------------	-------------------------------	----------	-------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UV

12/02/2028

Design Type

[Safety Relief Valve] BTA-22C300T1 (6.3 mm orifice)
Capacity Tests: Sec. UV at National Board Testing Lab on August 30, 2022
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.643 SCFM/PSIA
Media - Test: Air/Gas; Certified: Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Shanghai Beiting Valve Co., Ltd. {SHB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.125 in		31.17 mm ²	6.3 mm	1.575 mm	150-400 psi	Air	UV

Shanghai Huali Safety Devices Co., Ltd. (SHS)

Shanghai, 201109People's Republic of China

This Company Manufactures or Assembles:

Design Name: DS		NBCert # 01663	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	09/11/2029

Design Type

[Rupture Disk Device] DS
HolderDesignation: DHA, DHA-ZK
Capacity Tests: Sec. UD at National Board Testing Lab on December 13, 2017
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.730 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Shanghai Huali Safety Devices Co., Ltd. {SHS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.76 in ²			130.5-435 psi		UD
1.25 NPS		1.23 in ²			87-435 psi		UD
1.5 NPS		1.77 in ²			50.75-435 psi		UD
10 NPS		76.05 in ²			4.35-261 psi		UD
12 NPS		109.51 in ²			4.35-188.5 psi		UD
14 NPS		149.05 in ²			4.35-130.5 psi		UD
16 NPS		194.68 in ²			3.625-130.5 psi		UD
18 NPS		246.39 in ²			3.625-113.1 psi		UD
2 NPS		3.04 in ²			50.75-435 psi		UD
2.5 NPS		4.91 in ²			23.2-406 psi		UD
20 NPS		304.19 in ²			3.625-113.1 psi		UD
24 NPS		438.03 in ²			2.175-94.25 psi		UD
26 NPS		514.08 in ²			2.175-72.5 psi		UD
28 NPS		596.21 in ²			2.175-72.5 psi		UD
3 NPS		7.07 in ²			23.2-406 psi		UD
30 NPS		684.42 in ²			1.45-58 psi		UD
32 NPS		778.72 in ²			1.45-58 psi		UD
4 NPS		12.17 in ²			13.05-377 psi		UD
5 NPS		19.01 in ²			13.05-377 psi		UD
6 NPS		27.38 in ²			7.25-333.5 psi		UD
8 NPS		48.67 in ²			7.25-261 psi		UD

Design Name: FS		NBCert #	01652
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	09/11/2029
Design Type			
[Rupture Disk Device] FS HolderDesignation: FHA, FHA-ZK Capacity Tests: Sec. UD at National Board Testing Lab on December 12, 2017 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.770 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Shanghai Huali Safety Devices Co., Ltd. {SHS}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.76 in ²			17.4-174 psi		UD
1.25 NPS		1.23 in ²			17.4-174 psi		UD
1.5 NPS		1.77 in ²			13.05-145 psi		UD
10 NPS		76.05 in ²			8.7-58 psi		UD
12 NPS		109.51 in ²			8.7-58 psi		UD
14 NPS		149.05 in ²			4.35-43.5 psi		UD
16 NPS		194.68 in ²			4.35-36.25 psi		UD
18 NPS		246.39 in ²			2.9-29 psi		UD
2 NPS		3.04 in ²			13.05-145 psi		UD
2.5 NPS		4.91 in ²			13.05-145 psi		UD
20 NPS		304.19 in ²			2.9-29 psi		UD
24 NPS		438.03 in ²			1.45-29 psi		UD
3 NPS		7.07 in ²			13.05-116 psi		UD
4 NPS		12.17 in ²			13.05-87 psi		UD
5 NPS		19.01 in ²			13.05-87 psi		UD
6 NPS		27.38 in ²			10.88-72.5 psi		UD
8 NPS		48.67 in ²			10.88-72.5 psi		UD

Design Name: RM90		NBCert #	01630
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	09/11/2029
Design Type			
[Rupture Disk Device] RM90 HolderDesignation: ROHA, ROHA-ZK Capacity Tests: Sec. UD at National Board Testing Lab on December 12, 2017 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.500 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Shanghai Huali Safety Devices Co., Ltd. {SHS}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.76 in ²			217.5-3625 psi		UD
1.25 NPS		1.23 in ²			188.5-2900 psi		UD
1.5 NPS		1.77 in ²			145-2900 psi		UD
10 NPS		76.05 in ²			29-435 psi		UD
12 NPS		109.51 in ²			29-362.5 psi		UD
14 NPS		149.05 in ²			26.1-290 psi		UD
16 NPS		194.68 in ²			26.1-261 psi		UD
18 NPS		246.39 in ²			23.2-217.5 psi		UD
2 NPS		3.04 in ²			101.5-2900 psi		UD
2.5 NPS		4.91 in ²			87-2175 psi		UD
20 NPS		304.19 in ²			21.75-145 psi		UD
3 NPS		7.07 in ²			87-1740 psi		UD
4 NPS		12.17 in ²			72.5-1740 psi		UD
5 NPS		19.01 in ²			58-1160 psi		UD
6 NPS		27.38 in ²			43.5-1160 psi		UD
8 NPS		48.67 in ²			36.25-725 psi		UD

Design Name: RS		NBCert #	01641
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	09/11/2029

Design Type

[Rupture Disk Device] RS
HolderDesignation: ROHA, ROHA-ZK
Capacity Tests: Sec. UD at National Board Testing Lab on December 12, 2017
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 3.420 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: Shanghai Huali Safety Devices Co., Ltd. {SHS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.76 in ²			36.25-290 psi		UD
1.25 NPS		1.23 in ²			36.25-261 psi		UD
1.5 NPS		1.77 in ²			29-217.5 psi		UD
10 NPS		76.05 in ²			7.25-58 psi		UD
12 NPS		109.51 in ²			4.35-43.5 psi		UD
14 NPS		149.05 in ²			2.9-36.25 psi		UD
16 NPS		194.68 in ²			2.175-29 psi		UD
18 NPS		246.39 in ²			2.175-29 psi		UD
2 NPS		3.04 in ²			21.75-174 psi		UD
2.5 NPS		4.91 in ²			21.75-145 psi		UD
20 NPS		304.19 in ²			2.175-29 psi		UD

3 NPS	7.07 in ²	14.5-116 psi	UD
4 NPS	12.17 in ²	14.5-116 psi	UD
5 NPS	19.01 in ²	8.7-87 psi	UD
6 NPS	27.38 in ²	8.7-72.5 psi	UD
8 NPS	48.67 in ²	7.25-72.5 psi	UD

Shanghai Kaite Valve Manufacture Co., Ltd. (SKV)

Anting, Shanghai, 201814People's Republic of China

This Company Manufactures or Assembles:

Design Name: 11DE07xxxx		NBCert #	02631
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/13/2029
Design Type			
[Safety Relief Valve] 11DE07xxxx Capacity Tests: Sec. UV at National Board Testing Lab on September 6, 2022 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.781 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Shanghai Kaite Valve Manufacture Co., Ltd. {SKV}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	0.75 in	0.062 in ²	0.28125 in	0.07 in	150-300 psi	Air	UV

Design Name: 11EE09xxxx		NBCert #	02642
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/13/2029
Design Type			
[Safety Relief Valve] 11EE09xxxx Capacity Tests: Sec. UV at National Board Testing Lab on September 6, 2022 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.610 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Shanghai Kaite Valve Manufacture Co., Ltd. {SKV}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	0.75 NPS	0.11 in ²	0.375 in	0.094 in	150-300 psi	Air	UV

Design Name: 11FH13xxxx		NBCert #	00617
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	11/09/2027
Design Type			
[Safety Relief Valve] 11FH13xxxx Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2015 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.930 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Shanghai Kaite Valve Manufacture Co., Ltd. {SKV}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.875 in	1.25 in	126.68 mm ²	12.7 mm	3.175 mm	150-300 psi	Air	UV

Design Name: 11IG14xxxx		NBCert #	00594
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	11/09/2027
Design Type			
[Safety Relief Valve] 11IG14xxxx Capacity Tests: Sec. UV at National Board Testing Lab on June 23, 2015 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.739 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Shanghai Kaite Valve Manufacture Co., Ltd. {SKV}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.3125 in	1 in	160.38 mm ²	14.29 mm	3.573 mm	150-300 psi	Air	UV

Design Name: 11KH19xxxx		NBCert #	00628
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	11/09/2027
Design Type			
[Safety Relief Valve] 11KH19xxxx Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2015 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 6.430 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Start-to-Leak Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Shanghai Kaite Valve Manufacture Co., Ltd. {SKV}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.625 in	1.25 in	285.02 mm ²	19.05 mm	4.763 mm	50-300 psi		UV

Design Name: 11LL25xxxx		NBCert # 01551					
Manufacturer/Assembler		Designators		Expiration Date			
Manufacturer		UV		04/25/2030			
Design Type							
[Safety Relief Valve] 11LL25xxxx Capacity Tests: Sec. UV at National Board Testing Lab on December 8, 2017 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:11.000 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Shanghai Kaite Valve Manufacture Co., Ltd. {SKV}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 in	2 NPS	0.785 in²	1 in	0.25 in	50-155 psi	Air	UV

Shenyang Xinguang Aerospace Safety System Co., Ltd (SXA)

Nameplate Abbreviation: XG

Shenyang City, Liaoning Province, 110168People's Republic of China

This Company Manufactures or Assembles:

Design Name: NS			NBCert # 02484				
Manufacturer/Assembler		Designators		Expiration Date			
Manufacturer		UD		12/09/2028			
Design Type							
[Rupture Disk Device] NS HolderDesignation: NPZ Capacity Tests: Sec. UD at National Board Testing Lab on October 22, 2021 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.700 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: Shenyang Xinguang Aerospace Safety System Co., Ltd {SXA}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.954 in²			43.5-1450 psi		UD
1.5 NPS		2.575 in²			29-1305 psi		UD
10 NPS		80.365 in²			4.35-435 psi		UD
12 NPS		115.426 in²			2.9-435 psi		UD
14 NPS		135.33 in²			2.9-362.5 psi		UD
16 NPS		176.625 in²			2.9-290 psi		UD
18 NPS		223.411 in²			2.9-290 psi		UD
2 NPS		3.816 in²			14.5-1160 psi		UD
20 NPS		275.687 in²			2.9-217.5 psi		UD

24 NPS	402.289 in²	2.9-217.5 psi	UD
28 NPS	588.06 in²	2.9-145 psi	UD
3 NPS	8.999 in²	11.6-870 psi	UD
32 NPS	722.504 in²	2.9-145 psi	UD
36 NPS	982.068 in²	2.9-145 psi	UD
4 NPS	13.415 in²	8.7-725 psi	UD
40 NPS	1216.75 in²	2.9-145 psi	UD
6 NPS	29.611 in²	5.8-580 psi	UD
8 NPS	51.634 in²	4.35-580 psi	UD

Spartan Controls Ltd. (SPN)

Edmonton, AB T6B 3P2Canada

This Company Manufactures or Assembles:

Design Name:	243/249/443/449/546/843/849/943/5046/5049/8043/8049	NBCert #	01292
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	08/01/2028
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
Capacity Tests: Sec. UV at unknown lab on August 8, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV
2 NPS	3 NPS	1.496 in²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name:	253/259/453/459/853/859/953/959/5059/8053/8059	NBCert #	01304
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/01/2028

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
Capacity Tests: Sec. UV at unknown lab on July 31, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.627 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name:	263/269/463/469/566/863/869/963/969/5066/5069	NBCert #	01315
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/01/2028

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069
Capacity Tests: Sec. UV at unknown lab on July 30, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV

3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 08/01/2028

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.767 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 08/01/2028

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.491 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 81, 81P, 83, 84 NBCert # 01089

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/15/2028

Design Type

[Safety Relief Valve] 81, 81P, 83, 84
 Capacity Tests: Sec. UV at unknown lab on July 8, 1965
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.816 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}
 Comments: Type 81P and 84 have fixed blowdown.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 81P (Liquids)		NBCert #	01102
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	09/10/2030
Design Type			
[Relief Valve] 81P (Liquids) Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.720 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: 93% of pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name: 900 Series (Liquid), 7700, SNC			NBCert # 15499	
Manufacturer/Assembler		Designators		Expiration Date
Assembler		UV, V		08/01/2028

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.661 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name: 900 Series, 7700, SNC

NBCert #

15411

Manufacturer/Assembler

Designators

Expiration Date

Assembler

UV

08/01/2028

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
 Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV

1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name:	H Series (HCI, HSJ, HCA, HA, HB, HC, HCB, HCP, HJO, HN, HNA, HNB, HNP, HS, NBCert # 15006 HSA, HSB, HSC, HSP)						
--------------	---	--	--	--	--	--	--

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 09/10/2030

Design Type

[Safety Valve] H Series (HCI, HSJ, HCA, HA, HB, HC, HCB, HCP, HJO, HN, HNA, HNB, HNP, HS, HSA, HSB, HSC, HSP)
Capacity Tests: Sec. UV, V at unknown lab on September 1, 1939
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1.5 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-500 psi	Steam	UV, V
0.75 NPS	1.5 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-500 psi	Steam	UV, V
1-1.5 NPS	2 - 3 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-3100 psi	Steam	UV, V
1-2 NPS	2.5, 3 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-3100 psi	Steam	UV, V
1.5-2 NPS	3, 4, 6 NPS	0.785 in ²	[H] 1 in	0.25 in	15-5000 psi	Steam	UV, V
1.5 NPS	3 NPS	0.865 in ²	1.05 in	0.262 in	15-3100 psi	Steam	UV, V
1.5 NPS	3 NPS	0.994 in ²	[H2] 1.125 in	0.281 in	15-3100 psi	Steam	UV, V
2-3 NPS	3, 4, 6 NPS	1.288 in ²	[J] 1.281 in	0.32 in	15-5000 psi	Steam	UV, V
2 NPS	4 NPS	1.431 in ²	[J2] 1.35 in	0.338 in	15-3100 psi	Steam	UV, V
2.5-3 NPS	4, 6 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-6000 psi	Steam	UV, V
2.5 NPS	6 NPS	2.545 in ²	[K2] 1.8 in	0.45 in	15-6800 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.476 in	15-3100 psi	Steam	UV, V
3 NPS	6 NPS	3.341 in ²	[L2] 2.062 in	0.516 in	15-3100 psi	Steam	UV, V
3-4 NPS	6, 8 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-6000 psi	Steam	UV, V
3 NPS	6, 8 NPS	3.976 in ²	[M2] 2.25 in	0.563 in	15-6000 psi	Steam	UV, V
4 NPS	6 NPS	4.341 in ²	[N] 2.351 in	0.588 in	15-3100 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.712 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	7.07 in ²	[P2] 3 in	0.75 in	15-3100 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.937 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	12.25 in ²	[Q2] 3.95 in	0.988 in	15-3100 psi	Steam	UV, V
6 NPS	8, 10 NPS	16 in ²	[R] 4.513 in	1.128 in	15-3100 psi	Steam	UV, V
6 NPS	10 NPS	19.29 in ²	[RR] 4.956 in	1.239 in	15-3100 psi	Steam	UV, V
8 NPS	10, 12 NPS	26 in ²	[T] 5.75 in	1.437 in	15-500 psi	Steam	UV, V
8 NPS	12, 14 NPS	28.274 in ²	6 in	1.5 in	15-2000 psi	Steam	UV, V

10 NPS	14 NPS	44.18 in ²	7.5 in	1.875 in	15-500 psi	Steam	UV, V
12 NPS	16 NPS	63.62 in ²	9 in	2.25 in	15-500 psi	Steam	UV, V
14 NPS	18 NPS	86.59 in ²	10.5 in	2.625 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	95.21 in ²	11.01 in	2.753 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	114.04 in ²	12.05 in	3.02 in	15-500 psi	Steam	UV, V
18 NPS	24 NPS	143.14 in ²	13.5 in	3.375 in	15-500 psi	Steam	UV, V
20 NPS	24 NPS	176.71 in ²	15 in	3.75 in	15-500 psi	Steam	UV, V

Design Name:	HL, HSL	NBCert #	15589
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV, V	09/10/2030
-----------	-------	------------

Design Type

[Safety Valve] HL, HSL
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on November 3, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.869 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	1.5 NPS	0.339 in ²	[F] 0.657 in	0.164 in	15-725 psi	Steam	UV, V
1.25-2 NPS	1.5 NPS	0.553 in ²	[G] 0.839 in	0.21 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.868 in ²	[H] 1.051 in	0.263 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.327 in ²	[J] 1.3 in	0.325 in	15-725 psi	Steam	UV, V
2-3 NPS	3-4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-725 psi	Steam	UV, V
2.5-4 NPS	4-6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-725 psi	Steam	UV, V
3 NPS	4-6 NPS	3.955 in ²	[M] 2.244 in	0.561 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	4.831 in ²	[N] 2.48 in	0.62 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	7.031 in ²	[P] 2.992 in	0.748 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[QQ] 3.75 in	0.937 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	0.984 in	15-725 psi	Steam	UV, V

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Liquids)	NBCert #	15095
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV, V	08/01/2028
-----------	-------	------------

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABLNBCert # 15512

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/01/2028

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS, 8500, ACL/ABL
Capacity Tests: Sec. UV at Crosby Valve, LLC on June 28, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Air	UV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Air	UV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Air	UV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/01/2028

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV

1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV

12-14 NPS	16. 20 NPS	78.08 in²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16. 20 NPS	78.08 in²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

SPIRAX SARCO IND. COM. LTDA (SSB)

Nameplate Abbreviation:
SPIRAX/SARCO

Cotia - SP, 06705-050Brazil

This Company Manufactures or Assembles:

Design Name:	SV66H	NBCert #	48147
--------------	-------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	V	10/16/2030
--------------	---	------------

Design Type

[Safety Valve] SV66H
Capacity Tests: Sec. V at National Board Testing Lab on May 23, 2023
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.849 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: SPIRAX SARCO IND. COM. LTDA {SSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	0.328 in²	[F] 0.646 in	0.161 in	15-1200 psi	Steam	V
1.5 NPS	3 NPS	0.537 in²	[G] 0.827 in	0.208 in	15-1200 psi	Steam	V
1.5 NPS	3 NPS	0.842 in²	[H] 1.035 in	0.259 in	15-1200 psi	Steam	V
2.5-3 NPS	4 NPS	1.968 in²	[K] 1.583 in	0.395 in	15-1200 psi	Steam	V
3 NPS	6 NPS	3.055 in²	[L] 1.972 in	0.493 in	15-1200 psi	Steam	V
3-4 NPS	6 NPS	3.846 in²	[M] 2.213 in	0.553 in	15-1100 psi	Steam	V
4 NPS	6 NPS	4.633 in²	[N] 2.429 in	0.607 in	15-1000 psi	Steam	V
4 NPS	6 NPS	6.83 in²	[P] 2.949 in	0.737 in	15-1000 psi	Steam	V
6 NPS	8 NPS	11.811 in²	[Q] 3.878 in	0.969 in	15-740 psi	Steam	V

Design Name:	SV80H	NBCert #	48103
--------------	-------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	01/23/2030
--------------	----	------------

Design Type

[Safety Relief Valve] SV80H
Capacity Tests: Sec. UV at National Board Testing Lab on April 11, 2011
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: SPIRAX SARCO IND. COM. LTDA {SSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.155 in ²	[D] 0.445 in	0.11 in	15-2900 psi	Steam	UV
1-1.5 NPS	2, 3 NPS	0.155 in ²	[D] 0.445 in	0.11 in	15-6000 psi	Air	UV
1-1.5 NPS	2, 3 NPS	0.263 in ²	[E] 0.579 in	0.145 in	15-2900 psi	Steam	UV
1-1.5 NPS	2, 3 NPS	0.263 in ²	[E] 0.579 in	0.145 in	15-6000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.373 in ²	[F] 0.689 in	0.173 in	15-2900 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.373 in ²	[F] 0.689 in	0.173 in	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	0.537 in ²	[G] 0.827 in	0.208 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.537 in ²	[G] 0.827 in	0.208 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.842 in ²	[H] 1.035 in	0.271 in	15-2750 psi	Air	UV
1.5-2 NPS	3 NPS	0.842 in ²	[H] 1.035 in	0.271 in	15-2750 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.374 in ²	[J] 1.323 in	0.35 in	15-2700 psi	Air	UV
2-3 NPS	3, 4 NPS	1.374 in ²	[J] 1.323 in	0.35 in	15-2700 psi	Steam	UV
3 NPS	4, 6 NPS	1.967 in ²	[K] 1.583 in	0.421 in	15-2220 psi	Air	UV
3 NPS	4, 6 NPS	1.967 in ²	[K] 1.583 in	0.421 in	15-2220 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.056 in ²	[L] 1.972 in	0.523 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.056 in ²	[L] 1.972 in	0.523 in	15-1500 psi	Steam	UV
4 NPS	6 NPS	3.845 in ²	[M] 2.213 in	0.586 in	15-1100 psi	Air	UV
4 NPS	6 NPS	3.845 in ²	[M] 2.213 in	0.586 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	4.634 in ²	[N] 2.429 in	0.645 in	15-1000 psi	Air	UV
4 NPS	6 NPS	4.634 in ²	[N] 2.429 in	0.645 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	6.829 in ²	[P] 2.949 in	0.783 in	15-1000 psi	Air	UV
4 NPS	6 NPS	6.829 in ²	[P] 2.949 in	0.783 in	15-1000 psi	Steam	UV
6 NPS	8 NPS	11.811 in ²	[Q] 3.878 in	1.027 in	15-600 psi	Air	UV
6 NPS	8 NPS	11.811 in ²	[Q] 3.878 in	1.027 in	15-600 psi	Steam	UV
6 NPS	8, 10 NPS	17.066 in ²	[R] 4.661 in	1.259 in	15-300 psi	Air	UV
6 NPS	8, 10 NPS	17.066 in ²	[R] 4.661 in	1.259 in	15-300 psi	Steam	UV
8 NPS	10 NPS	27.721 in ²	[T] 5.941 in	1.574 in	15-300 psi	Air	UV
8 NPS	10 NPS	27.721 in ²	[T] 5.941 in	1.574 in	15-300 psi	Steam	UV
8 NPS	10 NPS	29.816 in ²	[T2] 6.161 in	1.632 in	15-300 psi	Air	UV
8 NPS	10 NPS	29.816 in ²	[T2] 6.161 in	1.632 in	15-300 psi	Steam	UV
10 NPS	14 NPS	45.346 in ²	[V] 7.598 in	2.055 in	15-180 psi	Air	UV
10 NPS	14 NPS	45.346 in ²	[V] 7.598 in	2.055 in	15-180 psi	Steam	UV
12 NPS	12, 16 NPS	67.918 in ²	[W] 9.299 in	2.511 in	15-150 psi	Air	UV
12 NPS	12, 16 NPS	67.918 in ²	[W] 9.299 in	2.511 in	15-150 psi	Steam	UV

Design Name: SV80H (liquid)		NBCert #	48114
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/23/2030

Design Type

[Safety Relief Valve] SV80H (liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on April 12, 2011
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.648 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: SPIRAX SARCO IND. COM. LTDA {SSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.155 in ²	[D] 0.445 in	0.11 in	15-6000 psi	Water	UV
1-1.5 NPS	2, 3 NPS	0.263 in ²	[E] 0.579 in	0.145 in	15-6000 psi	Water	UV
1.5 NPS	2, 3 NPS	0.373 in ²	[F] 0.689 in	0.173 in	15-5000 psi	Water	UV
1.5-2 NPS	3 NPS	0.537 in ²	[G] 0.827 in	0.208 in	15-3705 psi	Water	UV
1.5-2 NPS	3 NPS	0.842 in ²	[H] 1.035 in	0.271 in	15-2750 psi	Water	UV
2-3 NPS	3, 4 NPS	1.374 in ²	[J] 1.323 in	0.35 in	15-2700 psi	Water	UV
3 NPS	4, 6 NPS	1.967 in ²	[K] 1.583 in	0.421 in	15-2220 psi	Water	UV
3-4 NPS	4, 6 NPS	3.056 in ²	[L] 1.972 in	0.523 in	15-1500 psi	Water	UV
4 NPS	6 NPS	3.845 in ²	[M] 2.213 in	0.586 in	15-1100 psi	Water	UV
4 NPS	6 NPS	4.634 in ²	[N] 2.429 in	0.645 in	15-1000 psi	Water	UV
4 NPS	6 NPS	6.829 in ²	[P] 2.949 in	0.783 in	15-1000 psi	Water	UV
6 NPS	8 NPS	11.811 in ²	[Q] 3.878 in	1.027 in	15-600 psi	Water	UV
6 NPS	8, 10 NPS	17.066 in ²	[R] 4.661 in	1.259 in	15-300 psi	Water	UV
8 NPS	10 NPS	27.721 in ²	[T] 5.941 in	1.574 in	15-300 psi	Water	UV
8 NPS	10 NPS	29.816 in ²	[T2] 6.161 in	1.632 in	15-300 psi	Water	UV
10 NPS	14 NPS	45.346 in ²	[V] 7.598 in	2.055 in	15-180 psi	Water	UV
12 NPS	12(2), 16 NPS	67.918 in ²	[W] 9.299 in	2.511 in	15-150 psi	Water	UV

Design Name: SV81H

NBCert # 48125

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/23/2030

Design Type

[Safety Relief Valve] SV81H
Capacity Tests: Sec. UV at National Board Testing Lab on January 13, 2011
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.872 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: SPIRAX SARCO IND. COM. LTDA {SSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.086 in ²	[#1] 0.331 in	0.091 in	15-1500 psi	Steam	UV
0.5-1 NPS	1 NPS	0.086 in ²	[#1] 0.331 in	0.091 in	15-4000 psi	Air	UV
0.5-1 NPS	1 NPS	0.13 in ²	[#2] 0.407 in	0.11 in	15-1500 psi	Steam	UV
0.5-1 NPS	1 NPS	0.13 in ²	[#2] 0.407 in	0.11 in	15-3000 psi	Air	UV

1-1.5 NPS	1.5 NPS	0.228 in ²	[#3] 0.539 in	0.146 in	15-1500 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.228 in ²	[#3] 0.539 in	0.146 in	15-2540 psi	Air	UV
1.5-2 NPS	2 NPS	0.36 in ²	[#4] 0.677 in	0.185 in	15-1500 psi	Air	UV
1.5-2 NPS	2 NPS	0.36 in ²	[#4] 0.677 in	0.185 in	15-1500 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.568 in ²	[#5] 0.85 in	0.232 in	15-1140 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.568 in ²	[#5] 0.85 in	0.232 in	15-1140 psi	Steam	UV

Design Name:	SV81H (liquid)	NBCert #	48136
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/23/2030

Design Type

[Safety Relief Valve] SV81H (liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on January 14, 2011
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.646 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: SPIRAX SARCO IND. COM. LTDA {SSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.086 in ²	[#1] 0.331 in	0.091 in	15-4000 psi	Water	UV
0.5-1 NPS	1 NPS	0.13 in ²	[#2] 0.407 in	0.11 in	15-3000 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.228 in ²	[#3] 0.539 in	0.146 in	15-2540 psi	Water	UV
1.5-2 NPS	2 NPS	0.36 in ²	[#4] 0.677 in	0.185 in	15-1500 psi	Water	UV
1.5-2 NPS	2.5 NPS	0.568 in ²	[#5] 0.85 in	0.232 in	15-1140 psi	Water	UV

Spirax Sarco, Inc. (SPS)

Blythewood, SC 29016 United States

This Company Manufactures or Assembles:

Design Name:	SV7	NBCert #	71020
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	10/21/2025

Design Type

[Safety Valve] SV7
Capacity Tests: Sec. UV, V at National Board Testing Lab on July 30, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Spirax-Sarco Limited {SSL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	0.328 in ²	[F] 0.646 in	0.161 in	15-300 psi	Steam	UV
1.5 NPS	2 NPS	0.328 in ²	[F] 0.646 in	0.161 in	15-300 psi	Steam	V
1.5 NPS	2 NPS	0.537 in ²	[G] 0.827 in	0.207 in	15-300 psi	Steam	V
1.5 NPS	2 NPS	0.537 in ²	[G] 0.827 in	0.207 in	15-300 psi	Steam	UV
1.5 NPS	2.5 NPS	0.841 in ²	[H] 1.035 in	0.259 in	15-300 psi	Steam	UV
1.5 NPS	2.5 NPS	0.841 in ²	[H] 1.035 in	0.259 in	15-300 psi	Steam	V
1.5-2 NPS	2.5 NPS	1.374 in ²	[J] 1.323 in	0.33 in	15-300 psi	Steam	V
1.5-2 NPS	2.5 NPS	1.374 in ²	[J] 1.323 in	0.33 in	15-300 psi	Steam	UV
2-2.5 NPS	3 NPS	1.968 in ²	[K] 1.583 in	0.395 in	15-300 psi	Steam	V
2-2.5 NPS	3 NPS	1.968 in ²	[K] 1.583 in	0.395 in	15-300 psi	Steam	UV
2.5-3 NPS	4 NPS	3.054 in ²	[L] 1.972 in	0.493 in	15-300 psi	Steam	UV
2.5-3 NPS	4 NPS	3.054 in ²	[L] 1.972 in	0.493 in	15-300 psi	Steam	V
3 NPS	4 NPS	3.846 in ²	[M] 2.213 in	0.553 in	15-300 psi	Steam	V
3 NPS	4 NPS	3.846 in ²	[M] 2.213 in	0.553 in	15-300 psi	Steam	UV
4 NPS	6 NPS	4.633 in ²	[N] 2.429 in	0.607 in	15-300 psi	Steam	UV
4 NPS	6 NPS	4.633 in ²	[N] 2.429 in	0.607 in	15-300 psi	Steam	V
4 NPS	6 NPS	6.83 in ²	[P] 2.949 in	0.737 in	15-300 psi	Steam	V
4 NPS	6 NPS	6.83 in ²	[P] 2.949 in	0.737 in	15-300 psi	Steam	UV
6 NPS	8 NPS	11.811 in ²	[Q] 3.878 in	0.969 in	15-300 psi	Steam	UV
6 NPS	8 NPS	11.811 in ²	[Q] 3.878 in	0.969 in	15-300 psi	Steam	V
6 NPS	8 NPS	17.121 in ²	[R] 4.669 in	1.167 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.121 in ²	[R] 4.669 in	1.167 in	15-300 psi	Steam	UV

Spirax-Sarco Limited (SSL)

Nameplate Abbreviation: Spirax Sarco

Cheltenham, GL51 9NQUnited Kingdom

This Company Manufactures or Assembles:

Design Name: SV7			NBCert #	71020
Manufacturer/Assembler		Designators		Expiration Date
Manufacturer		UV, V		07/15/2028
Design Type				

[Safety Valve] SV7
Capacity Tests: Sec. UV, V at National Board Testing Lab on July 30, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Spirax-Sarco Limited {SSL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	0.328 in ²	[F] 0.646 in	0.161 in	15-300 psi	Steam	UV
1.5 NPS	2 NPS	0.328 in ²	[F] 0.646 in	0.161 in	15-300 psi	Steam	V
1.5 NPS	2 NPS	0.537 in ²	[G] 0.827 in	0.207 in	15-300 psi	Steam	V
1.5 NPS	2 NPS	0.537 in ²	[G] 0.827 in	0.207 in	15-300 psi	Steam	UV
1.5 NPS	2.5 NPS	0.841 in ²	[H] 1.035 in	0.259 in	15-300 psi	Steam	UV
1.5 NPS	2.5 NPS	0.841 in ²	[H] 1.035 in	0.259 in	15-300 psi	Steam	V
1.5-2 NPS	2.5 NPS	1.374 in ²	[J] 1.323 in	0.33 in	15-300 psi	Steam	V
1.5-2 NPS	2.5 NPS	1.374 in ²	[J] 1.323 in	0.33 in	15-300 psi	Steam	UV
2-2.5 NPS	3 NPS	1.968 in ²	[K] 1.583 in	0.395 in	15-300 psi	Steam	V
2-2.5 NPS	3 NPS	1.968 in ²	[K] 1.583 in	0.395 in	15-300 psi	Steam	UV
2.5-3 NPS	4 NPS	3.054 in ²	[L] 1.972 in	0.493 in	15-300 psi	Steam	UV
2.5-3 NPS	4 NPS	3.054 in ²	[L] 1.972 in	0.493 in	15-300 psi	Steam	V
3 NPS	4 NPS	3.846 in ²	[M] 2.213 in	0.553 in	15-300 psi	Steam	V
3 NPS	4 NPS	3.846 in ²	[M] 2.213 in	0.553 in	15-300 psi	Steam	UV
4 NPS	6 NPS	4.633 in ²	[N] 2.429 in	0.607 in	15-300 psi	Steam	UV
4 NPS	6 NPS	4.633 in ²	[N] 2.429 in	0.607 in	15-300 psi	Steam	V
4 NPS	6 NPS	6.83 in ²	[P] 2.949 in	0.737 in	15-300 psi	Steam	V
4 NPS	6 NPS	6.83 in ²	[P] 2.949 in	0.737 in	15-300 psi	Steam	UV
6 NPS	8 NPS	11.811 in ²	[Q] 3.878 in	0.969 in	15-300 psi	Steam	UV
6 NPS	8 NPS	11.811 in ²	[Q] 3.878 in	0.969 in	15-300 psi	Steam	V
6 NPS	8 NPS	17.121 in ²	[R] 4.669 in	1.167 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.121 in ²	[R] 4.669 in	1.167 in	15-300 psi	Steam	UV

St. Gabriel Valve Service, LLC (SGV)

St. Gabriel, LA 70776United States

This Company Manufactures or Assembles:

Design Name: 119 Series		NBCert # 11361
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	11/17/2026
Design Type		

[Safety Valve] 119 Series
Capacity Tests: Sec. UV, V at National Board Testing Lab on March 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Air	UV
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Steam	UV
1.5 NPS	2.5 NPS	1.358 in ²	[J] 1.315 in	0.329 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Steam	UV
2-3 NPS	3 NPS	1.926 in ²	[K] 1.566 in	0.392 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Steam	NV
2.5-4 NPS	4 NPS	2.99 in ²	[L] 1.951 in	0.488 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.774 in ²	[M] 2.192 in	0.548 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.55 in ²	[N] 2.407 in	0.602 in	15-250 psi	Steam	V
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Air	UV
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Steam	UV
4 NPS	6 NPS	6.692 in ²	[P] 2.919 in	0.73 in	15-250 psi	Steam	V
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Air	UV
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Steam	UV
6 NPS	8 NPS	11.593 in ²	[Q] 3.842 in	0.961 in	15-250 psi	Steam	V
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Air	UV
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Steam	UV
6 NPS	8 NPS	16.786 in ²	[R] 4.623 in	1.156 in	15-250 psi	Steam	V

Design Name: 19 Series	NBCert # 11282
------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 11/17/2026

Design Type

[Safety Valve] 19 Series
Capacity Tests: Sec. UV, V at unknown lab on March 27, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.826 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.129 in ²	[D] 0.406 in	0.101 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.129 in ²	[D] 0.406 in	0.101 in	15-300 psi	Steam	UV, V
0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Air	UV

0.75-1 NPS	1 NPS	0.23 in ²	[E] 0.541 in	0.135 in	15-300 psi	Steam	UV, V
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Air	UV
1-1.25 NPS	1.25 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-300 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-300 psi	Steam	UV, V
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Air	UV
1.5-2 NPS	2 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-300 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.509 in ²	[J] 1.386 in	0.347 in	15-300 psi	Steam	UV, V

Design Name:	500 Series	NBCert #	11462
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/17/2029

Design Type

[Safety Valve] 500 Series
Capacity Tests: Sec. UV at National Board Testing Lab on June 12, 2000
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.861 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.129 in ²	[D] 0.406 in	0.102 in	15-2000 psi	Air	UV
0.5-0.75 NPS	.75, 1 NPS	0.129 in ²	[D] 0.406 in	0.102 in	15-2000 psi	Steam	UV
0.75-1 NPS	1.25 NPS	0.229 in ²	[E] 0.539 in	0.135 in	15-2000 psi	Air	UV
0.75-1 NPS	1.25 NPS	0.229 in ²	[E] 0.539 in	0.135 in	15-2000 psi	Steam	UV
1-1.25 NPS	1.5 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-2000 psi	Air	UV
1-1.25 NPS	1.5 NPS	0.359 in ²	[F] 0.676 in	0.169 in	15-2000 psi	Steam	UV
1.25-1.5 NPS	2 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-2000 psi	Air	UV
1.25-1.5 NPS	2 NPS	0.589 in ²	[G] 0.866 in	0.217 in	15-2000 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-2000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.919 in ²	[H] 1.082 in	0.271 in	15-2000 psi	Steam	UV
2 NPS	3 NPS	1.504 in ²	[J] 1.384 in	0.346 in	15-2000 psi	Air	UV
2 NPS	3 NPS	1.504 in ²	[J] 1.384 in	0.346 in	15-2000 psi	Steam	UV

Design Name:	500 Series (Liquids)	NBCert #	11473
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/17/2029

Design Type

[Safety Relief Valve] 500 Series (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on February 25, 2000
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.689 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aalberts Integrated Piping Systems Americas, Inc. {CNB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75, 1 NPS	0.129 in²	[D] 0.406 in	0.102 in	15-1000 psi	Water	UV
0.75-1 NPS	1.25 NPS	0.229 in²	[E] 0.539 in	0.135 in	15-1000 psi	Water	UV
1-1.25 NPS	1.5 NPS	0.359 in²	[F] 0.676 in	0.169 in	15-1000 psi	Water	UV
1.25-1.5 NPS	2 NPS	0.589 in²	[G] 0.866 in	0.217 in	15-1000 psi	Water	UV
1.5-2 NPS	2.5 NPS	0.919 in²	[H] 1.082 in	0.271 in	15-1000 psi	Water	UV
2 NPS	3 NPS	1.504 in²	[J] 1.384 in	0.346 in	15-1000 psi	Water	UV

Suzhou BS&B Safety Systems Co., Ltd (SIP)

Suzhou, 215021People's Republic of China

This Company Manufactures or Assembles:

Design Name: 2" BV		NBCert # 77486
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/17/2030

Design Type

[Rupture Disk Device] 2" BV
HolderDesignation: FA-7R, FA-1F - 9F, UA-2,3,5,6
Capacity Tests: Sec. UD at National Board Testing Lab on August 11, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 0.550 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		2.24 in²			16-6000 psi		UD

Design Name: AV		NBCert #	77341
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	11/21/2025

Design Type

[Rupture Disk Device] AV
 HolderDesignation: AV7R, AV-7RS, AV-7FS, AV-1, -2, -3, -4, -5, -6, -7, -8, -9
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on November 4, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 4.350 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS		78.85 in ²			0.6-60 psi		UD
12 NPS		113.1 in ²			0.6-60 psi		UD
14 NPS		137.9 in ²			0.6-60 psi		UD
16 NPS		182.7 in ²			0.6-60 psi		UD
18 NPS		233.7 in ²			0.5-60 psi		UD
2 NPS		3.356 in ²			5-150 psi		UD
2.5 NPS		4.787 in ²			5-150 psi		UD
20 NPS		291 in ²			0.5-60 psi		UD
22 NPS		354.7 in ²			0.5-60 psi		UD
24 NPS		424.6 in ²			0.5-60 psi		UD
26 NPS		500.7 in ²			0.5-45 psi		UD
28 NPS		583.2 in ²			0.5-45 psi		UD
3 NPS		7.392 in ²			4-150 psi		UD
30 NPS		672 in ²			0.5-45 psi		UD
32 NPS		767 in ²			0.35-40 psi		UD
34 NPS		868.3 in ²			0.35-40 psi		UD
36 NPS		975.9 in ²			0.25-40 psi		UD
38 NPS		1090 in ²			0.25-40 psi		UD
4 NPS		12.73 in ²			2-150 psi		UD
40 NPS		1210 in ²			0.25-40 psi		UD
42 NPS		1336 in ²			0.25-40 psi		UD
44 NPS		1469 in ²			0.25-40 psi		UD
46 NPS		1608 in ²			0.25-40 psi		UD
48 NPS		1753 in ²			0.25-40 psi		UD
5 NPS		20 in ²			2-100 psi		UD
6 NPS		28.89 in ²			1-100 psi		UD
8 NPS		50.02 in ²			1-100 psi		UD

Design Name: AVV

NBCert # 78364

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/18/2030

Design Type

[Rupture Disk Device] AVV
 HolderDesignation: AV-75 (optional)
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on March 17, 2017
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value:10.500 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 in		0.4 in ²			10-150 psi		UD
1.5 in		0.95 in ²			7-150 psi		UD
10 in		45.5 in ²			0.6-60 psi		UD
12 in		62.75 in ²			0.6-60 psi		UD
14 in		74.5 in ²			0.6-60 psi		UD
16 in		111 in ²			0.6-60 psi		UD
18 in		158 in ²			0.5-60 psi		UD
2 in		1.6 in ²			5-150 psi		UD
20 in		195 in ²			0.5-60 psi		UD
24 in		280 in ²			0.5-60 psi		UD
28 in		382 in ²			0.5-60 psi		UD
3 in		4 in ²			4-150 psi		UD
30 in		425 in ²			0.5-60 psi		UD
32 in		500 in ²			0.35-40 psi		UD
36 in		630 in ²			0.25-40 psi		UD
4 in		8 in ²			2-150 psi		UD
40 in		780 in ²			0.25-40 psi		UD
44 in		945 in ²			0.25-40 psi		UD
48 in		1125 in ²			0.25-40 psi		UD
6 in		16.5 in ²			1-100 psi		UD
8 in		35.75 in ²			1-100 psi		UD

Design Name: B, BR, BRR (liquid)

NBCert # 77318

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UD

09/17/2026

Design Type

[Rupture Disk Device] B, BR, BRR (liquid)
 HolderDesignation: FA-7R, FA-1 - FA9, UA-2,3,5,6
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 12, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 1.470 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.189 in ²			80-30000 psi		UD
1 NPS		0.801 in ²			40-12000 psi		UD
1.5 NPS		1.76 in ²			26-6000 psi		UD
10 NPS		78.85 in ²			4-1400 psi		UD
12 NPS		112.5 in ²			4-1000 psi		UD
14 NPS		137.9 in ²			3-750 psi		UD
16 NPS		182.7 in ²			3-500 psi		UD
18 NPS		233.7 in ²			3-475 psi		UD
2 NPS		3.33 in ²			16-6000 psi		UD
20 NPS		291 in ²			2-450 psi		UD
24 NPS		424.6 in ²			2-230 psi		UD
3 NPS		6.514 in ²			12-6000 psi		UD
30 NPS		672 in ²			2-184 psi		UD
32 NPS		767 in ²			2-181 psi		UD
36 NPS		976 in ²			6-160 psi		UD
4 NPS		11.82 in ²			9-6000 psi		UD
40 NPS		1210 in ²			6-145 psi		UD
42 NPS		1336 in ²			3-138 psi		UD
44 NPS		1469 in ²			6-132 psi		UD
6 NPS		28.84 in ²			7-3600 psi		UD
8 NPS		49.89 in ²			5-3600 psi		UD

Design Name: B, BR, BRR, Welded B		NBCert #	77037
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	10/17/2030
Design Type			
[Rupture Disk Device] B, BR, BRR, Welded B HolderDesignation: FA-7R, FA1,2,3,4,5,6,7,8,9,UA-2,3,5,6 Capacity Tests: Sec. UD at National Board Testing Lab on September 15, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.710 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.189 in ²			80-30000 psi		UD
0.725 in		0.34 in ²			900-20000 psi		UD
1 NPS		0.801 in ²			40-12000 psi		UD
1.5 NPS		1.76 in ²			26-6000 psi	Air	UD
10 NPS		78.85 in ²			4-1400 psi		UD
12 NPS		112.5 in ²			4-1000 psi		UD

14 NPS	137.9 in ²	3-750 psi	UD
16 NPS	182.7 in ²	3-500 psi	UD
18 NPS	233.7 in ²	3-475 psi	UD
2 NPS	3.33 in ²	16-6000 psi	UD
20 NPS	291 in ²	2-450 psi	UD
24 NPS	424.6 in ²	2-230 psi	UD
3 NPS	6.514 in ²	12-6000 psi	UD
30 NPS	672 in ²	2-184 psi	UD
32 NPS	767 in ²	2-181 psi	UD
36 NPS	976 in ²	6-160 psi	UD
4 NPS	11.82 in ²	9-6000 psi	UD
40 NPS	1210 in ²	6-145 psi	UD
42 NPS	1336 in ²	6-138 psi	UD
44 NPS	1469 in ²	6-132 psi	UD
6 NPS	28.84 in ²	7-3600 psi	UD
8 NPS	49.9 in ²	5-3600 psi	UD

Design Name: BPSV NBCert # 01720

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	05/02/2031

Design Type

[Buckling Pin Non-reclosing Device] BPSV
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on September 11, 2018
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 7.000 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: MNFA
Designed by: Suzhou BS&B Safety Systems Co., Ltd {SIP}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS	10 NPS	43.29 in ²			0.5-150 psi	Air	UD
12 NPS	12 NPS	65.87 in ²			0.5-150 psi	Air	UD
14 NPS	14 NPS	87.72 in ²			0.5-150 psi	Air	UD
16 NPS	16 NPS	118.8 in ²			0.5-150 psi	Air	UD
18 NPS	18 NPS	159.53 in ²			0.5-150 psi	Air	UD
20 NPS	20 NPS	208.38 in ²			0.5-150 psi	Air	UD
24 NPS	24 NPS	292.69 in ²			0.5-150 psi	Air	UD
28 NPS	28 NPS	429.82 in ²			0.5-150 psi	Air	UD
30 NPS	30 NPS	497.18 in ²			0.5-150 psi	Air	UD
32 NPS	32 NPS	567.49 in ²			0.5-150 psi	Air	UD
34 NPS	34 NPS	642.46 in ²			0.5-150 psi	Air	UD
36 NPS	36 NPS	722.07 in ²			0.5-150 psi	Air	UD
4 NPS	4 NPS	5.69 in ²			0.5-150 psi	Air	UD

6 NPS	6 NPS	13.93 in ²		0.5-150 psi	Air	UD
8 NPS	8 NPS	27.05 in ²		0.5-150 psi	Air	UD
26 NPS	26 NPS	370.5 in ²	0 in	0.5-150 psi	Air	UD
40 NPS	40 NPS	895.24 in ²	0 in	0.5-150 psi	Air	UD
44 NPS	44 NPS	1087.01 in ²	0 in	0.5-150 psi	Air	UD
48 NPS	48 NPS	1297.37 in ²	0 in	0.5-150 psi	Air	UD
52 NPS	52 NPS	1526.33 in ²	0 in	0.5-150 psi	Air	UD
56 NPS	56 NPS	1773.89 in ²	0 in	0.5-150 psi	Air	UD
60 NPS	60 NPS	2040.04 in ²	0 in	0.5-150 psi	Air	UD
72 NPS	72 NPS	2950.06 in ²	0 in	0.5-150 psi	Air	UD

Design Name:	BV, BRV, BSV, BRSV	NBCert #	77026
Manufacturer/Assembler	Designators	Expiration Date	

Manufacturer UD 09/26/2025

Design Type

[Rupture Disk Device] BV, BRV, BSV, BRSV
 HolderDesignation: FA-7R, FA-7,FA-1,2,3,4,5,6,7,8,9,UA-2,3,5,6
 Capacity Tests: Sec. UD at National Board Testing Lab on July 13, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.800 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.57 in ²			145-12000 psi	Air	UD
1.5 NPS		1.44 in ²			95-6000 psi	Air	UD
10 NPS		70.88 in ²			14-1400 psi		UD
12 NPS		101.5 in ²			12-1000 psi		UD
14 NPS		130.3 in ²			11-750 psi		UD
16 NPS		176.7 in ²			9-500 psi		UD
18 NPS		202.4 in ²			8-475 psi		UD
2 NPS		2.24 in ²			55-6000 psi	Air	UD
20 NPS		280 in ²			8-450 psi		UD
24 NPS		380.1 in ²			37-230 psi		UD
3 NPS		5.41 in ²			41-6000 psi		UD
30 NPS		615.7 in ²			20-184 psi		UD
32 NPS		728 in ²			31-181 psi		UD
36 NPS		927 in ²			28-160 psi		UD
4 NPS		9.62 in ²			31-6000 psi		UD
40 NPS		1149 in ²			25-145 psi		UD
42 NPS		1269 in ²			24-138 psi		UD
44 NPS		1395 in ²			23-132 psi		UD
6 NPS		23.76 in ²			23-3600 psi		UD

8 NPS	44.18 in ²	18-3600 psi	UD
-------	-----------------------	-------------	----

Design Name:	BV,BRV,BSV,BRSV (liquid)	NBCert #	77273
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/18/2030

Design Type

[Rupture Disk Device] BV,BRV,BSV,BRSV (liquid)
HolderDesignation: FA-7R, FA-1 - FA-9,UA-,3,5,6
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on July 1, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 2.450 Unitless
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.57 in ²			145-12000 psi		UD
1.5 NPS		1.44 in ²			95-6000 psi		UD
10 NPS		70.88 in ²			14-1400 psi		UD
12 NPS		101.5 in ²			12-1000 psi		UD
14 NPS		130.3 in ²			11-750 psi		UD
16 NPS		176.7 in ²			9-500 psi		UD
18 NPS		202.4 in ²			8-475 psi		UD
2 NPS		2.24 in ²			55-6000 psi		UD
20 NPS		280 in ²			8-450 psi		UD
24 NPS		380.1 in ²			37-230 psi		UD
3 NPS		5.41 in ²			41-6000 psi		UD
30 NPS		615.8 in ²			20-184 psi		UD
32 NPS		728 in ²			31-181 psi		UD
36 NPS		927 in ²			28-160 psi		UD
4 NPS		9.62 in ²			31-6000 psi		UD
40 NPS		1149 in ²			25-145 psi		UD
42 NPS		1269 in ²			24-138 psi		UD
44 NPS		1395 in ²			23-132 psi		UD
6 NPS		23.76 in ²			23-3600 psi		UD
8 NPS		44.18 in ²			18-3600 psi		UD

Design Name:	D Series (liquid) DR, DRR	NBCert #	77352
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	05/02/2031

Design Type

[Rupture Disk Device] D Series (liquid) DR, DRR
 HolderDesignation: FA-7R, FA-1 - FA-9,UA-2,3,5,6, FF-*
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 28, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 1.300 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.801 in ²			44-2000 psi		UD
1.5 NPS		1.76 in ²			31-1400 psi		UD
10 NPS		78.8 in ²			4-480 psi		UD
12 NPS		112.5 in ²			3-1000 psi		UD
14 NPS		137.9 in ²			3-350 psi		UD
16 NPS		182.7 in ²			3-300 psi		UD
18 NPS		233.7 in ²			3-270 psi		UD
2 NPS		3.33 in ²			15-1100 psi		UD
20 NPS		291 in ²			3-240 psi		UD
24 NPS		424.6 in ²			3-200 psi		UD
28 NPS		584 in ²			3-170 psi	Air	UD
3 NPS		6.51 in ²			11-900 psi		UD
30 NPS		672 in ²			3-170 psi		UD
32 NPS		767 in ²			3-170 psi		UD
36 NPS		976 in ²			3-170 psi		UD
4 NPS		11.8 in ²			8-830 psi		UD
40 NPS		1210 in ²			3-170 psi		UD
42 NPS		1336 in ²			3-170 psi		UD
44 NPS		1465 in ²			3-170 psi		UD
6 NPS		28.84 in ²			6-640 psi		UD
8 NPS		49.9 in ²			5-590 psi		UD

Design Name: DV, D, DR, DRR, DRV

NBCert #

77048

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UD

07/10/2029

Design Type

[Rupture Disk Device] DV, D, DR, DRR, DRV
 HolderDesignation: FA-7R, FA-1F - 9F, UA-2,3,5,6, FF-*
 Capacity Tests: Sec. UD at National Board Testing Lab on September 15, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 1.190 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.69 in ²			44-2000 psi		UD
1.5 NPS		1.62 in ²			31-1400 psi		UD
10 NPS		74.6 in ²			4-480 psi		UD
12 NPS		106 in ²			3-400 psi		UD
14 NPS		135 in ²			3-350 psi		UD
16 NPS		176 in ²			3-300 psi		UD
18 NPS		223 in ²			3-270 psi		UD
2 NPS		2.95 in ²			15-1100 psi		UD
20 NPS		277 in ²			3-240 psi		UD
24 NPS		397 in ²			3-200 psi		UD
28 NPS	NPS	584 in ²			3-170 psi	Air	UD
3 NPS		6.49 in ²			11-900 psi		UD
30 NPS		661 in ²			3-170 psi		UD
36 NPS		907 in ²			3-170 psi		UD
4 NPS		11 in ²			8-830 psi		UD
40 NPS		1120 in ²			3-170 psi		UD
42 NPS		1234 in ²			3-170 psi		UD
44 NPS		1355 in ²			3-170 psi		UD
6 NPS		25.9 in ²			6-640 psi		UD
8 NPS		47.1 in ²			5-590 psi		UD

Design Name:	DV, DRV, DSV, DRSV (liquids)	NBCert #	77734
--------------	------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/11/2026

Design Type

[Rupture Disk Device] DV, DRV, DSV, DRSV (liquids)
HolderDesignation: FA-7R,FA-1F - FA-9F, UA-2,3,5,6, FF-*
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 11, 2002
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 2.600 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.57 in ²			44-2000 psi		UD
1.5 NPS		1.44 in ²			31-1400 psi		UD
10 NPS		70.88 in ²			4-480 psi		UD
12 NPS		101.5 in ²			3-1000 psi		UD
14 NPS		130.3 in ²			3-350 psi		UD
16 NPS		176.7 in ²			3-300 psi		UD
18 NPS		202.3 in ²			3-270 psi		UD

2 NPS	2.24 in ²	15-1100 psi	UD
20 NPS	280 in ²	3-240 psi	UD
24 NPS	380.1 in ²	3-200 psi	UD
28 NPS	584 in ²	3-170 psi	Air UD
3 NPS	5.41 in ²	11-900 psi	UD
30 NPS	615.7 in ²	3-170 psi	UD
32 NPS	728 in ²	3-170 psi	UD
36 NPS	927 in ²	3-170 psi	UD
4 NPS	9.62 in ²	8-830 psi	UD
40 NPS	1149 in ²	3-170 psi	UD
42 NPS	1269 in ²	3-170 psi	UD
44 NPS	1395 in ²	3-170 psi	UD
6 NPS	23.76 in ²	6-640 psi	UD
8 NPS	44.18 in ²	5-590 psi	UD

Design Name:	FRS	NBCert #	77284
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 01/12/2029

Design Type

[Rupture Disk Device] FRS
HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, S90-7R, S90-7R-TR, SRI-7RS
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 23, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.800 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			13.5-150 psi		UD
1.5 NPS		1.94 in ²			11.5-70 psi		UD
2 NPS		3.36 in ²			11.5-50 psi		UD

Design Name:	GCR-S, SE, SM, SS, SES, SMS, SME, SMES, SW, N, NS	NBCert #	77611
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 02/11/2029

Design Type

[Rupture Disk Device] GCR-S, SE, SM, SS, SES, SMS, SME, SMES, SW, N, NS
HolderDesignation: GR-C, FM-C, not req'd for -SM
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on November 22, 2000
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 1.950 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		1.5 in ²			10-300 psi	Air	UD
3 NPS		5.29 in ²			10-175 psi		UD
4 NPS		9.78 in ²			10-150 psi		UD
6 NPS		22.5 in ²			10-75 psi		UD
48.3 DN	DN	2.38 in ²	0 in	0 in	10-300 psi		UD
60.3 DN	DN	3.85 in ²	0 in	0 in	10-175 psi		UD
76.1 DN	DN	6.33 in ²	0 in	0 in	10-175 psi		UD

Design Name: GCR-S, SE, SM, SS, SES, SMS, SME, SMES, SW, N, NS (liquids) NBCert # 78195

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 12/20/2028

Design Type

[Rupture Disk Device] GCR-S, SE, SM, SS, SES, SMS, SME, SMES, SW, N, NS (liquids)
HolderDesignation: GR-C, FM-C (not req'd for SM)
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on October 5, 2015
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 2.750 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		1.5 in ²			10-300 psi		UD
3 NPS		5.29 in ²			10-175 psi		UD
4 NPS		9.78 in ²			10-150 psi		UD
6 NPS		22.5 in ²			10-75 psi		UD
48.3 DN	DN	2.38 in ²	0 in	0 in	10-300 psi		UD
60.3 DN	DN	3.85 in ²	0 in	0 in	10-300 psi		UD
76.1 DN	DN	6.33 in ²	0 in	0 in	10-300 psi		UD

Design Name: GCR-S,SE,SM,SS,SES,SMS, SME, SMES, SW, N, NS (2" liquids) NBCert # 78207

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 12/20/2028

Design Type

[Rupture Disk Device] GCR-S,SE,SM,SS,SES,SMS, SME, SMES, SW, N, NS (2" liquids)
HolderDesignation: GR-C, FM-C, not req'd for -SM
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on June 25, 2015
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krl
Certified Value: 1.420 Unitless
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		2.7 in²			10-300 psi	Water	UD
Design Name: GCR-S,SE,SM,SS,SES,SMS, SME, SMES, SW, N, NS (2")NBCert # 77420							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			11/21/2025	
Design Type							
[Rupture Disk Device] GCR-S,SE,SM,SS,SES,SMS, SME, SMES, SW, N, NS (2") HolderDesignation: GR-C, FM-C , not req'd for -SM Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on January 10, 2000 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value: 1.250 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		2.7 in²			10-300 psi	Air	UD
Design Name: GFN, GFA, XN, XN-85NBCert # 77060							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			01/06/2031	
Design Type							
[Rupture Disk Device] GFN, GFA, XN, XN-85 HolderDesignation: NF-7RS, NF-7R, NFI-7RS Capacity Tests: Sec. UD at National Board Testing Lab on December 18, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.550 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in²			113-1800 psi		UD
1.5 NPS		2.03 in²			81-1800 psi		UD
10 NPS		78.8 in²			45-1300 psi		UD
12 NPS		111.9 in²			41-1100 psi		UD
14 NPS		137.9 in²			37-750 psi		UD
16 NPS		176.7 in²			35-270 psi		UD
18 NPS		223.3 in²			33-240 psi		UD
2 NPS		3.36 in²			68-1800 psi		UD
20 NPS		277.9 in²			32-213 psi		UD
24 NPS		402 in²			30-177 psi		UD
3 NPS		7.39 in²			54-1600 psi		UD
4 NPS		12.7 in²			45-1400 psi		UD

6 NPS	28.9 in ²	36-1400 psi	UD
8 NPS	50 in ²	53-1300 psi	UD

Design Name:	GFR-S, -SM, -SE, -SS, -SMS, -SES, -SW (1.5")	NBCert #	77116
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UD	02/10/2029	

Design Type
[Rupture Disk Device] GFR-S, -SM, -SE, -SS, -SMS, -SES, -SW (1.5")
HolderDesignation: GRC
Capacity Tests: Sec. UD at National Board Testing Lab on December 18, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
Certified Value: 9.920 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		0.79 in ²			13.5-200 psi		UD

Design Name:	GFR-S, -SM, -SE, -SS, -SMS, -SES, -SW (2")	NBCert #	77127
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UD	12/20/2028	

Design Type
[Rupture Disk Device] GFR-S, -SM, -SE, -SS, -SMS, -SES, -SW (2")
HolderDesignation: GRC-C, FM-C, FT-C
Capacity Tests: Sec. UD at National Board Testing Lab on December 19, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krgl
Certified Value: 4.760 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS		1.77 in ²			11.5-150 psi		UD

Design Name:	GFR-S, -SM, -SE, -SS, -SMS, -SES, -SW 1 1/2" Liquid	NBCert #	77239
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UD	12/20/2028	

Design Type
[Rupture Disk Device] GFR-S, -SM, -SE, -SS, -SMS, -SES, -SW 1 1/2" Liquid
HolderDesignation: GR-C
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on April 26, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krl
Certified Value:11.500 Unitless
Media - Test: Air/Gas; Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		0.79 in²			13.5-200 psi		UD
Design Name: JRSNBCert # 77015							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			11/21/2025	
Design Type							
[Rupture Disk Device] JRS HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRI-7RS Capacity Tests: Sec. UD at National Board Testing Lab on July 10, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 0.310 Unitless Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: BS & B Safety Systems, LLC {BSB}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in²			22-180 psi		UD
1.5 NPS		1.89 in²			20-150 psi		UD
10 NPS		68.65 in²			12-36 psi		UD
12 NPS		102.28 in²			12-33 psi		UD
14 NPS		121.86 in²			9-30 psi		UD
16 NPS		156 in²			7-28 psi		UD
18 NPS		198 in²			6-26 psi		UD
2 NPS		3.35 in²			18-120 psi		UD
20 NPS		246 in²			5-24 psi		UD
24 NPS		357 in²			5-22 psi		UD
3 NPS		6.53 in²			16-80 psi		UD
30 NPS		592 in²			5-14 psi		UD
32 NPS		706.9 in²			5-14 psi		UD
36 NPS		868 in²			5-14 psi		UD
4 NPS		11.86 in²			14-70 psi		UD
42 NPS		1111 in²			5-14 psi		UD
6 NPS		25.08 in²			12-50 psi		UD
8 NPS		42.07 in²			12-42 psi		UD
28 NPS	NPS	513 in²	0 in	0 in	5-18 psi		UD
Design Name: RB-90NBCert # 77138							
Manufacturer/Assembler			Designators			Expiration Date	
Manufacturer			UD			11/21/2025	

Design Type

[Rupture Disk Device] RB-90
 HolderDesignation: RB-7R, RB-7F, RB-7FF, RB-7FS
 Capacity Tests: Sec. UD at National Board Testing Lab on February 19, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 3.470 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.831 in ²			30-1800 psi		UD
1.5 NPS		1.805 in ²			25-1700 psi		UD
10 NPS		67.62 in ²			15-800 psi		UD
12 NPS		101.8 in ²			15-800 psi		UD
14 NPS		121.7 in ²			15-800 psi		UD
16 NPS		162.8 in ²			15-800 psi		UD
18 NPS		209.99 in ²			13-700 psi		UD
2 NPS		3.153 in ²			22-1600 psi		UD
20 NPS		262.9 in ²			13-700 psi		UD
24 NPS		386.9 in ²			10-700 psi		UD
26 NPS		465 in ²			10-700 psi		UD
28 NPS		530.7 in ²			10-700 psi		UD
3 NPS		6.849 in ²			21-1500 psi		UD
30 NPS		617.7 in ²			10-700 psi		UD
32 NPS		698.4 in ²			10-700 psi		UD
34 NPS		790.1 in ²			10-700 psi		UD
36 NPS		872.8 in ²			10-700 psi		UD
4 NPS		11.84 in ²			20-1500 psi		UD
6 NPS		25.45 in ²			20-850 psi		UD
8 NPS		47.68 in ²			15-800 psi		UD

Design Name: RLS, RLS Welded Assembly NBCert # 77059

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	11/13/2030

Design Type

[Rupture Disk Device] RLS, RLS Welded Assembly
 HolderDesignation: SRB-7RS, SRB-7RS-TR, S90-7R, S90-7R-TR, SRB-7FS, SRB-7FR-TR, SMR-7R, SRI-7RS, SRB-7RS Special, SRB-QRS
 Capacity Tests: Sec. UD at National Board Testing Lab on August 12, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 1.140 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS		0.5 in ²			300-2000 psi		UD

1 NPS	0.84 in ²	125-2200 psi	UD
1.5 NPS	1.77 in ²	85-1800 psi	UD
10 NPS	73.9 in ²	35-250 psi	UD
12 NPS	99 in ²	35-150 psi	UD
14 NPS	131 in ²	35-130 psi	UD
16 NPS	172 in ²	25-110 psi	UD
18 NPS	219 in ²	25-90 psi	UD
2 NPS	3.23 in ²	70-1800 psi	UD
20 NPS	270 in ²	20-90 psi	UD
3 NPS	6.44 in ²	55-1600 psi	UD
4 NPS	11.54 in ²	45-1500 psi	UD
6 NPS	26.4 in ²	35-650 psi	UD
8 NPS	47 in ²	35-400 psi	UD

Design Name:	S-90 (Inconel)	NBCert #	77206
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	10/17/2030
--------------	----	------------

Design Type

[Rupture Disk Device] S-90 (Inconel)
HolderDesignation: S90-7R, S90-7R-TR, SRB-7RS, SRB-7RS-TR, SMR-7R, SRB-7FS, SRB-7FS-TR, SRI-7RS, SRB-QRS
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on April 24, 1999
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.230 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.864 in ²			170-1000 psi		UD
1.5 NPS		2.03 in ²			128-1000 psi		UD
10 NPS		78.8 in ²			36-700 psi		UD
12 NPS		111 in ²			33-600 psi		UD
14 NPS		135 in ²			30-500 psi		UD
16 NPS		176 in ²			28-200 psi		UD
18 NPS		223 in ²			26-160 psi		UD
2 NPS		3.36 in ²			96-1000 psi		UD
20 NPS		277 in ²			24-142 psi		UD
24 NPS		402 in ²			22-118 psi		UD
3 NPS		7.39 in ²			72-1000 psi		UD
30 NPS		672 in ²			20-80 psi		UD
4 NPS		12.7 in ²			60-800 psi		UD
6 NPS		28.9 in ²			48-800 psi		UD
8 NPS		50 in ²			42-700 psi		UD
40 NPS	NPS	1195 in ²		0 in	30-250 psi		UD

Design Name:	S90, S90 Welded Assembly	NBCert #	77082
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/17/2030

Design Type

[Rupture Disk Device] S90, S90 Welded Assembly
 HolderDesignation: SRB-7RS, SRB-7RS-TR, S90-7R, S90-7R-TR, SMR-7R, SRB-7FS, SRB-7FS-TR, SRI-7RS, SRB-QRS
 Capacity Tests: Sec. UD at National Board Testing Lab on July 27, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 1.130 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, LLC {BSB}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			75-1000 psi		UD
1.5 NPS		2.03 in ²			54-1000 psi		UD
10 NPS		78.8 in ²			30-700 psi		UD
12 NPS		111 in ²			27-600 psi		UD
14 NPS		135 in ²			25-500 psi		UD
16 NPS		176 in ²			23-475 psi		UD
18 NPS		223 in ²			22-475 psi		UD
2 NPS		3.36 in ²			45-1000 psi		UD
20 NPS		277 in ²			20-250 psi		UD
24 NPS		402 in ²			18-250 psi		UD
28 NPS		583 in ²			20-250 psi		UD
3 NPS		7.39 in ²			36-1000 psi		UD
30 NPS		672 in ²			20-250 psi		UD
4 NPS		12.7 in ²			30-800 psi		UD
40 NPS	NPS	1195 in ²			20-250 psi	Air	UD
6 NPS		28.8 in ²			24-800 psi		UD
8 NPS		50 in ²			35-700 psi		UD

Design Name:	SRD & CCS	NBCert #	78229
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/12/2029

Design Type

[Rupture Disk Device] SRD & CCS
 HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SMR-7R, SR-7R, SPR-7R, S90-7R, S90-7R-TR, SRI-7RS, SRB-QRS
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on May 19, 2016
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.590 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.84 in ²			481-750 psi		UD
1.5 NPS		1.77 in ²			421-600 psi		UD
2 NPS		3.23 in ²			421-500 psi		UD
3 NPS		6.44 in ²			281-500 psi		UD
4 NPS		11.54 in ²			271-500 psi		UD
6 NPS		26.44 in ²			101-200 psi		UD
8 NPS		47.07 in ²			76-150 psi		UD
10 NPS		73.94 in ²		0 in	60-125 psi		UD
12 NPS		99.1 in ²		0 in	45-90 psi		UD
24 NPS		334 in ²		0 in	32-60 psi		UD

Design Name:	SRD & CCS (Liquid)	NBCert #	78230
--------------	--------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/12/2029

Design Type

[Rupture Disk Device] SRD & CCS (Liquid)
 HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SMR-7R, SR-7R, SPR-7R, S90-7R, S90-7R-TR, SRI-7RS, SRB-QRS
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on May 19, 2016
 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krl
 Certified Value: 4.000 Unitless
 Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.84 in ²			481-750 psi		UD
1.5 NPS		1.77 in ²			421-600 psi		UD
2 NPS		3.23 in ²			421-500 psi		UD
3 NPS		6.44 in ²			281-500 psi		UD
4 NPS		11.54 in ²			271-500 psi		UD
6 NPS		26.44 in ²			101-200 psi		UD
8 NPS		47.07 in ²			76-150 psi		UD
10 NPS		73.94 in ²		0 in	60-125 psi		UD
12 NPS		99.1 in ²		0 in	45-90 psi		UD
24 NPS		334 in ²		0 in	32-60 psi		UD

Design Name:	SRD-L & CCS-L	NBCert #	78241
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/12/2029

Design Type

[Rupture Disk Device] SRD-L & CCS-L
 HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SMR-7R, SR-7R, SPR-7R, S90-7R, S90-7R-TR, SRI-7RS, SRB-QRS
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on May 19, 2016
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 3.400 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.84 in ²			75-480 psi		UD
1.5 NPS		1.77 in ²			75-420 psi		UD
2 NPS		3.23 in ²			75-420 psi		UD
3 NPS		6.44 in ²			45-280 psi		UD
4 NPS		11.54 in ²			20-270 psi		UD
6 NPS		26.44 in ²			20-100 psi		UD
8 NPS		47.07 in ²			15-75 psi		UD
10 NPS		73.94 in ²		0 in	13-60 psi		UD
12 NPS		99 in ²		0 in	13-45 psi		UD
14 NPS		131 in ²		0 in	12-40 psi		UD
16 NPS		172 in ²		0 in	12-38 psi		UD
18 NPS		219 in ²		0 in	10-36 psi		UD
20 NPS		270 in ²		0 in	10-34 psi		UD
24 NPS		334 in ²		0 in	10-32 psi		UD

Design Name: SRD-L & CCS-L (Liquid)

NBCert # 78252

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/12/2029

Design Type

[Rupture Disk Device] SRD-L & CCS-L (Liquid)
 HolderDesignation: SRB-7RS, SRB-7RS-TR, SRB-7FS, SRB-7FS-TR, SMR-7R, SR-7R, SPR-7R, S90-7R, S90-7R-TR, SRI-7RS, SRB-QRS
 Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on May 19, 2016
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 4.500 Unitless
 Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.84 in ²			75-480 psi		UD
1.5 NPS		1.77 in ²			75-420 psi		UD
2 NPS		3.23 in ²			75-420 psi		UD
3 NPS		6.44 in ²			45-280 psi		UD
4 NPS		11.54 in ²			20-270 psi		UD
6 NPS		26.44 in ²			20-100 psi		UD
8 NPS		47.07 in ²			15-75 psi		UD

10 NPS	73.94 in ²	0 in	13-60 psi	UD
12 NPS	99 in ²	0 in	13-45 psi	UD
14 NPS	131 in ²	0 in	12-40 psi	UD
16 NPS	172 in ²	0 in	12-38 psi	UD
18 NPS	219 in ²	0 in	10-36 psi	UD
20 NPS	270 in ²	0 in	10-36 psi	UD
24 NPS	334 in ²	0 in	10-32 psi	UD

Design Name:	XT (Liquid)	NBCert #	78094
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/11/2026

Design Type

[Rupture Disk Device] XT (Liquid)
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on February 13, 2013
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 0.500 Unitless
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			250-1450 psi	Water	UD
1.5 NPS		2.03 in ²			150-1450 psi	Water	UD
10 NPS		78.8 in ²			60-840 psi	Water	UD
12 NPS		111 in ²			60-720 psi	Water	UD
2 NPS		3.36 in ²			150-1450 psi	Water	UD
3 NPS		7.39 in ²			150-1300 psi	Water	UD
4 NPS		12.7 in ²			80-1150 psi	Water	UD
6 NPS		28.8 in ²			70-1040 psi	Water	UD
8 NPS		50 in ²			60-960 psi	Water	UD

Design Name:	XT, XT Welded Assembly	NBCert #	77149
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/11/2026

Design Type

[Rupture Disk Device] XT, XT Welded Assembly
HolderDesignation: NX-7R, NF-7R, NF-7RS, TL-7R, TLP-7R
Capacity Tests: Sec. UD at BS & B Safety Systems, LLC on August 1, 2006
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.500 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: BS & B Safety Systems, Ltd. {BSI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 in	in	0.86 in ²			80-1450 psi		UD

1.5 in	in	2.03 in ²	55-1450 psi	UD
10 in	in	78.8 in ²	60-840 psi	UD
12 in	in	111 in ²	60-720 psi	UD
2 in	in	3.36 in ²	45-1450 psi	UD
3 in	in	7.39 in ²	45-1300 psi	UD
4 in	in	12.7 in ²	40-1150 psi	UD
6 in	in	28.8 in ²	40-1040 psi	UD
8 in	in	50 in ²	40-960 psi	UD

SVC Inc. (SVK)

Gimpo-si, Gyeonggi-Do, 10117 Republic of Korea

This Company Manufactures or Assembles:

Design Name: SSR-S8000, SSR-S8000-B		NBCert #	94159
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	03/31/2029	
Design Type			
[Safety Relief Valve] SSR-S8000, SSR-S8000-B Capacity Tests: Sec. UV at National Board Testing Lab on June 5, 2003 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.855 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: SVC Inc. {SVK}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 - 2.5 NPS	0.11 in ²	[D] 0.374 in	0.094 in	15-2885 psi	Steam	UV
0.5-1 NPS	1 - 2.5 NPS	0.11 in ²	[D] 0.374 in	0.094 in	15-6000 psi	Air	UV
1-1.5 NPS	2 - 2.5 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-2885 psi	Steam	UV
1-1.5 NPS	2 - 2.5 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-6000 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.307 in ²	[F] 0.625 in	0.157 in	15-2885 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.307 in ²	[F] 0.625 in	0.157 in	15-5000 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.503 in ²	[G] 0.803 in	0.201 in	15-2885 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.503 in ²	[G] 0.803 in	0.201 in	15-3700 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.25 in	15-2060 psi	Steam	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.25 in	15-2750 psi	Air	UV
2-3 NPS	3, 4 NPS	1.287 in ²	[J] 1.283 in	0.321 in	15-2060 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.287 in ²	[J] 1.283 in	0.321 in	15-2700 psi	Air	UV
3 NPS	4, 6 NPS	1.838 in ²	[K] 1.531 in	0.383 in	15-2060 psi	Steam	UV
3 NPS	4, 6 NPS	1.838 in ²	[K] 1.531 in	0.383 in	15-2220 psi	Air	UV
3-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.909 in	0.478 in	15-1500 psi	Air	UV

3-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.909 in	0.478 in	15-1500 psi	Steam	UV
4 NPS	6 NPS	3.6 in ²	[M] 2.142 in	0.536 in	15-1100 psi	Air	UV
4 NPS	6 NPS	3.6 in ²	[M] 2.142 in	0.536 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-1000 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1000 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1000 psi	Steam	UV
6 NPS	6 NPS	11.05 in ²	[Q] 3.752 in	0.938 in	15-800 psi	Air	UV
6 NPS	6 NPS	11.05 in ²	[Q] 3.752 in	0.938 in	15-800 psi	Steam	UV
6 NPS	8 NPS	13.67 in ²	[Q2] 4.173 in	1.043 in	15-800 psi	Air	UV
6 NPS	8 NPS	13.67 in ²	[Q2] 4.173 in	1.043 in	15-800 psi	Steam	UV
6 NPS	8, 10 NPS	16 in ²	[R] 4.516 in	1.129 in	15-600 psi	Air	UV
6 NPS	8, 10 NPS	16 in ²	[R] 4.516 in	1.129 in	15-600 psi	Steam	UV
8 NPS	10 NPS	26 in ²	[T] 5.756 in	1.439 in	15-600 psi	Air	UV
8 NPS	10 NPS	26 in ²	[T] 5.756 in	1.439 in	15-600 psi	Steam	UV

Design Name: SSR-S8100, SSR-S8100-B NBCert # 94238

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/31/2029

Design Type

[Safety Relief Valve] SSR-S8100, SSR-S8100-B
Capacity Tests: Sec. UV at National Board Testing Lab on October 14, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: SVC Inc. {SVK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.5 NPS	.75-3 NPS	0.137 in ²	[D] 0.418 in	0.105 in	15-2885 psi	Steam	UV
0.5-1.5 NPS	.75-3 NPS	0.137 in ²	[D] 0.418 in	0.105 in	15-6000 psi	Air	UV
0.75-1.5 NPS	1-3 NPS	0.281 in ²	[E] 0.598 in	0.15 in	15-2885 psi	Steam	UV
0.75-1.5 NPS	1-3 NPS	0.281 in ²	[E] 0.598 in	0.15 in	15-6000 psi	Air	UV
1-2 NPS	2-3 NPS	0.377 in ²	[F] 0.693 in	0.173 in	15-2885 psi	Steam	UV
1-2 NPS	2-3 NPS	0.377 in ²	[F] 0.693 in	0.173 in	15-5000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.595 in ²	[G] 0.87 in	0.218 in	15-2885 psi	Steam	UV
1.5-2 NPS	2-3 NPS	0.595 in ²	[G] 0.87 in	0.218 in	15-3700 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.921 in ²	[H] 1.083 in	0.271 in	15-2060 psi	Steam	UV
1.5-2 NPS	2-3 NPS	0.921 in ²	[H] 1.083 in	0.271 in	15-2750 psi	Air	UV
2-3 NPS	3-4 NPS	1.5 in ²	[J] 1.382 in	0.346 in	15-2060 psi	Steam	UV
2-3 NPS	3-4 NPS	1.5 in ²	[J] 1.382 in	0.346 in	15-2700 psi	Air	UV
3 NPS	4-6 NPS	2.138 in ²	[K] 1.65 in	0.413 in	15-2060 psi	Steam	UV
3 NPS	4-6 NPS	2.138 in ²	[K] 1.65 in	0.413 in	15-2220 psi	Air	UV

3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.514 in	15-1500 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.514 in	15-1500 psi	Steam	UV
4 NPS	6 NPS	4.19 in ²	[M] 2.31 in	0.578 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.19 in ²	[M] 2.31 in	0.578 in	15-1500 psi	Steam	UV
4 NPS	6 NPS	5.06 in ²	[N] 2.538 in	0.635 in	15-1500 psi	Air	UV
4 NPS	6 NPS	5.06 in ²	[N] 2.538 in	0.635 in	15-1500 psi	Steam	UV
4 NPS	6 NPS	7.42 in ²	[P] 3.074 in	0.769 in	15-1500 psi	Air	UV
4 NPS	6 NPS	7.42 in ²	[P] 3.074 in	0.769 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	13.05 in ²	[Q] 4.076 in	1.019 in	15-1000 psi	Air	UV
6 NPS	8 NPS	13.05 in ²	[Q] 4.076 in	1.019 in	15-1000 psi	Steam	UV
6 NPS	8-10 NPS	18.6 in ²	[R] 4.866 in	1.217 in	15-1000 psi	Air	UV
6 NPS	8-10 NPS	18.6 in ²	[R] 4.866 in	1.217 in	15-1000 psi	Steam	UV
8 NPS	10 NPS	31 in ²	[T] 6.283 in	1.571 in	15-1000 psi	Air	UV
8 NPS	10 NPS	31 in ²	[T] 6.283 in	1.571 in	15-1000 psi	Steam	UV
10 NPS	14 NPS	47.74 in ²	[V] 7.796 in	1.949 in	15-500 psi	Air	UV
10 NPS	14 NPS	47.74 in ²	[V] 7.796 in	1.949 in	15-500 psi	Steam	UV
12 NPS	16 NPS	74 in ²	[W1] 9.707 in	2.427 in	15-500 psi	Air	UV
12 NPS	16 NPS	74 in ²	[W1] 9.707 in	2.427 in	15-500 psi	Steam	UV
14 NPS	18 NPS	90.7 in ²	[W2] 10.746 in	2.687 in	15-500 psi	Air	UV
14 NPS	18 NPS	90.7 in ²	[W2] 10.746 in	2.687 in	15-500 psi	Steam	UV
16 NPS	18-20 NPS	114.7 in ²	[W3] 12.085 in	3.021 in	15-500 psi	Air	UV
16 NPS	18-20 NPS	114.7 in ²	[W3] 12.085 in	3.021 in	15-500 psi	Steam	UV
18 NPS	24 NPS	140.7 in ²	[Y] 13.384 in	3.346 in	15-500 psi	Air	UV
18 NPS	24 NPS	140.7 in ²	[Y] 13.384 in	3.346 in	15-500 psi	Steam	UV
18 NPS	24 NPS	156 in ²	[Y2] 14.094 in	3.524 in	15-500 psi	Air	UV
18 NPS	24 NPS	156 in ²	[Y2] 14.094 in	3.524 in	15-500 psi	Steam	UV
20 NPS	24 NPS	180.4 in ²	[Z] 15.156 in	3.789 in	15-500 psi	Air	UV
20 NPS	24 NPS	180.4 in ²	[Z] 15.156 in	3.789 in	15-500 psi	Steam	UV
20 NPS	24 NPS	192.1 in ²	[Z2] 15.641 in	3.91 in	15-500 psi	Air	UV
20 NPS	24 NPS	192.1 in ²	[Z2] 15.641 in	3.91 in	15-500 psi	Steam	UV

Design Name: SSRW-S8000, SSRW-S8000-B NBCert # 94160

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/31/2029

Design Type

[Relief Valve] SSRW-S8000, SSRW-S8000-B
Capacity Tests: Sec. UV at National Board Testing Lab on June 5, 2003
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.668 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: SVC Inc. {SVK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 - 2.5 NPS	0.11 in ²	[D] 0.374 in	0.112 in	15-6000 psi	Water	UV
1-1.5 NPS	2 - 2.5 NPS	0.196 in ²	[E] 0.5 in	0.148 in	15-6000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.307 in ²	[F] 0.626 in	0.187 in	15-5000 psi	Water	UV
1.5-2 NPS	2.5, 3 NPS	0.503 in ²	[G] 0.803 in	0.236 in	15-3700 psi	Water	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.296 in	15-2750 psi	Water	UV
2-3 NPS	3, 4 NPS	1.287 in ²	[J] 1.283 in	0.374 in	15-2700 psi	Water	UV
3 NPS	4, 6 NPS	1.838 in ²	[K] 1.531 in	0.443 in	15-2220 psi	Water	UV
3-4 NPS	4 , 6 NPS	2.853 in ²	[L] 1.909 in	0.552 in	15-1500 psi	Water	UV
4 NPS	6 NPS	3.6 in ²	[M] 2.142 in	0.62 in	15-1100 psi	Water	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.68 in	15-1000 psi	Water	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.827 in	15-1000 psi	Water	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.752 in	1.083 in	15-600 psi	Water	UV
6 NPS	8 NPS	16 in ²	[R] 4.516 in	1.3 in	15-600 psi	Water	UV
8 NPS	10 NPS	26 in ²	[T] 5.756 in	1.664 in	15-300 psi	Water	UV

Design Name: SSRW-S8100, SSRW-S8100-B NBCert # 94249

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	03/31/2029

Design Type

[Relief Valve] SSRW-S8100, SSRW-S8100-B
Capacity Tests: Sec. UV at National Board Testing Lab on October 14, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.700 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: SVC Inc. {SVK}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.5 NPS	.75-3 NPS	0.137 in ²	[D] 0.418 in	0.125 in	15-6000 psi	Water	UV
0.75-1.5 NPS	1-3 NPS	0.281 in ²	[E] 0.598 in	0.179 in	15-6000 psi	Water	UV
1-2 NPS	2,3 NPS	0.377 in ²	[F] 0.693 in	0.208 in	15-5000 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.595 in ²	[G] 0.87 in	0.261 in	15-3700 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.921 in ²	[H] 1.083 in	0.325 in	15-2750 psi	Water	UV
2-3 NPS	3,4 NPS	1.5 in ²	[J] 1.382 in	0.415 in	15-2700 psi	Water	UV
3 NPS	4,6 NPS	2.138 in ²	[K] 1.65 in	0.495 in	15-2220 psi	Water	UV
3-4 NPS	4,6 NPS	3.317 in ²	[L] 2.055 in	0.617 in	15-1500 psi	Water	UV
4 NPS	6 NPS	4.19 in ²	[M] 2.31 in	0.693 in	15-1500 psi	Water	UV
4 NPS	6 NPS	5.06 in ²	[N] 2.538 in	0.761 in	15-1500 psi	Water	UV
4 NPS	6 NPS	7.42 in ²	[P] 3.074 in	0.922 in	15-1500 psi	Water	UV
6 NPS	8 NPS	13.05 in ²	[Q] 4.076 in	1.223 in	15-1000 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.866 in	1.46 in	15-1000 psi	Water	UV

8 NPS	10 NPS	31 in ²	[T] 6.283 in	1.885 in	15-1000 psi	Water	UV
10 NPS	14 NPS	47.74 in ²	[V] 7.796 in	2.339 in	15-500 psi	Water	UV
12 NPS	16 NPS	74 in ²	[W1] 9.707 in	2.912 in	15-500 psi	Water	UV
14 NPS	18 NPS	90.7 in ²	[W2] 10.746 in	3.224 in	15-500 psi	Water	UV
16 NPS	18, 20 NPS	114.7 in ²	[W3] 12.085 in	3.626 in	15-500 psi	Water	UV
18 NPS	24 NPS	140.7 in ²	[Y] 13.384 in	4.015 in	15-500 psi	Water	UV
18 NPS	24 NPS	156 in ²	[Y2] 14.094 in	4.228 in	15-500 psi	Water	UV
20 NPS	24 NPS	180.4 in ²	[Z] 15.156 in	4.547 in	15-500 psi	Water	UV
20 NPS	24 NPS	192.1 in ²	[Z2] 15.641 in	4.692 in	15-500 psi	Water	UV

Swan Associates, Inc (SWA)

Benicia, CA 94510United States

This Company Manufactures or Assembles:

Design Name: 900 Series (Liquid), 7700, SNC NBCert # 15499

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/11/2030

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name:	900 Series, 7700, SNC	NBCert #	15411
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/11/2030

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Liquids)	NBCert #	15095
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/11/2030

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V

1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name:	JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB	NBCert #	15208
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	05/02/2030
-----------	----	------------

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV

6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

TAI Milano S.p.A. (TAI)

Guardamiglio (Lodi), 26862Italy

This Company Manufactures or Assembles:

Design Name:	200	NBCert #	45605
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	V	09/06/2028

Design Type

[Safety Valve] 200

Capacity Tests: Sec. V at National Board Testing Lab on February 24, 2021

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Steam; Certified: Steam

Set Pressure Definition: Initial Audible Discharge

Blowdown Characteristics: Adjustable

Flow Area Configuration: Nozzle/Full Lift

Designed by: TAI Milano S.p.A. {TAI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	3 NPS	380 mm ²	[G] 22 mm	5.1 mm	14.7-360 bar	Steam	V
1.5-2 NPS	3-4 NPS	616 mm ²	[H3] 28 mm	6.5 mm	15-360 bar	Steam	V
2-3 NPS	3-6 NPS	908 mm ²	[J] 34 mm	7.9 mm	15-360 bar	Steam	V
2.5-3 NPS	4-6 NPS	1320 mm ²	[K] 41 mm	9.5 mm	15-360 bar	Steam	V
2.5-3 NPS	4-6 NPS	1660 mm ²	[K2] 46 mm	10.7 mm	15-360 bar	Steam	V
3-4 NPS	4-8 NPS	2120 mm ²	[L] 52 mm	12.1 mm	15-360 bar	Steam	V
3-4 NPS	6-8 NPS	2550 mm ²	[M] 57 mm	13.2 mm	15-360 bar	Steam	V
4 NPS	6-8 NPS	3110 mm ²	[N] 63 mm	14.6 mm	15-206 bar	Steam	V
4 NPS	6-8 NPS	3440 mm ²	[N2] 66.2 mm	16.7 mm	15-206 bar	Steam	V
4 NPS	6-8 NPS	4530 mm ²	[P] 76 mm	17.6 mm	15-147 bar	Steam	V
6 NPS	8 NPS	6360 mm ²	[P3] 90 mm	20.9 mm	15-115 bar	Steam	V
6 NPS	8 NPS	7080 mm ²	[Q1] 95 mm	22 mm	15-103 bar	Steam	V

6 NPS	8-10 NPS	9160 mm ²	[Q2] 108 mm	25 mm	15-93 bar	Steam	V
6 NPS	8-10 NPS	10380 mm ²	[R5] 115 mm	26.7 mm	15-83 bar	Steam	V
6 NPS	10 NPS	12470 mm ²	[R4] 126 mm	29 mm	15-75 bar	Steam	V

Design Name: 3000S NBCert # 45571

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer V 03/21/2029

Design Type

[Safety Valve] 3000S
Capacity Tests: Sec. V at National Board Testing Lab on October 7, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TAI Milano S.p.A. {TAI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	3 NPS	594 mm ²	[H] 27.5 mm	7.6 mm	1.5-80 bar	Steam	V
2-3 NPS	3-4 NPS	908 mm ²	[J] 34 mm	9.4 mm	1.5-80 bar	Steam	V
3 NPS	4 NPS	1320 mm ²	[K] 41 mm	11.3 mm	1.5-72 bar	Steam	V
3 NPS	4 NPS	1660 mm ²	[K2] 46 mm	12.7 mm	1.5-65 bar	Steam	V
3-4 NPS	4-6 NPS	2120 mm ²	[L] 52 mm	14.4 mm	1.5-80 bar	Steam	V
4 NPS	6 NPS	2550 mm ²	[M] 57 mm	15.8 mm	1.5-80 bar	Steam	V
4 NPS	6 NPS	3110 mm ²	[N] 63 mm	17.4 mm	1.5-80 bar	Steam	V
4 NPS	6 NPS	4530 mm ²	[P] 76 mm	21 mm	1.5-75 bar	Steam	V
6 NPS	8 NPS	6360 mm ²	[P3] 90 mm	24.9 mm	1.5-56.7 bar	Steam	V
6 NPS	8 NPS	7850 mm ²	[Q] 100 mm	27.6 mm	1.5-48.5 bar	Steam	V
6 NPS	8 NPS	10320 mm ²	[R1] 114.6 mm	31.7 mm	1.5-34.5 bar	Steam	V

Design Name: 3000W (Steam & Air/Gas) NBCert # 45616

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 04/12/2027

Design Type

[Safety Relief Valve] 3000W (Steam & Air/Gas)
Capacity Tests: Sec. UV at National Board Testing Lab on December 17, 2009
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.872 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TAI Milano S.p.A. {TAI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2, 3 NPS	78.5 mm ²	[D] 10 mm	2 mm	15-2900 psi	Steam	UV
1-1.8125 NPS	2, 3 NPS	78.5 mm ²	[D] 10 mm	2 mm	15-7542 psi	Air	UV

1-1.8125 NPS	2, 3 NPS	104 mm ²	[D2] 11.5 mm	2.9 mm	15-2900 psi	Steam	UV
1-1.8125 NPS	2, 3 NPS	104 mm ²	[D2] 11.5 mm	2.9 mm	15-7542 psi	Air	UV
1-1.8125 NPS	2, 3 NPS	143 mm ²	[E] 13.5 mm	4 mm	15-2900 psi	Steam	UV
1-1.8125 NPS	2, 3 NPS	143 mm ²	[E] 13.5 mm	4 mm	15-7542 psi	Air	UV
1.5-1.8125 NPS	2, 3 NPS	254 mm ²	[F] 18 mm	5.4 mm	15-2900 psi	Steam	UV
1.5-1.8125 NPS	2, 3 NPS	254 mm ²	[F] 18 mm	5.4 mm	15-5713 psi	Air	UV
1.5-2.0625 NPS	3 NPS	380 mm ²	[G] 22 mm	6.6 mm	15-2900 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	380 mm ²	[G] 22 mm	6.6 mm	15-4256 psi	Air	UV
1.5-2.5 NPS	3, 4 NPS	594 mm ²	[H] 27.5 mm	8.3 mm	15-2900 psi	Steam	UV
1.5-2.5 NPS	3, 4 NPS	594 mm ²	[H] 27.5 mm	8.3 mm	15-7540 psi	Air	UV
2-3 NPS	3, 4 NPS	908 mm ²	[J] 34 mm	10.2 mm	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	908 mm ²	[J] 34 mm	10.2 mm	15-5452 psi	Air	UV
3 NPS	4, 6 NPS	1320 mm ²	[K] 41 mm	12.3 mm	15-2567 psi	Air	UV
3 NPS	4, 6 NPS	1320 mm ²	[K] 41 mm	12.3 mm	15-2567 psi	Steam	UV
3 NPS	4, 6 NPS	1660 mm ²	[K2] 46 mm	13.8 mm	15-1685 psi	Air	UV
3 NPS	4, 6 NPS	1660 mm ²	[K2] 46 mm	13.8 mm	15-1685 psi	Steam	UV
3-4 NPS	4, 6 NPS	2120 mm ²	[L] 52 mm	15.6 mm	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	2120 mm ²	[L] 52 mm	15.6 mm	15-3741 psi	Air	UV
4 NPS	6 NPS	2550 mm ²	[M] 57 mm	17.1 mm	15-1472 psi	Air	UV
4 NPS	6 NPS	2550 mm ²	[M] 57 mm	17.1 mm	15-1472 psi	Steam	UV
4 NPS	6 NPS	3110 mm ²	[N] 63 mm	18.9 mm	15-2900 psi	Steam	UV
4 NPS	6 NPS	3110 mm ²	[N] 63 mm	18.9 mm	15-3698 psi	Air	UV
4 NPS	6 NPS	4530 mm ²	[P] 76 mm	22.8 mm	15-2291 psi	Air	UV
4 NPS	6 NPS	4530 mm ²	[P] 76 mm	22.8 mm	15-2291 psi	Steam	UV
6 NPS	8 NPS	6360 mm ²	[P3] 90 mm	27 mm	15-805 psi	Air	UV
6 NPS	8 NPS	6360 mm ²	[P3] 90 mm	27 mm	15-805 psi	Steam	UV
6 NPS	8 NPS	7850 mm ²	[Q] 100 mm	30 mm	15-657 psi	Air	UV
6 NPS	8 NPS	7850 mm ²	[Q] 100 mm	30 mm	15-657 psi	Steam	UV
6 NPS	8, 10 NPS	10315 mm ²	[R1] 114.6 mm	34.4 mm	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	10315 mm ²	[R1] 114.6 mm	34.4 mm	15-1500 psi	Steam	UV
8 NPS	10 NPS	16764 mm ²	[T1] 146.1 mm	43.9 mm	15-319 psi	Air	UV
8 NPS	10 NPS	16764 mm ²	[T1] 146.1 mm	43.9 mm	15-319 psi	Steam	UV

Design Name: Series 3000A		NBCert #	45515
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	04/12/2027	

Design Type

[Safety Relief Valve] Series 3000A

Capacity Tests: Sec. UV at National Board Testing Lab on December 16, 2009

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.875 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Initial Audible Discharge

Blowdown Characteristics: Adjustable (Single Ring)

Flow Area Configuration: Nozzle/Full Lift

Designed by: TAI Milano S.p.A. {TAI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2,3 NPS	78.5 mm ²	[D] 10 mm	1.7 mm	15-2900 psi	Steam	UV
1-2 NPS	2,3 NPS	78.5 mm ²	[D] 10 mm	1.7 mm	15-7542 psi	Air	UV
1-2 NPS	2,3 NPS	143 mm ²	[E] 13.5 mm	3.4 mm	15-2900 psi	Steam	UV
1-2 NPS	2,3 NPS	143 mm ²	[E] 13.5 mm	3.4 mm	15-7542 psi	Air	UV
1.5-2 NPS	2,3 NPS	254 mm ²	[F] 18 mm	4.5 mm	15-2900 psi	Steam	UV
1.5-2 NPS	2,3 NPS	254 mm ²	[F] 18 mm	4.5 mm	15-5947 psi	Air	UV
1.5-2.0625 NPS	3 NPS	380 mm ²	[G] 22 mm	5.5 mm	15-2900 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	380 mm ²	[G] 22 mm	5.5 mm	15-3903 psi	Air	UV
1.5-2.5 NPS	3,4 NPS	594 mm ²	[H] 27.5 mm	6.9 mm	15-2900 psi	Steam	UV
1.5-2.5 NPS	3,4 NPS	594 mm ²	[H] 27.5 mm	6.9 mm	15-7540 psi	Air	UV
2-3 NPS	3,4 NPS	908 mm ²	[J] 34 mm	8.5 mm	15-2700 psi	Air	UV
2-3 NPS	3,4 NPS	908 mm ²	[J] 34 mm	8.5 mm	15-2700 psi	Steam	UV
3 NPS	4,6 NPS	1320 mm ²	[K] 41 mm	10.3 mm	15-2221 psi	Air	UV
3 NPS	4,6 NPS	1320 mm ²	[K] 41 mm	10.3 mm	15-2221 psi	Steam	UV
3-4 NPS	4,6 NPS	1660 mm ²	[K2] 46 mm	11.5 mm	15-1562 psi	Air	UV
3-4 NPS	4,6 NPS	1660 mm ²	[K2] 46 mm	11.5 mm	15-1562 psi	Steam	UV
3-4 NPS	4,6 NPS	2120 mm ²	[L] 52 mm	13 mm	15-1499 psi	Air	UV
3-4 NPS	4,6 NPS	2120 mm ²	[L] 52 mm	13 mm	15-1499 psi	Steam	UV
4 NPS	6 NPS	2550 mm ²	[M] 57 mm	14.3 mm	15-1100 psi	Air	UV
4 NPS	6 NPS	2550 mm ²	[M] 57 mm	14.3 mm	15-1100 psi	Steam	UV
4 NPS	6 NPS	3110 mm ²	[N] 63 mm	15.8 mm	15-1580 psi	Air	UV
4 NPS	6 NPS	3110 mm ²	[N] 63 mm	15.8 mm	15-1580 psi	Steam	UV
4 NPS	6 NPS	4530 mm ²	[P] 76 mm	19 mm	15-1400 psi	Air	UV
4 NPS	6 NPS	4530 mm ²	[P] 76 mm	19 mm	15-1400 psi	Steam	UV
6 NPS	8 NPS	6360 mm ²	[P3] 90 mm	22.5 mm	15-805 psi	Air	UV
6 NPS	8 NPS	6360 mm ²	[P3] 90 mm	22.5 mm	15-805 psi	Steam	UV
6 NPS	8 NPS	7850 mm ²	[Q] 100 mm	25 mm	15-657 psi	Air	UV
6 NPS	8 NPS	7850 mm ²	[Q] 100 mm	25 mm	15-657 psi	Steam	UV
6 NPS	8,10 NPS	10315 mm ²	[R1] 114.6 mm	28.7 mm	15-300 psi	Air	UV
6 NPS	8,10 NPS	10315 mm ²	[R1] 114.6 mm	28.7 mm	15-300 psi	Steam	UV
8 NPS	10 NPS	16765 mm ²	[T1] 146.1 mm	36.5 mm	15-300 psi	Air	UV
8 NPS	10 NPS	16765 mm ²	[T1] 146.1 mm	36.5 mm	15-300 psi	Steam	UV

Design Name: Series 3000W		NBCert #	45526
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	04/12/2027	
Design Type			
[Relief Valve] Series 3000W Capacity Tests: Sec. UV at National Board Testing Lab on December 16, 2009 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.788 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: TAI Milano S.p.A. {TAI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2, 3 NPS	78.5 mm ²	[D] 10 mm	3.7 mm	1-520 bar	Water	UV
1-1.8125 NPS	2-3 NPS	104 mm ²	[D2] 11.5 mm	4.2 mm	1-520 bar	Water	UV
1-1.8125 NPS	2, 3 NPS	143 mm ²	[E] 13.5 mm	5.1 mm	1-520 bar	Water	UV
1.5-1.8125 NPS	2, 3 NPS	254 mm ²	[F] 18 mm	6.7 mm	1-394 bar	Water	UV
1.5-2.0625 NPS	3 NPS	380 mm ²	[G] 22 mm	8.2 mm	1-293.5 bar	Water	UV
1.5-2.5 NPS	3, 4 NPS	594 mm ²	[H] 27.5 mm	10.2 mm	1-520 bar	Water	UV
2-3 NPS	3, 4 NPS	908 mm ²	[J] 34 mm	12.6 mm	1-376.6 bar	Water	UV
3 NPS	4, 6 NPS	1320 mm ²	[K] 41 mm	15.2 mm	1-177 bar	Water	UV
3 NPS	4, 6 NPS	1660 mm ²	[K2] 46 mm	17 mm	1-116.2 bar	Water	UV
3-4 NPS	4, 6 NPS	2120 mm ²	[L] 52 mm	19.3 mm	1-258 bar	Water	UV
4 NPS	6 NPS	2550 mm ²	[M] 57 mm	21.1 mm	1-101.5 bar	Water	UV
4 NPS	6 NPS	3110 mm ²	[N] 63 mm	23.3 mm	1-255 bar	Water	UV
4 NPS	6 NPS	4530 mm ²	[P] 76 mm	28.2 mm	1-158 bar	Water	UV
6 NPS	8 NPS	6360 mm ²	[P3] 90 mm	33.3 mm	1-55.5 bar	Water	UV
6 NPS	8 NPS	7850 mm ²	[Q] 100 mm	37 mm	1-45.3 bar	Water	UV
6 NPS	8,10 NPS	10315 mm ²	[R1] 114.6 mm	42.5 mm	1-103.4 bar	Water	UV
8 NPS	10 NPS	16764 mm ²	[T1] 146.1 mm	54.1 mm	1-22 bar	Water	UV

Design Name: Series 4000		NBCert #	45537
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	04/14/2027	
Design Type			
[Safety Relief Valve] Series 4000 Capacity Tests: Sec. UV at National Board Testing Lab on December 16, 2009 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.960 SCFM/PSIA; (alternate medium): 5.510 PPH/PSIA Media - Test: Air/Gas; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: TAI Milano S.p.A. {TAI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1, 1.5 NPS	78.5 mm ²	[D] 10 mm	2.5 mm	15-2900 psi	Steam	UV
0.5-1 NPS	1, 1.5 NPS	78.5 mm ²	[D] 10 mm	2.5 mm	15-5176 psi	Air	UV

Design Name:	Series 4000W	NBCert #	45548
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 07/18/2028

Design Type

[Relief Valve] Series 4000W
Capacity Tests: Sec. UV at National Board Testing Lab on April 14, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.390 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TAI Milano S.p.A. {TAI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	78.5 mm ²	[D] 10 mm	1.75 mm	15-3402 psi	Water	UV

Design Name:	Series 9000 / 60, 70, 90 pilots Steam/Air/Gas	NBCert #	45559
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/04/2028

Design Type

[Pilot Operated Pressure Relief Valve] Series 9000 / 60, 70, 90 pilots Steam/Air/Gas
Capacity Tests: Sec. UV at National Board Testing Lab on April 13, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.843 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: TAI Milano S.p.A. {TAI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	254 mm ²	[F] 18 mm		1-200 bar	Steam	UV
1-1.5 NPS	2 NPS	254 mm ²	[F] 18 mm		1-425 bar	Air	UV
1.5-2 NPS	2, 3 NPS	380 mm ²	[G] 22 mm		3-200 bar	Steam	UV
1.5-2 NPS	2, 3 NPS	380 mm ²	[G] 22 mm		3-425 bar	Air	UV
1.5-2 NPS	3 NPS	594 mm ²	[H] 27.5 mm		4-200 bar	Steam	UV
1.5-2 NPS	3 NPS	594 mm ²	[H] 27.5 mm		4-425 bar	Air	UV
1.5-2 NPS	3 NPS	908 mm ²	[J] 34 mm		1-274 bar	Air	UV
1.5-2 NPS	3 NPS	908 mm ²	[J] 34 mm		1-200 bar	Steam	UV
2-3 NPS	3, 4 NPS	1660 mm ²	[K2] 46 mm		1-200 bar	Steam	UV
2-3 NPS	3, 4 NPS	1660 mm ²	[K2] 46 mm		1-255 bar	Air	UV
3-4 NPS	4, 6 NPS	2550 mm ²	[M] 57 mm		1-200 bar	Steam	UV

3-4 NPS	4, 6 NPS	2550 mm ²	[M] 57 mm	1-380 bar	Air	UV
4 NPS	6 NPS	3110 mm ²	[N] 63 mm	155-310 bar	Air	UV
4 NPS	6 NPS	3110 mm ²	[N] 63 mm	155-200 bar	Steam	UV
4 NPS	6 NPS	4530 mm ²	[P] 76 mm	1-200 bar	Steam	UV
4 NPS	6 NPS	4530 mm ²	[P] 76 mm	1-212 bar	Air	UV
4 NPS	6 NPS	7090 mm ²	[Q1] 95 mm	1-135 bar	Steam	UV
4 NPS	6 NPS	7090 mm ²	[Q1] 95 mm	1-135 bar	Air	UV
6 NPS	8 NPS	11300 mm ²	[R] 120 mm	1-148 bar	Air	UV
6 NPS	8 NPS	11300 mm ²	[R] 120 mm	1-148 bar	Steam	UV
6 NPS	8 NPS	14100 mm ²	[R3] 134 mm	1-118 bar	Steam	UV
6 NPS	8 NPS	14100 mm ²	[R3] 134 mm	1-118 bar	Air	UV
8 NPS	10 NPS	22700 mm ²	[T2] 170 mm	1-102 bar	Steam	UV
8 NPS	10 NPS	22700 mm ²	[T2] 170 mm	1-102 bar	Air	UV
10 NPS	14 NPS	38000 mm ²	[V] 220 mm	1-70 bar	Air	UV
10 NPS	14 NPS	38000 mm ²	[V] 220 mm	1-70 bar	Steam	UV
12 NPS	16 NPS	49000 mm ²	[V2] 250 mm	1-51 bar	Steam	UV
12 NPS	16 NPS	49000 mm ²	[V2] 250 mm	1-51 bar	Air	UV

Design Name: Series 9000 / 603,701, 703 Pilots (Air/Gas & Liquid) NBCert # 45627

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/15/2028

Design Type

[Pilot Operated Pressure Relief Valve] Series 9000 / 603,701, 703 Pilots (Air/Gas & Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on November 10, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.843 Unitless; (alternate medium): 0.655 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Initial Audible Discharge; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TAI Milano S.p.A. {TAI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	254 mm ²	[F] 18 mm	5.9 mm	1-425 bar	Water	UV
1.5-2 NPS	2, 3 NPS	380 mm ²	[G] 22 mm	7.2 mm	3-425 bar	Water	UV
1.5-2 NPS	3 NPS	594 mm ²	[H] 27.5 mm	9 mm	4-425 bar	Water	UV
1.5-2 NPS	3 NPS	908 mm ²	[J] 34 mm	11.1 mm	1-274 bar	Water	UV
2-3 NPS	3, 4 NPS	1660 mm ²	[K2] 46 mm	15.1 mm	1-255 bar	Water	UV
3-4 NPS	4, 6 NPS	2550 mm ²	[M] 57 mm	18.7 mm	1-380 bar	Water	UV
4-4 NPS	6 NPS	3110 mm ²	[N] 63 mm	20.7 mm	155-310 bar	Water	UV
4-4 NPS	6 NPS	4530 mm ²	[P] 76 mm	24.9 mm	1-212 bar	Water	UV
4-4 NPS	6 NPS	7090 mm ²	[Q1] 95 mm	31.2 mm	1-135 bar	Water	UV
6-6 NPS	8 NPS	11300 mm ²	[R] 120 mm	39.4 mm	1-148 bar	Water	UV
6-6 NPS	8 NPS	14100 mm ²	[R3] 134 mm	44 mm	1-118 bar	Water	UV
8-8 NPS	10 NPS	22700 mm ²	[T2] 170 mm	55.8 mm	1-102 bar	Water	UV

10-10 NPS	14 NPS	38000 mm²	[V] 220 mm	72.2 mm	1-70 bar	Water	UV
12 NPS	16 NPS	49000 mm²	[V2] 250 mm	82.1 mm	1-51 bar	Water	UV

Design Name:	Series 9000 / 70, 603,701, 703 Pilots (Liquids)	NBCert #	45560
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/04/2028

Design Type

[Pilot Operated Pressure Relief Valve] Series 9000 / 70, 603,701, 703 Pilots (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on April 16, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.655 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TAI Milano S.p.A. {TAI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	254 mm²	[F] 18 mm	5.9 mm	1-425 bar	Water	UV
1.5-2 NPS	2, 3 NPS	380 mm²	[G] 22 mm	7.2 mm	3-425 bar	Water	UV
1.5-2 NPS	3 NPS	594 mm²	[H] 27.5 mm	9 mm	4-425 bar	Water	UV
1.5-2 NPS	3 NPS	908 mm²	[J] 34 mm	11.1 mm	1-274 bar	Water	UV
2-3 NPS	3, 4 NPS	1660 mm²	[K2] 46 mm	15.1 mm	1-255 bar	Water	UV
3-4 NPS	4, 6 NPS	2550 mm²	[M] 57 mm	18.7 mm	1-380 bar	Water	UV
4-4 NPS	6 NPS	3110 mm²	[N] 63 mm	20.7 mm	155-310 bar	Water	UV
4-4 NPS	6 NPS	4530 mm²	[P] 76 mm	24.9 mm	1-212 bar	Water	UV
4-4 NPS	6 NPS	7090 mm²	[Q1] 95 mm	31.2 mm	1-135 bar	Water	UV
6-6 NPS	8 NPS	11300 mm²	[R] 120 mm	39.4 mm	1-148 bar	Water	UV
6-6 NPS	8 NPS	14100 mm²	[R3] 134 mm	44 mm	1-118 bar	Water	UV
8-8 NPS	10 NPS	22700 mm²	[T2] 170 mm	55.8 mm	1-102 bar	Water	UV
10-10 NPS	14 NPS	38000 mm²	[V] 220 mm	72.2 mm	1-70 bar	Water	UV
12 NPS	16 NPS	49000 in²	[V2] 250 mm	82.1 mm	1-51 bar	Water	UV

Design Name:	Series 9000 R / 60, 70, 90 pilots, Steam/Air/Gas	NBCert #	45582
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/04/2028

Design Type

[Pilot Operated Pressure Relief Valve] Series 9000 R / 60, 70, 90 pilots, Steam/Air/Gas
Capacity Tests: Sec. UV at National Board Testing Lab on April 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Annulus
Designed by: TAI Milano S.p.A. {TAI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	143 mm ²	[E] 18 mm	3.8 mm	1-200 bar	Steam	UV
1-1.5 NPS	2 NPS	78.5 mm ²	[D] 18 mm	2.1 mm	1-425 bar	Air	UV
1-1.5 NPS	2 NPS	143 mm ²	[E] 18 mm	3.8 mm	1-425 bar	Air	UV
1-1.5 NPS	2 NPS	78.5 mm ²	[D] 18 mm	2.1 mm	1-200 psi	Steam	UV
1.5 NPS	3 NPS	380 mm ²	[G] 27.5 mm	6.6 mm	5-200 bar	Steam	UV
1.5 NPS	3 NPS	380 mm ²	[G] 27.5 mm	6.6 mm	5-425 bar	Air	UV
1.5-2 NPS	3 NPS	380 mm ²	[G] 34 mm	5.4 mm	1-200 bar	Steam	UV
1.5-2 NPS	3 NPS	594 mm ²	[H] 34 mm	8.3 mm	1-200 bar	Steam	UV
1.5-2 NPS	3 NPS	380 mm ²	[G] 34 mm	5.4 mm	1-255 bar	Air	UV
1.5-2 NPS	3 NPS	594 mm ²	[H] 34 mm	8.3 mm	1-255 bar	Air	UV
2-3 NPS	3, 4 NPS	1320 mm ²	[K] 46 mm	13.3 mm	1-200 bar	Steam	UV
2-3 NPS	3, 4 NPS	1320 mm ²	[K] 46 mm	13.3 mm	1-320 bar	Air	UV
3 NPS	4 NPS	908 mm ²	[J] 46 mm	9.5 mm	1-200 bar	Steam	UV
3 NPS	4 NPS	908 mm ²	[J] 46 mm	9.5 mm	1-425 bar	Air	UV
3 NPS	4 NPS	1660 mm ²	[K2] 57 mm	13.9 mm	2.5-102 bar	Air	UV
3 NPS	4 NPS	1660 mm ²	[K2] 57 mm	13.9 mm	2.5-102 bar	Steam	UV
3 NPS	4 NPS	908 mm ²	[J] 57 mm	7.8 mm	2.5-102 bar	Air	UV
3 NPS	4 NPS	908 mm ²	[J] 57 mm	7.8 mm	2.5-102 bar	Steam	UV
3-4 NPS	4, 6 NPS	1320 mm ²	[K] 57 mm	11.2 mm	2.5-200 bar	Steam	UV
3-4 NPS	4, 6 NPS	2120 mm ²	[L] 57 mm	17 mm	1-200 bar	Steam	UV
3-4 NPS	4, 6 NPS	1320 mm ²	[K] 57 mm	11.2 mm	2.5-425 bar	Air	UV
3-4 NPS	4, 6 NPS	2120 mm ²	[L] 57 mm	17 mm	1-425 bar	Air	UV
4 NPS	6 NPS	2120 mm ²	[L] 76 mm	13.6 mm	1-200 bar	Steam	UV
4 NPS	6 NPS	2550 mm ²	[M] 76 mm	16.3 mm	1-200 bar	Steam	UV
4 NPS	6 NPS	1320 mm ²	[K] 76 mm	8.6 mm	1-200 bar	Steam	UV
4 NPS	6 NPS	2120 mm ²	[L] 76 mm	13.6 mm	1-255 bar	Air	UV
4 NPS	6 NPS	2550 mm ²	[M] 76 mm	16.3 mm	1-255 bar	Air	UV
4 NPS	6 NPS	1320 mm ²	[K] 76 mm	8.6 mm	1-255 bar	Air	UV
4 NPS	6 NPS	3110 mm ²	[N] 76 mm	19.5 mm	1-310 bar	Air	UV
4 NPS	6 NPS	3110 mm ²	[N] 76 mm	19.5 mm	1-200 bar	Steam	UV
4 NPS	6 NPS	5670 mm ²	[P2] 95 mm	27.7 mm	1-153 bar	Steam	UV
4 NPS	6 NPS	5670 mm ²	[P2] 95 mm	27.7 mm	1-153 bar	Air	UV
6 NPS	8 NPS	9160 mm ²	[Q2] 120 mm	33.3 mm	1-153 bar	Steam	UV
6 NPS	8 NPS	9160 mm ²	[Q2] 120 mm	33.3 mm	1-153 bar	Air	UV
6 NPS	8 NPS	7850 mm ²	[Q] 120 mm	29.4 mm	1-210 bar	Air	UV
6 NPS	8 NPS	7850 mm ²	[Q] 120 mm	29.4 mm	1-210 bar	Steam	UV
8 NPS	10 NPS	18400 mm ²	[T] 170 mm	49.9 mm	1-102 bar	Steam	UV
8 NPS	10 NPS	18400 mm ²	[T] 170 mm	49.9 mm	1-102 bar	Air	UV
10 NPS	14 NPS	31400 mm ²	[U] 220 mm	65.5 mm	1-70 bar	Air	UV

10 NPS	14 NPS	31400 mm ²	[U] 220 mm	65.5 mm	1-70 bar	Steam	UV
--------	--------	-----------------------	------------	---------	----------	-------	----

Design Name:	Series 9000 R / 603, 701, 703 Pilots (Air/Gas & Liquid)	NBCert #	45638
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 03/15/2028

Design Type

[Pilot Operated Pressure Relief Valve] Series 9000 R / 603, 701, 703 Pilots (Air/Gas & Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on November 10, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless; (alternate medium): 0.654 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Initial Audible Discharge; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Annulus
Designed by: TAI Milano S.p.A. {TAI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	78.5 mm ²	[D] 18 mm	2.1 mm	1-425 bar	Water	UV
1-1.5 NPS	2 NPS	143 mm ²	[E] 18 mm	3.8 mm	1-425 bar	Water	UV
1.5-1.5 NPS	3 NPS	380 mm ²	[G] 27.5 mm	6.6 mm	1-255 bar	Water	UV
1.5-2 NPS	3 NPS	380 mm ²	[G] 34 mm	5.4 mm	1-425 bar	Water	UV
1.5-2 NPS	3 NPS	594 mm ²	[H] 34 mm	8.3 mm	1-255 bar	Water	UV
2-3 NPS	3, 4 NPS	1320 mm ²	[K] 46 mm	13.3 mm	1-320 bar	Water	UV
3-3 NPS	4 NPS	908 mm ²	[J] 46 mm	9.5 mm	1-425 bar	Water	UV
3-3 NPS	4 NPS	1660 mm ²	[K2] 57 mm	13.9 mm	2.5-102 bar	Water	UV
3-3 NPS	4 NPS	908 mm ²	[J] 57 mm	7.8 mm	2.5-102 bar	Water	UV
3-4 NPS	4, 6 NPS	1320 mm ²	[K] 57 mm	11.2 mm	2.5-425 bar	Water	UV
3-4 NPS	4, 6 NPS	2120 mm ²	[L] 57 mm	17 mm	1-425 bar	Water	UV
4-4 NPS	6 NPS	2120 mm ²	[L] 76 mm	13.6 mm	1-255 bar	Water	UV
4-4 NPS	6 NPS	2550 mm ²	[M] 76 mm	16.3 mm	1-255 bar	Water	UV
4-4 NPS	6 NPS	1320 mm ²	[K] 76 mm	8.6 mm	1-255 bar	Air	UV
4-4 NPS	6 NPS	3110 mm ²	[N] 76 mm	19.5 mm	1-310 bar	Water	UV
4-4 NPS	6 NPS	5670 mm ²	[P2] 95 mm	27.7 mm	1-153 bar	Water	UV
6-6 NPS	8 NPS	9160 mm ²	[Q2] 120 mm	33.3 mm	1-153 bar	Water	UV
6-6 NPS	8 NPS	7850 mm ²	[Q] 120 mm	29.4 mm	1-210 bar	Water	UV
8-8 NPS	10 NPS	18400 mm ²	[T] 170 mm	49.9 mm	1-102 bar	Water	UV
10-10 NPS	14 NPS	31400 mm ²	[U] 220 mm	65.5 mm	1-70 bar	Water	UV

Design Name:	Series 9000 R / 70, 603, 701, 703 Pilots (Liquid)	NBCert #	45593
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/04/2028

Design Type

[Pilot Operated Pressure Relief Valve] Series 9000 R / 70, 603, 701, 703 Pilots (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on November 22, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.654 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Annulus
Designed by: TAI Milano S.p.A. {TAI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	78.5 mm ²	[D] 18 mm	2.1 mm	1-425 bar	Water	UV
1-1.5 NPS	2 NPS	143 mm ²	[E] 18 mm	3.8 mm	1-425 bar	Water	UV
1.5-1.5 NPS	3 NPS	380 mm ²	[G] 27.5 mm	6.6 mm	1-255 bar	Water	UV
1.5-2 NPS	3 NPS	380 mm ²	[G] 34 mm	5.4 mm	1-425 bar	Water	UV
1.5-2 NPS	3 NPS	594 mm ²	[H] 34 mm	8.3 mm	1-255 bar	Water	UV
2-3 NPS	3, 4 NPS	1320 mm ²	[K] 46 mm	13.3 mm	1-320 bar	Water	UV
3-3 NPS	4 NPS	908 mm ²	[J] 46 mm	9.5 mm	1-425 bar	Water	UV
3-3 NPS	4 NPS	1660 mm ²	[K2] 57 mm	13.9 mm	2.5-102 bar	Water	UV
3-3 NPS	4 NPS	908 mm ²	[J] 57 mm	7.8 mm	2.5-102 bar	Water	UV
3-4 NPS	4, 6 NPS	1320 mm ²	[K] 57 mm	11.2 mm	2.5-425 bar	Water	UV
3-4 NPS	4, 6 NPS	2120 mm ²	[L] 57 mm	17 mm	1-425 bar	Water	UV
4-4 NPS	6 NPS	2120 mm ²	[L] 76 mm	13.6 mm	1-255 bar	Water	UV
4-4 NPS	6 NPS	2550 mm ²	[M] 76 mm	16.3 mm	1-255 bar	Water	UV
4-4 NPS	6 NPS	1320 mm ²	[K] 76 mm	8.6 mm	1-255 bar	Air	UV
4-4 NPS	6 NPS	3110 mm ²	[N] 76 mm	19.5 mm	1-310 bar	Water	UV
4-4 NPS	6 NPS	5670 mm ²	[P2] 95 mm	27.7 mm	1-153 bar	Water	UV
6-6 NPS	8 NPS	9160 mm ²	[Q2] 120 mm	33.3 mm	1-153 bar	Water	UV
6-6 NPS	8 NPS	7850 mm ²	[Q] 120 mm	29.4 mm	1-210 bar	Water	UV
8-8 NPS	10 NPS	18400 mm ²	[T] 170 mm	49.9 mm	1-102 bar	Water	UV
10-10 NPS	14 NPS	31400 mm ²	[U] 220 mm	65.5 mm	1-70 bar	Water	UV

Target Rock Business Unit of Curtiss-Wright Flow Control Corporation (TRC)

E. Farmingdale, NY 11735United States

This Company Manufactures or Assembles:

Design Name: 2VRES-S-1			NBCert # 55280	
Manufacturer/Assembler		Designators		Expiration Date
Manufacturer		NV		10/25/2030

Design Type

[Vacuum Relief Valve] 2VRES-S-1
Capacity Tests: Sec. NV at National Board Testing Lab on August 24, 1993
Method of Establishing Relieving Capacity: Flow Capacity, Single Valve Method
Certified Value: 61.000 SCFM
Media - Test: Air/Gas; Certified: Air, Gas

Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	Top NPS	0.478 in ²	1.75 in		1-0 psi	Air	NV

Design Name: 67F NBCert # 55213

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer NV 03/01/2029

Design Type

[Pilot Operated Pressure Relief Valve] 67F
Capacity Tests: Sec. NV at Ohio State University (Robinson Laboratory) on November 20, 1967
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
6 NPS	10 NPS	12.56 in ²	4 in	2.05 in	800-1200 psi	Steam	NV
6 NPS	10 NPS	18.89 in ²	4.905 in	2.52 in	800-1200 psi	Steam	NV
6 NPS	10 NPS	18.93 in ²	4.91 in	2.58 in	1000-1200 psi	Steam	NV
6 NPS	10 NPS	19.16 in ²	4.94 in	2.58 in	1000-1200 psi	Steam	NV
6 NPS	10 NPS	19.87 in ²	5.03 in	2.58 in	1000-1200 psi	Steam	NV
6 NPS	10 NPS	20.62 in ²	5.125 in	2.78 in	1000-1200 psi	Steam	NV

Design Name: 69C, 0569C-001 NBCert # 55224

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer NV 10/07/2027

Design Type

[Pilot Operated Pressure Relief Valve] 69C, 0569C-001
Capacity Tests: Sec. NV at Ohio State University (Robinson Laboratory) on August 17, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.742 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
6 NPS	6 NPS	3.51 in ²	2.443 in	0.98 in	2250-2485 psi	Steam	NV

Design Name:	6AB (Class 1,2 & 3)	NBCert #	55099
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV	03/01/2029

Design Type

[Safety Valve] 6AB (Class 1,2 & 3)
Capacity Tests: Sec. NV at National Board Testing Lab (Picaway) on October 22, 1981
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.769 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
6 NPS	10 NPS	17.34 in ²	4.7 in	1.45 in	900-1400 psi	Steam	NV
6 NPS	8 NPS	18.19 in ²	4.812 in	1.444 in	900-1400 psi	Steam	NV

Design Name:	6AC (Class 1,2 & 3)	NBCert #	55101
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV	03/01/2029

Design Type

[Safety Valve] 6AC (Class 1,2 & 3)
Capacity Tests: Sec. NV, UV at National Board Testing Lab (Picaway) on October 22, 1981
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 4.732 PPH/PSIA; (alternate medium): 1.684 SCFM/PSIA
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-3 NPS	1 - 4 NPS	0.11 in ²	0.375 in	0.118 in	15-2900 psi	Air	NV
0.75-3 NPS	1 - 4 NPS	0.11 in ²	0.375 in	0.118 in	15-2900 psi	Steam	NV

Design Name:	6AD, Liquids	NBCert #	55291
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV	07/10/2030

Design Type

[Safety Relief Valve] 6AD, Liquids
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3 at unknown lab on June 22, 1983
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.080 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.11 in ²	0.375 in	0.125 in	50-3000 psi	Water	NV
0.75-1 NPS	1 NPS	0.11 in ²	0.375 in	0.125 in	50-3000 psi	Water	UV

Design Name: 6AH (Class 2 & 3) NBCert # 55156

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV	03/01/2029

Design Type

[Safety Relief Valve] 6AH (Class 2 & 3)
Capacity Tests: Sec. NV at National Board Testing Lab (Picaway) on June 17, 1982
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 6.670 PPH/PSIA; (alternate medium): 2.370 SCFM/PSIA
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.2485 in ²	0.5625 in	0.178 in	100-160 psi	Air	NV
0.75 NPS	1 NPS	0.2485 in ²	0.5625 in	0.178 in	100-160 psi	Steam	NV

Design Name: 6AK (78D016 Class 1, 2 & 3) NBCert # 55167

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV	03/01/2029

Design Type

[Safety Relief Valve] 6AK (78D016 Class 1, 2 & 3)
Capacity Tests: Sec. NV at National Board Testing Lab (Picaway) on October 6, 1982
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value: 1475.0 SCFM
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	0.502 in ²	0.8 in	0.21 in	275-275 psi	Air	NV

Design Name: 6AM NBCert # 55347

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV	10/25/2030

Design Type

[Safety Relief Valve] 6AM
Capacity Tests: Sec. NV at National Board Testing Lab on June 21, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.725 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.307 in ²	0.625 in	0.21 in	60-3000 psi	Water	NV

Design Name: 6AN NBCert # 55369

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer NV 10/25/2030

Design Type

[Safety Relief Valve] 6AN
Capacity Tests: Sec. NV at National Board Testing Lab on June 20, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.609 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-3 NPS	2 - 4 NPS	0.785 in ²	1 in	0.33 in	40-3000 psi	Water	NV

Design Name: 6AO, 93R-024 NBCert # 55325

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer NV 10/25/2030

Design Type

[Safety Relief Valve] 6AO, 93R-024
Capacity Tests: Sec. NV at National Board Testing Lab on June 21, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.422 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
6 NPS	10 NPS	18.67 in ²	4.876 in	1.125 in	30-3000 psi	Water	NV

Design Name: 6AR NBCert # 55303

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer NV 10/25/2030

Design Type

[Safety Relief Valve] 6AR
Capacity Tests: Sec. NV at National Board Testing Lab (Picaway) on August 29, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.431 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
6 NPS	8 NPS	9.32 in ²	4.3 in	0.69 in	30-150 psi	Water	NV

Design Name: 6AS	NBCert # 55314
------------------	----------------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer	NV	10/25/2030
--------------	----	------------

Design Type

[Safety Relief Valve] 6AS
Capacity Tests: Sec. NV at National Board Testing Lab on August 29, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.445 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS	4 NPS	3.768 in ²	2.438 in	0.49 in	50-150 psi	Water	NV

Design Name: 6AU	NBCert # 55381
------------------	----------------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer	NV	01/25/2027
--------------	----	------------

Design Type

[Relief Valve] 6AU
Capacity Tests: Sec. NV, UV at National Board Testing Lab on December 1, 1999
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.410 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 - 2.5 NPS	0.049 in ²	0.25 in		50-3000 psi	Water	NV

Design Name: 6AV	NBCert # 55392
------------------	----------------

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer	NV	09/27/2030
--------------	----	------------

Design Type

[Safety Relief Valve] 6AV
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3 at National Board Testing Lab on March 9, 2000
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.791 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
8 NPS	10 NPS	18.47 in ²	4.85 in	1.45 in	1100-1250 psi	Steam	NV

Design Name: 6AW (98V-005-3) NBCert # 55415

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer NV 07/07/2027

Design Type

[Safety Relief Valve] 6AW (98V-005-3)
Capacity Tests: Sec. NV, -Class 3 at National Board Testing Lab on June 9, 2000
Method of Establishing Relieving Capacity: Flow Capacity, Single Valve Method
Certified Value: 0.617 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.196 in ²	0.5 in	0.199 in	1544-1544 psi	Water	NV

Design Name: 6AX (98V-005-2) NBCert # 55426

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer NV 06/09/2027

Design Type

[Safety Relief Valve] 6AX (98V-005-2)
Capacity Tests: Sec. NV at National Board Testing Lab on June 9, 2000
Method of Establishing Relieving Capacity: Flow Capacity, Single Valve Method
Certified Value: 794.00 SCFM
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2.5 NPS	0.196 in ²	0.5 in	0.166 in	219-219 psi	Air	NV

Design Name: 6AY (97N-006) NBCert # 55437

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer NV 06/09/2027

Design Type

[Safety Relief Valve] 6AY (97N-006)
Capacity Tests: Sec. NV, -Class 3 at National Board Testing Lab on June 9, 2000
Method of Establishing Relieving Capacity: Flow Capacity, Single Valve Method
Certified Value:257.00 GPM
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 NPS	6 NPS	4.987 in ²	2.52 in	0.8 in	3-0 psi	Water	NV

Design Name: 6AZ (97N-014) NBCert # 55505

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

NV

08/01/2027

Design Type

[Safety Relief Valve] 6AZ (97N-014)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3 at National Board Testing Lab on July 14, 2000
Method of Establishing Relieving Capacity: Flow Capacity, Single Valve Method
Certified Value:673.00 SCFM
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	2.4 in ²	1.75 in	0.685 in	8-0 psi	Air	NV

Design Name: 6BA (97N-016) NBCert # 55493

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

NV

11/03/2027

Design Type

[Vacuum Relief Valve] 6BA (97N-016)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3 at National Board Testing Lab on November 3, 2000
Method of Establishing Relieving Capacity: Flow Capacity, Single Valve Method
Certified Value:1155.0 SCFM
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 NPS	4 NPS	12.75 in ²	4.25 in	1.5 in	0.25-0 psi	Air	NV

Design Name: 6BB NBCert # 55516

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

NV

02/13/2029

Design Type

[Vacuum Relief Valve] 6BB
Capacity Tests: Sec. NV at National Board Testing Lab on January 30, 2001
Method of Establishing Relieving Capacity: Flow Capacity, Single Valve Method
Certified Value: 516.00 SCFM
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 NPS	4 NPS	11.04 in ²	3.75 in		0.2-0 psi	Air	NV

Design Name: 6BC NBCert # 55527

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

NV

10/31/2025

Design Type

[Safety Relief Valve] 6BC
Capacity Tests: Sec. NV at National Board Testing Lab on October 31, 2003
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.782 SCFM/PSIA; (alternate medium): 2.197 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.049 in ²	0.25 in	0.083 in	25-1500 psi	Steam	NV
0.75 NPS	1 NPS	0.049 in ²	0.25 in	0.083 in	25-3000 psi	Air	NV

Design Name: 6BD NBCert # 55538

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

NV

03/20/2026

Design Type

[Safety Valve] 6BD
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3 at National Board Testing Lab on February 20, 2009
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.722 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
6 NPS	10 NPS	17.34 in ²	4.7 in	1.18 in	1100-1350 psi	Steam	NV

Design Name: 6BE (08U-007) NBCert # 55549

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

NV

05/27/2029

Design Type

[Vacuum Relief Valve] 6BE (08U-007)
Capacity Tests: Sec. NV, -Class 3 at National Board Testing Lab on May 27, 2011
Method of Establishing Relieving Capacity: Flow Capacity, Single Valve Method
Certified Value:91.000 SCFM
Media - ; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	1.5 NPS	1.41 in ²	1.34 in	0.37 in	-0.3 psi	Air	NV

Design Name: 6BF (08U-017) NBCert # 55550

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

NV

05/05/2029

Design Type

[Vacuum Relief Valve] 6BF (08U-017)
Capacity Tests: Sec. NV, -Class 3 at National Board Testing Lab on May 5, 2011
Method of Establishing Relieving Capacity: Flow Capacity, Single Valve Method
Certified Value:151.00 SCFM
Media - ; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	1.227 in ²	1.75 in	0.51 in	-3 psi	Air	NV

Design Name: 6BG (08U-011) NBCert # 55561

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

NV

07/08/2029

Design Type

[Vacuum Relief Valve] 6BG (08U-011)
Capacity Tests: Sec. NV, -Class 3 at National Board Testing Lab on July 8, 2011
Method of Establishing Relieving Capacity: Flow Capacity, Single Valve Method
Certified Value:1051.0 SCFM
Media - ; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 NPS		12.7 in ²	4.03 in	1.5 in	-0.3 psi	Air	NV

Design Name: 6BH NBCert # 55123

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

NV

07/14/2026

Design Type

[Vacuum Relief Valve] 6BH
Capacity Tests: Sec. NV, -Class 2, -Class 3 at National Board Testing Lab on July 14, 2014
Method of Establishing Relieving Capacity: Flow Capacity, Single Valve Method
Certified Value: 632.00 SCFM
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
	4 in	5.5 in ²	4.25 in	0.7 in	-0.3 psi	Air	NV

Design Name: 7567F NBCert # 55246

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

NV

03/01/2029

Design Type

[Pilot Operated Pressure Relief Valve] 7567F
Capacity Tests: Sec. NV at Ohio State University (Robinson Laboratory) on November 20, 1967
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
6 NPS	10 NPS	12.56 in ²	4 in	2.05 in	800-1200 psi	Steam	NV
6 NPS	10 NPS	18.89 in ²	4.905 in	2.52 in	800-1200 psi	Steam	NV
6 NPS	10 NPS	18.93 in ²	4.91 in	2.58 in	1000-1200 psi	Steam	NV
6 NPS	10 NPS	19.16 in ²	4.94 in	2.58 in	1000-1200 psi	Steam	NV
6 NPS	10 NPS	19.87 in ²	5.03 in	2.58 in	1000-1200 psi	Steam	NV
6 NPS	10 NPS	20.62 in ²	5.125 in	2.78 in	1000-1200 psi	Steam	NV

Design Name: 76A NBCert # 55235

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

NV

03/01/2029

Design Type

[Safety Valve] 76A
Capacity Tests: Sec. NV at National Board Testing Lab (Picaway) on June 23, 1977
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.778 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS	4 NPS	2.048 in ²	1.615 in	0.53 in	50-1600 psi	Steam	NV

4 NPS	6 NPS	3.464 in ²	2.1 in	0.69 in	50-1600 psi	Steam	NV
6 NPS	10 NPS	15.904 in ²	4.5 in	1.475 in	50-1600 psi	Steam	NV

Design Name:	93R-022A	NBCert #	55370
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV 03/01/2029

Design Type

[Safety Relief Valve] 93R-022A
Capacity Tests: Sec. NV at National Board Testing Lab on December 5, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 7.540 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Target Rock Business Unit of Curtiss-Wright Flow Control Corporation {TRC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	3 NPS	0.607 in ²	1.33 in	0.145 in	15-1000 psi	Water	NV

Taylor Valve Technology, Inc (TTS)

Nameplate Abbreviation: Taylor Valve

Oklahoma City, OK 73128United States

This Company Manufactures or Assembles:

Design Name:	1500 Series (Air)	NBCert #	02530
--------------	-------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 04/17/2030

Design Type

[Safety Relief Valve] 1500 Series (Air)
Capacity Tests: Sec. UV at National Board Testing Lab {unknown test date}
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.863 Unitless
Media - Test: Air/Gas; Certified: Air
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75 - 1 NPS	0.058 in ²	[C] 0.272 in	0.091 in	15-8000 psi	Air	UV
0.75-1.5 NPS	0.75 - 1.5 NPS	0.129 in ²	[D] 0.405 in	0.135 in	15-8000 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.23 in ²	[E] 0.541 in	0.18 in	15-8000 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.366 in ²	[F] 0.683 in	0.228 in	15-6400 psi	Air	UV
1.5-2 NPS	2 NPS	0.59 in ²	[G] 0.867 in	0.289 in	15-1500 psi	Air	UV

Design Name:	1500 Series (Liquid)	NBCert #	02541
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	04/17/2030

Design Type

[Relief Valve] 1500 Series (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab {unknown test date}
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.659 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75 - 1 NPS	0.058 in ²	[C] 0.272 in	0.091 in	15-8000 psi	Water	UV
0.75-1.5 NPS	0.75 - 1.5 NPS	0.129 in ²	[D] 0.405 in	0.135 in	15-8000 psi	Water	UV
1-2 NPS	1.5 - 2 NPS	0.23 in ²	[E] 0.541 in	0.18 in	15-8000 psi	Water	UV
1-2 NPS	1.5 - 2 NPS	0.366 in ²	[F] 0.683 in	0.228 in	15-6400 psi	Water	UV
1.5-2 NPS	2 NPS	0.59 in ²	[G] 0.867 in	0.289 in	15-1500 psi	Water	UV

Design Name:	19-311000	NBCert #	56393
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	09/08/2026

Design Type

[Safety Relief Valve] 19-311000
Capacity Tests: Sec. UV at National Board Testing Lab {unknown test date}
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.030 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.196 in ²	0.5 in	0.16 in	50-1600 psi	Air	UV

Design Name:	19-311000 (Liquid)	NBCert #	56405
--------------	--------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	09/08/2026

Design Type

[Relief Valve] 19-311000 (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab {unknown test date}
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 4.790 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 NPS	0.196 in²	0.5 in	0.16 in	50-1600 psi	Water	UV
Design Name: 19-312000			NBCert #		56416		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		09/08/2026		
Design Type							
[Safety Relief Valve] 19-312000 Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Annulus Designed by: Taylor Valve Technology, Inc {TTS}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.049 in²	0.5 in	0.09 in	50-1600 psi	Air	UV
Design Name: 19-312000 (Liquid)			NBCert #		56427		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		09/08/2026		
Design Type							
[Safety Relief Valve] 19-312000 (Liquid) Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Annulus Designed by: Taylor Valve Technology, Inc {TTS}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.049 in²	0.5 in	0.09 in	50-1600 psi	Water	UV
Design Name: 2500 Series (Air)			NBCert #		02552		
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		04/17/2030		
Design Type							
[Safety Relief Valve] 2500 Series (Air) Capacity Tests: Sec. UV at National Board Testing Lab {unknown test date} Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.868 Unitless Media - Test: Air/Gas; Certified: Air Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Taylor Valve Technology, Inc {TTS}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.5 NPS	2 NPS	0.317 in²	[F] 0.635 in	0.172 in	15-1480 psi	Air	UV
1.5-1.5 NPS	2.5 - 3 NPS	0.568 in²	[G] 0.85 in	0.23 in	15-1480 psi	Air	UV

1.5-2 NPS	3 NPS	0.911 in ²	[H] 1.077 in	0.292 in	15-1480 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.457 in ²	[J] 1.362 in	0.369 in	15-1480 psi	Air	UV
3-3 NPS	4 NPS	2.125 in ²	[K] 1.645 in	0.446 in	15-1480 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.281 in ²	[L] 2.044 in	0.554 in	15-1000 psi	Air	UV
4-4 NPS	6 NPS	4.047 in ²	[M] 2.27 in	0.615 in	15-1000 psi	Air	UV
4-4 NPS	6 NPS	4.988 in ²	[N] 2.52 in	0.775 in	15-1000 psi	Air	UV
4-4 NPS	6 NPS	7.33 in ²	[P] 3.055 in	0.828 in	15-1000 psi	Air	UV
6-6 NPS	8 NPS	12.699 in ²	[Q] 4.021 in	1.09 in	15-600 psi	Air	UV
6-6 NPS	8 NPS	18.383 in ²	[R] 4.838 in	1.21 in	15-300 psi	Air	UV
8-8 NPS	10 NPS	28.274 in ²	[T] 6 in	1.626 in	15-120 psi	Air	UV

Design Name: 2500 Series (Liquid)

NBCert #

02563

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

04/17/2030

Design Type

[Safety Valve] 2500 Series (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab {unknown test date}
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.664 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.5 NPS	2 NPS	0.317 in ²	[F] 0.635 in	0.172 in	15-1480 psi	Water	UV
1.5-1.5 NPS	2.5 - 3 NPS	0.568 in ²	[G] 0.85 in	0.23 in	15-1480 psi	Water	UV
1.5-2 NPS	3 NPS	0.911 in ²	[H] 1.077 in	0.292 in	15-1480 psi	Water	UV
2-3 NPS	3 - 4 NPS	1.457 in ²	[J] 1.362 in	0.369 in	15-1480 psi	Water	UV
3-3 NPS	4 NPS	2.125 in ²	[K] 1.645 in	0.446 in	15-1480 psi	Water	UV
3-4 NPS	4 - 6 NPS	3.281 in ²	[L] 2.044 in	0.554 in	15-1000 psi	Water	UV
4-4 NPS	6 NPS	4.047 in ²	[M] 2.27 in	0.615 in	15-1000 psi	Water	UV
4-4 NPS	6 NPS	4.988 in ²	[N] 2.52 in	0.775 in	15-1000 psi	Water	UV
4-4 NPS	6 NPS	7.33 in ²	[P] 3.055 in	0.828 in	15-1000 psi	Water	UV
6-6 NPS	8 NPS	12.699 in ²	[Q] 4.021 in	1.09 in	15-600 psi	Water	UV
6-6 NPS	8 NPS	18.383 in ²	[R] 4.838 in	1.21 in	15-300 psi	Water	UV
8-8 NPS	10 NPS	28.274 in ²	[T] 6 in	1.626 in	15-120 psi	Water	UV

Design Name: 2500 Series DR (25MDR, 25SDR, B25DR)
(Air)

NBCert #

02596

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

04/17/2030

Design Type

[Safety Relief Valve] 2500 Series DR (25MDR, 25SDR, B25DR) (Air)
Capacity Tests: Sec. UV at National Board Testing Lab {unknown test date}
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.580 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1 NPS	2 NPS	0.16 in ²	[DR] 0.635 in	0.08 in	15-1480 psi	Air	UV

Design Name:	2500 Series DR (25MDR, 25SDR, B25DR) (Liquid)	NBCert #	02608
--------------	--	----------	-------

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

04/17/2030

Design Type

[Relief Valve] 2500 Series DR (25MDR, 25SDR, B25DR) (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab {unknown test date}
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 4.590 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1 NPS	2 NPS	0.16 in ²	[DR] 0.635 in	0.08 in	15-1480 psi	Water	UV

Design Name:	2500 Series ER (25MER, 25SER, B25ER) (Air)	NBCert #	02574
--------------	---	----------	-------

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

04/17/2030

Design Type

[Safety Relief Valve] 2500 Series ER (25MER, 25SER, B25ER) (Air)
Capacity Tests: Sec. UV at National Board Testing Lab {unknown test date}
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.520 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1 NPS	2 NPS	0.219 in ²	[ER] 0.635 in	0.11 in	15-1480 psi	Air	UV

Design Name:	2500 Series ER (25MER, 25SER, B25ER) (Liquid)	NBCert #	02585
--------------	--	----------	-------

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

04/17/2030

Design Type

[Relief Valve] 2500 Series ER (25MER, 25SER, B25ER) (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab {unknown test date}
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.910 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1 NPS	2 NPS	0.219 in ²	[ER] 0.635 in	0.11 in	15-1480 psi	Water	UV

Design Name: 82-007000

NBCert # 56247

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

11/13/2025

Design Type

[Safety Relief Valve] 82-007000
Capacity Tests: Sec. UV at National Board Testing Lab on August 19, 1997
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:14.000 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	2 NPS	0.913 in ²	1.078 in	0.41 in	15-2000 psi	Air	UV

Design Name: 8250 Series

NBCert # 56124

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

05/02/2031

Design Type

[Safety Relief Valve] 8250 Series
Capacity Tests: Sec. UV at National Board Testing Lab on December 11, 2018
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1-2 NPS	0.062 in ²	[C] 0.281 in	0.11 in	300-10000 psi	Air	UV
0.5-1.5 NPS	0.75-2 NPS	0.128 in ²	[D] 0.404 in	0.17 in	15-5000 psi	Air	UV
0.75-1.5 NPS	1-2 NPS	0.212 in ²	[E] 0.52 in	0.19 in	15-3250 psi	Air	UV
1-2 NPS	2-3 NPS	0.357 in ²	[F] 0.674 in	0.27 in	15-3000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.472 in ²	[G] 0.775 in	0.3 in	15-2000 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.913 in ²	[H] 1.078 in	0.41 in	15-2000 psi	Air	UV

2-3 NPS	3-4 NPS	1.431 in ²	[J] 1.35 in	0.58 in	15-2000 psi	Air	UV
2.5-4 NPS	3-6 NPS	2.138 in ²	[K] 1.65 in	0.65 in	15-2000 psi	Air	UV
3-4 NPS	4-6 NPS	3.205 in ²	[L] 2.02 in	0.8 in	15-2000 psi	Air	UV
4-4 NPS	6 NPS	4.083 in ²	[M] 2.28 in	0.9 in	15-1000 psi	Air	UV

Design Name: 8250 Series (Liquid) NBCert # 56382

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/07/2025

Design Type

[Safety Relief Valve] 8250 Series (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab {unknown test date}
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.833 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1-2 NPS	0.062 in ²	[C] 0.281 in	0.11 in	300-10000 psi	Water	UV
0.5-1.5 NPS	0.75-2 NPS	0.128 in ²	[D] 0.404 in	0.17 in	15-5000 psi	Water	UV
0.75-1.5 NPS	1-2 NPS	0.212 in ²	[E] 0.52 in	0.19 in	15-3250 psi	Water	UV
1-2 NPS	2-3 NPS	0.357 in ²	[F] 0.674 in	0.27 in	15-3000 psi	Water	UV
1.5-2 NPS	2-3 NPS	0.472 in ²	[G] 0.775 in	0.3 in	15-2000 psi	Water	UV
1.5-2 NPS	2-3 NPS	0.913 in ²	[H] 1.078 in	0.41 in	15-2000 psi	Water	UV
2-3 NPS	3-4 NPS	1.431 in ²	[J] 1.35 in	0.58 in	15-2000 psi	Water	UV
2.5-4 NPS	3-6 NPS	2.138 in ²	[K] 1.65 in	0.65 in	15-2000 psi	Water	UV
3-4 NPS	4-6 NPS	3.205 in ²	[L] 2.02 in	0.8 in	15-2000 psi	Water	UV
4-4 NPS	6 NPS	4.083 in ²	[M] 2.28 in	0.9 in	15-1000 psi	Water	UV

Design Name: 83-001000 (Air and Gas) NBCert # 56203

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/04/2025

Design Type

[Safety Relief Valve] 83-001000 (Air and Gas)
Capacity Tests: Sec. UV at National Board Testing Lab on July 27, 1993
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:21.200 SCFM/PSIA
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2.5-3 NPS	3 NPS	1.431 in ²	1.35 in	0.58 in	15-1500 psi	Air	UV

Design Name: 83-002000 (Air and Gas)		NBCert #	56214
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	10/22/2025
Design Type			
[Safety Relief Valve] 83-002000 (Air and Gas) Capacity Tests: Sec. UV at National Board Testing Lab on October 7, 1993 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:29.030 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Taylor Valve Technology, Inc {TTS}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2.5-3 NPS	3 NPS	2.138 in ²	1.65 in	0.65 in	15-1000 psi	Air	UV

Design Name: 9300, 9300M		NBCert #	56315
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	02/03/2031
Design Type			
[Pilot Operated Pressure Relief Valve] 9300, 9300M Capacity Tests: Sec. UV at National Board Testing Lab on April 23, 2002 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas Set Pressure Definition(1): Pop; (2): Initial Audible Discharge Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot Flow Area Configuration: Nozzle/Full Lift Designed by: Taylor Valve Technology, Inc {TTS}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.202 in	15-3705 psi	Air	UV
1-1.5 NPS	2 NPS	0.212 in ²	[E] 0.52 in	0.26 in	15-3705 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.337 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.472 in ²	[G] 0.775 in	0.388 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.539 in	15-3705 psi	Air	UV
2-3 NPS	3, 4 NPS	1.431 in ²	[J] 1.35 in	0.675 in	15-2000 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.825 in	15-2000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.205 in ²	[L] 2.02 in	1.01 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.083 in ²	[M] 2.28 in	1.14 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.909 in ²	[N] 2.5 in	1.25 in	15-2000 psi	Air	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.5 in	15-1480 psi	Air	UV
6 NPS	8 NPS	12.566 in ²	[Q] 4 in	2 in	15-1480 psi	Air	UV
6 NPS	8 NPS	17.721 in ²	[R] 4.75 in	2.375 in	15-1480 psi	Air	UV
8 NPS	10 NPS	25.967 in ²	[T] 5.75 in	2.875 in	15-1480 psi	Air	UV

Design Name:	9300FB	NBCert #	56326
--------------	--------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/13/2031

Design Type
[Pilot Operated Pressure Relief Valve] 9300FB Capacity Tests: Sec. UV at National Board Testing Lab on July 31, 2002 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.774 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2, 3 NPS	1.767 in ²	1.5 in	0.75 in	15-2000 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	1.939 in	0.97 in	15-2000 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	2.9 in	1.45 in	15-1480 psi	Air	UV
4 NPS	6 NPS	11.491 in ²	3.825 in	1.915 in	15-1480 psi	Air	UV
6 NPS	8 NPS	26.067 in ²	5.761 in	2.88 in	15-1480 psi	Air	UV
8 NPS	10 NPS	45.664 in ²	7.625 in	3.812 in	15-1480 psi	Air	UV

Design Name:	9300M	NBCert #	56371
--------------	-------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/02/2030

Design Type
[Pilot Operated Pressure Relief Valve] 9300M Capacity Tests: Sec. UV at National Board Testing Lab on September 15, 2011 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.829 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.202 in	15-3705 psi	Water	UV
1-1.5 NPS	2 NPS	0.212 in ²	[E] 0.52 in	0.26 in	15-3705 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.337 in	15-3705 psi	Water	UV
1.5-2 NPS	3 NPS	0.472 in ²	[G] 0.775 in	0.388 in	15-3705 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.539 in	15-3705 psi	Water	UV
2-3 NPS	3, 4 NPS	1.431 in ²	[J] 1.35 in	0.675 in	15-2000 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.825 in	15-2000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.205 in ²	[L] 2.02 in	1.01 in	15-2000 psi	Water	UV
4 NPS	6 NPS	4.083 in ²	[M] 2.28 in	1.145 in	15-2000 psi	Water	UV
4 NPS	6 NPS	4.909 in ²	[N] 2.5 in	1.25 in	15-2000 psi	Water	UV

4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.5 in	15-1480 psi	Water	UV
6 NPS	8 NPS	12.566 in ²	[Q] 4 in	2 in	15-1480 psi	Water	UV
6 NPS	8 NPS	17.721 in ²	[R] 4.75 in	2.375 in	15-1480 psi	Water	UV
8 NPS	10 NPS	25.967 in ²	[T] 5.75 in	2.875 in	15-1480 psi	Water	UV

Design Name: Model C- Rupture Pin Relief Valve NBCert # 56630

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/04/2030

Design Type

[Buckling Pin Non-reclosing Device] Model C- Rupture Pin Relief Valve
Capacity Tests: Sec. UD at National Board Testing Lab on October 16, 2013
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.712 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: Nozzle/Full Lift
Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	1.5, 2 NPS	1.77 in ²	1.5 in	0.85 in	15-1480 psi	Air	UD
2 NPS	2, 3 NPS	2.95 in ²	1.94 in	0.9 in	15-1480 psi	Air	UD
3 NPS	3, 4 NPS	6.6 in ²	2.9 in	1.48 in	15-1480 psi	Air	UD
4 NPS	4, 6 NPS	11.49 in ²	3.826 in	1.71 in	15-1480 psi	Air	UD
6 NPS	6, 8 NPS	26.05 in ²	5.761 in	2.19 in	15-1480 psi	Air	UD
8 NPS	8, 10 NPS	45.64 in ²	7.625 in	2.66 in	15-1480 psi	Air	UD
10 NPS	10, 12 NPS	74.62 in ²	9.75 in	3.19 in	15-1480 psi	Air	UD
12 NPS	12, 14 NPS	108.38 in ²	11.75 in	3.69 in	15-1480 psi	Air	UD
14 NPS	14, 16 NPS	132.67 in ²	13 in	4 in	15-740 psi	Air	UD
16 NPS	16, 18 NPS	176.63 in ²	15 in	4.5 in	15-740 psi	Air	UD
18 NPS	18, 20 NPS	226.87 in ²	17 in	5 in	15-740 psi	Air	UD
20 NPS	20, 24 NPS	283.39 in ²	19 in	5.5 in	15-285 psi	Air	UD
24 NPS	24, 30 NPS	415.27 in ²	23 in	6.5 in	15-285 psi	Air	UD
30 NPS	30, 36 NPS	660.19 in ²	29 in	8 in	15-285 psi	Air	UD

Design Name: Model C- Rupture Pin Relief Valve (Liquid) NBCert # 56641

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/04/2030

Design Type

[Buckling Pin Non-reclosing Device] Model C- Rupture Pin Relief Valve (Liquid)
Capacity Tests: Sec. UD at National Board Testing Lab on October 15, 2013
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.595 Unitless
Media - ; Certified: Liquid
Set Pressure Definition: Buckling Pressure
Flow Area Configuration: Nozzle/Full Lift
Designed by: Taylor Valve Technology, Inc {TTS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	1.5, 2 NPS	1.77 in ²	1.5 in	0.85 in	15-1480 psi	Water	UD
2 NPS	2, 3 NPS	2.95 in ²	1.94 in	0.9 in	15-1480 psi	Water	UD
3 NPS	3, 4 NPS	6.6 in ²	2.9 in	1.48 in	15-1480 psi	Water	UD
4 NPS	4, 6 NPS	11.49 in ²	3.826 in	1.71 in	15-1480 psi	Water	UD
6 NPS	6, 8 NPS	26.05 in ²	5.761 in	2.19 in	15-1480 psi	Water	UD
8 NPS	8, 10 NPS	45.64 in ²	7.625 in	2.66 in	15-1480 psi	Water	UD
10 NPS	10, 12 NPS	74.62 in ²	9.75 in	3.19 in	15-1480 psi	Water	UD
12 NPS	12, 14 NPS	108.38 in ²	11.75 in	3.69 in	15-1480 psi	Water	UD
14 NPS	14, 16 NPS	132.67 in ²	13 in	4 in	15-740 psi	Water	UD
16 NPS	16, 18 NPS	176.63 in ²	15 in	4.5 in	15-740 psi	Water	UD
18 NPS	18, 20 NPS	226.87 in ²	17 in	5 in	15-740 psi	Water	UD
20 NPS	20, 24 NPS	283.39 in ²	19 in	5.5 in	15-285 psi	Water	UD
24 NPS	24, 30 NPS	415.27 in ²	23 in	6.5 in	15-285 psi	Water	UD
30 NPS	30, 36 NPS	660.19 in ²	29 in	8 in	15-285 psi	Water	UD

Team Industrial Services, Inc. (FAB)

Nameplate Abbreviation: TEAM BEN
225

Benicia, CA 94510 United States

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S		NBCert # 57057
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/02/2029
Design Type		
<p>[Safety Relief Valve] 2600 & 2600S Capacity Tests: Sec. UV at unknown lab on June 11, 1972 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.858 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}</p>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV

1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/28/2028

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name:	2600L (Liquids)	NBCert #	57068
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/28/2028

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/02/2029

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	08/02/2029
-----------	----	------------

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name:	900 Series (Liquid), 7700, SNC	NBCert #	15499
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/12/2025

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name:	900 Series, 7700, SNC	NBCert #	15411
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/31/2026

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV

0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name: H Series (HCI, HSJ, HCA, HA, HB, HC, HCB, HCP, HJO, HN, HNA, HNB, HNP, HS, NBCert # 15006 HSA, HSB, HSC, HSP)

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 02/07/2026

Design Type

[Safety Valve] H Series (HCI, HSJ, HCA, HA, HB, HC, HCB, HCP, HJO, HN, HNA, HNB, HNP, HS, HSA, HSB, HSC, HSP)
Capacity Tests: Sec. UV, V at unknown lab on September 1, 1939
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1.5 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-500 psi	Steam	UV, V
0.75 NPS	1.5 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-500 psi	Steam	UV, V
1-1.5 NPS	2 - 3 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-3100 psi	Steam	UV, V
1-2 NPS	2.5, 3 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-3100 psi	Steam	UV, V
1.5-2 NPS	3, 4, 6 NPS	0.785 in ²	[H] 1 in	0.25 in	15-5000 psi	Steam	UV, V
1.5 NPS	3 NPS	0.865 in ²	1.05 in	0.262 in	15-3100 psi	Steam	UV, V
1.5 NPS	3 NPS	0.994 in ²	[H2] 1.125 in	0.281 in	15-3100 psi	Steam	UV, V
2-3 NPS	3, 4, 6 NPS	1.288 in ²	[J] 1.281 in	0.32 in	15-5000 psi	Steam	UV, V
2 NPS	4 NPS	1.431 in ²	[J2] 1.35 in	0.338 in	15-3100 psi	Steam	UV, V
2.5-3 NPS	4, 6 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-6000 psi	Steam	UV, V
2.5 NPS	6 NPS	2.545 in ²	[K2] 1.8 in	0.45 in	15-6800 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.476 in	15-3100 psi	Steam	UV, V
3 NPS	6 NPS	3.341 in ²	[L2] 2.062 in	0.516 in	15-3100 psi	Steam	UV, V
3-4 NPS	6, 8 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-6000 psi	Steam	UV, V
3 NPS	6, 8 NPS	3.976 in ²	[M2] 2.25 in	0.563 in	15-6000 psi	Steam	UV, V
4 NPS	6 NPS	4.341 in ²	[N] 2.351 in	0.588 in	15-3100 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.712 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	7.07 in ²	[P2] 3 in	0.75 in	15-3100 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.937 in	15-1500 psi	Steam	UV, V

6 NPS	8 NPS	12.25 in ²	[Q2] 3.95 in	0.988 in	15-3100 psi	Steam	UV, V
6 NPS	8, 10 NPS	16 in ²	[R] 4.513 in	1.128 in	15-3100 psi	Steam	UV, V
6 NPS	10 NPS	19.29 in ²	[RR] 4.956 in	1.239 in	15-3100 psi	Steam	UV, V
8 NPS	10, 12 NPS	26 in ²	[T] 5.75 in	1.437 in	15-500 psi	Steam	UV, V
8 NPS	12, 14 NPS	28.274 in ²	6 in	1.5 in	15-2000 psi	Steam	UV, V
10 NPS	14 NPS	44.18 in ²	7.5 in	1.875 in	15-500 psi	Steam	UV, V
12 NPS	16 NPS	63.62 in ²	9 in	2.25 in	15-500 psi	Steam	UV, V
14 NPS	18 NPS	86.59 in ²	10.5 in	2.625 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	95.21 in ²	11.01 in	2.753 in	15-500 psi	Steam	UV, V
16 NPS	18, 20 NPS	114.04 in ²	12.05 in	3.02 in	15-500 psi	Steam	UV, V
18 NPS	24 NPS	143.14 in ²	13.5 in	3.375 in	15-500 psi	Steam	UV, V
20 NPS	24 NPS	176.71 in ²	15 in	3.75 in	15-500 psi	Steam	UV, V

Design Name: JLT-JOS/JLT-JBS/JLT-JDS (Liquids) NBCert # 15095

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 11/12/2025

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.656 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV

3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name: JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB NBCert # 15208

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/07/2026

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV

2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Sulphur, LA 70663United States

This Company Manufactures or Assembles:

Design Name:	2600 & 2600S	NBCert #	57057
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/05/2030

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV

6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name:	2600L (Liquids)	NBCert #	57068
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/05/2030

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V

4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S NBCert # 57237

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/05/2030

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids) NBCert # 57248

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/05/2030

Design Type

[Relief Valve] 2700L, 3700L (Liquids)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.676 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800

NBCert #

57024

Manufacturer/Assembler

Designators

Expiration Date

Assembler

UV

02/05/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3800

Capacity Tests: Sec. UV at unknown lab on May 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.859 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (3): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV

2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name: 3800L, PCL, PCM pilots

NBCert #

57215

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

02/05/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.782 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV

3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Team Industrial Services, Inc. (TME)

Nameplate Abbreviation: TEAM

Geismar, LA 70734United States

This Company Manufactures or Assembles:

Design Name:	9 Series	NBCert #	44019
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/08/2027

Design Type

[Safety Relief Valve] 9 Series
Capacity Tests: Sec. UV at National Board Testing Lab on July 24, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.823 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	0.236 in	0.07 in	15-4700 psi	Air	UV
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	0.236 in	0.07 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.124 in ²	0.398 in	0.1 in	14.5-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.124 in ²	0.398 in	0.1 in	14.5-4700 psi	Air	UV
0.75-1 NPS	1 NPS	0.222 in ²	0.531 in	0.13 in	14.5-2220 psi	Air	UV
0.75-1 NPS	1 NPS	0.222 in ²	0.531 in	0.13 in	14.5-2220 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.669 in	0.17 in	14.5-740 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.669 in	0.17 in	14.5-740 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	0.85 in	0.21 in	14.5-285 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	0.85 in	0.21 in	14.5-285 psi	Steam	UV

Design Name:	9 Series (Liquids)	NBCert #	44020
--------------	--------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/08/2027

Design Type

[Relief Valve] 9 Series (Liquids)
Capacity Tests: Sec. UV, V at National Board Testing Lab on July 24, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.632 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	[B] 0.236 in	0.07 in	15-6250 psi	Water	UV
0.5-1 NPS	1 NPS	0.124 in ²	[D] 0.398 in	0.1 in	14.5-6250 psi	Water	UV
0.75-1 NPS	1 NPS	0.222 in ²	[E] 0.531 in	0.13 in	14.5-2220 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	[F] 0.669 in	0.17 in	14.5-740 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	[G] 0.85 in	0.21 in	14.5-285 psi	Water	UV

Design Name: P3, P4 (liquids) NBCert # 92012

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

10/18/2027

Design Type

[Relief Valve] P3, P4 (liquids)
Capacity Tests: Sec. UV, V at National Board Testing Lab on December 7, 1993
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.631 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Water	UV, V
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Water	UV, V
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Water	UV, V
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Water	UV, V
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Water	UV, V
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Water	UV, V
4 NPS	6 NPS	7.032 in ²	[P] 2.992 in	0.94 in	15-1300 psi	Water	UV, V
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Water	UV, V
6 NPS	8-10 NPS	15.267 in ²	[R] 4.409 in	1.477 in	15-500 psi	Water	UV, V
8 NPS	10 NPS	28.126 in ²	[T] 5.984 in	1.88 in	15-500 psi	Water	UV, V

Design Name: P3, P4, P5	NBCert # 92001
-------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/18/2027

Design Type

[Safety Relief Valve] P3, P4, P5
Capacity Tests: Sec. UV at unknown lab on June 5, 1986
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Air	UV
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Air	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-2900 psi	Steam	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Air	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-2900 psi	Steam	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Air	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-2900 psi	Steam	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Air	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Steam	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Air	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Steam	UV
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Air	UV
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Steam	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Air	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Steam	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Air	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Steam	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Air	UV

10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Steam	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Air	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Steam	UV

Design Name: STARFLOW-V NBCert # 44110

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler V 07/08/2027

Design Type

[Safety Valve] STARFLOW-V
Capacity Tests: Sec. UV, V at National Board Testing Lab on April 26, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}
Comments: org. date added and V orif. area corrected from 38.548 to 38.485 JB 8-10-20
corrected H inlet to add 1.5" JB -8-2-21

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5-3 NPS	0.373 in ²	[F] 0.689 in	0.172 in	30-2250 psi	Steam	UV, V
1.25-2 NPS	1.5-3 NPS	0.589 in ²	[G] 0.8661 in	0.217 in	30-2250 psi	Steam	UV, V
1.5-2 NPS	2.5, 3 NPS	0.996 in ²	[H] 1.126 in	0.281 in	30-2250 psi	Steam	UV, V
1.5-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.3622 in	0.341 in	30-2250 psi	Steam	UV, V
2-3 NPS	3-6 NPS	1.667 in ²	[K] 1.457 in	0.364 in	30-2250 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.758 in ²	[L] 1.874 in	0.469 in	30-2250 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.983 in ²	[M] 2.252 in	0.563 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	5.303 in ²	[N] 2.5984 in	0.65 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	0.75 in	30-2250 psi	Steam	UV, V
6 NPS	8 NPS	10.148 in ²	[Q] 3.594 in	0.902 in	30-1494 psi	Steam	UV, V
6 NPS	8, 10 NPS	14.173 in ²	[R] 4.248 in	1.062 in	30-1494 psi	Steam	UV, V
8 NPS	10 NPS	23.997 in ²	[T] 5.528 in	1.382 in	30-740 psi	Steam	UV, V
10 NPS	14 NPS	38.485 in ²	[V] 7 in	1.75 in	30-740 psi	Steam	UV, V
12 NPS	2x12 NPS	55.438 in ²	[W] 8.402 in	2.1 in	30-740 psi	Steam	UV, V

Design Name: STARFLOW-V (Restricted Lift) NBCert # 44121

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler V 07/08/2027

Design Type

[Safety Valve] STARFLOW-V (Restricted Lift)
Capacity Tests: Sec. UV, V at National Board Testing Lab on April 27, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Restricted Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}
Comments: Org. date added and "V" orif. area corrected from 34.485 to 38.485 JB 8-10-20
corrected H by adding 1.5" inlet JB 8-2-21

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5-3 NPS	0.373 in ²	[F] 0.689 in	0.095 in	30-2250 psi	Steam	UV, V
1.25-2 NPS	1.5-3 NPS	0.589 in ²	[G] 0.8661 in	0.119 in	30-2250 psi	Steam	UV, V
1.5-2 NPS	2.5, 3 NPS	0.996 in ²	[H] 1.126 in	0.156 in	30-2250 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.3622 in	0.188 in	30-2250 psi	Steam	UV, V
2-3 NPS	3-6 NPS	1.667 in ²	[K] 1.457 in	0.201 in	30-2250 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.758 in ²	[L] 1.874 in	0.258 in	30-2250 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.983 in ²	[M] 2.252 in	0.31 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	5.303 in ²	[N] 2.5984 in	0.357 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	0.414 in	30-2250 psi	Steam	UV, V
6 NPS	8 NPS	10.148 in ²	[Q] 3.594 in	0.496 in	30-1494 psi	Steam	UV, V
6 NPS	8, 10 NPS	14.173 in ²	[R] 4.248 in	0.584 in	30-1494 psi	Steam	UV, V
8 NPS	10 NPS	23.997 in ²	[T] 5.528 in	0.76 in	30-740 psi	Steam	UV, V
10 NPS	14 NPS	38.485 in ²	[V] 7 in	0.963 in	30-740 psi	Steam	UV, V
12 NPS	2x12 NPS	55.438 in ²	[W] 8.402 in	1.155 in	30-740 psi	Steam	UV, V

Team Industrial Services, Inc. (TMF)

Nameplate Abbreviation: TEAM

Mobile, AL 36618United States

This Company Manufactures or Assembles:

Design Name: 78 (Pilot Operated)		NBCert #	44053
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	02/24/2027	

Design Type

[Pilot Operated Pressure Relief Valve] 78 (Pilot Operated)
Capacity Tests: Sec. UV at National Board Testing Lab on August 5, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.124 in ²	[D] 0.398 in	0.53 in	26.1-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.124 in ²	[D] 0.398 in	0.53 in	29-740 psi	Steam	UV
1-1.5 NPS	2 NPS	0.222 in ²	[E] 0.531 in	0.53 in	26.1-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.222 in ²	[E] 0.531 in	0.53 in	29-740 psi	Steam	UV
1-1.5 NPS	2 NPS	0.352 in ²	[F] 0.669 in	0.53 in	26.1-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.352 in ²	[F] 0.669 in	0.53 in	29-740 psi	Steam	UV
1.5-2 NPS	3 NPS	0.568 in ²	[G] 0.85 in	0.7 in	26.1-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.568 in ²	[G] 0.85 in	0.7 in	29-740 psi	Steam	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.7 in	26.1-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.7 in	29-740 psi	Steam	UV
2-3 NPS	3,4 NPS	1.457 in ²	[J] 1.362 in	0.8 in	26.1-6250 psi	Air	UV
2-3 NPS	3,4 NPS	1.457 in ²	[J] 1.362 in	0.8 in	29-740 psi	Steam	UV
3 NPS	4 NPS	2.097 in ²	[K] 1.634 in	1.18 in	26.1-3750 psi	Air	UV
3 NPS	4 NPS	2.097 in ²	[K] 1.634 in	1.18 in	29-740 psi	Steam	UV
3-4 NPS	4,6 NPS	3.229 in ²	[L] 2.028 in	1.18 in	26.1-3750 psi	Air	UV
3-4 NPS	4,6 NPS	3.229 in ²	[L] 2.028 in	1.18 in	29-740 psi	Steam	UV
4 NPS	6 NPS	4.095 in ²	[M] 2.284 in	1.57 in	26.1-3750 psi	Air	UV
4 NPS	6 NPS	4.095 in ²	[M] 2.284 in	1.57 in	29-740 psi	Steam	UV
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	1.57 in	26.1-3750 psi	Air	UV
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	1.57 in	29-740 psi	Steam	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.57 in	26.1-3750 psi	Air	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.57 in	29-740 psi	Steam	UV
6 NPS	8 NPS	12.915 in ²	[Q] 4.055 in	2.16 in	26.1-3750 psi	Air	UV
6 NPS	8 NPS	12.915 in ²	[Q] 4.055 in	2.16 in	29-740 psi	Steam	UV
6 NPS	8 NPS	15.904 in ²	[R] 4.5 in	2.16 in	26.1-1500 psi	Air	UV
6 NPS	8 NPS	15.904 in ²	[R] 4.5 in	2.16 in	29-740 psi	Steam	UV
8-8 NPS	10 NPS	28.274 in ²	[T] 6 in	2.99 in	26.1-1500 psi	Air	UV
8-8 NPS	10 NPS	28.274 in ²	[T] 6 in	2.99 in	29-740 psi	Steam	UV

Design Name:	78 (Pilot Operated, Liquid)	NBCert #	44064
--------------	-----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/07/2027

Design Type

[Pilot Operated Pressure Relief Valve] 78 (Pilot Operated, Liquid)
 Capacity Tests: Sec. UV, V at National Board Testing Lab on August 6, 1999
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.857 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.124 in ²	[D] 0.398 in	0.53 in	26.1-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.222 in ²	[E] 0.531 in	0.53 in	26.1-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.352 in ²	[F] 0.669 in	0.53 in	26.1-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.568 in ²	[G] 0.85 in	0.7 in	26.1-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.7 in	26.1-6250 psi	Water	UV
2-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.362 in	0.8 in	26.1-6250 psi	Water	UV
3 NPS	4 NPS	2.097 in ²	[K] 1.634 in	1.18 in	26.1-3750 psi	Water	UV
3-4 NPS	4, 6 NPS	3.229 in ²	[L] 2.028 in	1.18 in	26.1-3750 psi	Water	UV
4 NPS	6 NPS	4.095 in ²	[M] 2.283 in	1.57 in	26.1-3750 psi	Water	UV
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	1.57 in	26.1-3750 psi	Water	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.57 in	26.1-3750 psi	Water	UV
6 NPS	8 NPS	12.915 in ²	[Q] 4.055 in	2.16 in	26.1-3750 psi	Water	UV
6 NPS	8 NPS	15.904 in ²	[R] 4.5 in	2.16 in	26.1-1500 psi	Water	UV
8 NPS	10 NPS	28.274 in ²	[T] 6 in	2.99 in	26.1-1500 psi	Water	UV

Design Name: 9 Series

NBCert # 44019

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

02/24/2027

Design Type

[Safety Relief Valve] 9 Series
Capacity Tests: Sec. UV at National Board Testing Lab on July 24, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.823 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	0.236 in	0.07 in	15-4700 psi	Air	UV
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	0.236 in	0.07 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.124 in ²	0.398 in	0.1 in	14.5-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.124 in ²	0.398 in	0.1 in	14.5-4700 psi	Air	UV
0.75-1 NPS	1 NPS	0.222 in ²	0.531 in	0.13 in	14.5-2220 psi	Air	UV
0.75-1 NPS	1 NPS	0.222 in ²	0.531 in	0.13 in	14.5-2220 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.669 in	0.17 in	14.5-740 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.669 in	0.17 in	14.5-740 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	0.85 in	0.21 in	14.5-285 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	0.85 in	0.21 in	14.5-285 psi	Steam	UV

Design Name:	9 Series (Liquids)	NBCert #	44020
--------------	--------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/07/2027

Design Type

[Relief Valve] 9 Series (Liquids)
Capacity Tests: Sec. UV, V at National Board Testing Lab on July 24, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.632 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	[B] 0.236 in	0.07 in	15-6250 psi	Water	UV
0.5-1 NPS	1 NPS	0.124 in ²	[D] 0.398 in	0.1 in	14.5-6250 psi	Water	UV
0.75-1 NPS	1 NPS	0.222 in ²	[E] 0.531 in	0.13 in	14.5-2220 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	[F] 0.669 in	0.17 in	14.5-740 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	[G] 0.85 in	0.21 in	14.5-285 psi	Water	UV

Design Name:	P3, P4 (liquids)	NBCert #	92012
--------------	------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	02/24/2027

Design Type

[Relief Valve] P3, P4 (liquids)
Capacity Tests: Sec. UV, V at National Board Testing Lab on December 7, 1993
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.631 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Water	UV, V
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Water	UV, V
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Water	UV, V
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Water	UV, V
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Water	UV, V
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Water	UV, V
4 NPS	6 NPS	7.032 in ²	[P] 2.992 in	0.94 in	15-1300 psi	Water	UV, V

6 NPS	8 NPS	12.914 in²	[Q] 4.055 in	1.257 in	15-1000 psi	Water	UV, V
6 NPS	8-10 NPS	15.267 in²	[R] 4.409 in	1.477 in	15-500 psi	Water	UV, V
8 NPS	10 NPS	28.126 in²	[T] 5.984 in	1.88 in	15-500 psi	Water	UV, V
Design Name: P3, P4, P5				NBCert #	92001		
Manufacturer/Assembler			Designators		Expiration Date		
Assembler			UV		02/24/2027		
Design Type							
[Safety Relief Valve] P3, P4, P5 Capacity Tests: Sec. UV at unknown lab on June 5, 1986 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.876 Unitless Media - Test: Air/Gas; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: TRILLIUM Flow Technologies - France SAS {SAR}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2-3 NPS	0.134 in²	[D] 0.413 in	0.128 in	15-10000 psi	Air	UV
1-2 NPS	2-3 NPS	0.134 in²	[D] 0.413 in	0.128 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in²	[E] 0.59 in	0.183 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in²	[E] 0.59 in	0.183 in	15-7500 psi	Air	UV
1.5 NPS	2-3 NPS	0.373 in²	[F] 0.689 in	0.214 in	15-2900 psi	Steam	UV
1.5 NPS	2-3 NPS	0.373 in²	[F] 0.689 in	0.214 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.589 in²	[G] 0.866 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.589 in²	[G] 0.866 in	0.268 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.881 in²	[H] 1.059 in	0.328 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.881 in²	[H] 1.059 in	0.328 in	15-5000 psi	Air	UV
2-3 NPS	3-4 NPS	1.457 in²	[J] 1.362 in	0.422 in	15-2900 psi	Steam	UV
2-3 NPS	3-4 NPS	1.457 in²	[J] 1.362 in	0.422 in	15-3200 psi	Air	UV
3 NPS	4-6 NPS	2.097 in²	[K] 1.634 in	0.506 in	15-2900 psi	Steam	UV
3 NPS	4-6 NPS	2.097 in²	[K] 1.634 in	0.506 in	15-3200 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in²	[L] 2.045 in	0.634 in	15-2000 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in²	[L] 2.045 in	0.634 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.093 in²	[M] 2.283 in	0.708 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.093 in²	[M] 2.283 in	0.708 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.987 in²	[N] 2.52 in	0.781 in	15-1300 psi	Air	UV
4 NPS	6 NPS	4.987 in²	[N] 2.52 in	0.781 in	15-1300 psi	Steam	UV
4 NPS	6 NPS	7.215 in²	[P] 3.031 in	0.94 in	15-1300 psi	Air	UV
4 NPS	6 NPS	7.215 in²	[P] 3.031 in	0.94 in	15-1300 psi	Steam	UV
6 NPS	8 NPS	12.914 in²	[Q] 4.055 in	1.257 in	15-1000 psi	Air	UV
6 NPS	8 NPS	12.914 in²	[Q] 4.055 in	1.257 in	15-1000 psi	Steam	UV
6 NPS	8-10 NPS	17.818 in²	[R] 4.763 in	1.477 in	15-700 psi	Air	UV
6 NPS	8-10 NPS	17.818 in²	[R] 4.763 in	1.477 in	15-700 psi	Steam	UV

8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Air	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Steam	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Air	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Steam	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Air	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Steam	UV

Design Name:	STARFLOW-V	NBCert #	44110
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler V 07/08/2027

Design Type

[Safety Valve] STARFLOW-V
Capacity Tests: Sec. UV, V at National Board Testing Lab on April 26, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}
Comments: org. date added and V orif. area corrected from 38.548 to 38.485 JB 8-10-20
corrected H inlet to add 1.5" JB -8-2-21

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5-3 NPS	0.373 in ²	[F] 0.689 in	0.172 in	30-2250 psi	Steam	UV, V
1.25-2 NPS	1.5-3 NPS	0.589 in ²	[G] 0.8661 in	0.217 in	30-2250 psi	Steam	UV, V
1.5-2 NPS	2.5, 3 NPS	0.996 in ²	[H] 1.126 in	0.281 in	30-2250 psi	Steam	UV, V
1.5-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.3622 in	0.341 in	30-2250 psi	Steam	UV, V
2-3 NPS	3-6 NPS	1.667 in ²	[K] 1.457 in	0.364 in	30-2250 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.758 in ²	[L] 1.874 in	0.469 in	30-2250 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.983 in ²	[M] 2.252 in	0.563 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	5.303 in ²	[N] 2.5984 in	0.65 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	0.75 in	30-2250 psi	Steam	UV, V
6 NPS	8 NPS	10.148 in ²	[Q] 3.594 in	0.902 in	30-1494 psi	Steam	UV, V
6 NPS	8, 10 NPS	14.173 in ²	[R] 4.248 in	1.062 in	30-1494 psi	Steam	UV, V
8 NPS	10 NPS	23.997 in ²	[T] 5.528 in	1.382 in	30-740 psi	Steam	UV, V
10 NPS	14 NPS	38.485 in ²	[V] 7 in	1.75 in	30-740 psi	Steam	UV, V
12 NPS	2x12 NPS	55.438 in ²	[W] 8.402 in	2.1 in	30-740 psi	Steam	UV, V

Design Name:	STARFLOW-V (Restricted Lift)	NBCert #	44121
--------------	------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler V 07/07/2027

Design Type

[Safety Valve] STARFLOW-V (Restricted Lift)
 Capacity Tests: Sec. UV, V at National Board Testing Lab on April 27, 2017
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.876 Unitless
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Restricted Lift
 Designed by: TRILLIUM Flow Technologies - France SAS {SAR}
 Comments: Org. date added and "V" orif. area corrected from 34.485 to 38.485 JB 8-10-20
 corrected H by adding 1.5" inlet JB 8-2-21

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5-3 NPS	0.373 in ²	[F] 0.689 in	0.095 in	30-2250 psi	Steam	UV, V
1.25-2 NPS	1.5-3 NPS	0.589 in ²	[G] 0.8661 in	0.119 in	30-2250 psi	Steam	UV, V
1.5-2 NPS	2.5, 3 NPS	0.996 in ²	[H] 1.126 in	0.156 in	30-2250 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.3622 in	0.188 in	30-2250 psi	Steam	UV, V
2-3 NPS	3-6 NPS	1.667 in ²	[K] 1.457 in	0.201 in	30-2250 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.758 in ²	[L] 1.874 in	0.258 in	30-2250 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.983 in ²	[M] 2.252 in	0.31 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	5.303 in ²	[N] 2.5984 in	0.357 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	0.414 in	30-2250 psi	Steam	UV, V
6 NPS	8 NPS	10.148 in ²	[Q] 3.594 in	0.496 in	30-1494 psi	Steam	UV, V
6 NPS	8, 10 NPS	14.173 in ²	[R] 4.248 in	0.584 in	30-1494 psi	Steam	UV, V
8 NPS	10 NPS	23.997 in ²	[T] 5.528 in	0.76 in	30-740 psi	Steam	UV, V
10 NPS	14 NPS	38.485 in ²	[V] 7 in	0.963 in	30-740 psi	Steam	UV, V
12 NPS	2x12 NPS	55.438 in ²	[W] 8.402 in	1.155 in	30-740 psi	Steam	UV, V

Design Name: Starsteam V Series

NBCert # 92034

Manufacturer/Assembler	Designators	Expiration Date
Assembler	V	07/07/2027

Design Type

[Safety Valve] Starsteam V Series
 Capacity Tests: Sec. UV, V at National Board Testing Lab on August 3, 2012
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	3 NPS	0.996 in ²	[1] 1.125 in	0.2835 in	15-6525 psi	Steam	UV, V
2 NPS	3 NPS	1.667 in ²	[2] 1.456 in	0.3661 in	15-6525 psi	Steam	UV, V
2.5-6 NPS	6 NPS	2.758 in ²	[3] 1.874 in	0.4685 in	15-6525 psi	Steam	UV, V
3 NPS	6 NPS	3.983 in ²	[4] 2.251 in	0.562 in	15-6525 psi	Steam	UV, V
4 NPS	6 NPS	5.303 in ²	[5] 2.598 in	0.6496 in	15-6525 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[6] 3 in	0.752 in	15-3280 psi	Steam	UV, V

6 NPS	8 NPS	11.056 in ²	[Q] 3.751 in	0.9409 in	15-2798.5 psi	Steam	UV, V
6 NPS	10 NPS	15.904 in ²	[R] 4.5 in	1.126 in	15-1580 psi	Steam	UV, V
6 NPS	10 NPS	19.299 in ²	[RR] 4.957 in	1.239 in	15-1580 psi	Steam	UV, V
8 NPS	10 NPS	27.391 in ²	[T] 5.905 in	1.4764 in	15-1190 psi	Steam	UV, V

Design Name: Starsteam V Series (Res. Lift) NBCert # 92045

Manufacturer/Assembler	Designators	Expiration Date
Assembler	V	07/07/2027

Design Type

[Safety Valve] Starsteam V Series (Res. Lift)
Capacity Tests: Sec. UV, V at National Board Testing Lab on August 6, 2012
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Restricted Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	3 NPS	0.996 in ²	[1] 1.125 in	0.156 in	15-6525 psi	Steam	UV, V
2 NPS	3 NPS	1.667 in ²	[2] 1.456 in	0.201 in	15-6525 psi	Steam	UV, V
2.5 NPS	6 NPS	2.758 in ²	[3] 1.874 in	0.258 in	15-6525 psi	Steam	UV, V
3 NPS	6 NPS	3.983 in ²	[4] 2.251 in	0.309 in	15-6525 psi	Steam	UV, V
4 NPS	6 NPS	5.303 in ²	[5] 2.598 in	0.357 in	15-6525 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[6] 3 in	0.414 in	15-3280 psi	Steam	UV, V
6 NPS	8 NPS	11.056 in ²	[Q] 3.571 in	0.517 in	15-2798 psi	Steam	UV, V
6 NPS	10 NPS	15.904 in ²	[R] 4.5 in	0.619 in	15-1580 psi	Steam	UV, V
6 NPS	10 NPS	19.299 in ²	[RR] 4.957 in	0.681 in	15-1580 psi	Steam	UV, V
8 NPS	10 NPS	27.391 in ²	[T] 5.905 in	0.812 in	15-1190 psi	Steam	UV, V

Technical S.r.l. (TCI)

Nameplate Abbreviation: TECHNICAL

Vignate, Milano, 20060Italy

This Company Manufactures or Assembles:

Design Name: Series 10000		NBCert #	74135
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	06/14/2029

Design Type

[Safety Relief Valve] Series 10000
Capacity Tests: Sec. UV at National Board Testing Lab on December 13, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.875 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Technical S.r.l. {TCI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1 NPS	1 - 2 NPS	0.121 in ²	[D] 10 mm	2.1 mm	1-413 bar	Air	UV
0.75-2 NPS	1.5, 2 NPS	0.221 in ²	[E] 13.5 mm	3.2 mm	1-413 bar	Air	UV
1-2 NPS	1.5, 2 NPS	0.372 in ²	[F] 17.5 mm	4.2 mm	1-350 bar	Air	UV
1.5-2 NPS	2 NPS	0.562 in ²	[G] 21.5 mm	5.5 mm	1-330 bar	Air	UV
1.5-2 NPS	2 NPS	0.887 in ²	[H] 27 mm	7 mm	1-40 bar	Air	UV

Design Name: Series 10000 (Liquid) NBCert # 74124

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

01/10/2031

Design Type

[Relief Valve] Series 10000 (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on August 13, 2024
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.740 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Technical S.r.l. {TCI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	78.5 mm ²	[D] 10 mm	2.1 mm	1-431 bar	Water	UV

Design Name: Series 20000 NBCert # 74146

Manufacturer/Assembler

Designators

Expiration Date

Manufacturer

UV

11/26/2026

Design Type

[Safety Relief Valve] Series 20000
Capacity Tests: Sec. UV at National Board Testing Lab on December 13, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.703 SCFM/PSIA; (alternate medium): 4.784 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Technical S.r.l. {TCI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	[D] 0.375 in	2.1 mm	1-700 bar	Air	UV

Design Name: Series 30000	NBCert # 74157
---------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	11/26/2026
--------------	----	------------

Design Type

[Safety Relief Valve] Series 30000
 Capacity Tests: Sec. UV at National Board Testing Lab on May 4, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.856 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Technical S.r.l. {TCI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.121 in ²	[D] 10 mm	2.5 mm	1-413 bar	Air	UV
1-1.5 NPS	2, 3 NPS	0.147 in ²	[Do] 11 mm	2.8 mm	1-413 bar	Air	UV
1-1.5 NPS	2, 3 NPS	0.215 in ²	[E] 13.3 mm	3.1 mm	1-413 bar	Air	UV
1-1.5 NPS	2, 3 NPS	0.239 in ²	[Eo] 14 mm	3.4 mm	1-413 bar	Air	UV
1.5 NPS	2, 3 NPS	0.335 in ²	[F] 16.6 mm	4 mm	1-344 bar	Air	UV
1.5 NPS	2, 3 NPS	0.394 in ²	[Fo] 18 mm	4.9 mm	1-344 bar	Air	UV
1.5-2 NPS	3 NPS	0.547 in ²	[G] 21.2 mm	6.2 mm	1-255 bar	Air	UV
1.5-2 NPS	3 NPS	0.589 in ²	[Go] 22 mm	6.7 mm	1-255 bar	Air	UV
1.5-2 NPS	3 NPS	0.854 in ²	[H] 26.5 mm	9.8 mm	1-189 bar	Air	UV
1.5-2 NPS	3 NPS	0.914 in ²	[Ho] 27.4 mm	9.9 mm	1-189 bar	Air	UV
1.5-2 NPS	3 NPS	1.095 in ²	[H1] 30 mm	10 mm	1-189 bar	Air	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[J] 34 mm	11 mm	1-186 bar	Air	UV
2-3 NPS	3, 4 NPS	1.578 in ²	[Jo] 36 mm	12.2 mm	1-186 bar	Air	UV
3 NPS	4, 6 NPS	2.006 in ²	[K] 40.6 mm	13 mm	1-153 bar	Air	UV
3 NPS	4, 6 NPS	2.251 in ²	[Ko] 43 mm	13.6 mm	1-153 bar	Air	UV
3-4 NPS	4, 6 NPS	3.116 in ²	[L] 50.6 mm	16 mm	1-103 bar	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[Lo] 53 mm	17.4 mm	1-103 bar	Air	UV
4 NPS	6 NPS	3.116 in ²	[M] 56.8 mm	19 mm	1-75 bar	Air	UV
4 NPS	6 NPS	4.383 in ²	[Mo] 60 mm	19.6 mm	1-75 bar	Air	UV
4 NPS	6 NPS	4.74 in ²	[N] 62.4 mm	20 mm	1-68 bar	Air	UV
4 NPS	6 NPS	5.303 in ²	[No] 66 mm	21 mm	1-68 bar	Air	UV
4 NPS	6 NPS	6.976 in ²	[P] 75.7 mm	24 mm	1-68 bar	Air	UV
4 NPS	6 NPS	7.791 in ²	[Po] 80 mm	24.5 mm	1-68 bar	Air	UV
6 NPS	8 NPS	12.07 in ²	[Q] 99.6 mm	33 mm	1-41 bar	Air	UV
6 NPS	8 NPS	13.421 in ²	[Qo] 105 mm	37 mm	1-41 bar	Air	UV
6 NPS	8, 10 NPS	17.47 in ²	[R] 119.8 mm	40 mm	1-20 bar	Air	UV
8 NPS	10 NPS	28.42 in ²	[T] 152.8 mm	50 mm	1-20 bar	Air	UV
8 NPS	10 NPS	30.39 in ²	[To] 158 mm	51 mm	1-20 bar	Air	UV
10 NPS	12 NPS	39.43 in ²	[U] 180 mm	57 mm	1-12 bar	Air	UV

Design Name: Series 30000 (Liquid)	NBCert # 74179
------------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	01/18/2029
--------------	----	------------

Design Type

[Safety Relief Valve] Series 30000 (Liquid)
 Capacity Tests: Sec. UV at National Board Testing Lab on September 24, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.720 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: Start-to-Leak
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Technical S.r.l. {TCI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.121 in ²	[D] 10 mm	2.5 mm	1-413 bar	Water	UV
1-1.5 NPS	2, 3 NPS	0.147 in ²	[Do] 11 mm	2.8 mm	1-413 bar	Water	UV
1-1.5 NPS	2, 3 NPS	0.215 in ²	[E] 13.3 mm	3.1 mm	1-413 bar	Water	UV
1-1.5 NPS	2, 3 NPS	0.239 in ²	[Eo] 14 mm	3.4 mm	1-413 bar	Water	UV
1.5 NPS	2, 3 NPS	0.335 in ²	[F] 16.6 mm	4 mm	1-344 bar	Water	UV
1.5 NPS	2, 3 NPS	0.394 in ²	[Fo] 18 mm	4.9 mm	1-344 bar	Water	UV
1.5-2 NPS	3 NPS	0.547 in ²	[G] 21.2 mm	6.2 mm	1-255 bar	Water	UV
1.5-2 NPS	3 NPS	0.589 in ²	[Go] 22 mm	6.7 mm	1-255 bar	Water	UV
1.5-2 NPS	3 NPS	0.854 in ²	[H] 26.5 mm	9.8 mm	1-189 bar	Water	UV
1.5-2 NPS	3 NPS	5.896 in ²	[Ho] 27.4 mm	9.9 mm	1-189 bar	Water	UV
1.5-2 NPS	3 NPS	1.095 in ²	[H1] 30 mm	10 mm	1-189 bar	Water	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[J] 34 mm	11 mm	1-186 bar	Water	UV
2-3 NPS	3, 4 NPS	1.578 in ²	[Jo] 36 mm	12.2 mm	1-186 bar	Water	UV
3 NPS	4, 6 NPS	2.006 in ²	[K] 40.6 mm	13 mm	1-153 bar	Water	UV
3 NPS	4, 6 NPS	2.251 in ²	[Ko] 43 mm	13.6 mm	1-153 bar	Water	UV
3-4 NPS	4, 6 NPS	3.116 in ²	[L] 50.6 mm	16 mm	1-103 bar	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[Lo] 53 mm	17.4 mm	1-103 bar	Water	UV
4 NPS	6 NPS	3.927 in ²	[M] 56.8 mm	19 mm	1-75 bar	Water	UV
4 NPS	6 NPS	4.383 in ²	[Mo] 60 mm	19.6 mm	1-75 bar	Water	UV
4 NPS	6 NPS	4.74 in ²	[N] 62.4 mm	20 mm	1-68 bar	Water	UV
4 NPS	6 NPS	5.303 in ²	[No] 66 mm	21 mm	1-68 bar	Water	UV
4 NPS	6 NPS	6.976 in ²	[P] 75.7 mm	24 mm	1-68 bar	Water	UV
4 NPS	6 NPS	7.791 in ²	[Po] 80 mm	24.5 mm	1-68 bar	Water	UV
6 NPS	8 NPS	12.07 in ²	[Q] 99.6 mm	33 mm	1-41 bar	Water	UV
6 NPS	8 NPS	13.421 in ²	[Qo] 105 mm	37 mm	1-41 bar	Water	UV
6 NPS	8, 10 NPS	17.47 in ²	[R] 119.8 mm	40 mm	1-20 bar	Water	UV
8 NPS	10 NPS	28.42 in ²	[T] 152.8 mm	50 mm	1-20 bar	Water	UV
8 NPS	10 NPS	30.39 in ²	[To] 158 mm	51 mm	1-20 bar	Water	UV
10 NPS	12 NPS	39.43 in ²	[U] 180 mm	57 mm	1-12 bar	Water	UV

The Blythe Company, LLC (BLY)

Nameplate Abbreviation: The Blythe Company

Indian Land, SC 29707United States

This Company Manufactures or Assembles:

Design Name: 1400 Series		NBCert # 38113
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/25/2031
Design Type		
[Safety Relief Valve] 1400 Series Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 2015 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.291 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mercer Valve Co., Inc. {MVC}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5-1 NPS	0.02 in ²		0.06 in	150-10000 psi	Air	UV

Design Name: 81, 81P, 83, 84		NBCert # 01089
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/03/2031
Design Type		
[Safety Relief Valve] 81, 81P, 83, 84 Capacity Tests: Sec. UV at unknown lab on July 8, 1965 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.816 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC} Comments: Type 81P and 84 have fixed blowdown.		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV
1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV

1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name: 9100 NBCert # 38056

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/03/2031

Design Type

[Safety Relief Valve] 9100
Capacity Tests: Sec. UV at National Board Testing Lab on July 19, 1991
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.818 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.062 in ²	[C] 0.281 in	0.11 in	15-10000 psi	Air	UV
0.5-1.5 NPS	1 - 2 NPS	0.122 in ²	[D] 0.394 in	0.17 in	15-7500 psi	Air	UV
0.75-2 NPS	1 - 3 NPS	0.212 in ²	[E] 0.52 in	0.19 in	15-6000 psi	Air	UV
1-2 NPS	1-1/2 - 3 NPS	0.337 in ²	[F] 0.655 in	0.27 in	15-5000 psi	Air	UV
1.5-3 NPS	2 - 3 NPS	0.472 in ²	[G] 0.775 in	0.3 in	15-4000 psi	Air	UV
1.5-3 NPS	2 - 3 NPS	0.865 in ²	[H] 1.05 in	0.41 in	15-2750 psi	Air	UV
2-3 NPS	2-1/2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.58 in	15-2700 psi	Air	UV
2-3 NPS	3-4 NPS	1.622 in ²	[JO] 1.437 in	0.6 in	15-1800 psi	Air	UV
3-4 NPS	3,4,6 NPS	2.074 in ²	[K] 1.625 in	0.65 in	15-2200 psi	Air	UV
3-4 NPS	4, 6 NPS	3.205 in ²	[L] 2.02 in	0.8 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.08 in ²	[M] 2.28 in	0.9 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.909 in ²	[N] 2.5 in	0.985 in	15-740 psi	Air	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.2 in	15-525 psi	Air	UV

Design Name: 9100L (Liquids) NBCert # 38067

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/30/2025

Design Type

[Relief Valve] 9100L (Liquids)
Capacity Tests: Sec. UV at National Board Testing Lab on June 9, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.707 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.062 in ²	[C] 0.281 in	0.11 in	15-10000 psi	Water	UV
0.5-1 NPS	1 - 2 NPS	0.122 in ²	[D] 0.394 in	0.17 in	15-6500 psi	Water	UV
0.75-2 NPS	1 - 2 NPS	0.212 in ²	[E] 0.52 in	0.25 in	15-3500 psi	Water	UV
1-2 NPS	1.5 - 2.5 NPS	0.337 in ²	[F] 0.655 in	0.32 in	15-5000 psi	Water	UV
1.5-3 NPS	2 - 3 NPS	0.472 in ²	[G] 0.775 in	0.35 in	15-4000 psi	Water	UV
1.5-3 NPS	2 - 3 NPS	0.865 in ²	[H] 1.05 in	0.52 in	15-2750 psi	Water	UV
2-4 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.62 in	15-2700 psi	Water	UV
2-3 NPS	3-4 NPS	1.622 in ²	[JO] 1.437 in	0.64 in	15-1800 psi	Water	UV
3-4 NPS	3, 4 NPS	2.074 in ²	[K] 1.625 in	0.76 in	15-2220 psi	Water	UV
3-4 NPS	4, 6 NPS	3.205 in ²	[L] 2.02 in	0.82 in	15-2000 psi	Water	UV
4-4 NPS	6 NPS	4.08 in ²	[M] 2.28 in	0.95 in	15-2000 psi	Water	UV
4 NPS	6 NPS	4.909 in ²	[N] 2.5 in	0.985 in	15-740 psi	Water	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.2 in	15-525 psi	Water	UV

Design Name:	9500 (Full Port), S, M, E Pilots	NBCert #	38089
--------------	----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/03/2031

Design Type

[Pilot Operated Pressure Relief Valve] 9500 (Full Port), S, M, E Pilots
Capacity Tests: Sec. UV at National Board Testing Lab on July 18, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.820 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2,3 NPS	1.767 in ²	1.5 in	0.65 in	15-6170 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	1.939 in	0.85 in	15-3705 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	2.9 in	1.25 in	15-3700 psi	Air	UV
4 NPS	6 NPS	11.491 in ²	3.825 in	1.675 in	15-1530 psi	Air	UV
6 NPS	8 NPS	26.067 in ²	5.761 in	2.531 in	15-1480 psi	Air	UV
8 NPS	10 NPS	45.664 in ²	7.625 in	3.35 in	15-1480 psi	Air	UV

Design Name:	9500, S, M, E Pilots	NBCert #	38078
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/03/2031

Design Type

[Pilot Operated Pressure Relief Valve] 9500, S, M, E Pilots
Capacity Tests: Sec. UV at National Board Testing Lab on July 9, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.870 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Mercer Valve Co., Inc. {MVC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.151 in ²	[D] 0.439 in	0.2 in	15-6170 psi	Air	UV
1-1.5 NPS	2 NPS	0.223 in ²	[E] 0.533 in	0.25 in	15-6170 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.325 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.559 in ²	[G] 0.844 in	0.39 in	15-6170 psi	Air	UV
1.5-2 NPS	3 NPS	0.866 in ²	[H] 1.05 in	0.485 in	15-6170 psi	Air	UV
2-3 NPS	3,4 NPS	1.431 in ²	[J] 1.35 in	0.625 in	15-6170 psi	Air	UV
3 NPS	4 NPS	2.074 in ²	[K] 1.625 in	0.75 in	15-3705 psi	Air	UV
3-4 NPS	4,6 NPS	3.205 in ²	[L] 2.02 in	0.92 in	15-3705 psi	Air	UV
4 NPS	6 NPS	4.083 in ²	[M] 2.28 in	1.05 in	15-3705 psi	Air	UV
4 NPS	6 NPS	4.909 in ²	[N] 2.5 in	1.15 in	15-3705 psi	Air	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.38 in	15-3705 psi	Air	UV
6 NPS	8 NPS	12.566 in ²	[Q] 4 in	1.84 in	15-1480 psi	Air	UV
6 NPS	8 NPS	17.721 in ²	[R] 4.75 in	2.185 in	15-1480 psi	Air	UV
8 NPS	10 NPS	25.967 in ²	[T] 5.75 in	2.625 in	15-1480 psi	Air	UV

Toro Field Services, LLC (TOR)

Nameplate Abbreviation: TORO FS

Odessa, TX 79764United States

This Company Manufactures or Assembles:

Design Name:	78 (Pilot Operated)	NBCert #	44053
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	07/07/2029	

Design Type

[Pilot Operated Pressure Relief Valve] 78 (Pilot Operated)
Capacity Tests: Sec. UV at National Board Testing Lab on August 5, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.124 in ²	[D] 0.398 in	0.53 in	26.1-6250 psi	Air	UV

1-1.5 NPS	2 NPS	0.124 in ²	[D] 0.398 in	0.53 in	29-740 psi	Steam	UV
1-1.5 NPS	2 NPS	0.222 in ²	[E] 0.531 in	0.53 in	26.1-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.222 in ²	[E] 0.531 in	0.53 in	29-740 psi	Steam	UV
1-1.5 NPS	2 NPS	0.352 in ²	[F] 0.669 in	0.53 in	26.1-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.352 in ²	[F] 0.669 in	0.53 in	29-740 psi	Steam	UV
1.5-2 NPS	3 NPS	0.568 in ²	[G] 0.85 in	0.7 in	26.1-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.568 in ²	[G] 0.85 in	0.7 in	29-740 psi	Steam	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.7 in	26.1-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.7 in	29-740 psi	Steam	UV
2-3 NPS	3,4 NPS	1.457 in ²	[J] 1.362 in	0.8 in	26.1-6250 psi	Air	UV
2-3 NPS	3,4 NPS	1.457 in ²	[J] 1.362 in	0.8 in	29-740 psi	Steam	UV
3 NPS	4 NPS	2.097 in ²	[K] 1.634 in	1.18 in	26.1-3750 psi	Air	UV
3 NPS	4 NPS	2.097 in ²	[K] 1.634 in	1.18 in	29-740 psi	Steam	UV
3-4 NPS	4,6 NPS	3.229 in ²	[L] 2.028 in	1.18 in	26.1-3750 psi	Air	UV
3-4 NPS	4,6 NPS	3.229 in ²	[L] 2.028 in	1.18 in	29-740 psi	Steam	UV
4 NPS	6 NPS	4.095 in ²	[M] 2.284 in	1.57 in	26.1-3750 psi	Air	UV
4 NPS	6 NPS	4.095 in ²	[M] 2.284 in	1.57 in	29-740 psi	Steam	UV
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	1.57 in	26.1-3750 psi	Air	UV
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	1.57 in	29-740 psi	Steam	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.57 in	26.1-3750 psi	Air	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.57 in	29-740 psi	Steam	UV
6 NPS	8 NPS	12.915 in ²	[Q] 4.055 in	2.16 in	26.1-3750 psi	Air	UV
6 NPS	8 NPS	12.915 in ²	[Q] 4.055 in	2.16 in	29-740 psi	Steam	UV
6 NPS	8 NPS	15.904 in ²	[R] 4.5 in	2.16 in	26.1-1500 psi	Air	UV
6 NPS	8 NPS	15.904 in ²	[R] 4.5 in	2.16 in	29-740 psi	Steam	UV
8-8 NPS	10 NPS	28.274 in ²	[T] 6 in	2.99 in	26.1-1500 psi	Air	UV
8-8 NPS	10 NPS	28.274 in ²	[T] 6 in	2.99 in	29-740 psi	Steam	UV

Design Name: 78 (Pilot Operated, Liquid)

NBCert #

44064

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

03/24/2029

Design Type

[Pilot Operated Pressure Relief Valve] 78 (Pilot Operated, Liquid)
Capacity Tests: Sec. UV, V at National Board Testing Lab on August 6, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.857 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.124 in ²	[D] 0.398 in	0.53 in	26.1-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.222 in ²	[E] 0.531 in	0.53 in	26.1-6250 psi	Water	UV

1-1.5 NPS	2 NPS	0.352 in ²	[F] 0.669 in	0.53 in	26.1-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.568 in ²	[G] 0.85 in	0.7 in	26.1-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.7 in	26.1-6250 psi	Water	UV
2-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.362 in	0.8 in	26.1-6250 psi	Water	UV
3 NPS	4 NPS	2.097 in ²	[K] 1.634 in	1.18 in	26.1-3750 psi	Water	UV
3-4 NPS	4, 6 NPS	3.229 in ²	[L] 2.028 in	1.18 in	26.1-3750 psi	Water	UV
4 NPS	6 NPS	4.095 in ²	[M] 2.283 in	1.57 in	26.1-3750 psi	Water	UV
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	1.57 in	26.1-3750 psi	Water	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.57 in	26.1-3750 psi	Water	UV
6 NPS	8 NPS	12.915 in ²	[Q] 4.055 in	2.16 in	26.1-3750 psi	Water	UV
6 NPS	8 NPS	15.904 in ²	[R] 4.5 in	2.16 in	26.1-1500 psi	Water	UV
8 NPS	10 NPS	28.274 in ²	[T] 6 in	2.99 in	26.1-1500 psi	Water	UV

Design Name: 9 Series NBCert # 44019

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/24/2029

Design Type

[Safety Relief Valve] 9 Series
Capacity Tests: Sec. UV at National Board Testing Lab on July 24, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.823 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	0.236 in	0.07 in	15-4700 psi	Air	UV
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	0.236 in	0.07 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.124 in ²	0.398 in	0.1 in	14.5-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.124 in ²	0.398 in	0.1 in	14.5-4700 psi	Air	UV
0.75-1 NPS	1 NPS	0.222 in ²	0.531 in	0.13 in	14.5-2220 psi	Air	UV
0.75-1 NPS	1 NPS	0.222 in ²	0.531 in	0.13 in	14.5-2220 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.669 in	0.17 in	14.5-740 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.669 in	0.17 in	14.5-740 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	0.85 in	0.21 in	14.5-285 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	0.85 in	0.21 in	14.5-285 psi	Steam	UV

Design Name: P3, P4 (liquids) NBCert # 92012

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/24/2029

Design Type

[Relief Valve] P3, P4 (liquids)
 Capacity Tests: Sec. UV, V at National Board Testing Lab on December 7, 1993
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.631 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Water	UV, V
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Water	UV, V
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Water	UV, V
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Water	UV, V
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Water	UV, V
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Water	UV, V
4 NPS	6 NPS	7.032 in ²	[P] 2.992 in	0.94 in	15-1300 psi	Water	UV, V
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Water	UV, V
6 NPS	8-10 NPS	15.267 in ²	[R] 4.409 in	1.477 in	15-500 psi	Water	UV, V
8 NPS	10 NPS	28.126 in ²	[T] 5.984 in	1.88 in	15-500 psi	Water	UV, V

Design Name: P3, P4, P5

NBCert # 92001

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/07/2029

Design Type

[Safety Relief Valve] P3, P4, P5
 Capacity Tests: Sec. UV at unknown lab on June 5, 1986
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.876 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Air	UV
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Air	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-2900 psi	Steam	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-2900 psi	Steam	UV

1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Air	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-2900 psi	Steam	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Air	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-2900 psi	Steam	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Air	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Steam	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Air	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Steam	UV
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Air	UV
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Steam	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Air	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Steam	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Air	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Steam	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Air	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Steam	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Air	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Steam	UV

Total Valve Systems (TVO)

Broken Arrow, OK 74012United States

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S		NBCert # 57057
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/21/2029
Design Type		

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV

18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam) NBCert # 57260

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/11/2029

Design Type

[Safety Relief Valve] 2600L (Air & Steam)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV

8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name:	2600L (Liquids)	NBCert #	57068
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/04/2029

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 04/11/2029

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids)

NBCert #

57248

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/04/2029

Design Type

[Relief Valve] 2700L, 3700L (Liquids)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.676 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV

0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800	NBCert # 57024
-------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/14/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3800
Capacity Tests: Sec. UV at unknown lab on May 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.859 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV

4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name: 3800FP	NBCert # 57035
---------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	12/19/2025
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 3800FP
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on April 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-1050 psi	Steam	UV
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-11300 psi	Air	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-1050 psi	Steam	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-11300 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-1050 psi	Steam	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-11300 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-1050 psi	Steam	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-11300 psi	Air	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-6300 psi	Air	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-6300 psi	Air	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-2300 psi	Air	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1500 psi	Air	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-800 psi	Steam	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-1500 psi	Air	UV

Design Name: 3800L, PCL, PCM pilots		NBCert # 57215
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	02/21/2029
Design Type		
[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.782 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition(1): Pop; (2): First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Design Name: 4200 / 4400		NBCert # 57282
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	04/11/2029
Design Type		
[Safety Valve] 4200 / 4400 Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.872 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

Design Name: TRV 6820

NBCert #

00606

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UD

09/25/2026

Design Type

[Spring Loaded Non-Reclosing Pressure Relief Device] TRV 6820

Capacity Tests: Sec. UD at Oklahoma Safety Equipment Company, Inc. (OSECO) on June 25, 2014

Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg

Certified Value: 9.530 Unitless

Media - Test: Air/Gas; Certified: Compressible (Krg)

Set Pressure Definition: Pop

Flow Area Configuration: MNFA

Designed by: Total Valve Systems {TVO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10-10 NPS	10 NPS	49 in ²			15-285 psi		UD
10-10 NPS	10 NPS	41.6 in ²			15-1480 psi		UD
10-10 NPS	10 NPS	46.6 in ²			15-740 psi		UD
12-12 NPS	12 NPS	75.5 in ²			15-285 psi		UD
12-12 NPS	12 NPS	60.5 in ²			15-1480 psi		UD
12-12 NPS	12 NPS	66.8 in ²			15-740 psi		UD
14-14 NPS	14 NPS	97.6 in ²			15-285 psi		UD
14-14 NPS	14 NPS	87.6 in ²			15-1480 psi		UD
14-14 NPS	14 NPS	93.5 in ²			15-740 psi		UD
16-16 NPS	16 NPS	116.7 in ²			15-1480 psi		UD
16-16 NPS	16 NPS	123.9 in ²			15-740 psi		UD
16-16 NPS	16 NPS	128.6 in ²			15-285 psi		UD
18-18 NPS	18 NPS	152.4 in ²			15-1480 psi		UD
18-18 NPS	18 NPS	158.8 in ²			15-740 psi		UD
18-18 NPS	18 NPS	164.2 in ²			15-285 psi		UD
20-20 NPS	20 NPS	204.5 in ²			15-740 psi		UD
20-20 NPS	20 NPS	194.4 in ²			15-1480 psi		UD

20-20 NPS	20 NPS	210.6 in ²	15-285 psi	UD
24-24 NPS	24 NPS	307 in ²	15-740 psi	UD
24-24 NPS	24 NPS	286.2 in ²	15-1480 psi	UD
24-24 NPS	24 NPS	324.7 in ²	15-285 psi	UD
36-36 NPS	36 NPS	787.7 in ²	15-285 psi	UD
36-36 NPS	36 NPS	762.9 in ²	15-740 psi	UD
48-48 NPS	48 NPS	1358.2 in ²	15-740 psi	UD
48-48 NPS	48 NPS	1425.5 in ²	15-285 psi	UD
60-60 NPS	60 NPS	2169 in ²	15-740 psi	UD
60-60 NPS	60 NPS	2267 in ²	15-285 psi	UD
6-6 NPS	6 NPS	15.5 in ²	15-285 psi	UD
6-6 NPS	6 NPS	10.1 in ²	15-1480 psi	UD
6-6 NPS	6 NPS	12.8 in ²	15-740 psi	UD
72-72 NPS	72 NPS	3334 in ²	15-285 psi	UD
72-72 NPS	72 NPS	3174 in ²	15-740 psi	UD
84-84 NPS	84 NPS	4270 in ²	15-740 psi	UD
84-84 NPS	84 NPS	4546 in ²	15-285 psi	UD
8-8 NPS	8 NPS	29.2 in ²	15-285 psi	UD
8-8 NPS	8 NPS	23.2 in ²	15-1480 psi	UD
8-8 NPS	8 NPS	27.8 in ²	15-740 psi	UD

TRILLIUM Flow Technologies - France SAS (SAR)

Nameplate Abbreviation: TRILLIUM
FLOW TECHNOLOGIES

Vendin-le-Vieil, 62880France

This Company Manufactures or Assembles:

Design Name:	74 Series	NBCert #	44097
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UV	08/04/2028
--------------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 74 Series
Capacity Tests: Sec. UV at National Board Testing Lab on January 13, 2016
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.831 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 in	3 in	3.044 in ²	1.968 in	0.886 in	15-30 psi	Air	UV
3 in	4 in	7.792 in ²	3.15 in	1.417 in	15-30 psi	Air	UV
4 in	6 in	12.174 in ²	3.937 in	1.772 in	15-30 psi	Air	UV

6 NPS	8 NPS	27.39 in ²	5.906 in	2.953 in	15-30 psi	Air	UV
8 NPS	10 NPS	48.695 in ²	7.874 in	3.937 in	15-30 psi	Air	UV
10 NPS	12 NPS	76.085 in ²	9.842 in	4.921 in	15-30 psi	Air	UV
12 NPS	16 NPS	109.56 in ²	11.811 in	5.906 in	15-30 psi	Air	UV
14 NPS	18 NPS	149.13 in ²	13.78 in	6.89 in	15-30 psi	Air	UV

Design Name:	76 Series	NBCert #	44042
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 06/29/2026

Design Type

[Pilot Operated Pressure Relief Valve] 76 Series
Capacity Tests: Sec. UV at National Board Testing Lab on July 24, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.848 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}
Comments: Sizes and pressures listed are for valves manufactured after January 1, 2025. Please consult Manufacturer or National Board for historical data.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.13 in ²	[D] 0.405 in	0.101 in	26.1-10000 psi	Air	UV
1-1.5 NPS	2, 3 NPS	0.13 in ²	[D] 0.405 in	0.101 in	26.1-4350 psi	Steam	UV
1-1.5 NPS	2, 3 NPS	0.23 in ²	[E] 0.539 in	0.135 in	26.1-4350 psi	Steam	UV
1-1.5 NPS	2, 3 NPS	0.23 in ²	[E] 0.539 in	0.135 in	26.1-6250 psi	Air	UV
1-1.5 NPS	2, 3 NPS	0.36 in ²	[F] 0.673 in	0.169 in	26.1-4350 psi	Steam	UV
1-1.5 NPS	2, 3 NPS	0.36 in ²	[F] 0.673 in	0.169 in	26.1-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.59 in ²	[G] 0.866 in	0.217 in	26.1-4350 psi	Steam	UV
1.5-2 NPS	3 NPS	0.59 in ²	[G] 0.866 in	0.217 in	26.1-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.92 in ²	[H] 1.083 in	0.272 in	26.1-4350 psi	Steam	UV
1.5-2 NPS	3 NPS	0.92 in ²	[H] 1.083 in	0.272 in	26.1-6250 psi	Air	UV
2-3 NPS	3, 4 NPS	1.5 in ²	[J] 1.382 in	0.346 in	26.1-10000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.5 in ²	[J] 1.382 in	0.346 in	26.1-10000 psi	Steam	UV
3 NPS	4, 6 NPS	2.15 in ²	[K] 1.654 in	0.414 in	26.1-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.15 in ²	[K] 1.654 in	0.414 in	26.1-10000 psi	Steam	UV
3-4 NPS	6 NPS	3.35 in ²	[L] 2.067 in	0.516 in	26.1-3750 psi	Air	UV
3-4 NPS	6 NPS	3.35 in ²	[L] 2.067 in	0.516 in	26.1-3750 psi	Steam	UV
3-4 NPS	6 NPS	4.2 in ²	[M] 2.311 in	0.579 in	26.1-3750 psi	Air	UV
3-4 NPS	6 NPS	4.2 in ²	[M] 2.311 in	0.579 in	26.1-3750 psi	Steam	UV
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	0.665 in	26.1-2250 psi	Air	UV
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	0.665 in	26.1-2250 psi	Steam	UV
4 NPS	6 NPS	7.44 in ²	[P1] 3.079 in	0.903 in	26.1-2250 psi	Air	UV
4 NPS	6 NPS	7.44 in ²	[P1] 3.079 in	0.903 in	26.1-2250 psi	Steam	UV
6 NPS	8 NPS	12.915 in ²	[Q] 4.055 in	1.011 in	26.1-2250 psi	Air	UV

6 NPS	8 NPS	12.915 in ²	[Q] 4.055 in	1.011 in	26.1-2250 psi	Steam	UV
6 NPS	8, 10 NPS	18.6 in ²	[R1] 4.866 in	1.427 in	26.1-2250 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R1] 4.866 in	1.427 in	26.1-2250 psi	Steam	UV
8 NPS	10 NPS	22.19 in ²	[S] 5.315 in	1.331 in	26.1-1495 psi	Air	UV
8 NPS	10 NPS	22.19 in ²	[S] 5.315 in	1.331 in	26.1-1495 psi	Steam	UV
8 NPS	10 NPS	30.24 in ²	[T1] 6.205 in	1.82 in	26.1-1495 psi	Air	UV
8 NPS	10 NPS	30.24 in ²	[T1] 6.205 in	1.82 in	26.1-1495 psi	Steam	UV
10 NPS	14 NPS	39.44 in ²	[U] 7.087 in	1.771 in	26.1-290 psi	Air	UV
10 NPS	14 NPS	39.44 in ²	[U] 7.087 in	1.771 in	26.1-290 psi	Steam	UV
12 NPS	2x12 NPS	61.63 in ²	[W] 8.858 in	2.217 in	26.1-290 psi	Air	UV
12 NPS	2x12 NPS	61.63 in ²	[W] 8.858 in	2.217 in	26.1-290 psi	Steam	UV

Design Name:	76 Series (Liquid)	NBCert #	92056
--------------	--------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 03/19/2026

Design Type

[Pilot Operated Pressure Relief Valve] 76 Series (Liquid)
Capacity Tests: Sec. UV, V at National Board Testing Lab on June 7, 2013
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.850 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}
Comments: Sizes and pressures listed are for valves manufactured after January 1, 2025. Please consult Manufacturer or National Board for historical data.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.13 in ²	[D] 0.406 in	0.102 in	100-10000 psi	Water	UV
1-1.5 NPS	2, 3 NPS	0.23 in ²	[E] 0.539 in	0.135 in	100-6960 psi	Water	UV
1.5-1.5 NPS	2, 3 NPS	0.36 in ²	[F] 0.673 in	0.169 in	100-6960 psi	Water	UV
1.5-2 NPS	3 NPS	0.59 in ²	[G] 0.866 in	0.217 in	100-6960 psi	Water	UV
1.5-2 NPS	3 NPS	0.92 in ²	[H] 1.083 in	0.272 in	100-6960 psi	Water	UV
2-3 NPS	3, 4 NPS	1.5 in ²	[J] 1.382 in	0.346 in	100-3750 psi	Water	UV
3-3 NPS	4, 6 NPS	2.15 in ²	[K] 1.654 in	0.414 in	100-3750 psi	Water	UV
3-4 NPS	6 NPS	3.35 in ²	[L] 2.067 in	0.516 in	100-10000 psi	Water	UV
4-4 NPS	6 NPS	4.2 in ²	[M] 2.311 in	0.579 in	100-3750 psi	Water	UV
4-4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	0.665 in	100-3750 psi	Water	UV
4-4 NPS	6 NPS	7.069 in ²	[P] 3 in	0.771 in	100-3750 psi	Water	UV
6-6 NPS	8 NPS	12.92 in ²	[Q] 4.055 in	1.011 in	100-3750 psi	Water	UV
6-6 NPS	8, 10 NPS	15.9 in ²	[R] 4.5 in	1.217 in	100-3750 psi	Water	UV
8-8 NPS	10 NPS	22.19 in ²	[S] 5.315 in	1.331 in	100-1500 psi	Water	UV
8-8 NPS	10 NPS	28.27 in ²	[T] 6 in	1.551 in	100-1500 psi	Water	UV
10-10 NPS	14 NPS	39.44 in ²	[U] 7.087 in	1.771 in	100-750 psi	Water	UV
12-12 NPS	2x12 NPS	61.63 in ²	[W] 8.858 in	2.217 in	100-750 psi	Water	UV

Design Name: 76 Series Steam & Liquid (Water K=0.850) NBCert # 44031

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	V	12/03/2027

Design Type

[Pilot Operated Pressure Relief Valve] 76 Series Steam & Liquid (Water K=0.850)
 Capacity Tests: Sec. V at National Board Testing Lab on October 27, 2014
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.873 Unitless; (alternate medium): 0.850 Unitless
 Media - Test: Liquid, Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: TRILLIUM Flow Technologies - France SAS {SAR}
 Comments: Ref.: Code Case 2446

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.124 in ²	[D] 0.398 in	0.1 in	100-6960 psi	Steam	V
1-1.5 NPS	2, 3 NPS	0.124 in ²	[D] 0.398 in	0.1 in	100-6960 psi	Water	V
1-1.5 NPS	2, 3 NPS	0.222 in ²	[E] 0.531 in	0.13 in	100-6960 psi	Steam	V
1-1.5 NPS	2, 3 NPS	0.222 in ²	[E] 0.531 in	0.13 in	100-6960 psi	Water	V
1-1.5 NPS	2, 3 NPS	0.352 in ²	[F] 0.669 in	0.17 in	100-6960 psi	Steam	V
1-1.5 NPS	2, 3 NPS	0.352 in ²	[F] 0.669 in	0.17 in	100-6960 psi	Water	V
1.5-2 NPS	2, 3 NPS	0.568 in ²	[G] 0.85 in	0.21 in	100-6960 psi	Steam	V
1.5-2 NPS	2, 3 NPS	0.568 in ²	[G] 0.85 in	0.21 in	100-6960 psi	Water	V
1.5-2 NPS	2, 3 NPS	0.887 in ²	[H] 1.063 in	0.43 in	100-6960 psi	Steam	V
1.5-2 NPS	2, 3 NPS	0.887 in ²	[H] 1.063 in	0.43 in	100-6960 psi	Water	V
2-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.362 in	0.34 in	100-6960 psi	Steam	V
2-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.362 in	0.34 in	100-6960 psi	Water	V
3 NPS	4, 6 NPS	2.097 in ²	[K] 1.634 in	0.41 in	100-6960 psi	Steam	V
3 NPS	4, 6 NPS	2.097 in ²	[K] 1.634 in	0.41 in	100-6960 psi	Water	V
3-4 NPS	4, 6 NPS	3.229 in ²	[L] 2.028 in	0.51 in	100-3750 psi	Steam	V
3-4 NPS	4, 6 NPS	3.229 in ²	[L] 2.028 in	0.51 in	100-3750 psi	Water	V
4 NPS	6 NPS	3.818 in ²	[M] 2.205 in	0.57 in	100-3750 psi	Steam	V
4 NPS	6 NPS	3.818 in ²	[M] 2.205 in	0.57 in	100-3750 psi	Water	V
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	0.64 in	100-3750 psi	Steam	V
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	0.64 in	100-3750 psi	Water	V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	0.75 in	100-3750 psi	Steam	V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	0.75 in	100-3750 psi	Water	V
6 NPS	8 NPS	12.92 in ²	[Q] 4.055 in	1.01 in	100-3750 psi	Steam	V
6 NPS	8 NPS	12.92 in ²	[Q] 4.055 in	1.01 in	100-3750 psi	Water	V
6 NPS	8,10 NPS	15.9 in ²	[R] 4.5 in	1.13 in	100-3750 psi	Steam	V
6 NPS	8,10 NPS	15.9 in ²	[R] 4.5 in	1.13 in	100-3750 psi	Water	V
8 NPS	10 NPS	22.19 in ²	[S] 5.315 in	1.33 in	100-1500 psi	Steam	V
8 NPS	10 NPS	22.19 in ²	[S] 5.315 in	1.33 in	100-1500 psi	Water	V

8 NPS	10 NPS	28.27 in ²	[T] 6 in	1.5 in	100-1500 psi	Water	V
8 NPS	10 NPS	28.27 in ²	[T] 6 in	1.5 in	100-1500 psi	Steam	V
10 NPS	14 NPS	39.44 in ²	[U] 7.087 in	1.77 in	100-750 psi	Steam	V
10 NPS	14 NPS	39.44 in ²	[U] 7.087 in	1.77 in	100-750 psi	Water	V
12 NPS	2x12 NPS	61.63 in ²	[W] 8.858 in	2.21 in	100-750 psi	Steam	V
12 NPS	2x12 NPS	61.63 in ²	[W] 8.858 in	2.21 in	100-750 psi	Water	V

Design Name: 78 (Pilot Operated)

NBCert # 44053

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer

UV

04/17/2030

Design Type

[Pilot Operated Pressure Relief Valve] 78 (Pilot Operated)
Capacity Tests: Sec. UV at National Board Testing Lab on August 5, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.124 in ²	[D] 0.398 in	0.53 in	26.1-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.124 in ²	[D] 0.398 in	0.53 in	29-740 psi	Steam	UV
1-1.5 NPS	2 NPS	0.222 in ²	[E] 0.531 in	0.53 in	26.1-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.222 in ²	[E] 0.531 in	0.53 in	29-740 psi	Steam	UV
1-1.5 NPS	2 NPS	0.352 in ²	[F] 0.669 in	0.53 in	26.1-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.352 in ²	[F] 0.669 in	0.53 in	29-740 psi	Steam	UV
1.5-2 NPS	3 NPS	0.568 in ²	[G] 0.85 in	0.7 in	26.1-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.568 in ²	[G] 0.85 in	0.7 in	29-740 psi	Steam	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.7 in	26.1-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.7 in	29-740 psi	Steam	UV
2-3 NPS	3,4 NPS	1.457 in ²	[J] 1.362 in	0.8 in	26.1-6250 psi	Air	UV
2-3 NPS	3,4 NPS	1.457 in ²	[J] 1.362 in	0.8 in	29-740 psi	Steam	UV
3 NPS	4 NPS	2.097 in ²	[K] 1.634 in	1.18 in	26.1-3750 psi	Air	UV
3 NPS	4 NPS	2.097 in ²	[K] 1.634 in	1.18 in	29-740 psi	Steam	UV
3-4 NPS	4,6 NPS	3.229 in ²	[L] 2.028 in	1.18 in	26.1-3750 psi	Air	UV
3-4 NPS	4,6 NPS	3.229 in ²	[L] 2.028 in	1.18 in	29-740 psi	Steam	UV
4 NPS	6 NPS	4.095 in ²	[M] 2.284 in	1.57 in	26.1-3750 psi	Air	UV
4 NPS	6 NPS	4.095 in ²	[M] 2.284 in	1.57 in	29-740 psi	Steam	UV
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	1.57 in	26.1-3750 psi	Air	UV
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	1.57 in	29-740 psi	Steam	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.57 in	26.1-3750 psi	Air	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.57 in	29-740 psi	Steam	UV
6 NPS	8 NPS	12.915 in ²	[Q] 4.055 in	2.16 in	26.1-3750 psi	Air	UV

6 NPS	8 NPS	12.915 in ²	[Q] 4.055 in	2.16 in	29-740 psi	Steam	UV
6 NPS	8 NPS	15.904 in ²	[R] 4.5 in	2.16 in	26.1-1500 psi	Air	UV
6 NPS	8 NPS	15.904 in ²	[R] 4.5 in	2.16 in	29-740 psi	Steam	UV
8-8 NPS	10 NPS	28.274 in ²	[T] 6 in	2.99 in	26.1-1500 psi	Air	UV
8-8 NPS	10 NPS	28.274 in ²	[T] 6 in	2.99 in	29-740 psi	Steam	UV

Design Name: 78 (Pilot Operated, Liquid) NBCert # 44064

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 04/17/2030

Design Type

[Pilot Operated Pressure Relief Valve] 78 (Pilot Operated, Liquid)
Capacity Tests: Sec. UV, V at National Board Testing Lab on August 6, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.857 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.124 in ²	[D] 0.398 in	0.53 in	26.1-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.222 in ²	[E] 0.531 in	0.53 in	26.1-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.352 in ²	[F] 0.669 in	0.53 in	26.1-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.568 in ²	[G] 0.85 in	0.7 in	26.1-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.7 in	26.1-6250 psi	Water	UV
2-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.362 in	0.8 in	26.1-6250 psi	Water	UV
3 NPS	4 NPS	2.097 in ²	[K] 1.634 in	1.18 in	26.1-3750 psi	Water	UV
3-4 NPS	4, 6 NPS	3.229 in ²	[L] 2.028 in	1.18 in	26.1-3750 psi	Water	UV
4 NPS	6 NPS	4.095 in ²	[M] 2.283 in	1.57 in	26.1-3750 psi	Water	UV
4 NPS	6 NPS	5.143 in ²	[N] 2.559 in	1.57 in	26.1-3750 psi	Water	UV
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.57 in	26.1-3750 psi	Water	UV
6 NPS	8 NPS	12.915 in ²	[Q] 4.055 in	2.16 in	26.1-3750 psi	Water	UV
6 NPS	8 NPS	15.904 in ²	[R] 4.5 in	2.16 in	26.1-1500 psi	Water	UV
8 NPS	10 NPS	28.274 in ²	[T] 6 in	2.99 in	26.1-1500 psi	Water	UV

Design Name: 78FB Series NBCert # 44075

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 08/18/2028

Design Type

[Pilot Operated Pressure Relief Valve] 78FB Series
Capacity Tests: Sec. UV at National Board Testing Lab on December 13, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.832 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.5 in ²	1.382 in	0.691 in	15-6236 psi	Air	UV
1.5 NPS	2 NPS	1.5 in ²	1.382 in	0.691 in	15-720 psi	Steam	UV
2 NPS	3, 3 Dual NPS	3.04 in ²	1.969 in	0.984 in	15-6236 psi	Air	UV
2 NPS	3, 3 Dual NPS	3.04 in ²	1.969 in	0.984 in	15-720 psi	Steam	UV
3 NPS	4, 4 Dual NPS	6.74 in ²	2.929 in	1.465 in	15-3742 psi	Air	UV
3 NPS	4, 4 Dual NPS	6.74 in ²	2.929 in	1.465 in	15-720 psi	Steam	UV
4 NPS	6, 6 Dual NPS	12.17 in ²	3.937 in	1.969 in	15-3742 psi	Air	UV
4 NPS	6, 6 Dual NPS	12.17 in ²	3.937 in	1.969 in	15-720 psi	Steam	UV
6 NPS	8, 8 Dual NPS	23.86 in ²	5.512 in	2.756 in	15-1494 psi	Air	UV
6 NPS	8, 8 Dual NPS	23.86 in ²	5.512 in	2.756 in	15-720 psi	Steam	UV
8 NPS	8 Dual NPS	38.139 in ²	6.969 in	3.484 in	15-1494 psi	Air	UV
8 NPS	8 Dual NPS	38.139 in ²	6.969 in	3.484 in	15-720 psi	Steam	UV
8 NPS	10, 10 Dual NPS	44.41 in ²	7.52 in	4.793 in	15-1494 psi	Air	UV
8 NPS	10, 10 Dual NPS	44.41 in ²	7.52 in	4.793 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.18 in ²	9.587 in	4.793 in	15-740 psi	Air	UV
10 NPS	14 NPS	72.18 in ²	9.587 in	4.793 in	15-720 psi	Steam	UV

Design Name: 78FB Series (Liquid)	NBCert # 44086
-----------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 08/18/2028

Design Type

[Pilot Operated Pressure Relief Valve] 78FB Series (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on January 21, 2022
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.705 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.5 in ²	1.382 in	0.691 in	15-6236 psi	Water	UV
2 NPS	3, 3 Dual NPS	3.04 in ²	1.969 in	0.984 in	15-6236 psi	Water	UV
3 NPS	4, 4 Dual NPS	6.74 in ²	2.929 in	1.465 in	15-3742 psi	Water	UV
4 NPS	6, 6 Dual NPS	12.17 in ²	3.937 in	1.969 in	15-3742 psi	Water	UV
6 NPS	8, 8 Dual NPS	23.86 in ²	5.512 in	2.756 in	15-1494 psi	Water	UV
8 NPS	8 Dual NPS	38.139 in ²	6.969 in	3.484 in	15-1494 psi	Water	UV
8 NPS	10, 10 Dual NPS	44.41 in ²	7.52 in	4.793 in	15-1494 psi	Water	UV
10 NPS	14 NPS	72.18 in ²	9.587 in	4.793 in	15-740 psi	Water	UV

Design Name: 9 Series		NBCert # 44019
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	06/30/2026
Design Type		
[Safety Relief Valve] 9 Series Capacity Tests: Sec. UV at National Board Testing Lab on July 24, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.823 Unitless Media - Test: Air/Gas; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: TRILLIUM Flow Technologies - France SAS {SAR}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	0.236 in	0.07 in	15-4700 psi	Air	UV
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	0.236 in	0.07 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.124 in ²	0.398 in	0.1 in	14.5-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.124 in ²	0.398 in	0.1 in	14.5-4700 psi	Air	UV
0.75-1 NPS	1 NPS	0.222 in ²	0.531 in	0.13 in	14.5-2220 psi	Air	UV
0.75-1 NPS	1 NPS	0.222 in ²	0.531 in	0.13 in	14.5-2220 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.669 in	0.17 in	14.5-740 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	0.669 in	0.17 in	14.5-740 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	0.85 in	0.21 in	14.5-285 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	0.85 in	0.21 in	14.5-285 psi	Steam	UV

Design Name: 9 Series (Liquids)		NBCert # 44020
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/09/2026
Design Type		
[Relief Valve] 9 Series (Liquids) Capacity Tests: Sec. UV, V at National Board Testing Lab on July 24, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.632 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: TRILLIUM Flow Technologies - France SAS {SAR}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	[B] 0.236 in	0.07 in	15-6250 psi	Water	UV
0.5-1 NPS	1 NPS	0.124 in ²	[D] 0.398 in	0.1 in	14.5-6250 psi	Water	UV
0.75-1 NPS	1 NPS	0.222 in ²	[E] 0.531 in	0.13 in	14.5-2220 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	[F] 0.669 in	0.17 in	14.5-740 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	[G] 0.85 in	0.21 in	14.5-285 psi	Water	UV

Design Name:	P3, P4 (liquids)	NBCert #	92012
--------------	------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	04/17/2030

Design Type

[Relief Valve] P3, P4 (liquids)
Capacity Tests: Sec. UV, V at National Board Testing Lab on December 7, 1993
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.631 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Water	UV, V
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Water	UV, V
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Water	UV, V
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Water	UV, V
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Water	UV, V
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Water	UV, V
4 NPS	6 NPS	7.032 in ²	[P] 2.992 in	0.94 in	15-1300 psi	Water	UV, V
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Water	UV, V
6 NPS	8-10 NPS	15.267 in ²	[R] 4.409 in	1.477 in	15-500 psi	Water	UV, V
8 NPS	10 NPS	28.126 in ²	[T] 5.984 in	1.88 in	15-500 psi	Water	UV, V

Design Name:	P3, P4, P5	NBCert #	92001
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	12/20/2030

Design Type

[Safety Relief Valve] P3, P4, P5
Capacity Tests: Sec. UV at unknown lab on June 5, 1986
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Air	UV
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-2900 psi	Steam	UV

1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Air	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-2900 psi	Steam	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Air	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-2900 psi	Steam	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Air	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-2900 psi	Steam	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Air	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Steam	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Air	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Steam	UV
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Air	UV
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Steam	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Air	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Steam	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Air	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Steam	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Air	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Steam	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Air	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Steam	UV

Design Name: STARFLOW-V

NBCert # 44110

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	12/20/2029

Design Type

[Safety Valve] STARFLOW-V
Capacity Tests: Sec. UV, V at National Board Testing Lab on April 26, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}
Comments: org. date added and V orif. area corrected from 38.548 to 38.485 JB 8-10-20
corrected H inlet to add 1.5" JB -8-2-21

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5-3 NPS	0.373 in ²	[F] 0.689 in	0.172 in	30-2250 psi	Steam	UV, V
1.25-2 NPS	1.5-3 NPS	0.589 in ²	[G] 0.8661 in	0.217 in	30-2250 psi	Steam	UV, V
1.5-2 NPS	2.5, 3 NPS	0.996 in ²	[H] 1.126 in	0.281 in	30-2250 psi	Steam	UV, V
1.5-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.3622 in	0.341 in	30-2250 psi	Steam	UV, V
2-3 NPS	3-6 NPS	1.667 in ²	[K] 1.457 in	0.364 in	30-2250 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.758 in ²	[L] 1.874 in	0.469 in	30-2250 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.983 in ²	[M] 2.252 in	0.563 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	5.303 in ²	[N] 2.5984 in	0.65 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	0.75 in	30-2250 psi	Steam	UV, V
6 NPS	8 NPS	10.148 in ²	[Q] 3.594 in	0.902 in	30-1494 psi	Steam	UV, V
6 NPS	8, 10 NPS	14.173 in ²	[R] 4.248 in	1.062 in	30-1494 psi	Steam	UV, V
8 NPS	10 NPS	23.997 in ²	[T] 5.528 in	1.382 in	30-740 psi	Steam	UV, V
10 NPS	14 NPS	38.485 in ²	[V] 7 in	1.75 in	30-740 psi	Steam	UV, V
12 NPS	2x12 NPS	55.438 in ²	[W] 8.402 in	2.1 in	30-740 psi	Steam	UV, V

Design Name: STARFLOW-V (Restricted Lift) NBCert # 44121

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV, V	12/20/2029

Design Type

[Safety Valve] STARFLOW-V (Restricted Lift)
Capacity Tests: Sec. UV, V at National Board Testing Lab on April 27, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Restricted Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}
Comments: Org. date added and "V" orif. area corrected from 34.485 to 38.485 JB 8-10-20
corrected H by adding 1.5" inlet JB 8-2-21

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5-3 NPS	0.373 in ²	[F] 0.689 in	0.095 in	30-2250 psi	Steam	UV, V
1.25-2 NPS	1.5-3 NPS	0.589 in ²	[G] 0.8661 in	0.119 in	30-2250 psi	Steam	UV, V
1.5-2 NPS	2.5, 3 NPS	0.996 in ²	[H] 1.126 in	0.156 in	30-2250 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.457 in ²	[J] 1.3622 in	0.188 in	30-2250 psi	Steam	UV, V
2-3 NPS	3-6 NPS	1.667 in ²	[K] 1.457 in	0.201 in	30-2250 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.758 in ²	[L] 1.874 in	0.258 in	30-2250 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.983 in ²	[M] 2.252 in	0.31 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	5.303 in ²	[N] 2.5984 in	0.357 in	30-2250 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	0.414 in	30-2250 psi	Steam	UV, V
6 NPS	8 NPS	10.148 in ²	[Q] 3.594 in	0.496 in	30-1494 psi	Steam	UV, V
6 NPS	8, 10 NPS	14.173 in ²	[R] 4.248 in	0.584 in	30-1494 psi	Steam	UV, V
8 NPS	10 NPS	23.997 in ²	[T] 5.528 in	0.76 in	30-740 psi	Steam	UV, V

10 NPS	14 NPS	38.485 in ²	[V] 7 in	0.963 in	30-740 psi	Steam	UV, V
12 NPS	2x12 NPS	55.438 in ²	[W] 8.402 in	1.155 in	30-740 psi	Steam	UV, V

Design Name:	Starsteam V Series	NBCert #	92034
--------------	--------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 07/24/2025

Design Type

[Safety Valve] Starsteam V Series
Capacity Tests: Sec. UV, V at National Board Testing Lab on August 3, 2012
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	3 NPS	0.996 in ²	[1] 1.125 in	0.2835 in	15-6525 psi	Steam	UV, V
2 NPS	3 NPS	1.667 in ²	[2] 1.456 in	0.3661 in	15-6525 psi	Steam	UV, V
2.5-6 NPS	6 NPS	2.758 in ²	[3] 1.874 in	0.4685 in	15-6525 psi	Steam	UV, V
3 NPS	6 NPS	3.983 in ²	[4] 2.251 in	0.562 in	15-6525 psi	Steam	UV, V
4 NPS	6 NPS	5.303 in ²	[5] 2.598 in	0.6496 in	15-6525 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[6] 3 in	0.752 in	15-3280 psi	Steam	UV, V
6 NPS	8 NPS	11.056 in ²	[Q] 3.751 in	0.9409 in	15-2798.5 psi	Steam	UV, V
6 NPS	10 NPS	15.904 in ²	[R] 4.5 in	1.126 in	15-1580 psi	Steam	UV, V
6 NPS	10 NPS	19.299 in ²	[RR] 4.957 in	1.239 in	15-1580 psi	Steam	UV, V
8 NPS	10 NPS	27.391 in ²	[T] 5.905 in	1.4764 in	15-1190 psi	Steam	UV, V

Design Name:	Starsteam V Series (Res. Lift)	NBCert #	92045
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV, V 01/24/2031

Design Type

[Safety Valve] Starsteam V Series (Res. Lift)
Capacity Tests: Sec. UV, V at National Board Testing Lab on August 6, 2012
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Restricted Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	3 NPS	0.996 in ²	[1] 1.125 in	0.156 in	15-6525 psi	Steam	UV, V
2 NPS	3 NPS	1.667 in ²	[2] 1.456 in	0.201 in	15-6525 psi	Steam	UV, V
2.5 NPS	6 NPS	2.758 in ²	[3] 1.874 in	0.258 in	15-6525 psi	Steam	UV, V
3 NPS	6 NPS	3.983 in ²	[4] 2.251 in	0.309 in	15-6525 psi	Steam	UV, V

4 NPS	6 NPS	5.303 in ²	[5] 2.598 in	0.357 in	15-6525 psi	Steam	UV, V
4 NPS	6 NPS	7.069 in ²	[6] 3 in	0.414 in	15-3280 psi	Steam	UV, V
6 NPS	8 NPS	11.056 in ²	[Q] 3.571 in	0.517 in	15-2798 psi	Steam	UV, V
6 NPS	10 NPS	15.904 in ²	[R] 4.5 in	0.619 in	15-1580 psi	Steam	UV, V
6 NPS	10 NPS	19.299 in ²	[RR] 4.957 in	0.681 in	15-1580 psi	Steam	UV, V
8 NPS	10 NPS	27.391 in ²	[T] 5.905 in	0.812 in	15-1190 psi	Steam	UV, V

TRILLIUM FLOW TECHNOLOGIES FRANCE SAS (WPI)

SAINT VICTORET, 13730France

This Company Manufactures or Assembles:

Design Name: 9 Series (Liquids) NBCert # 44020

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV 07/08/2028

Design Type

[Relief Valve] 9 Series (Liquids)
Capacity Tests: Sec. UV, V at National Board Testing Lab on July 24, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.632 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	0.5, 1 NPS	0.0438 in ²	[B] 0.236 in	0.07 in	15-6250 psi	Water	UV
0.5-1 NPS	1 NPS	0.124 in ²	[D] 0.398 in	0.1 in	14.5-6250 psi	Water	UV
0.75-1 NPS	1 NPS	0.222 in ²	[E] 0.531 in	0.13 in	14.5-2220 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.352 in ²	[F] 0.669 in	0.17 in	14.5-740 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.568 in ²	[G] 0.85 in	0.21 in	14.5-285 psi	Water	UV

Design Name: 9 Series LBD NBCert # 92450

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer NV, -Class 3 03/14/2029

Design Type

[Safety Relief Valve] 9 Series LBD
Capacity Tests: Sec. NV, -Class 3 at National Board Testing Lab on March 14, 2023
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value: 47.900 GPM
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM FLOW TECHNOLOGIES FRANCE SAS {WPI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.124 in ²	[D] 0.398 in	0.1 in	200-200 psi	Water	NV, -Class 3

Design Name:	P3, P4 (liquids)	NBCert #	92012
--------------	------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 3	05/24/2028

Design Type

[Relief Valve] P3, P4 (liquids)
Capacity Tests: Sec. UV, V at National Board Testing Lab on December 7, 1993
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.631 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Water	UV, V
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Water	UV, V
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Water	UV, V
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Water	UV, V
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Water	UV, V
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Water	UV, V
4 NPS	6 NPS	7.032 in ²	[P] 2.992 in	0.94 in	15-1300 psi	Water	UV, V
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Water	UV, V
6 NPS	8-10 NPS	15.267 in ²	[R] 4.409 in	1.477 in	15-500 psi	Water	UV, V
8 NPS	10 NPS	28.126 in ²	[T] 5.984 in	1.88 in	15-500 psi	Water	UV, V

Design Name:	P3, P4, P5	NBCert #	92001
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV, -Class 3	05/24/2028

Design Type

[Safety Relief Valve] P3, P4, P5
Capacity Tests: Sec. UV at unknown lab on June 5, 1986
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.876 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Air	UV
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Air	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-2900 psi	Steam	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Air	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-2900 psi	Steam	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Air	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-2900 psi	Steam	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Air	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Steam	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Air	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Steam	UV
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Air	UV
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Steam	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Air	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Steam	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Air	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Steam	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Air	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Steam	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Air	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Steam	UV

Design Name: SD04X25

NBCert # 92461

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	NV	12/20/2028

Design Type

[Vacuum Relief Valve] SD04X25
Capacity Tests: Sec. NV, -Class 3 at National Board Testing Lab on December 20, 2022
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:152.00 SCFM
Media - Test: Air/Gas; Certified: Air/Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM FLOW TECHNOLOGIES FRANCE SAS {WPI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	1.5 NPS	2.63 in ²	1.83 in	0.417 in	-0.3-0 psi	Air	NV, -Class 3

Design Name: SD05A01 NBCert # 92472

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	NV, -Class 3	05/18/2029
--------------	--------------	------------

Design Type

[Vacuum Relief Valve] SD05A01
Capacity Tests: Sec. NV, -Class 3 at National Board Testing Lab {unknown test date}
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:286.00 SCFM
Media - Test: Air/Gas; Certified: Air/Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM FLOW TECHNOLOGIES FRANCE SAS {WPI}
Comments: Test at 5 psi max.

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	3.8 in ²	2.2 in	0.502 in	-3-0 psi	Air	NV, -Class 3

Design Name: SD10X01 NBCert # 92483

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	NV, -Class 3	03/14/2029
--------------	--------------	------------

Design Type

[Vacuum Relief Valve] SD10X01
Capacity Tests: Sec. NV, -Class 3 at National Board Testing Lab on March 14, 2023
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:788.00 SCFM
Media - Test: Air/Gas; Certified: Air/Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM FLOW TECHNOLOGIES FRANCE SAS {WPI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 NPS	4 NPS	16.47 in ²	4.58 in	1.044 in	-0.2--0.2 psi	Air	NV, -Class 3

Design Name: SD10X06 NBCert # 92494

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	NV, -Class 3	03/14/2029
--------------	--------------	------------

Design Type

[Vacuum Relief Valve] SD10X06
Capacity Tests: Sec. NV, -Class 3 at National Board Testing Lab on March 14, 2023
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value: 806.00 SCFM
Media - Test: Air/Gas; Certified: Air/Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration:
Designed by: TRILLIUM FLOW TECHNOLOGIES FRANCE SAS {WPI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
4 NPS	4 NPS	16.47 in ²	4.58 in	1.044 in	-0.3--0.3 psi	Air	NV, -Class 3

Design Name: Starflow P Series (3 psi) NBCert # 92449

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer NV, -Class 3 05/25/2028

Design Type

[Safety Relief Valve] Starflow P Series (3 psi)
Capacity Tests: Sec. NV, -Class 3 at National Board Testing Lab on May 25, 2022
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value: 0.000 SCFM
Media - Test: Air/Gas; Certified: Air
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM FLOW TECHNOLOGIES FRANCE SAS {WPI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2-2 NPS	3 NPS	0.274 in ²	[E] 0.591 in	0.183 in	3-3 psi	Air	NV, -Class 3

Design Name: Starflow SF NBCert # 92438

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer NV, -Class 2, -Class 3 02/09/2029

Design Type

[Safety Relief Valve] Starflow SF
Capacity Tests: Sec. NV, -Class 2, -Class 3 at National Board Testing Lab on February 6, 2023
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.590 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM FLOW TECHNOLOGIES FRANCE SAS {WPI}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.134 in ²	[D] 0.413 in	0.128 in	80-900 psi	Water	NV, -Class 2, -Class 3

Trillium Flow Technologies Suzhou Ltd (WSZ)

Jiangsu, 215555People's Republic of China

This Company Manufactures or Assembles:

Design Name:	P3, P4 (liquids)	NBCert #	92012
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	04/16/2030	

Design Type

[Relief Valve] P3, P4 (liquids)
Capacity Tests: Sec. UV, V at National Board Testing Lab on December 7, 1993
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.631 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Water	UV, V
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Water	UV, V
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Water	UV, V
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Water	UV, V
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Water	UV, V
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Water	UV, V
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Water	UV, V
4 NPS	6 NPS	7.032 in ²	[P] 2.992 in	0.94 in	15-1300 psi	Water	UV, V
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Water	UV, V
6 NPS	8-10 NPS	15.267 in ²	[R] 4.409 in	1.477 in	15-500 psi	Water	UV, V
8 NPS	10 NPS	28.126 in ²	[T] 5.984 in	1.88 in	15-500 psi	Water	UV, V

Design Name:	P3, P4, P5	NBCert #	92001
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UV	01/17/2030	

Design Type

[Safety Relief Valve] P3, P4, P5
 Capacity Tests: Sec. UV at unknown lab on June 5, 1986
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.876 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: TRILLIUM Flow Technologies - France SAS {SAR}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-10000 psi	Air	UV
1-2 NPS	2-3 NPS	0.134 in ²	[D] 0.413 in	0.128 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-2900 psi	Steam	UV
1-1.5 NPS	2-3 NPS	0.273 in ²	[E] 0.59 in	0.183 in	15-7500 psi	Air	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-2900 psi	Steam	UV
1.5 NPS	2-3 NPS	0.373 in ²	[F] 0.689 in	0.214 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.589 in ²	[G] 0.866 in	0.268 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.881 in ²	[H] 1.059 in	0.328 in	15-5000 psi	Air	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-2900 psi	Steam	UV
2-3 NPS	3-4 NPS	1.457 in ²	[J] 1.362 in	0.422 in	15-3200 psi	Air	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-2900 psi	Steam	UV
3 NPS	4-6 NPS	2.097 in ²	[K] 1.634 in	0.506 in	15-3200 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Air	UV
3-4 NPS	4-6 NPS	3.284 in ²	[L] 2.045 in	0.634 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Air	UV
4 NPS	6 NPS	4.093 in ²	[M] 2.283 in	0.708 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Air	UV
4 NPS	6 NPS	4.987 in ²	[N] 2.52 in	0.781 in	15-1300 psi	Steam	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Air	UV
4 NPS	6 NPS	7.215 in ²	[P] 3.031 in	0.94 in	15-1300 psi	Steam	UV
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Air	UV
6 NPS	8 NPS	12.914 in ²	[Q] 4.055 in	1.257 in	15-1000 psi	Steam	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Air	UV
6 NPS	8-10 NPS	17.818 in ²	[R] 4.763 in	1.477 in	15-700 psi	Steam	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Air	UV
8 NPS	10 NPS	28.871 in ²	[T] 6.063 in	1.88 in	15-600 psi	Steam	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Air	UV
10 NPS	14 NPS	46.759 in ²	[V] 7.716 in	2.392 in	15-450 psi	Steam	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Air	UV
12 NPS	Dual 12 NPS	70.108 in ²	[W] 9.448 in	2.93 in	15-450 psi	Steam	UV

Tri-State Valves & Controls, Inc. (PLD)

Indianapolis, IN 46219United States

This Company Manufactures or Assembles:

Design Name:	Kunkle 6000, 6252 Series	NBCert #	36324
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV, V	08/02/2025	

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2.5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V

2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 910 to 919

NBCert # 36100

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/02/2025

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name:	Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)		NBCert #	36111	
Manufacturer/Assembler			Designators		Expiration Date
Assembler			UV		10/28/2025
Design Type					
[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid) Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.710 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}					

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 , 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

Tundra Process Solutions Ltd. (TPS)

Edmonton, AB T5S 2L2Canada

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S		NBCert #	57057
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV	01/04/2030	
Design Type			
[Safety Relief Valve] 2600 & 2600S Capacity Tests: Sec. UV at unknown lab on June 11, 1972 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.858 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV

1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name:	2600 Series Restricted Lift version of Cert Number 57057	NBCert #	57406
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	08/08/2030
-----------	----	------------

Design Type

[Safety Relief Valve] 2600 Series Restricted Lift version of Cert Number 57057
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 10, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Air	UV
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Steam	UV
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Air	UV
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Steam	UV
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Air	UV
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Steam	UV
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.08 in	15-7000 psi	Air	UV
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.08 in	15-7000 psi	Steam	UV
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.095 in	15-6000 psi	Air	UV
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.095 in	15-6000 psi	Steam	UV
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.122 in	15-6000 psi	Air	UV
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.122 in	15-6000 psi	Steam	UV
3 in	4, 6 in	2.042 in ²	[K] 1.612 in	0.145 in	15-5000 psi	Air	UV
3 in	4, 6 in	2.042 in ²	[K] 1.612 in	0.145 in	15-5000 psi	Steam	UV
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.181 in	15-4000 psi	Air	UV
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.181 in	15-4000 psi	Steam	UV
4 in	6 in	4 in ²	[M] 2.257 in	0.203 in	15-3000 psi	Air	UV
4 in	6 in	4 in ²	[M] 2.257 in	0.203 in	15-3000 psi	Steam	UV
4 in	6 in	4.822 in ²	[N] 2.478 in	0.223 in	15-3000 psi	Air	UV
4 in	6 in	4.822 in ²	[N] 2.478 in	0.223 in	15-3000 psi	Steam	UV
4 in	6 in	7.087 in ²	[P] 3.004 in	0.27 in	15-2500 psi	Air	UV
4 in	6 in	7.087 in ²	[P] 3.004 in	0.27 in	15-2500 psi	Steam	UV
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.356 in	15-2000 psi	Air	UV
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.356 in	15-2000 psi	Steam	UV
6 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.428 in	15-1500 psi	Air	UV
6 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.428 in	15-1500 psi	Steam	UV
8 in	10 in	28.94 in ²	[T] 6.07 in	0.546 in	15-1000 psi	Air	UV
8 in	10 in	28.94 in ²	[T] 6.07 in	0.546 in	15-1000 psi	Steam	UV
8 in	10 in	31.5 in ²	[U] 6.333 in	0.57 in	15-300 psi	Air	UV

8 in	10 in	31.5 in ²	[U] 6.333 in	0.57 in	15-300 psi	Steam	UV
10 in	14 in	49.4 in ²	[V] 7.93 in	0.714 in	15-1000 psi	Air	UV
10 in	14 in	49.4 in ²	[V] 7.93 in	0.714 in	15-1000 psi	Steam	UV
12 in	16 in	63.62 in ²	[W] 9 in	0.81 in	15-1000 psi	Air	UV
12 in	16 in	63.62 in ²	[W] 9 in	0.81 in	15-1000 psi	Steam	UV
16 in	18 in	104 in ²	[W2] 11.507 in	1.036 in	15-750 psi	Air	UV
16 in	18 in	104 in ²	[W2] 11.507 in	1.036 in	15-750 psi	Steam	UV
16 in	20 in	113.1 in ²	[X] 12 in	1.08 in	15-750 psi	Air	UV
16 in	20 in	113.1 in ²	[X] 12 in	1.08 in	15-750 psi	Steam	UV
18 in	24 in	143.1 in ²	[Y] 13.5 in	1.215 in	15-750 psi	Air	UV
18 in	24 in	143.1 in ²	[Y] 13.5 in	1.215 in	15-750 psi	Steam	UV
20 in	24 in	176.7 in ²	[Z] 15 in	1.35 in	15-750 psi	Air	UV
20 in	24 in	176.7 in ²	[Z] 15 in	1.35 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

06/14/2027

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV

4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Air & Steam) Series Restricted Lift version of Cert Number 57260 NBCert # 57439

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/08/2030

Design Type

[Safety Relief Valve] 2600L (Air & Steam) Series Restricted Lift version of Cert Number 57260
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 6, 2018
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.08 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.08 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.08 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.089 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.089 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.111 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.111 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.142 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.142 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.169 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.169 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.211 in	15-2900 psi	Steam	UV

3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.211 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.237 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.237 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.26 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.26 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.315 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.315 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.415 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.415 in	15-2000 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	0.5 in	15-1500 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	0.5 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	0.638 in	15-1000 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	0.638 in	15-1000 psi	Steam	UV
8 NPS	10 NPS	31.5 in ²	[U] 6.333 in	0.665 in	15-300 psi	Air	UV
8 NPS	10 NPS	31.5 in ²	[U] 6.333 in	0.665 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids)	NBCert # 57068
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 01/04/2030

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V

8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name:	2600L (Liquids) Series Restricted Lift version of Cert Number 57068.	NBCert #	57417
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 11/28/2029

Design Type

[Safety Relief Valve] 2600L (Liquids) Series Restricted Lift version of Cert Number 57068.
Capacity Tests: Sec. UV, V at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on January 23, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Water	UV, V
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-6000 psi	Water	UV, V
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-5000 psi	Water	UV, V
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.098 in	15-3600 psi	Water	UV, V
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.122 in	15-2750 psi	Water	UV, V
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.156 in	15-2700 psi	Water	UV, V
3 in	4, 6 in	2.041 in ²	[K] 1.612 in	0.187 in	15-2200 psi	Water	UV, V
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.232 in	15-1500 psi	Water	UV, V
4 in	6 in	4 in ²	[M] 2.257 in	0.261 in	15-1100 psi	Water	UV, V
4 in	6 in	4.822 in ²	[N] 2.478 in	0.287 in	15-1000 psi	Water	UV, V
4 in	6 in	7.087 in ²	[P] 3.004 in	0.348 in	15-1000 psi	Water	UV, V
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.458 in	15-900 psi	Water	UV, V
6-8 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.551 in	15-600 psi	Water	UV, V
8 in	10 in	28.94 in ²	[T] 6.07 in	0.702 in	15-300 psi	Water	UV, V
8 in	10 in	31.5 in ²	[U] 6.333 in	0.741 in	15-300 psi	Water	UV, V

Design Name:	2700, 2700S, 3700, 3700S	NBCert #	57237
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/04/2030

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	01/04/2030
-----------	----	------------

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800

NBCert #

57024

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	01/04/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3800
 Capacity Tests: Sec. UV at unknown lab on May 20, 1994
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.859 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV

8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name: 3800FP NBCert # 57035

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/04/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3800FP
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on April 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (3): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-1050 psi	Steam	UV
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-11300 psi	Air	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-1050 psi	Steam	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-11300 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-1050 psi	Steam	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-11300 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-1050 psi	Steam	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-11300 psi	Air	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-1050 psi	Steam	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-6300 psi	Air	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-6300 psi	Air	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-2300 psi	Air	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1500 psi	Air	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-800 psi	Steam	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-1500 psi	Air	UV

Design Name: 3800L, PCL, PCM pilots NBCert # 57215

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/06/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots
 Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.782 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition(1): Pop; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Design Name: 6400/6600 (previously 2500 & 4600) NBCert # 57046

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	06/14/2027

Design Type

[Safety Valve] 6400/6600 (previously 2500 & 4600)
 Capacity Tests: Sec. UV, V at Ohio State University (Robinson Laboratory) on January 28, 1972
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.858 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	V
1-1.5 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	V

1-1.5 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	V
1.5 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	V
1.5-2 NPS	2.5 - 3 NPS	0.559 in ²	[G] 0.844 in	0.211 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.264 in	15-2900 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	V
2-3 NPS	3 - 4 NPS	1.43 in ²	[J] 1.35 in	0.338 in	15-2900 psi	Steam	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Air	UV
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	V
2.5-3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.403 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.502 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.564 in	15-2900 psi	Steam	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Air	UV
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	V
3-4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.62 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.751 in	15-2900 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	0.988 in	15-2000 psi	Steam	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Air	UV
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	V
6 NPS	8 , 10 NPS	17.78 in ²	[R] 4.758 in	1.19 in	15-2000 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	V
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	1.518 in	15-1500 psi	Steam	UV

TVE Co., Ltd. (TOA)

Amagasaki-shi, Hyogo, 660-0054Japan

This Company Manufactures or Assembles:

Design Name:	A1700	NBCert #	01450
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	V	09/26/2029	

Design Type

[Safety Valve] A1700
Capacity Tests: Sec. UV, V at National Board Testing Lab on June 21, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.864 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: TVE Co., Ltd. {TOA}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	2.0, 3.0 NPS	0.638 in ²	0.9016 in	0.229 in	70-2872 psi	Steam	UV, V
1.25-1.5 NPS	2.0, 3.0 NPS	0.689 in ²	0.9371 in	0.237 in	70-2872 psi	Steam	UV, V
1.25-1.5 NPS	2.0, 3.0 NPS	0.701 in ²	0.9449 in	0.237 in	70-2872 psi	Steam	UV, V
1.5-2 NPS	2.5, 4.0 NPS	0.995 in ²	1.126 in	0.284 in	70-3191 psi	Steam	UV, V
1.5-2 NPS	2.5, 4.0 NPS	1.095 in ²	1.1812 in	0.296 in	70-3191 psi	Steam	UV, V
1.5-2 NPS	2.5, 4.0 NPS	1.188 in ²	1.23 in	0.308 in	70-3191 psi	Steam	UV, V
2-2.5 NPS	3.0, 4.0 NPS	1.711 in ²	1.4764 in	0.371 in	70-3191 psi	Steam	UV, V
2-2.5 NPS	3.0, 4.0 NPS	1.767 in ²	1.5 in	0.378 in	70-3191 psi	Steam	UV, V
2-2.5 NPS	3.0, 4.0 NPS	1.957 in ²	1.5788 in	0.398 in	70-3191 psi	Steam	UV, V
2.5-3 NPS	4.0-8.0 NPS	2.758 in ²	1.8741 in	0.469 in	70-6223 psi	Steam	UV, V
2.5-3 NPS	4.0-8.0 NPS	2.899 in ²	1.9213 in	0.481 in	70-6223 psi	Steam	UV, V
2.5-3 NPS	6.0, 8.0 NPS	3.031 in ²	1.9646 in	0.493 in	727-6223 psi	Steam	UV, V
2.5-3 NPS	4.0-6.0 NPS	3.458 in ²	2.0985 in	0.528 in	70-3191 psi	Steam	UV, V
3-3.5 NPS	5.0-8.0 NPS	3.858 in ²	2.2166 in	0.556 in	70-6223 psi	Steam	UV, V
3-3.5 NPS	5.0-8.0 NPS	3.983 in ²	2.252 in	0.563 in	70-6223 psi	Steam	UV, V
3-3.5 NPS	8.0 NPS	4.166 in ²	2.3032 in	0.579 in	727-6223 psi	Steam	UV, V
3-3.5 NPS	5.0-8.0 NPS	4.382 in ²	2.3623 in	0.591 in	70-6223 psi	Steam	UV, V
3-3.5 NPS	5.0-8.0 NPS	4.664 in ²	2.4371 in	0.611 in	70-3191 psi	Steam	UV, V
3.5-4 NPS	6.0 NPS	5.415 in ²	2.626 in	0.658 in	70-2234 psi	Steam	UV, V
3.5-4 NPS	6.0 NPS	5.546 in ²	2.6575 in	0.666 in	70-2234 psi	Steam	UV, V
3.5-4 NPS	6.0 NPS	5.931 in ²	2.7481 in	0.689 in	70-2234 psi	Steam	UV, V
4-5 NPS	6.0-8.0 NPS	6.847 in ²	2.9528 in	0.741 in	70-1755 psi	Steam	UV, V
4-5 NPS	6.0-8.0 NPS	7.068 in ²	3 in	0.752 in	70-1755 psi	Steam	UV, V

4-5 NPS	6.0-8.0 NPS	7.559 in ²	3.1024 in	0.776 in	70-1755 psi	Steam	UV, V
4-5 NPS	6.0-8.0 NPS	8.145 in ²	3.2205 in	0.808 in	70-1755 psi	Steam	UV, V
5-6 NPS	8.0-10.0 NPS	10.711 in ²	3.693 in	0.926 in	70-1755 psi	Steam	UV, V
5-6 NPS	8.0-10.0 NPS	11.056 in ²	3.752 in	0.941 in	70-1755 psi	Steam	UV, V
5-6 NPS	8.0-10.0 NPS	12.393 in ²	3.9725 in	0.997 in	70-1755 psi	Steam	UV, V
6-8 NPS	10.0-12.0 NPS	15.407 in ²	4.4292 in	1.111 in	70-1755 psi	Steam	UV, V
6-8 NPS	10.0-12.0 NPS	15.903 in ²	4.5 in	1.126 in	70-1755 psi	Steam	UV, V
6-8 NPS	10.0-12.0 NPS	17.094 in ²	4.6654 in	1.17 in	70-1755 psi	Steam	UV, V
6-8 NPS	10.0-12.0 NPS	19.295 in ²	4.9567 in	1.241 in	70-1755 psi	Steam	UV, V
8-10 NPS	12.0, 14.0 NPS	27.39 in ²	5.9056 in	1.477 in	70-320 psi	Steam	UV, V
8-10 NPS	12.0, 14.0 NPS	28.273 in ²	6 in	1.5 in	70-320 psi	Steam	UV, V
8-10 NPS	12.0, 14.0 NPS	28.646 in ²	6.0394 in	1.512 in	70-320 psi	Steam	UV, V

TVI, Inc. (TRA)	Nameplate Abbreviation: TVI
------------------------	------------------------------------

El Dorado, AR 71730United States

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S	NBCert # 57057
---------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/25/2029

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV

2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Liquids)	NBCert # 57068
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/25/2029

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S

NBCert # 57237

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

07/25/2029

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV

1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name:	2700L, 3700L (Liquids)	NBCert #	57248
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/25/2029

Design Type

[Relief Valve] 2700L, 3700L (Liquids)
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.676 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

TVI, Inc. (TVC)

Calvert City, KY 42029 United States

This Company Manufactures or Assembles:

Design Name:	2600 & 2600S	NBCert #	57057
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/13/2026

Design Type

[Safety Relief Valve] 2600 & 2600S

Capacity Tests: Sec. UV at unknown lab on June 11, 1972

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable (Single Ring)

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV

12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600 Series Restricted Lift version of Cert Number 57057 NBCert # 57406

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 03/28/2029

Design Type

[Safety Relief Valve] 2600 Series Restricted Lift version of Cert Number 57057
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 10, 2017
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Air	UV
1-1.5 in	2, 2.5, 3 in	0.15 in ²	[D] 0.437 in	0.08 in	15-10000 psi	Steam	UV
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Air	UV
1-1.5 in	2, 2.5, 3 in	0.225 in ²	[E] 0.535 in	0.08 in	15-10000 psi	Steam	UV
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Air	UV
1.5 in	2, 2.5, 3 in	0.371 in ²	[F] 0.687 in	0.08 in	15-10000 psi	Steam	UV
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.08 in	15-7000 psi	Air	UV
1.5-2 in	2.5, 3 in	0.559 in ²	[G] 0.844 in	0.08 in	15-7000 psi	Steam	UV
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.095 in	15-6000 psi	Air	UV
1.5-2 in	3 in	0.873 in ²	[H] 1.054 in	0.095 in	15-6000 psi	Steam	UV
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.122 in	15-6000 psi	Air	UV
2-3 in	3, 4 in	1.43 in ²	[J] 1.35 in	0.122 in	15-6000 psi	Steam	UV
3 in	4, 6 in	2.042 in ²	[K] 1.612 in	0.145 in	15-5000 psi	Air	UV
3 in	4, 6 in	2.042 in ²	[K] 1.612 in	0.145 in	15-5000 psi	Steam	UV
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.181 in	15-4000 psi	Air	UV
3-4 in	4, 6 in	3.17 in ²	[L] 2.009 in	0.181 in	15-4000 psi	Steam	UV
4 in	6 in	4 in ²	[M] 2.257 in	0.203 in	15-3000 psi	Air	UV
4 in	6 in	4 in ²	[M] 2.257 in	0.203 in	15-3000 psi	Steam	UV
4 in	6 in	4.822 in ²	[N] 2.478 in	0.223 in	15-3000 psi	Air	UV
4 in	6 in	4.822 in ²	[N] 2.478 in	0.223 in	15-3000 psi	Steam	UV

4 in	6 in	7.087 in ²	[P] 3.004 in	0.27 in	15-2500 psi	Air	UV
4 in	6 in	7.087 in ²	[P] 3.004 in	0.27 in	15-2500 psi	Steam	UV
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.356 in	15-2000 psi	Air	UV
6 in	8 in	12.27 in ²	[Q] 3.952 in	0.356 in	15-2000 psi	Steam	UV
6 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.428 in	15-1500 psi	Air	UV
6 in	8, 10 in	17.78 in ²	[R] 4.758 in	0.428 in	15-1500 psi	Steam	UV
8 in	10 in	28.94 in ²	[T] 6.07 in	0.546 in	15-1000 psi	Air	UV
8 in	10 in	28.94 in ²	[T] 6.07 in	0.546 in	15-1000 psi	Steam	UV
8 in	10 in	31.5 in ²	[U] 6.333 in	0.57 in	15-300 psi	Air	UV
8 in	10 in	31.5 in ²	[U] 6.333 in	0.57 in	15-300 psi	Steam	UV
10 in	14 in	49.4 in ²	[V] 7.93 in	0.714 in	15-1000 psi	Air	UV
10 in	14 in	49.4 in ²	[V] 7.93 in	0.714 in	15-1000 psi	Steam	UV
12 in	16 in	63.62 in ²	[W] 9 in	0.81 in	15-1000 psi	Air	UV
12 in	16 in	63.62 in ²	[W] 9 in	0.81 in	15-1000 psi	Steam	UV
16 in	18 in	104 in ²	[W2] 11.507 in	1.036 in	15-750 psi	Air	UV
16 in	18 in	104 in ²	[W2] 11.507 in	1.036 in	15-750 psi	Steam	UV
16 in	20 in	113.1 in ²	[X] 12 in	1.08 in	15-750 psi	Air	UV
16 in	20 in	113.1 in ²	[X] 12 in	1.08 in	15-750 psi	Steam	UV
18 in	24 in	143.1 in ²	[Y] 13.5 in	1.215 in	15-750 psi	Air	UV
18 in	24 in	143.1 in ²	[Y] 13.5 in	1.215 in	15-750 psi	Steam	UV
20 in	24 in	176.7 in ²	[Z] 15 in	1.35 in	15-750 psi	Air	UV
20 in	24 in	176.7 in ²	[Z] 15 in	1.35 in	15-750 psi	Steam	UV

Design Name: 2600L (Air & Steam)

NBCert #

57260

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/29/2026

Design Type

[Safety Relief Valve] 2600L (Air & Steam)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on March 5, 2004

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-2900 psi	Steam	UV

1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.295 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.369 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.473 in	15-6000 psi	Air	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-2900 psi	Steam	UV
3 NPS	4, 6 NPS	2.042 in ²	[K] 1.612 in	0.564 in	15-5000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-2900 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.703 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.79 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.867 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.05 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.383 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.665 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.125 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.217 in	15-300 psi	Steam	UV

Design Name: 2600L (Liquids)	NBCert # 57068
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/13/2026

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V

3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S

NBCert # 57237

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/15/2029

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids)		NBCert #	57248
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	06/17/2029
Design Type			
[Relief Valve] 2700L, 3700L (Liquids) Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.676 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 4200 / 4400		NBCert #	57282
Manufacturer/Assembler		Designators	Expiration Date
Assembler		V	04/29/2026
Design Type			
[Safety Valve] 4200 / 4400 Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.872 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V

4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

TVI, Inc. (TVI)	Nameplate Abbreviation: TVI
------------------------	------------------------------------

Memphis, TN 38108United States

This Company Manufactures or Assembles:

Design Name: 2600 & 2600S	NBCert # 57057
---------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/23/2029

Design Type

[Safety Relief Valve] 2600 & 2600S
Capacity Tests: Sec. UV at unknown lab on June 11, 1972
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.858 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV

4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name: 2600L (Liquids)	NBCert # 57068
------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	11/02/2029

Design Type

[Relief Valve] 2600L (Liquids)
 Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.652 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V

3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S

NBCert #

57237

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

03/23/2029

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.878 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids)		NBCert #	57248
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	04/28/2026
Design Type			
[Relief Valve] 2700L, 3700L (Liquids) Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.676 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 4200 / 4400		NBCert #	57282
Manufacturer/Assembler		Designators	Expiration Date
Assembler		V	03/23/2029
Design Type			
[Safety Valve] 4200 / 4400 Capacity Tests: Sec. UV, V at National Board Testing Lab on June 9, 2005 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.872 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Dual Ring) Flow Area Configuration: Nozzle/Full Lift Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.316 in ²	[F] 0.634 in	0.159 in	15-1480 psi	Steam	UV, V
1.25 NPS	1.5 NPS	0.518 in ²	[G] 0.812 in	0.203 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	0.809 in ²	[H] 1.015 in	0.254 in	15-1480 psi	Steam	UV, V
1.5 NPS	2.5 NPS	1.325 in ²	[J] 1.299 in	0.325 in	15-1480 psi	Steam	UV, V
2 NPS	3 NPS	1.897 in ²	[K] 1.554 in	0.389 in	15-1480 psi	Steam	UV, V
2.5 NPS	4 NPS	2.938 in ²	[L] 1.934 in	0.484 in	15-1480 psi	Steam	UV, V
3 NPS	4 NPS	3.822 in ²	[M] 2.206 in	0.552 in	15-1480 psi	Steam	UV, V

4 NPS	6 NPS	4.471 in ²	[N] 2.386 in	0.597 in	15-1480 psi	Steam	UV, V
4 NPS	6 NPS	6.573 in ²	[P] 2.893 in	0.723 in	15-1480 psi	Steam	UV, V
6 NPS	8 NPS	11.389 in ²	[Q] 3.808 in	0.952 in	15-1480 psi	Steam	UV, V

Unified Valve Group Ltd (UNI)

Nameplate Abbreviation: Unified Valve Group

Calgary, AB T1Y 7C1Canada

This Company Manufactures or Assembles:

Design Name: 459/462		NBCert # 37112	
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	09/28/2030
Design Type			
[Safety Relief Valve] 459/462 Capacity Tests: Sec. UV at National Board Testing Lab on February 17, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.811 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Initial Audible Discharge Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Air	UV
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Air	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Steam	UV

Design Name: 459/462 liquids		NBCert # 37101	
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	09/28/2030
Design Type			
[Relief Valve] 459/462 liquids Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.566 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: LESER GmbH & Co. KG {LES}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Water	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Water	UV
0.5-1.5 NPS	1-2.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Water	UV
1-2 NPS	1.5-2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Water	UV

Design Name: 526	NBCert # 37224
------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/28/2030

Design Type

[Safety Relief Valve] 526
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 22, 2001
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Air	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-2900 psi	Steam	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Air	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-2900 psi	Steam	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Steam	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Air	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Steam	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Air	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Steam	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Air	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Steam	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Air	UV

6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Steam	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Air	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Steam	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Air	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Steam	UV

Design Name:	526D	NBCert #	37246
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/28/2030

Design Type

[Safety Relief Valve] 526D
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on March 4, 2002
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.990 SCFM/PSIA; (alternate medium): 5.590 PPH/PSIA
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-10878 psi	Air	UV

V TEX Corporation (VTX)

Nameplate Abbreviation: V TEX

Hitachinaka, Ibaraki, 312-0003Japan

This Company Manufactures or Assembles:

Design Name:	FB Series	NBCert #	00471
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 12/02/2026

Design Type

[Rupture Disk Device] FB Series
HolderDesignation: FBF, FBS
Capacity Tests: Sec. UD at National Board Testing Lab on June 10, 2014
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 1.000 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: V TEX Corporation {VTX}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1 NPS	0.773 in ²			49-1450 psi	Air	UD
1.5 NPS	1.5 NPS	1.87 in ²			35-1160 psi	Air	UD
10 NPS	10 NPS	78.5 in ²			15-435 psi	Air	UD

12 NPS	12 NPS	111 in ²	12-290 psi	Air	UD
14 NPS	14 NPS	137 in ²	12-290 psi	Air	UD
16 NPS	16 NPS	182 in ²	12-290 psi	Air	UD
18 NPS	18 NPS	233 in ²	12-290 psi	Air	UD
2 NPS	2.0 NPS	3.35 in ²	28-1160 psi	Air	UD
20 NPS	20 NPS	291 in ²	12-290 psi	Air	UD
24 NPS	24 NPS	424 in ²	10-145 psi	Air	UD
26 NPS	26 NPS	499 in ²	10-145 psi	Air	UD
28 NPS	28 NPS	580 in ²	10-145 psi	Air	UD
3 NPS	3 NPS	7.39 in ²	25-1015 psi	Air	UD
30 NPS	30 NPS	667 in ²	10-145 psi	Air	UD
32 NPS	32 NPS	760 in ²	10-145 psi	Air	UD
34 NPS	34 NPS	851 in ²	10-145 psi	Air	UD
36 NPS	36 NPS	956 in ²	10-145 psi	Air	UD
4 NPS	4 NPS	12.7 in ²	22-1015 psi	Air	UD
6 NPS	6 NPS	28.8 in ²	20-800 psi	Air	UD
8 NPS	8 NPS	50 in ²	15-580 psi	Air	UD

Design Name: FMB Series

NBCert #

01584

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	01/26/2030

Design Type

[Rupture Disk Device] FMB Series
HolderDesignation: FMBS, FMBF
Capacity Tests: Sec. UD at National Board Testing Lab on August 24, 2017
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.900 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: V TEX Corporation {VTX}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.821 in ²			79-2030 psi	Air	UD
1.5 NPS		1.94 in ²			60-2030 psi	Air	UD
10 NPS		78.8 in ²			26-435 psi	Air	UD
12 NPS		113 in ²			22-290 psi	Air	UD
14 NPS		137 in ²			26-290 psi	Air	UD
16 NPS		182 in ²			22-290 psi	Air	UD
18 NPS		233 in ²			18-290 psi	Air	UD
2 NPS		3.35 in ²			55-2030 psi	Air	UD
20 NPS		291 in ²			15-290 psi	Air	UD
3 NPS		7.39 in ²			45-1885 psi	Air	UD
3 NPS		8.89 in ²			45-1885 psi	Air	UD
4 NPS		12.7 in ²			40-1450 psi	Air	UD

6 NPS	28.8 in²	30-800 psi	Air	UD
8 NPS	50 in²	35-580 psi	Air	UD

Valve & Actuation Services, LLC (VAS)
Nameplate Abbreviation: C&K - Mobile

Theodore, AL 36582United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3		NBCert # 18032
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	10/13/2028
Design Type		
[Safety Valve] 1541, 1543, 1541-3, 1543-3 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V

2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1811, 1511 NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 10/13/2028

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA (Liquids) NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 10/13/2028

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/13/2028

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV

1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series			NBCert # 18706	
Manufacturer/Assembler		Designators		Expiration Date
Assembler		UV		10/13/2028

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/09/2029

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV

1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/13/2028

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 10/13/2028

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name:	1900-DM	NBCert #	19066
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/13/2028

Design Type

[Safety Relief Valve] 1900-DM
Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2			NBCert # 18166	
Manufacturer/Assembler		Designators	Expiration Date	
Assembler		UV	10/13/2028	

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler

Designators

Expiration Date

Assembler

UV, V

10/13/2028

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 3900-TM (39PV, 39MV pilots) NBCert # 01438

Manufacturer/Assembler

Designators

Expiration Date

Assembler

UV

03/09/2029

Design Type

[Pilot Operated Pressure Relief Valve] 3900-TM (39PV, 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; (alternate medium): 0.743 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid, Steam; Certified: Air, Gas, Liquid, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge; (3): First Steady Stream
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-15000 psi	Water	UV

1-1.8125 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Water	UV
1-1.8125 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-15000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.913 in ²	[H] 1.07 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-15000 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
10 NPS	14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Valve & Actuation Services, LLC d/b/a Chalmers & Kubeck - South (CHK)

Nameplate Abbreviation: Chalmers & Kubeck - South

Gastonia, NC 28054United States

This Company Manufactures or Assembles:

Design Name:	1541, 1543, 1541-3, 1543-3	NBCert #	18032
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV, V	06/12/2030
-----------	-------	------------

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV

0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1700 & 2700 NBCert # 18100

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	05/02/2030

Design Type

[Safety Valve] 1700 & 2700
Capacity Tests: Sec. UV, V at Dresser, Inc. on August 1, 1957
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	50-5800 psi	Steam	V
4 NPS	4 dual NPS	1.84 in ²	[K] 1.531 in	0.383 in	50-5800 psi	Steam	V

2-3 NPS	4, 6 NPS	2.545 in ²	[#3] 1.8 in	0.45 in	50-5800 psi	Steam	UV, V
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-2575 psi	Steam	UV
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	50-5800 psi	Steam	V
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	15-3100 psi	Steam	UV
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	50-5800 psi	Steam	V
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	15-3100 psi	Steam	UV
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	15-1800 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	1.24 in	50-2200 psi	Steam	UV, V
8-10 NPS	10,12 NPS	28.3 in ²	[T] 6 in	1.5 in	50-1500 psi	Steam	UV, V

Design Name: 1700 & 2700 (Restricted Lift version of Cert. # 18100) NBCert # 18111

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	09/09/2030

Design Type

[Safety Valve] 1700 & 2700 (Restricted Lift version of Cert. # 18100)
Capacity Tests: Sec. UV, V at unknown lab on October 13, 1981
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	50-5800 psi	Steam	V
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	15-3100 psi	Steam	UV
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	50-5800 psi	Steam	V
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-2575 psi	Steam	UV
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	50-2575 psi	Steam	V

2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	50-5800 psi	Steam	V
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	15-3100 psi	Steam	UV
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	50-5800 psi	Steam	V
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	15-3100 psi	Steam	UV
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.946 in	0.296 in	15-2000 psi	Steam	UV, V
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	0.372 in	50-2200 psi	Steam	V
8-10 NPS	10, 12 NPS	28.3 in ²	[T] 6 in	0.45 in	50-1500 psi	Steam	UV, V

Design Name: 1811, 1511

NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV, V

05/02/2030

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV

4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	05/02/2030

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/02/2030

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV

10 NPS	14 NPS	50.26 in²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV
Design Name:		1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)		NBCert #	18223		
Manufacturer/Assembler			Designators			Expiration Date	
Assembler			UV			05/02/2030	
Design Type							
[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)							
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985							
Method of Establishing Relieving Capacity: Flow Capacity, K							
Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)							
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam							
Set Pressure Definition: Pop							
Blowdown Characteristics: Adjustable (Single Ring)							
Flow Area Configuration: Restricted Lift							
Designed by: Dresser, LLC. {DPT}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV

8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/02/2030

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/02/2030

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2

NBCert #

18144

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

05/02/2030

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids) NBCert #

18751

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV, V

05/02/2030

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 3.256 GPM/SQ. RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM

NBCert # 19066

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

02/21/2030

Design Type

[Safety Relief Valve] 1900-DM
 Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
 Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
 Set Pressure Definition(1): Pop; (2): First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name:	1900-DM-D	NBCert #	19088
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/20/2030

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name:	1900-DM-E	NBCert #	19099
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 02/20/2030

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name: 1900E-2, 1900-30E-2		NBCert #	18166
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	05/02/2030
Design Type			
[Safety Relief Valve] 1900E-2, 1900-30E-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids)		NBCert #	18762
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV, V	05/02/2030
Design Type			
[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids) Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.798 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids)		NBCert #	19077
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	06/12/2030
Design Type			
[Relief Valve] 19110M & 19110H (Liquids) Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.264 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name:	1982	NBCert #	18379
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 05/02/2030

Design Type

[Safety Relief Valve] 1982
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at unknown lab on May 6, 1980
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Air	NV, UV
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Steam	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Air	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Steam	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Air	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Steam	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Air	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Air	NV, UV

Design Name:	1982 LS, 820000LS	NBCert #	18380
--------------	-------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 05/02/2030

Design Type

[Relief Valve] 1982 LS, 820000LS
Capacity Tests: Sec. UV at Dresser, Inc. on December 19, 1984
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.758 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	NV
0.5-0.75 NPS	.75 - 1 NPS	0.121 in ²	0.393 in	0.137 in	15-500 psi	Water	UV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	NV
0.75-1 NPS	1 , 1.5 NPS	0.216 in ²	0.524 in	0.162 in	15-500 psi	Water	UV

1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	NV
1-1.25 NPS	1.5 NPS	0.332 in ²	0.65 in	0.236 in	15-500 psi	Water	UV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	NV
1.5-2 NPS	2, 2.5 NPS	0.857 in ²	1.045 in	0.343 in	15-500 psi	Water	UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	NV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.43 in	15-500 psi	Water	UV

Design Name: 3900 (39PV, 39MV pilots) NBCert # 18447

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/02/2030

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV

2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name:	3900 (39PV, 39MV pilots, liquid)	NBCert #	18458
--------------	----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	02/21/2030
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV

6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Valve & Actuation Services, LLC d/b/a Chalmers & Kubeck - South (CKD)

Nameplate Abbreviation: Chalmers & Kubeck - South

Decatur, AL 35601United States

This Company Manufactures or Assembles:

Design Name:	1541, 1543, 1541-3, 1543-3	NBCert #	18032
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV, V	09/22/2027	

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV

1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1811, 1511			NBCert # 18122	
Manufacturer/Assembler		Designators		Expiration Date
Assembler		UV, V		09/22/2027

Design Type				
[Safety Valve] 1811, 1511 Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.877 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}				

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V

6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV
-------	-------	-----------------------	-------------	----------	-------------	-----	----

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
Manufacturer/Assembler	Designators	Expiration Date	

Assembler UV, V 09/22/2027

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name:	1900, 1900-30, 1900-35	NBCert #	18201
Manufacturer/Assembler	Designators	Expiration Date	

Assembler UV 09/22/2027

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Single Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV

10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/22/2027

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/22/2027

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 09/22/2027

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 09/22/2027

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900E-2, 1900-30E-2		NBCert #	18166
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	09/22/2027
Design Type			
[Safety Relief Valve] 1900E-2, 1900-30E-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids)		NBCert #	18762
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV, V	09/22/2027
Design Type			
[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids) Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.798 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids)		NBCert #	19077
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	07/12/2030
Design Type			
[Relief Valve] 19110M & 19110H (Liquids) Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.264 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Valve & Actuation Services, LLC d/b/a Chalmers & Kubeck - South (KSC)

Cayce, SC 29033United States

This Company Manufactures or Assembles:

Design Name:	1541, 1543, 1541-3, 1543-3	NBCert #	18032
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	12/14/2028

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV

2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name:	1811, 1511	NBCert #	18122
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV, V 12/15/2028

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 12/15/2028

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/15/2028

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV

1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series			NBCert # 18706	
Manufacturer/Assembler		Designators		Expiration Date
Assembler		UV		12/15/2028

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/15/2028

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV

1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	1900D-2, 1900-30D-2	NBCert #	18144
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/06/2028

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name:	1900D-2, 1900-30D-2 LA & DALA (Liquids)	NBCert #	18751
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/25/2028

Design Type

[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.256 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/06/2028

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/25/2028

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids) NBCert # 19077

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/22/2028

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 2900 (39PV & 39MV pilots) NBCert # 18863

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/08/2028

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
 Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.855 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV

12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV
--------	--------	------------------------	---------------	----------	------------	-------	----

Design Name:	3900 (39PV, 39MV pilots)	NBCert #	18447
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/06/2028

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV

4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Valve & Actuation Services, LLC d/b/a Chalmers & Kubeck - South (VSI)

Nameplate Abbreviation: Chalmers &
Kubeck - South

Chattanooga, TN 37419United States

This Company Manufactures or Assembles:

Design Name:	1541, 1543, 1541-3, 1543-3	NBCert #	18032
--------------	----------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	09/18/2030

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name:	1811, 1511	NBCert #	18122
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	12/17/2030

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA
(Liquids)

NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	09/19/2030

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V

1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

09/18/2030

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV

3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 19000 Series NBCert # 18706

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/18/2030

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV

0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert #

18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

01/23/2031

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2

NBCert #

18144

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

09/19/2030

Design Type

[Safety Relief Valve] 1900D-2, 1900-30D-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900-DM

NBCert # 19066

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/29/2027

Design Type

[Safety Relief Valve] 1900-DM
Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV

8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name:	1900-DM-D	NBCert #	19088
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/29/2027

Design Type

[Safety Relief Valve] 1900-DM-D
Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name:	1900-DM-E	NBCert #	19099
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/24/2030

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/19/2030

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name: 1900E-2, 1900-30E-2 LA & DALA (Liquids) NBCert # 18762

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV, V

01/23/2031

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 5.798 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 19110M & 19110H (Liquids) NBCert # 19077

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

08/06/2027

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name: 1982		NBCert # 18379
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	09/18/2030
Design Type		
[Safety Relief Valve] 1982 Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at unknown lab on May 6, 1980 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.855 Unitless Media - Test: Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Air	NV, UV
0.5 NPS	.75 NPS	0.121 in ²	0.393 in	0.092 in	15-500 psi	Steam	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Air	NV, UV
0.75 NPS	1 NPS	0.216 in ²	0.524 in	0.123 in	15-500 psi	Steam	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Air	NV, UV
1 NPS	1.5 NPS	0.332 in ²	0.65 in	0.15 in	15-500 psi	Steam	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Air	NV, UV
1.5 NPS	2 NPS	0.857 in ²	1.045 in	0.243 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Steam	NV, UV
2 NPS	2.5 NPS	1.399 in ²	1.335 in	0.31 in	15-500 psi	Air	NV, UV

Design Name: 3900 (39PV, 39MV pilots)		NBCert # 18447
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/29/2030
Design Type		
[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots) Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.878 Unitless Media - ; Certified: Air, Gas, Steam Set Pressure Definition(1): Pop; (2): Initial Audible Discharge Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV

1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV

6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid) NBCert # 18458

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/06/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.743 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV

2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV
8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

Valve & Actuation Services, LLC. d/b/a Chalmers & Kubeck - South (CKS)

Nameplate Abbreviation: Chalmers & Kubeck South

Watkinsville, GA 30677United States

This Company Manufactures or Assembles:

Design Name: 1541, 1543, 1541-3, 1543-3		NBCert #	18032
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV, V	06/14/2027	
Design Type			

[Safety Valve] 1541, 1543, 1541-3, 1543-3
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name:	1811, 1511	NBCert #	18122
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV, V	06/15/2027
-----------	-------	------------

Design Type

[Safety Valve] 1811, 1511
 Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.877 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V

1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name:	1900, 1900-30 1900-35 LA & DALA (Liquids)	NBCert #	18784
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/16/2027

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V
1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V

6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35 NBCert # 18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/12/2027

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV

6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name:	19000 Series	NBCert #	18706
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/16/2027

Design Type

[Safety Relief Valve] 19000 Series
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name:	19000 Series, Liquid	NBCert #	18717
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/14/2027

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name:	19110M & 19110H (Liquids)	NBCert #	19077
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/28/2027

Design Type

[Relief Valve] 19110M & 19110H (Liquids)
Capacity Tests: Sec. NV, -Class 1, -Class 2, -Class 3, UV at Dresser, Inc. on July 29, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 2.264 GPM/SQ. RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-440 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	50-5000 psi	Water	NV, -Class 2, -Class 3

Design Name:	3900 (39PV, 39MV pilots)	NBCert #	18447
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 01/28/2027

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV

4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Valve Sales Inc (VAE)

Tulsa, OK 74107United States

This Company Manufactures or Assembles:

Design Name:	1541, 1543, 1541-3, 1543-3	NBCert #	18032
Manufacturer/Assembler	Designators	Expiration Date	
Assembler	UV, V	09/01/2029	

Design Type

[Safety Valve] 1541, 1543, 1541-3, 1543-3
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on March 11, 1975
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-250 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D] 0.375 in	0.094 in	15-300 psi	Air	NV, UV
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Steam	NV, UV, V
0.5-0.75 NPS	.75 NPS	0.11 in ²	[D3] 0.393 in	0.094 in	15-350 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-250 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.125 in	15-300 psi	Air	NV, UV
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-300 psi	Steam	NV, UV, V
0.75-1 NPS	1 NPS	0.196 in ²	[E3] 0.524 in	0.125 in	15-350 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-250 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-300 psi	Air	NV, UV
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-300 psi	Steam	NV, UV, V
1-1.25 NPS	1.25 NPS	0.307 in ²	[F3] 0.65 in	0.156 in	15-350 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-250 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-300 psi	Air	NV, UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-300 psi	Steam	NV, UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G3] 0.835 in	0.2 in	15-350 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-250 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H] 1 in	0.25 in	15-300 psi	Air	NV, UV
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-300 psi	Steam	NV, UV, V
1.5-2 NPS	2 NPS	0.785 in ²	[H3] 1.045 in	0.25 in	15-350 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-250 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.32 in	15-300 psi	Air	NV, UV
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-300 psi	Steam	NV, UV, V
2-2.5 NPS	2.5 NPS	1.287 in ²	[J3] 1.335 in	0.32 in	15-350 psi	Air	NV, UV

Design Name: 1700 & 2700

NBCert # 18100

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	03/22/2029

Design Type

[Safety Valve] 1700 & 2700
 Capacity Tests: Sec. UV, V at Dresser, Inc. on August 1, 1957
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[#9] 0.75 in	0.188 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[#1] 1.125 in	0.281 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3 - 6 NPS	1.431 in ²	[#2] 1.35 in	0.338 in	50-5800 psi	Steam	V
4 NPS	4 dual NPS	1.84 in ²	[K] 1.531 in	0.383 in	50-5800 psi	Steam	V
2-3 NPS	4, 6 NPS	2.545 in ²	[#3] 1.8 in	0.45 in	50-5800 psi	Steam	UV, V
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-2575 psi	Steam	UV
2.5-2.5 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[#5] 2.062 in	0.516 in	50-5800 psi	Steam	V
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	15-3100 psi	Steam	UV
3-3 NPS	6, 8 NPS	3.976 in ²	[#4] 2.25 in	0.563 in	50-5800 psi	Steam	V
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	15-3100 psi	Steam	UV
4 NPS	6,8 NPS	7.07 in ²	[#6] 3 in	0.75 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.948 in	0.987 in	15-2000 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	15-1800 psi	Steam	UV
6 NPS	8, 10 NPS	14.18 in ²	[#8] 4.25 in	1.063 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	1.129 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	1.24 in	50-2200 psi	Steam	UV, V
8-10 NPS	10,12 NPS	28.3 in ²	[T] 6 in	1.5 in	50-1500 psi	Steam	UV, V

Design Name: 1700 & 2700 (Restricted Lift version of Cert. # 18100) NBCert # 18111

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	12/21/2028

Design Type

[Safety Valve] 1700 & 2700 (Restricted Lift version of Cert. # 18100)
 Capacity Tests: Sec. UV, V at unknown lab on October 13, 1981
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless; Certification Provisions: Restricted Lift (Prev. CC 1923 &/or 1945)
 Media - Test: Steam; Certified: Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Restricted Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	15-3000 psi	Steam	UV
1-1.5 NPS	3 NPS	0.442 in ²	[9] 0.75 in	0.08 in	50-3000 psi	Steam	V
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	15-3100 psi	Steam	UV
1.25-2.5 NPS	3, 4 NPS	0.994 in ²	[1] 1.125 in	0.084 in	50-5800 psi	Steam	V
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	15-3100 psi	Steam	UV
1.5-2.5 NPS	3-6 NPS	1.431 in ²	[2] 1.35 in	0.101 in	50-5800 psi	Steam	V
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	15-3100 psi	Steam	UV
2-3 NPS	6 NPS	2.545 in ²	[3] 1.8 in	0.135 in	50-5800 psi	Steam	V
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	15-2575 psi	Steam	UV
2.5-3 NPS	6 NPS	2.853 in ²	[L] 1.906 in	0.143 in	50-2575 psi	Steam	V
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	15-3100 psi	Steam	UV
2.5-3 NPS	6, 8 NPS	3.341 in ²	[5] 2.062 in	0.155 in	50-5800 psi	Steam	V
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	15-3100 psi	Steam	UV
3-4 NPS	6, 8 NPS	3.976 in ²	[4] 2.25 in	0.169 in	50-5800 psi	Steam	V
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	15-3100 psi	Steam	UV
4 NPS	6, 8 NPS	7.07 in ²	[6] 3 in	0.225 in	50-3100 psi	Steam	V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	15-2093 psi	Steam	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.281 in	50-2093 psi	Steam	V
6 NPS	8 NPS	12.25 in ²	[Q] 3.946 in	0.296 in	15-2000 psi	Steam	UV, V
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	14.18 in ²	[8] 4.25 in	0.319 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	15-1800 psi	Steam	UV
6-8 NPS	8, 10 NPS	16 in ²	[R] 4.515 in	0.339 in	50-2000 psi	Steam	V
6-8 NPS	8, 10 NPS	19.29 in ²	[RR] 4.956 in	0.372 in	50-2200 psi	Steam	V
8-10 NPS	10, 12 NPS	28.3 in ²	[T] 6 in	0.45 in	50-1500 psi	Steam	UV, V

Design Name: 1811, 1511

NBCert # 18122

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	12/22/2028

Design Type

[Safety Valve] 1811, 1511
Capacity Tests: Sec. UV, V at Dresser, Inc. on March 11, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.877 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1500 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1500 psi	Air	UV
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.287 in ²	[J] 1.281 in	0.321 in	15-1500 psi	Air	UV
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Steam	UV, V
2-3 NPS	3, 4 NPS	1.84 in ²	[K] 1.531 in	0.383 in	15-1500 psi	Air	UV
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Steam	UV, V
2.5-4 NPS	4, 6 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1500 psi	Air	UV
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Steam	UV, V
3-4 NPS	4, 6 NPS	3.6 in ²	[M] 2.14 in	0.535 in	15-1500 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	4.34 in ²	[N] 2.351 in	0.588 in	15-1500 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Steam	UV, V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-1500 psi	Air	UV
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Steam	UV, V
6 NPS	8 NPS	11.05 in ²	[Q] 3.75 in	0.938 in	15-1500 psi	Air	UV

Design Name: 1900, 1900-30 1900-35 LA & DALA
(Liquids)

NBCert # 18784

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	12/12/2028

Design Type

[Relief Valve] 1900, 1900-30 1900-35 LA & DALA (Liquids)
Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.670 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.128 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	NV, UV, V

1-1.5 NPS	2 - 3 NPS	0.228 in ²	[E] 0.5387 in	0.127 in	15-7500 psi	Water	NV, UV, V
1.5-1.5 NPS	2 - 3 NPS	0.357 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	NV, UV, V
1.5-2 NPS	2.5, 3 NPS	0.585 in ²	[G] 0.863 in	0.205 in	15-6000 psi	Water	NV, UV, V
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.395 in	15-5000 psi	Water	NV, UV, V
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-5000 psi	Water	NV, UV, V
3-3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3400 psi	Water	NV, UV, V
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	NV, UV, V
4-4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	NV, UV, V
4-4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	NV, UV, V
6-6 NPS	8 NPS	12.851 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	NV, UV, V
6-6 NPS	8, 10 NPS	18.604 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	NV, UV, V
8-8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	2.212 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	30.21 in ²	[T-4] 6.205 in	2.272 in	15-360 psi	Water	NV, UV, V
8-8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.272 in	15-300 psi	Water	NV, UV, V
10-10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	NV, UV, V
12-12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	NV, UV, V

Design Name: 1900, 1900-30, 1900-35

NBCert #

18201

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/12/2028

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35
Capacity Tests: Sec. NV, UV at Dresser, Inc. on October 11, 1954
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.4035 in	0.11 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-2000 psi	Steam	NV, UV
1.5 NPS	2-3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	2-1/2, 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2540 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3300 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-3100 psi	Air	NV, UV

3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-3400 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-850 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	1.68 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	1.723 in	15-300 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.162 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Air	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	NV, UV

Design Name: 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201) NBCert # 18223

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/22/2029

Design Type

[Safety Relief Valve] 1900, 1900-30, 1900-35 (R.L.) (Restricted lift version of 18201)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 19, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless; Certification Provisions: Restricted Lift (Prev. CC N-394 or 1945)
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.1279 in ²	[D] 0.4036 in	0.08 in	15-6250 psi	Steam	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Air	NV, UV
1-1.5 NPS	2, 3 NPS	0.2279 in ²	[E] 0.5387 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Air	NV, UV

1.5 NPS	2, 3 NPS	0.3568 in ²	[F] 0.674 in	0.08 in	15-6250 psi	Steam	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-6000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5849 in ²	[G] 0.863 in	0.08 in	15-4230 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-3300 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.087 in	15-2540 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-3100 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.112 in	15-2540 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-3400 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.134 in	15-2540 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.167 in	15-2900 psi	Steam	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.187 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Air	NV, UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.205 in	15-1600 psi	Steam	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Air	NV, UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.249 in	15-1700 psi	Steam	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Air	NV, UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	0.327 in	15-900 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	0.387 in	15-650 psi	Steam	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	28.624 in ²	[T] 6.04 in	0.504 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	30.21 in ²	[T4] 6.205 in	0.517 in	15-360 psi	Steam	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-360 psi	Air	NV, UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	0.552 in	15-300 psi	Steam	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Air	NV, UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	0.648 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Steam	NV, UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	0.757 in	15-300 psi	Air	NV, UV

Design Name: 19000 Series		NBCert # 18706
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/12/2028
Design Type		

[Safety Relief Valve] 19000 Series
 Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 26, 1994
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - ; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.039 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-2903 psi	Steam	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-5000 psi	Air	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Air	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-2000 psi	Steam	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Air	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Steam	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Air	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Steam	NV, -Class 2, -Class 3, UV

Design Name: 19000 Series, Liquid

NBCert # 18717

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

12/12/2028

Design Type

[Relief Valve] 19000 Series, Liquid
Capacity Tests: Sec. NV, -Class 2, -Class 3, UV at Dresser, Inc. on August 30, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.673 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	1 NPS	0.019 in ²	0.156 in	0.045 in	15-15000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.049 in ²	0.25 in	0.079 in	200-6250 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-5000 psi	Water	NV, -Class 2, -Class 3, UV
0.5-1 NPS	1 NPS	0.096 in ²	0.35 in	0.11 in	15-550 psi	Water	NV, -Class 1
0.5-1 NPS	1 NPS	0.11 in ²	0.375 in	0.118 in	15-290 psi	Water	NV, -Class 2, -Class 3, UV
0.75-1 NPS	1 NPS	0.126 in ²	0.401 in	0.126 in	15-8000 psi	Water	NV, -Class 2, -Class 3, UV
1-1 NPS	1.5 NPS	0.226 in ²	0.537 in	0.169 in	15-6400 psi	Water	NV, -Class 2, -Class 3, UV
1.5-1.5 NPS	2 NPS	0.357 in ²	0.675 in	0.212 in	15-1500 psi	Water	NV, -Class 2, -Class 3, UV
2-2 NPS	2.5 NPS	0.567 in ²	0.85 in	0.266 in	15-1000 psi	Water	NV, -Class 2, -Class 3, UV

Design Name: 1900D-2, 1900-30D-2		NBCert #	18144
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	12/12/2028
Design Type			
[Safety Relief Valve] 1900D-2, 1900-30D-2 Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 5.630 PPH/PSIA; (alternate medium): 2.004 SCFM/PSIA Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam Set Pressure Definition: Pop Blowdown Characteristics: Adjustable (Single Ring) Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.066 in	15-6250 psi	Air	UV

Design Name: 1900D-2, 1900-30D-2 LA & DALA (Liquids)		NBCert #	18751
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	12/12/2028
Design Type			
[Relief Valve] 1900D-2, 1900-30D-2 LA & DALA (Liquids) Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.256 GPM/SQ.RT. PSID Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.674 in	0.056 in	15-6250 psi	Water	NV, UV, V

Design Name: 1900-DM		NBCert #	19066
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	03/22/2029
Design Type			
[Safety Relief Valve] 1900-DM Capacity Tests: Sec. UV at Dresser, Inc. on March 15, 2010 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.855 Unitless; (alternate medium): 0.670 Unitless; Certification Provisions: Multiple Media (Code Case 2787) Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid Set Pressure Definition(1): Pop; (2): First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Dresser, LLC. {DPT}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Air	UV

1.5-1.8125 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	2 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-10000 psi	Water	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Air	UV
1.5-2.0625 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Water	UV
2-3.0625 NPS	3, 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Air	UV
3 NPS	4, 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-3000 psi	Water	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Air	UV
3-4 NPS	4, 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-2900 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	0.846 in	15-1600 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-1600 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-1700 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-900 psi	Water	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Air	UV
6 NPS	8, 10 NPS	18.6 in ²	[R] 4.867 in	1.782 in	15-650 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-408 psi	Water	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Air	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	2.428 in	15-360 psi	Water	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8 in	2.93 in	15-300 psi	Water	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-300 psi	Water	UV

Design Name: 1900-DM-D

NBCert #

19088

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/22/2029

Design Type

[Safety Relief Valve] 1900-DM-D

Capacity Tests: Sec. UV at National Board Testing Lab on March 18, 2010

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 1.991 SCFM/PSIA; (alternate medium): 3.256 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)

Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid

Set Pressure Definition(1): Pop; (2): First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Curtain Area

Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Air	UV
1-1.8125 NPS	2-3 NPS	0.1279 in ²	[D] 0.674 in	0.067 in	15-10000 psi	Water	UV

Design Name:	1900-DM-E	NBCert #	19099
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	03/22/2029

Design Type

[Safety Relief Valve] 1900-DM-E
Capacity Tests: Sec. UV at National Board Testing Lab on March 10, 2010
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.558 SCFM/PSIA; (alternate medium): 5.798 GPM/SQ.RT. PSID; Certification Provisions: Multiple Media (Code Case 2787)
Media - Test: Air/Gas, Liquid; Certified: Air, Gas, Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Air	UV
1-1.8125 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.105 in	15-10000 psi	Water	UV

Design Name:	1900E-2, 1900-30E-2	NBCert #	18166
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/12/2028

Design Type

[Safety Relief Valve] 1900E-2, 1900-30E-2
Capacity Tests: Sec. NV, UV at Dresser, Inc. on August 16, 1977
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:10.040 PPH/PSIA; (alternate medium): 3.570 SCFM/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Curtain Area
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-4230 psi	Steam	NV, UV
1-1.5 NPS	2-3 NPS	0.2279 in ²	[E] 0.674 in	0.119 in	15-6250 psi	Air	NV, UV

Design Name:	1900E-2, 1900-30E-2 LA & DALA (Liquids)	NBCert #	18762
--------------	---	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	12/12/2028

Design Type

[Relief Valve] 1900E-2, 1900-30E-2 LA & DALA (Liquids)
 Capacity Tests: Sec. NV, UV, V at Dresser, Inc. on July 12, 1995
 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
 Certified Value: 5.798 GPM/SQ. RT. PSID
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Curtain Area
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.674 in	0.093 in	15-6250 psi	Water	NV, UV, V

Design Name: 2900 (39PV & 39MV pilots - Liquid) NBCert # 18874

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

03/22/2029

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots - Liquid)
 Capacity Tests: Sec. UV, V at Dresser, Inc. on June 25, 1999
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.670 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.095 in	15-6250 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.127 in	15-6250 psi	Water	UV, V
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.16 in	15-6250 psi	Water	UV, V
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.205 in	15-6250 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.395 in	15-6250 psi	Water	UV, V
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.506 in	15-6000 psi	Water	UV, V
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.605 in	15-6000 psi	Water	UV, V
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.753 in	15-3750 psi	Water	UV, V
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.846 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.929 in	15-2250 psi	Water	UV, V
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1.126 in	15-2250 psi	Water	UV, V
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.482 in	15-1500 psi	Water	UV, V
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.738 in	15-1500 psi	Water	UV, V
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2.272 in	15-905 psi	Water	UV, V
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Water	UV, V
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.93 in	15-675 psi	Water	UV, V
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	3.675 in	15-535 psi	Water	UV, V

Design Name:	2900 (39PV & 39MV pilots)	NBCert #	18863
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	03/22/2029
-----------	----	------------

Design Type

[Pilot Operated Pressure Relief Valve] 2900 (39PV & 39MV pilots)
Capacity Tests: Sec. UV at Dresser, Inc. on June 25, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.855 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.1279 in ²	[D] 0.4036 in	0.11 in	15-7200 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-4230 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.2279 in ²	[E] 0.5387 in	0.147 in	15-6250 psi	Air	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-4230 psi	Steam	UV
1.5 NPS	2 - 3 NPS	0.3568 in ²	[F] 0.674 in	0.182 in	15-7200 psi	Air	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-4230 psi	Steam	UV
1.5-2 NPS	2.5 - 3 NPS	0.5849 in ²	[G] 0.863 in	0.234 in	15-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-2500 psi	Steam	UV
1.5-2 NPS	3 NPS	0.9127 in ²	[H] 1.078 in	0.292 in	15-3750 psi	Air	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-2500 psi	Steam	UV
2-3 NPS	3 - 4 NPS	1.496 in ²	[J] 1.38 in	0.374 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-2600 psi	Steam	UV
3 NPS	4 - 6 NPS	2.138 in ²	[K] 1.65 in	0.446 in	15-6000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-3750 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.317 in ²	[L] 2.055 in	0.556 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-2250 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.3086 in	0.625 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	0.685 in	15-1600 psi	Steam	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-2250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	0.83 in	15-1700 psi	Steam	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.09 in	15-900 psi	Steam	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-1500 psi	Air	UV
6 NPS	8 - 10 NPS	18.6 in ²	[R] 4.867 in	1.29 in	15-905 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	1.723 in	15-905 psi	Steam	UV
8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Air	UV

8 NPS	10 NPS	35 in ²	[U] 6.688 in	1.841 in	15-905 psi	Steam	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-675 psi	Air	UV
10 NPS	14 NPS	50.26 in ²	[V] 8.002 in	2.162 in	15-300 psi	Steam	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-535 psi	Air	UV
12 NPS	16 NPS	78.996 in ²	[W] 10.029 in	2.523 in	15-300 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots)

NBCert #

18447

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

12/12/2028

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots)
Capacity Tests: Sec. NV, UV at Dresser, Inc. on May 19, 1988
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-2150 psi	Steam	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-750 psi	Steam	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-2150 psi	Steam	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Air	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-750 psi	Steam	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-2150 psi	Steam	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Air	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-750 psi	Steam	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-2150 psi	Steam	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Air	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-750 psi	Steam	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-2150 psi	Steam	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-2150 psi	Steam	UV

2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Air	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-750 psi	Steam	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-2150 psi	Steam	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-6250 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Air	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-750 psi	Steam	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-2150 psi	Steam	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-750 psi	Steam	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Steam	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Air	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Steam	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Air	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Steam	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Air	UV
8 NPS	10, 12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-750 psi	Steam	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Steam	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Air	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Steam	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Air	UV
12 NPS	16 NPS	99.51 in ²	11.256 in	4.88 in	15-750 psi	Steam	UV

Design Name: 3900 (39PV, 39MV pilots, liquid)

NBCert #

18458

Manufacturer/Assembler

Designators

Expiration Date

Assembler

UV

12/12/2028

Design Type

[Pilot Operated Pressure Relief Valve] 3900 (39PV, 39MV pilots, liquid)
 Capacity Tests: Sec. NV, UV at Dresser, Inc. on June 1, 1988
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.743 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Dresser, LLC. {DPT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.128 in ²	[D] 0.404 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.228 in ²	[E] 0.539 in	0.25 in	15-6250 psi	Water	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	NV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.585 in ²	[G] 0.863 in	0.5 in	15-6250 psi	Water	UV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	NV
1.5-2 NPS	3 NPS	0.913 in ²	[H] 1.078 in	0.5 in	15-6250 psi	Water	UV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	NV
2-3 NPS	3-4 NPS	1.496 in ²	[J] 1.38 in	0.5 in	15-6250 psi	Water	UV
1.5 NPS	2 NPS	1.621 in ²	1.437 in	0.25 in	15-6250 psi	Water	UV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	NV
3 NPS	4 NPS	2.138 in ²	[K] 1.65 in	0.68 in	15-6250 psi	Water	UV
2 NPS	3 NPS	2.764 in ²	1.876 in	0.5 in	15-6250 psi	Water	UV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	NV
3-4 NPS	4-6 NPS	3.317 in ²	[L] 2.055 in	0.68 in	15-6250 psi	Water	UV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	4.186 in ²	[M] 2.309 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	5.047 in ²	[N] 2.535 in	1 in	15-3750 psi	Water	UV
3 NPS	4 NPS	6.321 in ²	2.837 in	0.68 in	15-3750 psi	Water	UV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	NV
4 NPS	6 NPS	7.417 in ²	[P] 3.073 in	1 in	15-3750 psi	Water	UV
4 NPS	6 NPS	10.76 in ²	3.701 in	1 in	15-3750 psi	Water	UV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	12.85 in ²	[Q] 4.045 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	NV
6 NPS	8 NPS	18.6 in ²	[R] 4.866 in	1.31 in	15-1500 psi	Water	UV
6 NPS	8, 10 NPS	24.95 in ²	5.636 in	1.31 in	15-1500 psi	Water	UV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	NV
8 NPS	10 NPS	30.21 in ²	[T] 6.205 in	2 in	15-1500 psi	Water	UV

8 NPS	10-12 NPS	44.18 in ²	7.5 in	2 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	NV
10 NPS	10-14 NPS	63.62 in ²	[W] 9 in	3 in	15-1500 psi	Water	UV
10 NPS	10-14 NPS	69.94 in ²	9.437 in	3 in	15-1500 psi	Water	UV

ValvTechnologies, LLC (VLC)

Nameplate Abbreviation:
ValvTechnologies

Houston, TX 77092United States

This Company Manufactures or Assembles:

Design Name: EOL121NRA*P1-MK1H NBCert # 59082

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	V	08/01/2031

Design Type

[Power Actuated Relief Valve] EOL121NRA*P1-MK1H
Capacity Tests: Sec. V at National Board Testing Lab on December 4, 2002
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:109.20 PPH/PSIA
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Power Actuated
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ValvTechnologies, LLC {VLC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2.5 NPS	4 NPS	2.48 in ²	1.777 in		55-5000 psi	Steam	V

Design Name: ERV 3 1/16" Bore NBCert # 59037

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	V	06/09/2030

Design Type

[Power Actuated Relief Valve] ERV 3 1/16" Bore
Capacity Tests: Sec. V at National Board Testing Lab on June 9, 1997
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:312.20 PPH/PSIA
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Power Actuated
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ValvTechnologies, LLC {VLC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
3 NPS	3, 8 NPS	7.366 in ²	3.063 in		15-1440 psi	Steam	V

Design Name: Z***-05*****_*****_*** NBCert # 59059

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	V	02/23/2030

Design Type

[Power Actuated Relief Valve] Z***-05*****_*****_***

Capacity Tests: Sec. V at National Board Testing Lab on February 27, 2018

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 11.000 PPH/PSIA

Media - Test: Steam; Certified: Steam

Set Pressure Definition: Power Actuated

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: ValvTechnologies, LLC {VLC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1.5 NPS	0.307 in ²	0.625 in		15-5000 psi	Steam	V

Design Name: Z***-103***5* NBCert # 59127

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

V

05/09/2026

Design Type

[Power Actuated Relief Valve] Z***-103***5*

Capacity Tests: Sec. V at National Board Testing Lab on May 9, 2014

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 33.700 PPH/PSIA

Media - Test: Steam; Certified: Steam

Set Pressure Definition: Power Actuated

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: ValvTechnologies, LLC {VLC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5 NPS	0.882 in ²	1.06 in		15-1500 psi	Steam	V

Design Name: Z***-105***8*, Z***-105***6* NBCert # 59105

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

V

10/09/2027

Design Type

[Power Actuated Relief Valve] Z***-105***8*, Z***-105***6*

Capacity Tests: Sec. V at National Board Testing Lab on June 24, 2010

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value: 38.100 PPH/PSIA

Media - Test: Steam; Certified: Steam

Set Pressure Definition: Power Actuated

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: ValvTechnologies, LLC {VLC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2, 3 NPS	0.887 in ²	1.062 in		75-5000 psi	Steam	V

Design Name: Z***-107*****_*****_*** NBCert # 59026

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

V

01/06/2026

Design Type

[Power Actuated Relief Valve] Z***-107*****_*****_***

Capacity Tests: Sec. V at National Board Testing Lab on September 9, 1993

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value:32.400 PPH/PSIA

Media - Test: Steam; Certified: Steam

Set Pressure Definition: Power Actuated

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: ValvTechnologies, LLC {VLC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2.5 NPS	4 NPS	0.886 in ²	1.062 in		15-5000 psi	Steam	V

Design Name: Z***-14*****_*****_***

NBCert # 59015

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

V

01/06/2026

Design Type

[Power Actuated Relief Valve] Z***-14*****_*****_***

Capacity Tests: Sec. V at National Board Testing Lab on September 9, 1993

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value:73.700 PPH/PSIA

Media - Test: Steam; Certified: Steam

Set Pressure Definition: Power Actuated

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: ValvTechnologies, LLC {VLC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2.5 NPS	4 NPS	1.767 in ²	1.5 in		15-5000 psi	Steam	V

Design Name: Z***-145*****_*****_***

NBCert # 59071

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

V

10/15/2027

Design Type

[Power Actuated Relief Valve] Z***-145*****_*****_***

Capacity Tests: Sec. V at National Board Testing Lab on October 15, 2021

Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method

Certified Value:76.760 PPH/PSIA

Media - Test: Steam; Certified: Steam

Set Pressure Definition: Power Actuated

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: ValvTechnologies, LLC {VLC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.767 in ²	1.5 in		15-1755 psi	Steam	V

Design Name: Z***-21*****_*****_***

NBCert # 59060

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

V

06/16/2030

Design Type

[Power Actuated Relief Valve] Z***-21*****-****-***
Capacity Tests: Sec. V at National Board Testing Lab on June 16, 1992
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:143.20 PPH/PSIA
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Power Actuated
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ValvTechnologies, LLC {VLC}
Comments: Previous designations: EOL-1-SV-FP and E*9121

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2.5-4 NPS	4 NPS	3.547 in²	2.125 in		15-5000 psi	Steam	V

Design Name:	Z***-51C***E**Z-*****-V**	NBCert #	59138
--------------	---------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	V	09/24/2027

Design Type

[Power Actuated Relief Valve] Z***-51C***E**Z-*****-V**
Capacity Tests: Sec. V at National Board Testing Lab on September 24, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.862 Unitless; Certification Provisions: Exceeds Lab Limits (Prev. CC 2397)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Power Actuated
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: ValvTechnologies, LLC {VLC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
6 NPS	10 NPS	20.629 in²	5.125 in		15-750 psi	Steam	V

Valvulas Nacional S. A. (VNS) Nameplate Abbreviation: Nacional Safety Valves

Rubi (Barcelona), 08191Spain

This Company Manufactures or Assembles:

Design Name:	5100	NBCert #	96173
--------------	------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/18/2028

Design Type

[Safety Relief Valve] 5100
Capacity Tests: Sec. UV at National Board Testing Lab on July 27, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.864 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Valvulas Nacional S. A. {VNS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75-1 NPS	0.048 in ²	[C] 0.248 in	0.071 in	15-2900 psi	Steam	UV
0.5-1 NPS	0.75-1 NPS	0.048 in ²	[C] 0.248 in	0.071 in	15-6237 psi	Air	UV
0.5-1 NPS	1 NPS	0.122 in ²	[D] 0.394 in	0.118 in	15-2900 psi	Steam	UV
0.5-1 NPS	1 NPS	0.122 in ²	[D] 0.394 in	0.118 in	15-4206 psi	Air	UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.15 in	15-2900 psi	Air	UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.15 in	15-2900 psi	Steam	UV

Design Name: 5100 (Liquid)	NBCert # 96184
----------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	01/18/2028

Design Type

[Safety Relief Valve] 5100 (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on May 19, 2021
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.750 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Valvulas Nacional S. A. {VNS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75-1 NPS	0.048 in ²	[C] 0.248 in	0.087 in	15-6237 psi	Water	UV
0.5-1 NPS	1 NPS	0.122 in ²	[D] 0.394 in	0.138 in	15-4206 psi	Water	UV
0.75-1 NPS	1 NPS	0.196 in ²	[E] 0.5 in	0.177 in	15-2900 psi	Water	UV

Design Name: 6400	NBCert # 96016
-------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	02/11/2031

Design Type

[Safety Relief Valve] 6400
Capacity Tests: Sec. UV at National Board Testing Lab on October 1, 2013
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.873 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Valvulas Nacional S. A. {VNS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.122 in ²	[D] 0.394 in	0.157 in	15-2900 psi	Steam	UV
1-1.5 NPS	2, 3 NPS	0.122 in ²	[D] 0.394 in	0.157 in	15-6004 psi	Air	UV
1-1.5 NPS	2, 3 NPS	0.222 in ²	[E] 0.531 in	0.157 in	15-6004 psi	Air	UV
1-1.5 NPS	2, 3 NPS	0.222 in ²	[E] 0.531 in	0.157 in	15-2900 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.352 in ²	[F] 0.669 in	0.276 in	15-2900 psi	Steam	UV

1.5 NPS	2, 3 NPS	0.352 in ²	[F] 0.669 in	0.276 in	15-5003 psi	Air	UV
1.5-2 NPS	3 NPS	0.563 in ²	[G] 0.846 in	0.354 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.563 in ²	[G] 0.846 in	0.354 in	15-3698 psi	Air	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.433 in	15-2775 psi	Steam	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.433 in	15-2755 psi	Air	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[J] 1.339 in	0.512 in	15-2697 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[J] 1.339 in	0.512 in	15-2697 psi	Air	UV
3 NPS	4, 6 NPS	2.046 in ²	[K] 1.614 in	0.551 in	15-2219 psi	Steam	UV
3 NPS	4, 6 NPS	2.046 in ²	[K] 1.614 in	0.551 in	15-2219 psi	Air	UV
3-4 NPS	4, 6 NPS	3.166 in ²	[L] 2.008 in	0.63 in	15-1494 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.166 in ²	[L] 2.008 in	0.63 in	15-1494 psi	Air	UV
4 NPS	6 NPS	4.025 in ²	[M] 2.264 in	0.748 in	15-1102 psi	Steam	UV
4 NPS	6 NPS	4.025 in ²	[M] 2.264 in	0.748 in	15-1102 psi	Air	UV
4 NPS	6 NPS	4.986 in ²	[N] 2.52 in	0.787 in	15-1001 psi	Air	UV
4 NPS	6 NPS	4.986 in ²	[N] 2.52 in	0.787 in	15-1001 psi	Steam	UV
4 NPS	6 NPS	7.218 in ²	[P] 3.031 in	0.945 in	15-1001 psi	Steam	UV
4 NPS	6 NPS	7.218 in ²	[P] 3.031 in	0.945 in	15-1001 psi	Air	UV
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	1.181 in	15-595 psi	Steam	UV
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	1.181 in	15-595 psi	Air	UV
6 NPS	8, 10 NPS	17.53 in ²	[R] 4.724 in	1.339 in	15-305 psi	Air	UV
6 NPS	8, 10 NPS	17.53 in ²	[R] 4.724 in	1.339 in	15-305 psi	Steam	UV
8 NPS	10 NPS	28.497 in ²	[T] 6.024 in	1.654 in	15-305 psi	Steam	UV
8 NPS	10 NPS	28.497 in ²	[T] 6.024 in	1.654 in	15-305 psi	Air	UV

Design Name: 6400 (Liquid)	NBCert # 96027
----------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/11/2031

Design Type

[Safety Relief Valve] 6400 (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on October 1, 2013
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Valvulas Nacional S. A. {VNS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2, 3 NPS	0.122 in ²	[D] 0.394 in	0.071 in	15-6004 psi	Water	UV
1-1.5 NPS	2, 3 NPS	0.222 in ²	[E] 0.531 in	0.209 in	15-6004 psi	Water	UV
1.5 NPS	2, 3 NPS	0.352 in ²	[F] 0.669 in	0.26 in	15-5003 psi	Water	UV
1.5-2 NPS	3 NPS	0.563 in ²	[G] 0.846 in	0.394 in	15-3698 psi	Water	UV
1.5-2 NPS	3 NPS	0.887 in ²	[H] 1.063 in	0.512 in	15-2755 psi	Water	UV
2-3 NPS	3, 4 NPS	1.407 in ²	[J] 1.339 in	0.551 in	15-2697 psi	Water	UV

3 NPS	4, 6 NPS	2.046 in ²	[K] 1.614 in	0.63 in	15-2219 psi	Water	UV
3-4 NPS	4, 6 NPS	3.166 in ²	[L] 2.008 in	0.787 in	15-1494 psi	Water	UV
4 NPS	6 NPS	4.025 in ²	[M] 2.264 in	0.866 in	15-1102 psi	Water	UV
4 NPS	6 NPS	4.986 in ²	[N] 2.52 in	0.906 in	15-1001 psi	Water	UV
4 NPS	6 NPS	7.218 in ²	[P] 3.031 in	1.102 in	15-1001 psi	Water	UV
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	1.22 in	15-595 psi	Water	UV
6 NPS	8, 10 NPS	17.53 in ²	[R] 4.724 in	1.535 in	15-305 psi	Water	UV
8 NPS	10 NPS	28.497 in ²	[T] 6.024 in	1.929 in	15-305 psi	Water	UV

Design Name:	MVP648T10	NBCert #	96263
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UV 02/23/2030

Design Type

[Pilot Operated Pressure Relief Valve] MVP648T10
HolderDesignation:
Capacity Tests: Sec. UV at National Board Testing Lab on October 5, 2023
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.860 Unitless; (alternate medium): 0.000
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Valvulas Nacional S. A. {VNS}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
8 NPS	10 NPS	28.497 in ²	[T]	2.28 in	30-288 psi	Air	UV

Vaptec Equipement de Vapeur Industrielle Inc. (VEV)

Nameplate Abbreviation: Vaptec

Montreal, QC H4S 1V3Canada

This Company Manufactures or Assembles:

Design Name:	441/442/444	NBCert #	37044
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/05/2030

Design Type

[Safety Relief Valve] 441/442/444
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on February 17, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.699 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Air	UV

1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Steam	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Air	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Steam	UV
1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Air	UV
1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Steam	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Air	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Steam	UV
2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Air	UV
2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Steam	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Air	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Steam	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Air	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Steam	UV
5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Air	UV
5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Steam	UV
6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Air	UV
6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Steam	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Air	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Steam	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Air	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Steam	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Air	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Steam	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Air	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Steam	UV

Design Name: 441/442/444 liquids

NBCert #

37055

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

12/20/2029

Design Type

[Relief Valve] 441/442/444 liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on September 6, 1996
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.521 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.5,2 NPS	0.644 in ²	0.906 in	0.277 in	15-715 psi	Water	UV
1.25-1.5 NPS	2 NPS	1.024 in ²	1.142 in	0.349 in	15-715 psi	Water	UV
1.5 NPS	2.5,3 NPS	1.667 in ²	1.457 in	0.446 in	15-715 psi	Water	UV
2 NPS	3 NPS	2.576 in ²	1.811 in	0.554 in	15-715 psi	Water	UV

2.5-3 NPS	4 NPS	4.383 in ²	2.362 in	0.723 in	15-500 psi	Water	UV
3 NPS	5 NPS	6.666 in ²	2.913 in	0.891 in	15-500 psi	Water	UV
4 NPS	6 NPS	10.304 in ²	3.622 in	1.108 in	15-418 psi	Water	UV
5 NPS	8 NPS	11.692 in ²	3.858 in	1.181 in	15-315 psi	Water	UV
6 NPS	10 NPS	19.021 in ²	4.921 in	1.506 in	15-290 psi	Water	UV
8 NPS	12 NPS	33.143 in ²	6.496 in	1.988 in	15-430 psi	Water	UV
10 NPS	14 NPS	48.695 in ²	7.874 in	2.409 in	15-300 psi	Water	UV
12 NPS	16 NPS	67.229 in ²	9.252 in	2.831 in	15-310 psi	Water	UV
16 NPS	20 NPS	105.94 in ²	11.614 in	3.554 in	15-175 psi	Water	UV

Design Name:	459/462	NBCert #	37112
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/05/2030

Design Type

[Safety Relief Valve] 459/462
Capacity Tests: Sec. UV at National Board Testing Lab on February 17, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.811 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Air	UV
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Air	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Steam	UV

Design Name:	459/462 liquids	NBCert #	37101
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 12/20/2029

Design Type

[Relief Valve] 459/462 liquids
Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.566 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Water	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Water	UV
0.5-1.5 NPS	1-2.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Water	UV
1-2 NPS	1.5-2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Water	UV

Design Name: 526	NBCert # 37224
------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/05/2030

Design Type

[Safety Relief Valve] 526
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 22, 2001
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.801 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Air	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-2900 psi	Steam	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Air	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-2900 psi	Steam	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Steam	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Air	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Steam	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Air	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Steam	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Air	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Steam	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Air	UV

6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Steam	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Air	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Steam	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Air	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Steam	UV

Design Name: 526 (Liquids)

NBCert #

37235

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

12/20/2029

Design Type

[Relief Valve] 526 (Liquids)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on January 2, 2002
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.579 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Water	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Water	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Water	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Water	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Water	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Water	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.6698 in	15-1850 psi	Water	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Water	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Water	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Water	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.249 in	15-1038.5 psi	Water	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Water	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-914 psi	Water	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Water	UV

Design Name: 560, 570

NBCert #

02080

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV, V

08/05/2030

Design Type

[Safety Valve] 560, 570
 Capacity Tests: Sec. UV, V at National Board Testing Lab on November 10, 2005
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.856 Unitless
 Media - Test: Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Adjustable (Dual Ring)
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Aquatrol, Incorporated {AQT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-300 psi	Steam	UV, V
0.75-1 NPS	1 NPS	0.221 in ²	[E] 0.53 in	0.132 in	15-300 psi	Air	UV
0.75-1 NPS	1 NPS	0.221 in ²	[E] 0.53 in	0.132 in	15-300 psi	Steam	UV, V
1-1.25 NPS	1.25 NPS	0.352 in ²	[F] 0.67 in	0.167 in	15-300 psi	Air	UV
1-1.25 NPS	1.25 NPS	0.352 in ²	[F] 0.67 in	0.167 in	15-300 psi	Steam	UV, V
1.25-1.5 NPS	1.5 NPS	0.567 in ²	[G] 0.85 in	0.212 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5 NPS	0.567 in ²	[G] 0.85 in	0.212 in	15-300 psi	Steam	UV, V
1.5-2 NPS	2 NPS	0.899 in ²	[H] 1.07 in	0.267 in	15-300 psi	Air	UV
1.5-2 NPS	2 NPS	0.899 in ²	[H] 1.07 in	0.267 in	15-300 psi	Steam	UV, V
2-2.5 NPS	2.5 NPS	1.463 in ²	[J] 1.365 in	0.41 in	15-300 psi	Air	UV
2-2.5 NPS	2.5 NPS	1.463 in ²	[J] 1.365 in	0.41 in	15-300 psi	Steam	UV, V

Design Name: Series 740

NBCert #

02091

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/05/2030

Design Type

[Safety Relief Valve] Series 740
 Capacity Tests: Sec. UV at National Board Testing Lab on November 21, 2012
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.878 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Pop
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Aquatrol, Incorporated {AQT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75, 1 NPS	0.125 in ²	[D] 0.4 in	0.105 in	15-1500 psi	Air	UV
0.5-1 NPS	0.75, 1 NPS	0.125 in ²	[D] 0.4 in	0.105 in	15-300 psi	Steam	UV
0.5-1.25 NPS	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-1500 psi	Air	UV
0.5-1.25 NPS	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-300 psi	Steam	UV
0.75-1.5 in	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-1500 psi	Air	UV
0.75-1.5 in	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-300 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.353 in ²	[F] 0.67 in	0.17 in	15-300 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.353 in ²	[F] 0.67 in	0.17 in	15-750 psi	Air	UV
1-2 in	1.5 NPS	0.353 in ²	[F] 0.67 in	0.017 in	15-750 psi	Air	UV

1-2 in	1.5 NPS	0.353 in ²	[F] 0.67 in	0.017 in	15-300 psi	Steam	UV
1.25-2 NPS	2 NPS	0.554 in ²	[G] 0.84 in	0.215 in	15-300 psi	Steam	UV
1.25-2 NPS	2 NPS	0.554 in ²	[G] 0.84 in	0.215 in	15-700 psi	Air	UV
1.5-2.5 NPS	2, 2.5 NPS	0.923 in ²	[H] 1.084 in	0.28 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2, 2.5 NPS	0.923 in ²	[H] 1.084 in	0.28 in	15-600 psi	Air	UV
2-3 NPS	3 NPS	1.418 in ²	[J] 1.344 in	0.34 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	1.418 in ²	[J] 1.344 in	0.34 in	15-600 psi	Air	UV

Design Name:	Series 740 (Liquid)	NBCert #	02103
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 12/20/2029

Design Type

[Safety Relief Valve] Series 740 (Liquid)
Capacity Tests: Sec. UV at National Board Testing Lab on November 20, 2012
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.791 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Flow Area Configuration: Nozzle/Full Lift
Designed by: Aquatrol, Incorporated {AQT}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.75, 1 NPS	0.125 in ²	[D] 0.4 in	0.105 in	15-1500 psi	Water	UV
0.75-1.25 NPS	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-1500 psi	Water	UV
0.75-1.5 in	1, 1.25 NPS	0.217 in ²	[E] 0.526 in	0.135 in	15-1500 psi	Water	UV
1-1.5 NPS	1.5 NPS	0.353 in ²	[F] 0.67 in	0.17 in	15-750 psi	Water	UV
1-2 in	1.5 NPS	0.353 in ²	[F] 0.67 in	0.017 in	15-750 psi	Water	UV
1.25-2 NPS	2 NPS	0.554 in ²	[G] 0.84 in	0.215 in	15-700 psi	Water	UV
1.5-2.5 NPS	2, 2.5 NPS	0.923 in ²	[H] 1.084 in	0.28 in	15-600 psi	Water	UV
2-3 NPS	3 NPS	1.418 in ²	[J] 1.344 in	0.34 in	15-600 psi	Water	UV

Vinson Process Controls Company, LP (POK)

Tulsa, OK 74116United States

This Company Manufactures or Assembles:

Design Name:	HL, HSL	NBCert #	15589
--------------	---------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler V 10/07/2030

Design Type

[Safety Valve] HL, HSL
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on November 3, 1999
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.869 Unitless
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25-2 NPS	1.5 NPS	0.339 in ²	[F] 0.657 in	0.164 in	15-725 psi	Steam	UV, V
1.25-2 NPS	1.5 NPS	0.553 in ²	[G] 0.839 in	0.21 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	0.868 in ²	[H] 1.051 in	0.263 in	15-725 psi	Steam	UV, V
1.5-2.5 NPS	2.5 NPS	1.327 in ²	[J] 1.3 in	0.325 in	15-725 psi	Steam	UV, V
2-3 NPS	3-4 NPS	2.046 in ²	[K] 1.614 in	0.404 in	15-725 psi	Steam	UV, V
2.5-4 NPS	4-6 NPS	3.167 in ²	[L] 2.008 in	0.502 in	15-725 psi	Steam	UV, V
3 NPS	4-6 NPS	3.955 in ²	[M] 2.244 in	0.561 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	4.831 in ²	[N] 2.48 in	0.62 in	15-725 psi	Steam	UV, V
4 NPS	6 NPS	7.031 in ²	[P] 2.992 in	0.748 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	11.045 in ²	[QQ] 3.75 in	0.937 in	15-725 psi	Steam	UV, V
6 NPS	8 NPS	12.174 in ²	[Q] 3.937 in	0.984 in	15-725 psi	Steam	UV, V

Vinson Process Controls Company, LP (VIN)

Carrollton, TX 75007United States

This Company Manufactures or Assembles:

Design Name: 243/249/443/449/546/843/849/943/5046/5049/8043/8049 NBCert # 01292

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/24/2030

Design Type

[Pilot Operated Pressure Relief Valve] 243/249/443/449/546/843/849/943/5046/5049/8043/8049
Capacity Tests: Sec. UV at unknown lab on August 8, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.25 in	15-720 psi	Steam	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	15-10600 psi	Air	UV
1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.446 in	25-720 psi	Steam	UV

2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.637 in	15-720 psi	Steam	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-720 psi	Steam	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.645 in ²	[P] 3.12 in	1.62 in	15-720 psi	Steam	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.597 in ²	[R] 4.866 in	2.435 in	15-720 psi	Steam	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-10600 psi	Air	UV
8 NPS	10 NPS	30.582 in ²	[T] 6.24 in	3.12 in	15-720 psi	Steam	UV

Design Name: 253/259/453/459/853/859/953/959/5059/8053/8059 NBCert # 01304

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/24/2030

Design Type

[Pilot Operated Pressure Relief Valve] 253/259/453/459/853/859/953/959/5059/8053/8059
Capacity Tests: Sec. UV at unknown lab on July 31, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.627 Unitless
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.205 in ²	[D] 0.674 in	0.079 in	15-15000 psi	Air	UV
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-15000 psi	Air	UV
1.5 NPS	2, 3 NPS	0.831 in ²	[G] 1.078 in	0.241 in	15-10600 psi	Air	UV
2 NPS	3 NPS	0.85 in ²	[G] 1.38 in	0.191 in	15-15000 psi	Air	UV
2 NPS	3 NPS	1.312 in ²	[H] 1.38 in	0.295 in	15-15000 psi	Air	UV
3 NPS	3 NPS	2.132 in ²	[J] 2.055 in	0.323 in	15-10600 psi	Air	UV
3 NPS	4 NPS	3.043 in ²	[K] 2.055 in	0.461 in	15-10600 psi	Air	UV
4 NPS	6 NPS	7.188 in ²	[N] 3.12 in	0.725 in	15-10600 psi	Air	UV
4 NPS	6 NPS	4.729 in ²	[L] 3.12 in	0.477 in	15-10600 psi	Air	UV
4 NPS	6 NPS	5.959 in ²	[M] 3.12 in	0.601 in	15-10600 psi	Air	UV
6 NPS	8, 10 NPS	18.294 in ²	[Q] 4.866 in	1.185 in	15-10600 psi	Air	UV

Design Name: 263/269/463/469/566/863/869/963/969/5066/5069 NBCert # 01315

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/24/2030

Design Type

[Pilot Operated Pressure Relief Valve] 263/269/463/469/566/863/869/963/969/5066/5069
 Capacity Tests: Sec. UV at unknown lab on July 30, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.860 Unitless
 Media - Test: Air/Gas; Certified: Air, Gas, Steam
 Set Pressure Definition(1): Pop; (2): Initial Audible Discharge
 Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-10600 psi	Air	UV
1-1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-720 psi	Steam	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-10600 psi	Air	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-720 psi	Steam	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-10600 psi	Air	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.62 in	15-720 psi	Steam	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-10600 psi	Air	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-2220 psi	Steam	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-10600 psi	Air	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-720 psi	Steam	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-10600 psi	Air	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-720 psi	Steam	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-10600 psi	Air	UV
8 NPS	10 NPS	36.605 in ²	6.827 in	3.755 in	15-720 psi	Steam	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-1480 psi	Air	UV
8 NPS	10 NPS	37.523 in ²	6.912 in	3.802 in	15-720 psi	Steam	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-1480 psi	Air	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-720 psi	Steam	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-10600 psi	Air	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-720 psi	Steam	UV

Design Name: 443/449/546/843/849/943/949/5046/5049 (Liquids) NBCert # 01337

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/24/2030

Design Type

[Pilot Operated Pressure Relief Valve] 443/449/546/843/849/943/949/5046/5049(Liquids)
 Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.767 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.357 in ²	[F] 0.674 in	0.21 in	15-7600 psi	Water	UV, V

1.5 NPS	2, 3 NPS	0.913 in ²	[H] 1.078 in	0.51 in	15-7600 psi	Water	UV, V
2 NPS	3 NPS	1.496 in ²	[J] 1.38 in	0.82 in	15-7600 psi	Water	UV, V
3 NPS	4 NPS	3.317 in ²	[L] 2.055 in	1.155 in	15-7600 psi	Water	UV, V
4 NPS	6 NPS	7.069 in ²	[P] 3 in	1.62 in	15-7600 psi	Water	UV, V
6 NPS	8, 10 NPS	15.904 in ²	[R] 4.5 in	2.435 in	15-7600 psi	Water	UV, V
8 NPS	10 NPS	28.274 in ²	[T] 6 in	3.12 in	15-7600 psi	Water	UV, V

Design Name: 453/459/853/859/953/959/5059 (Liquids) NBCert # 01326

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/24/2030

Design Type

[Pilot Operated Pressure Relief Valve] 453/459/853/859/953/959/5059 (Liquids)
Capacity Tests: Sec. UV, V at Crosby Valve, LLC on August 5, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.491 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	V
1-1.5 NPS	2 NPS	0.356 in ²	[E] 0.674 in	0.137 in	15-7600 psi	Water	UV
1-1.5 NPS	2 NPS	0.221 in ²	[D] 0.674 in	0.085 in	15-7600 psi	Water	UV
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	V
1.5 NPS	2, 3 NPS	0.911 in ²	[G] 1.078 in	0.264 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	V
2 NPS	3 NPS	1.005 in ²	[G] 1.38 in	0.226 in	15-7600 psi	Water	UV
2 NPS	3 NPS	1.495 in ²	[H] 1.38 in	0.336 in	15-7600 psi	Water	UV
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	V
3 NPS	4 NPS	2.574 in ²	[J] 2.055 in	0.39 in	15-7600 psi	Water	UV
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	V
3 NPS	4 NPS	3.313 in ²	[K] 2.055 in	0.502 in	15-7600 psi	Water	UV
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	V
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	V
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	V
4 NPS	6 NPS	5.711 in ²	[L] 3 in	0.576 in	15-7600 psi	Water	UV
4 NPS	6 NPS	6.385 in ²	[M] 3 in	0.644 in	15-7600 psi	Water	UV
4 NPS	6 NPS	7.059 in ²	[N] 3 in	0.712 in	15-7600 psi	Water	UV
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	V
6 NPS	8, 10 NPS	15.885 in ²	[Q] 4.5 in	1.029 in	15-7600 psi	Water	UV

Design Name: 463/469/566/863/869/963/969/5066/5069 (Liquids)		NBCert #	01348
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	10/24/2030
Design Type			
[Pilot Operated Pressure Relief Valve] 463/469/566/863/869/963/969/5066/5069 (Liquids) Capacity Tests: Sec. UV at Crosby Valve, LLC on August 27, 1997 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.712 Unitless Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.496 in ²	1.38 in	0.96 in	15-7600 psi	Water	UV
2 NPS	3 NPS	2.895 in ²	1.92 in	1.155 in	15-7600 psi	Water	UV
3 NPS	4 NPS	6.733 in ²	2.928 in	1.315 in	15-7600 psi	Water	UV
4 NPS	6 NPS	10.758 in ²	3.701 in	2.035 in	15-7600 psi	Water	UV
6 NPS	8 NPS	23.328 in ²	5.45 in	3 in	15-7600 psi	Water	UV
8 NPS	8 NPS	32.17 in ²	6.4 in	3.52 in	15-7600 psi	Water	UV
8 NPS	10 NPS	44.179 in ²	7.5 in	4.125 in	15-7600 psi	Water	UV
10 NPS	14 NPS	72.006 in ²	9.575 in	5.35 in	15-7600 psi	Water	UV

Design Name: 81, 81P, 83, 84		NBCert #	01089
Manufacturer/Assembler		Designators	Expiration Date
Assembler		UV	10/24/2030
Design Type			
[Safety Relief Valve] 81, 81P, 83, 84 Capacity Tests: Sec. UV at unknown lab on July 8, 1965 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.816 Unitless Media - Test: Air/Gas, Steam; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Adjustable Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC} Comments: Type 81P and 84 have fixed blowdown.			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25-2 NPS	.75 - 2 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	20-22000 psi	Air	UV
0.5-2 NPS	.75 - 2 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-12500 psi	Air	UV
0.5-2 NPS	.75 - 2.5 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-5000 psi	Air	NV
0.5-2 NPS	1 - 2.5 NPS	0.11 in ²	[-6] 0.375 in	0.12 in	20-9600 psi	Air	UV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-5000 psi	Air	NV
0.75-2 NPS	1 - 2.5 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	20-6000 psi	Air	UV

1.5 NPS	2 NPS	0.307 in ²	[F] 0.625 in	0.28 in	20-4040 psi	Air	UV
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	20-6000 psi	Air	UV
1.5-2 NPS	3 NPS	0.785 in ²	[H] 1 in	0.41 in	20-2580 psi	Air	UV
2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	20-1620 psi	Air	UV

Design Name:	81P (Liquids)	NBCert #	01102
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/24/2030

Design Type

[Relief Valve] 81P (Liquids)
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on November 26, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.720 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: 93% of pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.012 in ²	[-2] 0.125 in	0.05 in	200-12500 psi	Water	UV, V
0.5-1 NPS	0.5-1 NPS	0.028 in ²	[-3] 0.188 in	0.06 in	200-12500 psi	Water	UV, V
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-5000 psi	Water	NV
0.5-2 NPS	1 - 2 NPS	0.049 in ²	[-4] 0.25 in	0.09 in	50-12500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.11 in ²	[-6] 0.375 in	0.13 in	50-8500 psi	Water	UV, V
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-5000 psi	Water	NV
0.75-2 NPS	1 - 2 NPS	0.196 in ²	[-8] 0.5 in	0.16 in	50-6000 psi	Water	UV, V
1.5-2 NPS	2-3 NPS	0.503 in ²	[G] 0.8 in	0.34 in	50-6000 psi	Water	UV, V
2-2 NPS	3 NPS	1.287 in ²	[J] 1.28 in	0.46 in	50-1620 psi	Water	UV, V

Design Name:	900 Series (Liquid), 7700, SNC	NBCert #	15499
--------------	--------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 10/24/2030

Design Type

[Relief Valve] 900 Series (Liquid), 7700, SNC
Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 9, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.661 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	NV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	NV

0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Water	UV, V
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	NV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Water	UV, V
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	NV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Water	UV, V
1-1.5 NPS	1.5 - 2 NPS	0.2951 in ²	0.613 in	0.265 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	NV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Water	UV, V
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	NV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Water	UV, V

Design Name:	900 Series, 7700, SNC	NBCert #	15411
--------------	-----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/24/2030

Design Type

[Safety Relief Valve] 900 Series, 7700, SNC
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on February 14, 1990
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-10000 psi	Air	UV
0.5-1 NPS	.5 - 1 NPS	0.0551 in ²	[#10] 0.265 in	0.074 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.0845 in ²	[#5] 0.328 in	0.106 in	15-2900 psi	Steam	NV, UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-10000 psi	Air	UV
0.5-1 NPS	1 - 1.5 NPS	0.1244 in ²	[#6] 0.398 in	0.128 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-2900 psi	Steam	NV, UV
1-2 NPS	1.5 - 2 NPS	0.2198 in ²	[#7] 0.529 in	0.17 in	15-5000 psi	Air	UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-2900 psi	Steam	NV, UV
1.5-2 NPS	2 NPS	0.3473 in ²	[#8] 0.665 in	0.215 in	15-5000 psi	Air	UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-2900 psi	Steam	NV, UV
1.5 NPS	2.5 NPS	0.5674 in ²	[#9] 0.85 in	0.274 in	15-5000 psi	Air	UV

Design Name:	JLT-JOS/JLT-JBS/JLT-JDS (Liquids)	NBCert #	15095
--------------	-----------------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/24/2030

Design Type

[Safety Relief Valve] JLT-JOS/JLT-JBS/JLT-JDS (Liquids)
 Capacity Tests: Sec. NV, UV, V at Crosby Valve, LLC on February 5, 1980
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.656 Unitless
 Media - Test: Liquid; Certified: Liquid
 Set Pressure Definition: First Steady Stream
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	NV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.151 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.205 in	15-6170 psi	Water	UV, V
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	NV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.257 in	15-6170 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	NV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.328 in	15-6170 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	NV
1.5-2 NPS	3 NPS	0.6249 in ²	0.892 in	0.342 in	15-2500 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	NV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.41 in	15-3705 psi	Water	UV, V
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	NV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.525 in	15-3705 psi	Water	UV, V
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	NV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.628 in	15-3705 psi	Water	UV, V
3 NPS	4-6 NPS	2.109 in ²	1.639 in	0.632 in	15-3705 psi	Water	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	NV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.782 in	15-3705 psi	Water	UV, V
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	NV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.878 in	15-2220 psi	Water	UV, V
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	NV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.964 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	NV
4 NPS	6 NPS	7.205 in ²	[P] 3.029 in	1.169 in	15-1480 psi	Water	UV, V
4 NPS	6 NPS	7.997 in ²	[P2] 3.191 in	1.232 in	15-1500 psi	Water	UV, V
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.539 in	15-1480 psi	Water	UV, V
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	NV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.852 in	15-1480 psi	Water	UV, V
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	NV
8 NPS	10, 12 NPS	29.359 in ²	[T] 6.114 in	2.361 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	UV, V
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	2.444 in	15-740 psi	Water	NV

Design Name:	JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB	NBCert #	15208
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV	10/24/2030
-----------	----	------------

Design Type

[Safety Relief Valve] JOS-E/JBS-E/JOS-H-E/JBS-H-E/JOS-JDS-E, 8400, AC/AB
Capacity Tests: Sec. NV, UV at Crosby Valve, LLC on April 1, 1975
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-15000 psi	Air	NV, UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.121 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.151 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-15000 psi	Air	NV, UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.165 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-2000 psi	Steam	NV, UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.207 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.265 in	15-2000 psi	Steam	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-15000 psi	Air	NV, UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.331 in	15-2000 psi	Steam	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-10000 psi	Air	NV, UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.424 in	15-2000 psi	Steam	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-10000 psi	Air	NV, UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.507 in	15-2000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-1000 psi	Steam	NV, UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.601 in	15-3000 psi	Air	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-2000 psi	Steam	NV, UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.631 in	15-5000 psi	Air	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-2000 psi	Steam	NV, UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.709 in	15-5000 psi	Air	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.779 in	15-3000 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Air	NV, UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.85 in	15-2250 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-1480 psi	Steam	NV, UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.945 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-1000 psi	Steam	NV, UV

6 NPS	8 NPS	11.045 in ²	3.75 in	1.243 in	15-3750 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	12.174 in ²	3.937 in	1.243 in	15-2250 psi	Steam	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Air	NV, UV
6 NPS	10 NPS	12.236 in ²	3.947 in	1.496 in	15-2250 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-1480 psi	Steam	NV, UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	1.243 in	15-3000 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Air	NV, UV
6 NPS	8 NPS	15.288 in ²	4.412 in	1.414 in	15-2250 psi	Steam	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Air	NV, UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	1.496 in	15-1480 psi	Steam	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Air	NV, UV
8 NPS	10 NPS	18.254 in ²	4.821 in	1.907 in	15-2250 psi	Steam	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	1.907 in	15-740 psi	Steam	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Air	NV, UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	1.974 in	15-740 psi	Steam	NV, UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	2.435 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Air	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	3.111 in	15-325 psi	Steam	UV

Design Name: JOS-E-RL/JBS-E-RL/JDS-E-RL (Restricted Lift version of cert 15208) NBCert # 01045

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	10/23/2030

Design Type

[Safety Relief Valve] JOS-E-RL/JBS-E-RL/JDS-E-RL (Restricted Lift version of cert 15208)
Capacity Tests: Sec. UV at unknown lab on May 26, 2015
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.865 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Restricted Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-15000 psi	Air	UV
0.75-1.5 NPS	2 - 3 NPS	0.1244 in ²	[D] 0.398 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.187 in ²	0.488 in	0.08 in	15-8490 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.08 in	15-15000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.2214 in ²	[E] 0.531 in	0.08 in	15-2000 psi	Steam	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.08 in	15-15000 psi	Air	UV
1-1.5 NPS	2 - 3 NPS	0.3473 in ²	[F] 0.665 in	0.08 in	15-2000 psi	Steam	UV

1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.08 in	15-15000 psi	Air	UV
1.5-2 NPS	2.5, 3 NPS	0.5674 in ²	[G] 0.85 in	0.08 in	15-2000 psi	Steam	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.099 in	15-15000 psi	Air	UV
1.5-2 NPS	3 NPS	0.8874 in ²	[H] 1.063 in	0.099 in	15-2000 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.127 in	15-10000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.453 in ²	[J] 1.36 in	0.127 in	15-2000 psi	Steam	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.152 in	15-10000 psi	Air	UV
3 NPS	4, 6 NPS	2.076 in ²	[K] 1.626 in	0.152 in	15-2000 psi	Steam	UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.18 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	2.714 in ²	1.859 in	0.18 in	15-3000 psi	Air	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.189 in	15-2000 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.221 in ²	[L] 2.025 in	0.189 in	15-5000 psi	Air	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.213 in	15-2000 psi	Steam	UV
3-4 NPS	6 NPS	4.065 in ²	[M] 2.275 in	0.213 in	15-5000 psi	Air	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.234 in	15-1480 psi	Steam	UV
4 NPS	6 NPS	4.9 in ²	[N] 2.498 in	0.234 in	15-3000 psi	Air	UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.255 in	15-2250 psi	Air	UV
4 NPS	6 NPS	5.444 in ²	2.633 in	0.255 in	15-2250 psi	Steam	UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.284 in	15-1480 psi	Steam	UV
4 NPS	6 NPS	7.206 in ²	[P] 3.029 in	0.284 in	15-3000 psi	Air	UV
6 NPS	8 NPS	11.045 in ²	3.75 in	0.373 in	15-1000 psi	Steam	UV
6 NPS	8 NPS	11.045 in ²	3.75 in	0.373 in	15-3750 psi	Air	UV
6 NPS	8 NPS	12.174 in ²	3.937 in	0.373 in	15-2250 psi	Air	UV
6 NPS	8 NPS	12.174 in ²	3.937 in	0.373 in	15-2250 psi	Steam	UV
6 NPS	10 NPS	12.236 in ²	3.947 in	0.449 in	15-2250 psi	Air	UV
6 NPS	10 NPS	12.236 in ²	3.947 in	0.449 in	15-2250 psi	Steam	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.373 in	15-1480 psi	Steam	UV
6 NPS	8 NPS	12.472 in ²	[Q] 3.985 in	0.373 in	15-3000 psi	Air	UV
6 NPS	8 NPS	15.288 in ²	4.412 in	0.424 in	15-2250 psi	Air	UV
6 NPS	8 NPS	15.288 in ²	4.412 in	0.424 in	15-2250 psi	Steam	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.449 in	15-1480 psi	Air	UV
6 NPS	8, 10 NPS	18.065 in ²	[R] 4.796 in	0.449 in	15-1480 psi	Steam	UV
8 NPS	10 NPS	18.254 in ²	4.821 in	0.572 in	15-2250 psi	Air	UV
8 NPS	10 NPS	18.254 in ²	4.821 in	0.572 in	15-2250 psi	Steam	UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	0.572 in	15-740 psi	Air	UV
8 NPS	10 NPS	29.359 in ²	[T] 6.114 in	0.572 in	15-740 psi	Steam	UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	0.592 in	15-740 psi	Air	UV
8 NPS	10 NPS	31.47 in ²	[T2] 6.33 in	0.592 in	15-740 psi	Steam	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	0.731 in	15-325 psi	Air	UV
10-12 NPS	14, 16 NPS	47.84 in ²	[V] 7.805 in	0.731 in	15-325 psi	Steam	UV
12-14 NPS	16, 20 NPS	78.08 in ²	[W] 9.971 in	0.933 in	15-325 psi	Air	UV

12-14 NPS	16. 20 NPS	78.08 in ²	[W] 9.971 in	0.933 in	15-325 psi	Steam	UV
-----------	------------	-----------------------	--------------	----------	------------	-------	----

VRC Protx LLC (VRR)

Evanston, WY 82930United States

This Company Manufactures or Assembles:

Design Name: Kunkle 264, 265, 266 & 267		NBCert # 36267
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/05/2030
Design Type		
<div>[Safety Relief Valve] Kunkle 264, 265, 266 & 267</div> <div>Capacity Tests: Sec. UV at unknown lab on July 20, 1956</div> <div>Method of Establishing Relieving Capacity: Flow Capacity, K</div> <div>Certified Value: 0.766 Unitless</div> <div>Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam</div> <div>Set Pressure Definition: Pop</div> <div>Blowdown Characteristics: Fixed</div> <div>Flow Area Configuration: Nozzle/Full Lift</div> <div>Designed by: Emerson Automation Solutions Final Control US LP {AGC}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.115 in	15-2000 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.11 in ²	0.375 in	0.115 in	15-3300 psi	Air	UV

Design Name: Kunkle 300,600		NBCert # 36076
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	08/06/2030
Design Type		
<div>[Safety Valve] Kunkle 300,600</div> <div>Capacity Tests: Sec. UV, V at unknown lab on February 10, 1961</div> <div>Method of Establishing Relieving Capacity: Flow Capacity, K</div> <div>Certified Value: 0.878 Unitless</div> <div>Media - Test: Steam; Certified: Air, Gas, Steam</div> <div>Set Pressure Definition: Pop</div> <div>Blowdown Characteristics: Adjustable (Dual Ring)</div> <div>Flow Area Configuration: Nozzle/Full Lift</div> <div>Designed by: Emerson Automation Solutions Final Control US LP {AGC}</div>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.307 in ²	[F] 0.625 in	0.156 in	15-1000 psi	Steam	UV
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Air	UV
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	V
1.25 NPS	1.5 NPS	0.503 in ²	[G] 0.8 in	0.2 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Air	UV

1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	V
1.5 NPS	2.5 NPS	0.785 in ²	[H] 1 in	0.25 in	15-1000 psi	Steam	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Air	UV
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	V
1.5 NPS	2.5 NPS	1.287 in ²	[J] 1.28 in	0.32 in	15-1000 psi	Steam	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Air	UV
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	V
2 NPS	3 NPS	1.839 in ²	[K] 1.53 in	0.383 in	15-1000 psi	Steam	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Air	UV
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	V
2.5 NPS	4 NPS	2.853 in ²	[L] 1.906 in	0.477 in	15-1000 psi	Steam	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Air	UV
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	V
3 NPS	4 NPS	3.597 in ²	[M] 2.14 in	0.535 in	15-1000 psi	Steam	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Air	UV
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	V
4 NPS	6 NPS	4.34 in ²	[N] 2.35 in	0.588 in	15-750 psi	Steam	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Air	UV
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	V
4 NPS	6 NPS	6.38 in ²	[P] 2.85 in	0.713 in	15-750 psi	Steam	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Air	UV
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	V
6 NPS	8 NPS	11.045 in ²	[Q] 3.75 in	0.938 in	15-600 psi	Steam	UV

Design Name: Kunkle 337		NBCert # 36278
Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/13/2030
Design Type		
<p>[Safety Relief Valve] Kunkle 337 Capacity Tests: Sec. UV at unknown lab on February 22, 1982 Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.860 Unitless Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Emerson Automation Solutions Final Control US LP {AGC}</p>		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	1.916 in ²	1.562 in	0.612 in	15-60 psi	Air	UV
2.5 NPS	2.5 NPS	2.786 in ²	1.883 in	0.755 in	15-60 psi	Air	UV
3 NPS	3 NPS	4.037 in ²	2.267 in	0.91 in	15-60 psi	Air	UV

Design Name:	Kunkle 6000, 6252 Series	NBCert #	36324
--------------	--------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler	UV, V	08/06/2030
-----------	-------	------------

Design Type

[Safety Valve] Kunkle 6000, 6252 Series
Capacity Tests: Sec. UV, V at unknown lab on March 24, 1982
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Dual Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Air	UV
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	V
0.5-0.75 NPS	.75 NPS	0.121 in ²	[D] 0.393 in	0.094 in	15-300 psi	Steam	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Air	UV
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	V
0.75-1 NPS	1, 1.25 NPS	0.216 in ²	[E] 0.524 in	0.125 in	15-300 psi	Steam	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Air	UV
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	V
1-1.25 NPS	1.25, 1.5 NPS	0.336 in ²	[F] 0.654 in	0.156 in	15-300 psi	Steam	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Air	UV
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	V
1.25-1.5 NPS	1.5, 2 NPS	0.554 in ²	[G] 0.84 in	0.2 in	15-300 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Air	UV
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	V
1.5-2 NPS	2, 2.5 NPS	0.863 in ²	[H] 1.048 in	0.25 in	15-300 psi	Steam	UV
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Air	UV
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	V
1.5-2.5 NPS	2 .5, 3 NPS	1.414 in ²	[J] 1.342 in	0.32 in	15-300 psi	Steam	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Air	UV
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	V
2-3 NPS	3 NPS	2.022 in ²	[K] 1.605 in	0.432 in	15-250 psi	Steam	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Air	UV
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	V
2.5-4 NPS	4 NPS	3.138 in ²	[L] 1.999 in	0.539 in	15-250 psi	Steam	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Air	UV
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	V
3-4 NPS	4 NPS	3.96 in ²	[M] 2.246 in	0.605 in	15-250 psi	Steam	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Air	UV
4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	V

4 NPS	6 NPS	4.774 in ²	[N] 2.466 in	0.664 in	15-250 psi	Steam	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Air	UV
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	V
4 NPS	6 NPS	7.018 in ²	[P] 2.99 in	0.805 in	15-250 psi	Steam	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Air	UV
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	V
6 NPS	8 NPS	12.155 in ²	[Q] 3.935 in	1.06 in	15-250 psi	Steam	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Air	UV
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	V
6 NPS	8 NPS	17.6 in ²	[R] 4.735 in	1.276 in	15-250 psi	Steam	UV

Design Name: Kunkle 910 to 919

NBCert #

36100

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	08/05/2030

Design Type

[Safety Relief Valve] Kunkle 910 to 919
Capacity Tests: Sec. UV at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Air	UV
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Air	UV
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Air	UV
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Air	UV
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Air	UV
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	UV

Design Name: Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)

NBCert #

36111

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV, V	06/13/2030

Design Type

[Relief Valve] Kunkle 910 to 919 (Sect. VIII Liquid), 928 and 929 (Sect. I Liquid)
Capacity Tests: Sec. UV, V at unknown lab on May 8, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.710 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75 , 1 NPS	0.1213 in ²	[D] 0.393 in	0.126 in	15-1400 psi	Water	UV, V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.168 in	15-1000 psi	Water	UV, V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.21 in	15-700 psi	Water	UV, V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.268 in	15-600 psi	Water	UV, V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.336 in	15-500 psi	Water	UV, V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.429 in	15-500 psi	Water	UV, V

Design Name:	Kunkle 920, 921, 927, Agco A (High Temp. water)	NBCert #	36098
Manufacturer/Assembler		Designators	Expiration Date
Assembler		V	08/07/2030

Design Type

[Safety Valve] Kunkle 920, 921, 927, Agco A (High Temp. water)
Capacity Tests: Sec. V at unknown lab on May 19, 1969
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless; Certification Provisions: Forced Flow Steam Generator/High Temp Hot Water (10% BD)
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Flow Area Configuration: Nozzle/Full Lift
Designed by: Emerson Automation Solutions Final Control US LP {AGC}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.1213 in ²	[D] 0.393 in	0.106 in	15-1400 psi	Steam	V
0.75-1.25 NPS	1.25 NPS	0.2157 in ²	[E] 0.524 in	0.142 in	15-1100 psi	Steam	V
1-1.5 NPS	1.5 NPS	0.3369 in ²	[F] 0.655 in	0.177 in	15-1100 psi	Steam	V
1.25-2 NPS	2 NPS	0.553 in ²	[G] 0.839 in	0.227 in	15-1100 psi	Steam	V
1.5-2 NPS	2.5 NPS	0.864 in ²	[H] 1.049 in	0.283 in	15-1000 psi	Steam	V
2-2.5 NPS	3 NPS	1.415 in ²	[J] 1.342 in	0.363 in	15-800 psi	Steam	V

Watts Regulator Company (WWF)
Nameplate Abbreviation: WATTS
REGULATOR OR WATTS REGULATOR
CO.

Franklin, NH 03235United States

This Company Manufactures or Assembles:

Design Name: (L) 315 Mod. M1 and M2		NBCert #	63223
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	08/29/2029
Design Type			
[Safety Valve] (L) 315 Mod. M1 and M2 Capacity Tests: Sec. HV at National Board Testing Lab on September 19, 1995 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:379.00 PPH; Certification Provisions: (HV) Low Pressure Steam Media - Test: Steam; Certified: Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.307 in ²	0.625 in		15-15 psi	Steam	HV

Design Name: (LF, M) 335 Mod. M1 & M2		NBCert #	63256
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	01/25/2029
Design Type			
[Safety Relief Valve] (LF, M) 335 Mod. M1 & M2 Capacity Tests: Sec. HV at National Board Testing Lab on June 22, 1995 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:529.00 PPH Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.307 in ²	0.625 in		30-30 psi	Steam	HV

Design Name: 1" 140S, 140X (Mod. M15) (LF prefix also)		NBCert #	63043
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	01/26/2029
Design Type			
[Temperature Actuated Pressure Relief Valve] 1" 140S, 140X (Mod. M15) (LF prefix also) Capacity Tests: Sec. HV at Ohio State University (Robinson Laboratory) on March 7, 1971 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:17.160 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1 NPS	0.601 in ²	0.875 in	0.265 in	75-150 psi	Steam	HV

Design Name: 1" 40L (LL) 40XL (Z2) , Mod 15 (LF prefix also)		NBCert #	63032
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	01/26/2029
Design Type			
[Temperature Actuated Pressure Relief Valve] 1" 40L (LL) 40XL (Z2) , Mod 15 (LF prefix also) Capacity Tests: Sec. HV at Ohio State University (Robinson Laboratory) on March 6, 1971 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:11.880 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1 NPS	0.442 in ²	0.75 in	0.265 in	75-150 psi	Steam	HV

Design Name: 1" N240X(-6,-9),1-1/4 N241X(-5,-8) Mod. M15 (LF prefix also)		NBCert #	63100
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	04/04/2029
Design Type			
[Temperature Actuated Pressure Relief Valve] 1" N240X(-6,-9),1-1/4 N241X(-5,-8) Mod. M15 (LF prefix also) Capacity Tests: Sec. HV at Ohio State University (Robinson Laboratory) on January 16, 1971 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:22.590 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.25 NPS	1 NPS	0.785 in ²	1 in	0.245 in	75-150 psi	Steam	HV

Design Name: 174A M3, 474A M2, M474-M2 (3/4")(also LF prefix)		NBCert #	63054
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	01/25/2029
Design Type			
[Safety Relief Valve] 174A M3, 474A M2, M474-M2 (3/4")(also LF prefix) Capacity Tests: Sec. HV at unknown lab on June 3, 1973 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:13.610 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.442 in ²	0.75 in	0.265 in	30-150 psi	Steam	HV

Design Name: 174A Model M1 (1")(also LF prefix)		NBCert #	63065
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	01/25/2029
Design Type			
[Safety Relief Valve] 174A Model M1 (1")(also LF prefix) Capacity Tests: Sec. HV at Ohio State University (Robinson Laboratory) on February 7, 1957 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:21.204 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1 NPS	0.601 in ²	0.875 in	0.265 in	30-150 psi	Steam	HV

Design Name: 174A, LF174A M1 (1-1/4")		NBCert #	63076
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	01/05/2029
Design Type			
[Safety Relief Valve] 174A, LF174A M1 (1-1/4") Capacity Tests: Sec. HV at unknown lab on March 23, 1976 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:35.360 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.25 NPS	1.227 in ²	1.255 in	0.375 in	30-150 psi	Steam	HV

Design Name: 174A, LF174A Model M (1-1/2")		NBCert #	63087
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	10/07/2026
Design Type			
[Safety Relief Valve] 174A, LF174A Model M (1-1/2") Capacity Tests: Sec. HV at Ohio State University (Robinson Laboratory) on February 7, 1957 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:42.450 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	1.5 NPS	1.767 in ²	1.5 in	0.361 in	30-150 psi	Steam	HV

Design Name: 174A, LF174A Model M (2")		NBCert # 63098
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	10/07/2026
Design Type		
[Safety Relief Valve] 174A, LF174A Model M (2") Capacity Tests: Sec. HV at Ohio State University (Robinson Laboratory) on February 7, 1957 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:80.000 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2 NPS	3.14 in²	2 in	0.375 in	30-150 psi	Steam	HV

Design Name: 3/4" (M)354A		NBCert # 63403
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	04/04/2029
Design Type		
[Safety Relief Valve] 3/4" (M)354A Capacity Tests: Sec. HV at National Board Testing Lab on August 29, 2001 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:555.00 PPH Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.307 in²	0.625 in		30-30 psi	Steam	HV

Design Name: 3/4" 40L, (LL, LLL) 40XL, 140S, 140X, (Z2) Mod. M15 (LF prefix also)		NBCert # 63021
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	01/26/2029
Design Type		
[Temperature Actuated Pressure Relief Valve] 3/4" 40L, (LL, LLL) 40XL, 140S, 140X, (Z2) Mod. M15 (LF prefix also) Capacity Tests: Sec. HV at unknown lab on March 6, 1973 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 8.000 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.442 in²	0.75 in	0.265 in	75-150 psi	Steam	HV

Design Name: 330-M1 & M330-M1		NBCert # 63267
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	08/24/2029
Design Type		
[Safety Relief Valve] 330-M1 & M330-M1 Capacity Tests: Sec. HV at National Board Testing Lab on December 1, 1997 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:375.00 PPH Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.273 in ²	0.59 in		30-30 psi	Steam	HV

Design Name: 340-3, 340X-8 M15, 342-3, 342X-8 M15 (T & P) (LF prefix also)		NBCert # 63122
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	04/04/2029
Design Type		
[Temperature Actuated Pressure Relief Valve] 340-3, 340X-8 M15, 342-3, 342X-8 M15 (T & P) (LF prefix also) Capacity Tests: Sec. HV at Ohio State University (Robinson Laboratory) on January 17, 1971 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:35.500 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5-2 NPS	1.5 NPS	1.227 in ²	1.25 in	0.312 in	75-150 psi	Steam	HV

Design Name: 374A & M374 Model M & TACO Inc. 333-1 (also LF prefix)		NBCert # 63144
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	04/09/2027
Design Type		
[Safety Relief Valve] 374A & M374 Model M & TACO Inc. 333-1(also LF prefix) Capacity Tests: Sec. HV at Ohio State University (Robinson Laboratory) on February 16, 1960 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:11.430 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.442 in ²	0.75 in	0.218 in	30-50 psi	Steam	HV

Design Name: 375-M1 & M375-M1		NBCert # 63302
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	01/26/2029
Design Type		
[Safety Relief Valve] 375-M1 & M375-M1 Capacity Tests: Sec. HV at National Board Testing Lab on May 15, 2000 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:783.00 PPH Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.3068 in ²	0.625 in	0.125 in	75-75 psi	Steam	HV

Design Name: 3L, 10L, (F, SL, L, LL, LLL, RL) 100XL Mod. M7 (LF prefix also)		NBCert # 63009
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	01/26/2029
Design Type		
[Temperature Actuated Pressure Relief Valve] 3L, 10L, (F, SL, L, LL, LLL, RL) 100XL Mod. M7 (LF prefix also) Capacity Tests: Sec. HV at unknown lab on September 23, 1982 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.060 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Curtain Area Designed by: Watts Regulator Company {WWF}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.172 in ²	0.468 in	0.062 in	75-150 psi	Steam	HV

Design Name: 415 M1 (3/4")		NBCert # 63245
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	01/25/2029
Design Type		
[Safety Valve] 415 M1 (3/4") Capacity Tests: Sec. HV at National Board Testing Lab on August 16, 1996 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:450.00 PPH; Certification Provisions: (HV) Low Pressure Steam Media - Test: Steam; Certified: Steam Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS				15-15 psi	Steam	HV

Design Name:	415 Model M (1 1/2")	NBCert #	63289
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	02/23/2027

Design Type

[Safety Valve] 415 Model M (1 1/2")
Capacity Tests: Sec. HV at National Board Testing Lab on January 10, 2000
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:1862.0 PPH; Certification Provisions: (HV) Low Pressure Steam
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Designed by: Watts Regulator Company {WWF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS	1.227 in ²	1.25 in		15-15 psi	Steam	HV

Design Name:	415 Model M (1 1/4")	NBCert #	63278
--------------	----------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	02/23/2027

Design Type

[Safety Valve] 415 Model M (1 1/4")
Capacity Tests: Sec. HV at National Board Testing Lab on January 10, 2000
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:1232.0 PPH; Certification Provisions: (HV) Low Pressure Steam
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Designed by: Watts Regulator Company {WWF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	0.785 in ²	1 in		15-15 psi	Steam	HV

Design Name:	415-M1 (1")	NBCert #	63324
--------------	-------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	01/25/2029

Design Type

[Safety Valve] 415-M1 (1")
Capacity Tests: Sec. HV at National Board Testing Lab on October 31, 1996
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value:643.00 PPH; Certification Provisions: (HV) Low Pressure Steam
Media - Test: Steam; Certified: Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Watts Regulator Company {WWF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1 NPS	0.46 in ²	0.765 in	0.25 in	15-15 psi	Steam	HV

Design Name: 4L, LF4L, M7 (3/4")		NBCert #	63335
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	04/04/2029
Design Type			
[Safety Relief Valve] 4L, LF4L, M7 (3/4") Capacity Tests: Sec. HV at National Board Testing Lab on November 30, 2011 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:648.00 PPH Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.17 in²	0.468 in	0.12 in	150 psi	Steam	HV

Design Name: 4L, LF4L, M8 (3/4")		NBCert #	63313
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		HV	06/25/2027
Design Type			
[Safety Relief Valve] 4L, LF4L, M8 (3/4") Capacity Tests: Sec. HV at National Board Testing Lab on January 19, 2021 Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method Certified Value:870300 BTU/HR Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: 40 CC Method Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	0.75 NPS	0.17 in²	0.468 in	0.12 in	150-150 psi	Steam	HV

Design Name: 740 Model M (1 1/2")		NBCert #	63201
Manufacturer/Assembler	Designators		Expiration Date
Manufacturer	HV		04/04/2029
Design Type			
[Safety Relief Valve] 740 Model M (1 1/2") Capacity Tests: Sec. HV at unknown lab on March 24, 1973 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:60.800 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Watts Regulator Company {WWF}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	2 NPS		1.5 in	0.437 in	30-75 psi	Steam	HV

Design Name: 740 Model M (1 1/4")		NBCert # 63199
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	03/16/2027
Design Type		
[Safety Relief Valve] 740 Model M (1 1/4") Capacity Tests: Sec. HV at Ohio State University (Robinson Laboratory) on December 28, 1956 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:44.100 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Designed by: Watts Regulator Company {WWF}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.25 NPS	1.5 NPS	1.227 in ²	1.255 in	0.37 in	30-75 psi	Steam	HV

Design Name: 740 Model M (1")		NBCert # 63188
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	03/06/2027
Design Type		
[Safety Relief Valve] 740 Model M (1") Capacity Tests: Sec. HV at Ohio State University (Robinson Laboratory) on February 10, 1973 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:27.250 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Designed by: Watts Regulator Company {WWF}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	1.25 NPS	0.785 in ²	1 in	0.302 in	30-75 psi	Steam	HV

Design Name: 740 Model M (2")		NBCert # 63212
Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	HV	03/06/2027
Design Type		
[Safety Relief Valve] 740 Model M (2") Capacity Tests: Sec. HV at Ohio State University (Robinson Laboratory) on January 17, 1957 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value:110.07 PPH/PSIA Media - Test: Steam; Certified: Saturated Water Set Pressure Definition: Pop Blowdown Characteristics: Fixed Designed by: Watts Regulator Company {WWF}		

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	2.5 NPS	3.142 in ²	2 in	0.585 in	30-75 psi	Steam	HV

Design Name:	740 Model M1 (3/4")	NBCert #	63177
--------------	---------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer HV 03/06/2027

Design Type

[Safety Relief Valve] 740 Model M1 (3/4")
Capacity Tests: Sec. HV at Ohio State University (Robinson Laboratory) on February 10, 1973
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value:19.400 PPH/PSIA
Media - Test: Steam; Certified: Saturated Water
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Designed by: Watts Regulator Company {WWF}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	1 NPS	0.559 in ²	0.844 in	0.265 in	30-75 psi	Steam	HV

Westech Industrial Ltd (WEI)

Nameplate Abbreviation: WIL

London, ON N5V 4K8Canada

This Company Manufactures or Assembles:

Design Name:	437	NBCert #	37213
--------------	-----	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/14/2029

Design Type

[Safety Relief Valve] 437
Capacity Tests: Sec. UV at Leser Gmbh & Co., KG on November 8, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.020 SCFM/PSIA; (alternate medium): 2.870 PPH/PSIA
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Air	UV
0.375-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Steam	UV

Design Name:	437 (Liquids)	NBCert #	37189
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 08/14/2029

Design Type

[Relief Valve] 437 (Liquids)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 22, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.540 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5 - 1.5 NPS	0.082 in ²	0.394 in	0.055 in	15-2610 psi	Water	UV

Design Name: 438 Sub Types 481, 439 NBCert # 37190

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 05/25/2029

Design Type

[Safety Relief Valve] 438 Sub Types 481, 439
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 12, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 0.904 SCFM/PSIA; (alternate medium): 2.530 PPH/PSIA
Media - Test: Air/Gas; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-1 NPS	0.5 - 1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Air	UV
0.375-1 NPS	0.5 - 1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Steam	UV

Design Name: 438 Sub Types 481, 439, Liquids NBCert # 37202

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 05/24/2029

Design Type

[Safety Relief Valve] 438 Sub Types 481, 439, Liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 23, 2001
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.490 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	0.5-1 NPS	0.064 in ²	0.394 in	0.043 in	15-2610 psi	Water	UV

Design Name: 459/462 NBCert # 37112

Manufacturer/Assembler**Designators****Expiration Date**

Assembler UV 05/25/2029

Design Type

[Safety Relief Valve] 459/462
Capacity Tests: Sec. UV at National Board Testing Lab on February 17, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.811 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Air	UV
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Air	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	1-1.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Air	UV
1-2 NPS	1.5 - 2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Steam	UV

Design Name: 459/462 liquids NBCert # 37101

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

05/24/2029

Design Type

[Relief Valve] 459/462 liquids
Capacity Tests: Sec. UV at National Board Testing Lab on January 29, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.566 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1.8125 NPS	1-2 NPS	0.0438 in ²	0.236 in	0.043 in	15-13780 psi	Water	UV
0.5-1.5 NPS	1-1.5 NPS	0.0986 in ²	0.354 in	0.08 in	15-6175 psi	Water	UV
0.5-1.5 NPS	1-2.5 NPS	0.206 in ²	0.512 in	0.118 in	15-2940 psi	Water	UV
1-2 NPS	1.5-2 NPS	0.373 in ²	0.689 in	0.159 in	15-1470 psi	Water	UV

Design Name: 526 NBCert # 37224

Manufacturer/Assembler**Designators****Expiration Date**

Assembler

UV

05/25/2029

Design Type

[Safety Relief Valve] 526
 Capacity Tests: Sec. UV at Leser GmbH & Co., KG on November 22, 2001
 Method of Establishing Relieving Capacity: Flow Capacity, K
 Certified Value: 0.801 Unitless
 Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Adjustable
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Air	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-2900 psi	Steam	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Air	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Air	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-2900 psi	Steam	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Air	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-2900 psi	Steam	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Air	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.669 in	15-1850 psi	Steam	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Air	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Steam	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Air	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Steam	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Air	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Steam	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Air	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.248 in	15-1038.5 psi	Steam	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Air	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Steam	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Air	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-913.5 psi	Steam	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Air	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Steam	UV

Design Name: 526 (Liquids) NBCert # 37235

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/24/2029

Design Type

[Relief Valve] 526 (Liquids)
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on January 2, 2002
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.579 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.239 in ²	[E] 0.551 in	0.138 in	15-6000 psi	Water	UV
1.5-1.5 NPS	2,3 NPS	0.394 in ²	[F] 0.709 in	0.217 in	15-5000 psi	Water	UV
1.5-2 NPS	3 NPS	0.616 in ²	[G] 0.886 in	0.268 in	15-3705 psi	Water	UV
1.5-2 NPS	3 NPS	0.975 in ²	[H] 1.114 in	0.323 in	15-8850 psi	Water	UV
2-3 NPS	3,4 NPS	1.578 in ²	[J] 1.417 in	0.453 in	15-4134 psi	Water	UV
3 NPS	4,6 NPS	2.251 in ²	[K] 1.693 in	0.532 in	15-3700 psi	Water	UV
3-4 NPS	4,6 NPS	3.484 in ²	[L] 2.106 in	0.6698 in	15-1850 psi	Water	UV
4 NPS	6 NPS	4.426 in ²	[M] 2.374 in	0.768 in	15-1100 psi	Water	UV
4 NPS	6 NPS	5.302 in ²	[N] 2.598 in	0.827 in	15-2760 psi	Water	UV
4 NPS	6 NPS	7.79 in ²	[P] 3.15 in	1.036 in	15-1400 psi	Water	UV
6 NPS	8 NPS	13.548 in ²	[Q] 4.154 in	1.249 in	15-1038.5 psi	Water	UV
6 NPS	8 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-100 psi	Water	UV
6 NPS	10 NPS	19.325 in ²	[R] 4.961 in	1.497 in	15-914 psi	Water	UV
8 NPS	10 NPS	31.749 in ²	[T] 6.358 in	1.931 in	15-522 psi	Water	UV

Design Name: 526D

NBCert # 37246

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/25/2029

Design Type

[Safety Relief Valve] 526D
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on March 4, 2002
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 1.990 SCFM/PSIA; (alternate medium): 5.590 PPH/PSIA
Media - ; Certified: Air, Gas, Steam
Set Pressure Definition: Initial Audible Discharge
Blowdown Characteristics: Adjustable
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-2900 psi	Steam	UV
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-10878 psi	Air	UV

Design Name: 526D Liquids

NBCert # 37257

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	05/24/2029

Design Type

[Relief Valve] 526D Liquids
Capacity Tests: Sec. UV at Leser GmbH & Co., KG on March 4, 2002
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method
Certified Value: 3.110 GPM/SQ.RT. PSID
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Curtain Area
Designed by: LESER GmbH & Co. KG {LES}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2,3 NPS	0.121 in ²	[D] 0.551 in	0.0551 in	15-10878 psi	Water	UV

YONGYI VALVE GROUP CO., LTD. (YOY)

Nameplate Abbreviation: YOY

Zhejiang, 325105 People's Republic of China

This Company Manufactures or Assembles:

Design Name: YFA42C-150C 2J3 NBCert # 04127

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/03/2029

Design Type

[Safety Relief Valve] YFA42C-150C 2J3
Capacity Tests: Sec. UV at National Board Testing Lab on September 19, 2016
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value: 2578.0 SCFM
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Designed by: YONGYI VALVE GROUP CO., LTD. {YOY}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
2 NPS	3 NPS	1.285 in ²	[J] 1.2795 in	0.32 in	100-100 psi	Air	UV

Design Name: YFA42C-300aC 1-1/2G3 NBCert # 04116

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UV	08/03/2029

Design Type

[Safety Relief Valve] YFA42C-300aC 1-1/2G3
Capacity Tests: Sec. UV at National Board Testing Lab on September 19, 2016
Method of Establishing Relieving Capacity: Flow Capacity, 3-Device Method
Certified Value: 1892.0 SCFM
Media - Test: Air/Gas; Certified: Air, Gas
Set Pressure Definition: Pop
Blowdown Characteristics: Adjustable (Single Ring)
Designed by: YONGYI VALVE GROUP CO., LTD. {YOY}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS	3 NPS	0.501 in ²	[G] 0.8 in	0.2 in	200-200 psi	Air	UV

Dammam, 31411Saudi Arabia

This Company Manufactures or Assembles:

Design Name:	2600 & 2600S	NBCert #	57057
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	04/27/2027

Design Type

[Safety Relief Valve] 2600 & 2600S

Capacity Tests: Sec. UV at unknown lab on June 11, 1972

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.858 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition: Pop

Blowdown Characteristics: Adjustable (Single Ring)

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.109 in	15-2900 psi	Steam	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-10000 psi	Air	UV
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-10000 psi	Air	UV
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.172 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-2900 psi	Steam	UV
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.253 in	15-7000 psi	Air	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-2900 psi	Steam	UV
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.316 in	15-6000 psi	Air	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-2900 psi	Steam	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.405 in	15-6000 psi	Air	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-2900 psi	Steam	UV
3 NPS	4 - 6 NPS	2.042 in ²	[K] 1.612 in	0.484 in	15-5000 psi	Air	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-2900 psi	Steam	UV
3-4 NPS	4 - 6 NPS	3.17 in ²	[L] 2.009 in	0.603 in	15-4000 psi	Air	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.677 in	15-3000 psi	Air	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-2900 psi	Steam	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.743 in	15-3000 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Air	UV
4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	0.901 in	15-2500 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Air	UV

6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.186 in	15-2000 psi	Steam	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Air	UV
6-8 NPS	8 - 10 NPS	17.78 in ²	[R] 4.758 in	1.427 in	15-1500 psi	Steam	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Air	UV
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	1.821 in	15-1000 psi	Steam	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Air	UV
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	1.899 in	15-300 psi	Steam	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Air	UV
10 NPS	14 NPS	49.4 in ²	[V] 7.93 in	2.379 in	15-1000 psi	Steam	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Air	UV
12 NPS	16 NPS	63.62 in ²	[W] 9 in	2.7 in	15-1000 psi	Steam	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Air	UV
16 NPS	18 NPS	104 in ²	[W2] 11.507 in	3.452 in	15-750 psi	Steam	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Air	UV
16 NPS	20 NPS	113.1 in ²	[X] 12 in	3.6 in	15-750 psi	Steam	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Air	UV
18 NPS	24 NPS	143.1 in ²	[Y] 13.5 in	4.05 in	15-750 psi	Steam	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Air	UV
20 NPS	24 NPS	176.7 in ²	[Z] 15 in	4.5 in	15-750 psi	Steam	UV

Design Name:	2600L (Liquids)	NBCert #	57068
--------------	-----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 06/03/2026

Design Type

[Relief Valve] 2600L (Liquids)
Capacity Tests: Sec. UV, V at unknown lab on January 29, 1985
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.652 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition: First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-2 NPS	2 - 3 NPS	0.15 in ²	[D] 0.437 in	0.131 in	15-10000 psi	Water	UV, V
1-2 NPS	2 - 3 NPS	0.225 in ²	[E] 0.535 in	0.16 in	15-6000 psi	Water	UV, V
1.5-2 NPS	2 - 3 NPS	0.371 in ²	[F] 0.687 in	0.206 in	15-5000 psi	Water	UV, V
1.5-2 NPS	2.5, 3 NPS	0.559 in ²	[G] 0.844 in	0.326 in	15-3600 psi	Water	UV, V
1.5-2 NPS	3 NPS	0.873 in ²	[H] 1.054 in	0.407 in	15-2750 psi	Water	UV, V
2-3 NPS	2 - 4 NPS	1.43 in ²	[J] 1.35 in	0.521 in	15-2700 psi	Water	UV, V
3 NPS	4, 6 NPS	2.041 in ²	[K] 1.612 in	0.622 in	15-2200 psi	Water	UV, V
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.775 in	15-1500 psi	Water	UV, V
4 NPS	6 NPS	4 in ²	[M] 2.257 in	0.871 in	15-1100 psi	Water	UV, V
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.957 in	15-1000 psi	Water	UV, V

4 NPS	6 NPS	7.087 in ²	[P] 3.004 in	1.16 in	15-1000 psi	Water	UV, V
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.525 in	15-900 psi	Water	UV, V
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.837 in	15-600 psi	Water	UV, V
8-10 NPS	10, 12 NPS	28.94 in ²	[T] 6.07 in	2.339 in	15-300 psi	Water	UV, V
8-10 NPS	10, 12 NPS	31.5 in ²	[U] 6.333 in	2.47 in	15-300 psi	Water	UV, V
12 NPS	16 NPS	63.62 in ²	[W] 9 in	3.5 in	15-300 psi	Water	UV, V

Design Name: 2700, 2700S, 3700, 3700S NBCert # 57237

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/28/2025

Design Type

[Safety Relief Valve] 2700, 2700S, 3700, 3700S
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 14, 1994
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.878 Unitless
Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam
Set Pressure Definition: Pop
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-2900 psi	Steam	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Air	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-2900 psi	Steam	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-10000 psi	Air	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.0895 in	15-2900 psi	Steam	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Air	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-2900 psi	Steam	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Air	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-2900 psi	Steam	UV
1.5-2 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Air	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-2900 psi	Steam	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Air	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-2900 psi	Steam	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Air	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-2900 psi	Steam	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Air	UV

Design Name: 2700L, 3700L (Liquids) NBCert # 57248

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	07/28/2025

Design Type

[Relief Valve] 2700L, 3700L (Liquids)

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on September 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.676 Unitless

Media - Test: Liquid; Certified: Liquid

Set Pressure Definition: First Steady Stream

Blowdown Characteristics: Fixed

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-1 NPS	.75, 1 NPS	0.038 in ²	[B] 0.22 in	0.05 in	15-16000 psi	Water	UV
0.5-1.5 NPS	.75 - 2 NPS	0.068 in ²	[C] 0.295 in	0.074 in	15-10000 psi	Water	UV
0.5-1 NPS	.75, 1 NPS	0.098 in ²	[1] 0.358 in	0.089 in	15-10000 psi	Water	UV
0.5-2 NPS	0.75 - 2 NPS	0.125 in ²	[D] 0.4 in	0.1 in	15-10000 psi	Water	UV
1 NPS	1.5, 2 NPS	0.223 in ²	[E] 0.533 in	0.134 in	15-10000 psi	Water	UV
1.5 NPS	2, 2.5 NPS	0.35 in ²	[F] 0.668 in	0.167 in	15-7000 psi	Water	UV
1.5-2 NPS	2., 3 NPS	0.573 in ²	[G] 0.855 in	0.215 in	15-5000 psi	Water	UV
2 NPS	3 NPS	0.898 in ²	[H] 1.069 in	0.268 in	15-4000 psi	Water	UV
3 NPS	4 NPS	1.47 in ²	[J] 1.368 in	0.342 in	15-3000 psi	Water	UV

Design Name: 3800

NBCert #

57024

Manufacturer/Assembler	Designators	Expiration Date
Assembler	UV	06/03/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3800

Capacity Tests: Sec. UV at unknown lab on May 20, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.859 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (3): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Air	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-1050 psi	Steam	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Air	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-1050 psi	Steam	UV
1-2 NPS	2, 3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Air	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-1050 psi	Steam	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Air	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-1050 psi	Steam	UV
1.5-3 NPS	2, 3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Air	UV

2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-1050 psi	Steam	UV
2-3 NPS	3, 4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Air	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Air	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-1050 psi	Steam	UV
3-4 NPS	4, 6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Air	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-1050 psi	Steam	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Air	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Air	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-1050 psi	Steam	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Air	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Air	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Air	UV

Design Name: 3800FP

NBCert # 57035

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler

UV

06/03/2026

Design Type

[Pilot Operated Pressure Relief Valve] 3800FP

Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on April 26, 1994

Method of Establishing Relieving Capacity: Flow Capacity, K

Certified Value: 0.801 Unitless

Media - Test: Air/Gas, Steam; Certified: Air, Gas, Steam

Set Pressure Definition(1): Pop; (3): Initial Audible Discharge

Blowdown Characteristics: Adjustable and Fixed for Mod. Pilot

Flow Area Configuration: Nozzle/Full Lift

Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-1050 psi	Steam	UV
1 NPS	2, 3 NPS	0.719 in ²	[A] 0.957 in	0.354 in	15-11300 psi	Air	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-1050 psi	Steam	UV
1.5 NPS	2, 3 NPS	1.767 in ²	[1] 1.5 in	0.555 in	15-11300 psi	Air	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-1050 psi	Steam	UV
2 NPS	3 NPS	2.953 in ²	[2] 1.939 in	0.717 in	15-11300 psi	Air	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-1050 psi	Steam	UV
3 NPS	4 NPS	6.605 in ²	[3] 2.9 in	1.073 in	15-11300 psi	Air	UV
4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-1050 psi	Steam	UV

4 NPS	6 NPS	11.5 in ²	[4] 3.826 in	1.416 in	15-6300 psi	Air	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-1050 psi	Steam	UV
6 NPS	8 NPS	26.07 in ²	[6] 5.761 in	2.132 in	15-6300 psi	Air	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-1050 psi	Steam	UV
8 NPS	10 NPS	45.66 in ²	[8] 7.625 in	2.821 in	15-2300 psi	Air	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1050 psi	Steam	UV
10 NPS	14 NPS	72 in ²	[10] 9.575 in	3.55 in	15-1500 psi	Air	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-800 psi	Steam	UV
12 NPS	16 NPS	109.5 in ²	[12] 11.81 in	4.37 in	15-1500 psi	Air	UV

Design Name: 3800L, PCL, PCM pilots NBCert # 57215

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Assembler UV 07/28/2025

Design Type

[Pilot Operated Pressure Relief Valve] 3800L, PCL, PCM pilots
Capacity Tests: Sec. UV at Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation on February 4, 1997
Method of Establishing Relieving Capacity: Flow Capacity, K
Certified Value: 0.782 Unitless
Media - Test: Liquid; Certified: Liquid
Set Pressure Definition(1): Pop; (2): First Steady Stream
Blowdown Characteristics: Fixed
Flow Area Configuration: Nozzle/Full Lift
Designed by: Farris Engineering, a Division of Curtiss-Wright Flow Control Corporation {TFO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.5 NPS	2 NPS	0.15 in ²	[D] 0.437 in	0.162 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.225 in ²	[E] 0.535 in	0.198 in	15-11300 psi	Water	UV
1-1.5 NPS	2 NPS	0.371 in ²	[F] 0.687 in	0.254 in	15-11300 psi	Water	UV
1.5-2 NPS	2,3 NPS	0.559 in ²	[G] 0.844 in	0.312 in	15-11300 psi	Water	UV
1.5-2 NPS	2, 3 NPS	0.873 in ²	[H] 1.054 in	0.39 in	15-11300 psi	Water	UV
2-3 NPS	3, 4 NPS	1.43 in ²	[J] 1.35 in	0.5 in	15-11300 psi	Water	UV
3 NPS	4 NPS	2.042 in ²	[K] 1.612 in	0.596 in	15-11300 psi	Water	UV
3-4 NPS	4,6 NPS	3.17 in ²	[L] 2.009 in	0.743 in	15-11300 psi	Water	UV
3-4 NPS	4, 6 NPS	3.42 in ²	[L1] 2.088 in	0.773 in	15-6300 psi	Water	UV
3-4 NPS	4, 6 NPS	4 in ²	[M] 2.257 in	0.835 in	15-6300 psi	Water	UV
4 NPS	6 NPS	4.822 in ²	[N] 2.478 in	0.917 in	15-6300 psi	Water	UV
4-6 NPS	6, 8 NPS	7.087 in ²	[P] 3.004 in	1.111 in	15-6300 psi	Water	UV
6 NPS	8 NPS	12.27 in ²	[Q] 3.952 in	1.462 in	15-6300 psi	Water	UV
6-8 NPS	8, 10 NPS	17.78 in ²	[R] 4.758 in	1.76 in	15-6300 psi	Water	UV
8 NPS	10 NPS	28.94 in ²	[T] 6.07 in	2.246 in	15-2300 psi	Water	UV
10 NPS	14 NPS	49.02 in ²	[V] 7.9 in	2.94 in	15-1500 psi	Water	UV

Zeeco, Inc. (ZCO)

Broken Arrow, OK 74014United States

This Company Manufactures or Assembles:

Design Name: DA-BPV			NBCert # 03317				
Manufacturer/Assembler		Designators		Expiration Date			
Manufacturer		UD		11/22/2029			
Design Type							
[Buckling Pin Non-reclosing Device] DA-BPV Capacity Tests: Sec. UD at National Board Testing Lab on July 25, 2017 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg Certified Value: 2.170 Unitless; Certification Provisions: Exceeds Lab Limits (Prev. CC 2397) Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Buckling Pressure Flow Area Configuration: Nozzle/Full Lift Designed by: Zeeco, Inc. {ZCO}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
6 NPS	6 NPS	28.274 in²	6 in	3.57 in	15-50 psi		UD
8 NPS	8 NPS	48.955 in²	7.895 in	4.69 in	15-50 psi		UD
10 NPS	10 NPS	77.21 in²	9.915 in	5.89 in	15-50 psi		UD
12 NPS	12 NPS	110.66 in²	11.87 in	7.06 in	15-50 psi		UD
14 NPS	14 NPS	134.99 in²	13.11 in	7.8 in	15-50 psi		UD
16 NPS	16 NPS	178.37 in²	15.07 in	8.97 in	15-50 psi		UD
18 NPS	18 NPS	228.72 in²	17.065 in	10.15 in	15-50 psi		UD
20 NPS	20 NPS	284.87 in²	19.045 in	11.32 in	15-50 psi		UD
22 NPS	22 NPS	343.4 in²	20.91 in	12.44 in	15-50 psi		UD
24 NPS	24 NPS	406.67 in²	22.755 in	13.53 in	15-50 psi		UD
26 NPS	26 NPS	480.7 in²	24.74 in	14.71 in	15-50 psi		UD
28 NPS	28 NPS	559.9 in²	26.7 in	15.88 in	15-50 psi		UD
30 NPS	30 NPS	646.47 in²	28.69 in	17.06 in	15-50 psi		UD
32 NPS	32 NPS	739.5 in²	30.66 in	18.23 in	15-50 psi		UD
34 NPS	34 NPS	836 in²	32.53 in	19.4 in	15-50 psi		UD
36 NPS	36 NPS	939.6 in²	34.59 in	20.57 in	15-50 psi		UD
38 NPS	38 NPS	1049 in²	36.55 in	21.74 in	15-50 psi		UD
40 NPS	40 NPS	1168 in²	38.56 in	22.93 in	15-50 psi		UD
42 NPS	42 NPS	1290 in²	40.53 in	24.1 in	15-50 psi		UD
44 NPS	44 NPS	1420 in²	42.53 in	25.3 in	15-50 psi		UD
46 NPS	46 NPS	1555 in²	44.5 in	26.46 in	15-50 psi		UD
48 NPS	48 NPS	1698 in²	46.5 in	27.63 in	15-50 psi		UD
82 NPS	82 NPS	5014 in²	47.51 in	47.51 in	15-50 psi		UD
50 NPS	50 NPS	1841 in²	48.42 in	28.79 in	15-50 psi		UD

52 NPS	52 NPS	1994 in ²	50.39 in	29.97 in	15-50 psi	UD
54 NPS	54 NPS	2154 in ²	52.37 in	31.14 in	15-50 psi	UD
56 NPS	56 NPS	2319 in ²	54.34 in	32.31 in	15-50 psi	UD
58 NPS	58 NPS	2490 in ²	56.31 in	33.48 in	15-50 psi	UD
60 NPS	60 NPS	2666 in ²	58.26 in	34.65 in	15-50 psi	UD
62 NPS	62 NPS	2849 in ²	60.23 in	35.82 in	15-50 psi	UD
64 NPS	64 NPS	3039 in ²	62.2 in	36.99 in	15-50 psi	UD
66 NPS	66 NPS	3234 in ²	64.17 in	38.16 in	15-50 psi	UD
68 NPS	68 NPS	3435 in ²	66.14 in	39.33 in	15-50 psi	UD
70 NPS	70 NPS	3642 in ²	68.1 in	40.5 in	15-50 psi	UD
72 NPS	72 NPS	3856 in ²	70.07 in	41.67 in	15-50 psi	UD
74 NPS	74 NPS	4076 in ²	72.04 in	42.83 in	15-50 psi	UD
76 NPS	76 NPS	4301 in ²	74 in	44 in	15-50 psi	UD
78 NPS	78 NPS	4533 in ²	75.97 in	45.17 in	15-50 psi	UD
80 NPS	80 NPS	4770 in ²	77.94 in	46.34 in	15-50 psi	UD
84 NPS	84 NPS	5246 in ²	81.78 in	48.68 in	15-50 psi	UD
86 NPS	86 NPS	5520 in ²	83.84 in	49.85 in	15-50 psi	UD
90 NPS	90 NPS	6050 in ²	87.77 in	52.19 in	15-50 psi	UD
92 NPS	92 NPS	6325 in ²	89.74 in	53.36 in	15-50 psi	UD
94 NPS	94 NPS	6605 in ²	91.7 in	54.53 in	15-50 psi	UD
96 NPS	96 NPS	6891 in ²	93.67 in	55.7 in	15-50 psi	UD
88 NPS	88 NPS	5782 in ²	858 in	51.02 in	15-50 psi	UD

Design Name: SL-BFV	NBCert # 03328
---------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	02/01/2028

Design Type

[Spring Loaded Non-Reclosing Pressure Relief Device] SL-BFV
Capacity Tests: Sec. UD at National Board Testing Lab on February 1, 2022
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 9.400 Unitless; Certification Provisions: Exceeds Lab Limits (Prev. CC 2397)
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Pop
Flow Area Configuration: MNFA
Designed by: Zeeco, Inc. {ZCO}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
10 NPS	10 NPS	46.65 in ²			15-500 psi		UD
10 NPS	10 NPS	51.15 in ²			15-290 psi		UD
12 NPS	12 NPS	69.22 in ²			15-500 psi		UD
12 NPS	12 NPS	74.77 in ²			15-290 psi		UD
14 NPS	14 NPS	88.04 in ²			15-290 psi		UD
14 NPS	14 NPS	85.19 in ²			15-500 psi		UD
16 NPS	16 NPS	115.83 in ²			15-500 psi		UD

16 NPS	16 NPS	117.77 in ²	15-290 psi	UD
18 NPS	18 NPS	140.14 in ²	15-500 psi	UD
18 NPS	18 NPS	153.12 in ²	15-290 psi	UD
20 NPS	20 NPS	178.29 in ²	15-500 psi	UD
20 NPS	20 NPS	237.05 in ²	15-290 psi	UD
22 NPS	22 NPS	221.7 in ²	15-500 psi	UD
22 NPS	22 NPS	237.05 in ²	15-290 psi	UD
24 NPS	24 NPS	266.3 in ²	15-500 psi	UD
24 NPS	24 NPS	285.04 in ²	15-290 psi	UD
26 NPS	26 NPS	320.41 in ²	15-500 psi	UD
26 NPS	26 NPS	334.5 in ²	15-290 psi	UD
28 NPS	28 NPS	393.01 in ²	15-290 psi	UD
28 NPS	28 NPS	374.89 in ²	15-500 psi	UD
30 NPS	30 NPS	441.34 in ²	15-500 psi	UD
30 NPS	30 NPS	452.4 in ²	15-290 psi	UD
32 NPS	32 NPS	512.32 in ²	15-500 psi	UD
32 NPS	32 NPS	514.73 in ²	15-290 psi	UD
34 NPS	34 NPS	581.09 in ²	15-290 psi	UD
34 NPS	34 NPS	543.55 in ²	15-500 psi	UD
36 NPS	36 NPS	608.1 in ²	15-500 psi	UD
36 NPS	36 NPS	656 in ²	15-290 psi	UD
38 NPS	38 NPS	686.4 in ²	15-500 psi	UD
38 NPS	38 NPS	730.91 in ²	15-290 psi	UD
40 NPS	40 NPS	809.87 in ²	15-290 psi	UD
40 NPS	40 NPS	765.29 in ²	15-500 psi	UD
42 NPS	42 NPS	854.49 in ²	15-500 psi	UD
42 NPS	42 NPS	892.3 in ²	15-290 psi	UD
44 NPS	44 NPS	958.27 in ²	15-500 psi	UD
44 NPS	44 NPS	1005.67 in ²	15-290 psi	UD
46 NPS	46 NPS	1045 in ²	15-500 psi	UD
46 NPS	46 NPS	1101.2 in ²	15-290 psi	UD
48 NPS	48 NPS	1196.34 in ²	15-290 psi	UD
48 NPS	48 NPS	1134.03 in ²	15-500 psi	UD
50 NPS	50 NPS	1248.73 in ²	15-500 psi	UD
50 NPS	50 NPS	1305.45 in ²	15-290 psi	UD
52 NPS	52 NPS	1357.84 in ²	15-500 psi	UD
52 NPS	52 NPS	1414.15 in ²	15-290 psi	UD
54 NPS	54 NPS	1505.43 in ²	15-500 psi	UD
54 NPS	54 NPS	1525.02 in ²	15-290 psi	UD
56 NPS	56 NPS	1596.05 in ²	15-500 psi	UD
56 NPS	56 NPS	1640.08 in ²	15-290 psi	UD

58 NPS	58 NPS	1703.91 in²	15-500 psi	UD
58 NPS	58 NPS	1759.32 in²	15-290 psi	UD
6 NPS	6 NPS	15.95 in²	15-500 psi	UD
6 NPS	6 NPS	16.47 in²	15-290 psi	UD
60 NPS	60 NPS	1929.87 in²	15-290 psi	UD
60 NPS	60 NPS	1851.37 in²	15-500 psi	UD
62 NPS	62 NPS	1991.67 in²	15-500 psi	UD
62 NPS	62 NPS	2060.68 in²	15-290 psi	UD
64 NPS	64 NPS	2122.77 in²	15-500 psi	UD
64 NPS	64 NPS	2195.77 in²	15-290 psi	UD
66 NPS	66 NPS	2234.01 in²	15-500 psi	UD
66 NPS	66 NPS	2335.15 in²	15-290 psi	UD
68 NPS	68 NPS	2490.07 in²	15-290 psi	UD
68 NPS	68 NPS	2378.42 in²	15-500 psi	UD
70 NPS	70 NPS	2540.99 in²	15-500 psi	UD
70 NPS	70 NPS	2637.08 in²	15-290 psi	UD
72 NPS	72 NPS	2719.9 in²	15-500 psi	UD
72 NPS	72 NPS	2799.08 in²	15-290 psi	UD
74 NPS	74 NPS	2945.13 in²	15-290 psi	UD
74 NPS	74 NPS	2802.81 in²	15-500 psi	UD
76 NPS	76 NPS	3004.82 in²	15-500 psi	UD
76 NPS	76 NPS	3156.9 in²	15-290 psi	UD
78 NPS	78 NPS	3167.57 in²	15-500 psi	UD
78 NPS	78 NPS	3327.88 in²	15-290 psi	UD
8 NPS	8 NPS	30.88 in²	15-500 psi	UD
8 NPS	8 NPS	32.37 in²	15-290 psi	UD
80 NPS	80 NPS	3503.39 in²	15-290 psi	UD
80 NPS	80 NPS	3334.62 in²	15-500 psi	UD
82 NPS	82 NPS	3499.46 in²	15-500 psi	UD
82 NPS	82 NPS	3676.57 in²	15-290 psi	UD
84 NPS	84 NPS	3674.7 in²	15-500 psi	UD
84 NPS	84 NPS	3860.68 in²	15-290 psi	UD
86 NPS	86 NPS	3854.13 in²	15-500 psi	UD
86 NPS	86 NPS	4049.19 in²	15-290 psi	UD
88 NPS	88 NPS	4242.08 in²	15-290 psi	UD
88 NPS	88 NPS	4037.73 in²	15-500 psi	UD
90 NPS	90 NPS	4225.47 in²	15-500 psi	UD
90 NPS	90 NPS	4439.33 in²	15-290 psi	UD
92 NPS	92 NPS	4417.34 in²	15-500 psi	UD
92 NPS	92 NPS	4640.91 in²	15-290 psi	UD
94 NPS	94 NPS	4846.78 in²	15-290 psi	UD

94 NPS	94 NPS	4613.29 in²	15-500 psi	UD
96 NPS	96 NPS	4813.32 in²	15-500 psi	UD
96 NPS	96 NPS	5056.93 in²	15-290 psi	UD

ZETKAMA Sp. z o.o. (ZTK)

Nameplate Abbreviation: ZETKAMA

41-209 Sosnowiec, Poland

This Company Manufactures or Assembles:

Design Name: 600 (Liquid)		NBCert #	02776
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	04/18/2030
Design Type			
[Relief Valve] 600 (Liquid) HolderDesignation: Capacity Tests: Sec. UV at National Board Testing Lab {unknown test date} Method of Establishing Relieving Capacity: Flow Capacity, K Certified Value: 0.718 Unitless; (alternate medium): 0.000 Media - Test: Liquid; Certified: Liquid Set Pressure Definition: First Steady Stream Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: ZETKAMA Sp. z o.o. {ZTK}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS	2 NPS	0.175 in²	[D] 0.472 in	0.118 in	15-1480 psi	Water	UV
1 NPS	2 NPS	0.206 in²	[E] 0.512 in	0.158 in	15-1480 psi	Water	UV
1.5 NPS	2 NPS	0.352 in²	[F] 0.669 in	0.13 in	15-1480 psi	Water	UV
1.5 NPS	3 NPS	0.589 in²	[G] 0.866 in	0.295 in	15-1480 psi	Water	UV
1.5-2 NPS	3 NPS	1.024 in²	[H] 1.142 in	0.472 in	15-1480 psi	Water	UV
2-3 NPS	3, 4 NPS	1.491 in²	[J] 1.378 in	0.472 in	15-1480 psi	Water	UV
3 NPS	4 NPS	2.046 in²	[K] 1.614 in	0.551 in	15-1480 psi	Water	UV
3-4 NPS	4, 6 NPS	3.043 in²	[L] 1.969 in	0.827 in	15-1480 psi	Water	UV
4 NPS	6 NPS	3.75 in²	[M] 2.185 in	0.709 in	15-1480 psi	Water	UV
4 NPS	6 NPS	4.909 in²	[N] 2.5 in	0.984 in	15-726 psi	Water	UV
4 NPS	6 NPS	7.032 in²	[P] 2.992 in	1.417 in	15-525 psi	Water	UV
6 NPS	8 NPS	12.174 in²	[Q] 3.937 in	1.575 in	15-300 psi	Water	UV
6 NPS	8, 10 NPS	17.824 in²	[R] 4.764 in	2.205 in	15-230 psi	Water	UV
8 NPS	10 NPS	28.126 in²	[T] 5.984 in	2.3622 in	15-300 psi	Water	UV

Zhejiang Chaochao Safety Valve Manufacturing Co., Ltd. (CXI)

Nameplate Abbreviation: Chaochao

Xiaolin Town, Cixi City, 315321People's Republic of China

This Company Manufactures or Assembles:

Design Name: AX2.II		NBCert #	12755
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	05/03/2029
Design Type			
[Safety Relief Valve] AX2.II Capacity Tests: Sec. UV at National Board Testing Lab on February 2, 2005 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.310 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Zhejiang Chaochao Safety Valve Manufacturing Co., Ltd. {CXI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.25 NPS		12.5 mm ²	4 mm	1 mm	75-250 psi	Air	UV

Design Name: CAGU24		NBCert #	12867
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	04/12/2029
Design Type			
[Safety Relief Valve] CAGU24 Capacity Tests: Sec. UV at National Board Testing Lab on November 30, 2016 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.700 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Zhejiang Chaochao Safety Valve Manufacturing Co., Ltd. {CXI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.25 NPS	Side NPS	0.048 in ²	0.248 in	0.062 in	50-350 psi	Air	UV

Design Name: CAX3.11-2.5		NBCert #	12823
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/28/2027
Design Type			
[Safety Relief Valve] CAX3.11-2.5 Capacity Tests: Sec. UV at National Board Testing Lab on July 22, 2015 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 0.873 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Zhejiang Chaochao Safety Valve Manufacturing Co., Ltd. {CXI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.375 NPS		0.06 in ²	0.276 in		75-250 psi	Air	UV

Design Name: CAXL4-2.5		NBCert #	12812
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/28/2027
Design Type			
[Safety Relief Valve] CAXL4-2.5 Capacity Tests: Sec. UV at National Board Testing Lab on July 22, 2015 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.837 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Zhejiang Chaochao Safety Valve Manufacturing Co., Ltd. {CXI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5-0.5 NPS		0.122 in ²	0.394 in		75-250 psi	Air	UV

Design Name: CAXL6-2.5		NBCert #	12834
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/28/2027
Design Type			
[Safety Relief Valve] CAXL6-2.5 Capacity Tests: Sec. UV at National Board Testing Lab on July 22, 2015 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 3.254 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Zhejiang Chaochao Safety Valve Manufacturing Co., Ltd. {CXI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-0.75 NPS		0.221 in ²	[E] 0.531 in ²		15-250 psi	Air	UV

Design Name: CAXL8.II - 2.5		NBCert #	12856
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	01/28/2027
Design Type			
[Safety Relief Valve] CAXL8.II - 2.5 Capacity Tests: Sec. UV at National Board Testing Lab on October 8, 2015 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 7.212 SCFM/PSIA Media - Test: Air/Gas; Certified: Air, Gas Set Pressure Definition: Pop Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Zhejiang Chaochao Safety Valve Manufacturing Co., Ltd. {CXI}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1 NPS		0.439 in ²	0.748 in	0.187 in	75-250 psi	Air	UV

Burlington, ON L7L 5R8Canada

This Company Manufactures or Assembles:

Design Name: CWA-0231-XX Series		NBCert #	82088
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UD	07/28/2029	
Design Type			
[Rupture Disk Device] CWA-0231-XX Series HolderDesignation: N/A - Integral Welded Assembly Capacity Tests: Sec. UD at National Board Testing Lab on March 6, 2023 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg Certified Value:23.380 Unitless; (alternate medium): 0.000 Media - Test: Air/Gas; Certified: Compressible (Krg) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: ZOOK Canada Inc. {PEL}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.12 in ²			1050-3000 psi		UD

Design Name: FAX-L, SFAZ-L and SFA-II-L and SFA-L Series Rupture Disks		NBCert #	82189
Manufacturer/Assembler	Designators		Expiration Date
Manufacturer	UD		09/30/2027
Design Type			
[Rupture Disk Device] FAX-L, SFAZ-L and SFA-II-L and SFA-L Series Rupture Disks HolderDesignation: FAH, FAHI, UH, UHZ, SF7A, and FS1U - FS6U Series, CWA Capacity Tests: Sec. UD at National Board Testing Lab on June 26, 2015 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl Certified Value: 1.780 Unitless Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: ZOOK Canada Inc. {PEL}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.3 in ²			200-6000 psi	Water	UD
0.75 NPS		0.53 in ²			125-6000 psi	Water	UD
1 NPS		0.86 in ²			79-6000 psi	Water	UD
1.5 NPS		2.04 in ²			73-6000 psi	Water	UD
10 NPS		78.85 in ²			22-1480 psi	Water	UD
12 NPS		113.1 in ²			20-740 psi	Water	UD
14 NPS		137.89 in ²			17-500 psi	Water	UD
16 NPS		182.65 in ²			15-285 psi	Water	UD
18 NPS		233.71 in ²			15-285 psi	Water	UD

2 NPS	3.36 in ²		61-3600 psi	Water	UD
20 NPS	291.04 in ²		15-285 psi	Water	UD
24 NPS	424.56 in ²		15-285 psi	Water	UD
3 NPS	7.39 in ²		40-3600 psi	Water	UD
4 NPS	12.73 in ²		32-3000 psi	Water	UD
6 NPS	28.89 in ²		27-2200 psi	Water	UD
8 NPS	50.03 in ²		25-1480 psi	Water	UD
2.5 NPS	4.79 in ²	0 in	45-3600 psi		UD

Design Name:	RA4, RLP	NBCert #	82077
--------------	----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 06/25/2031

Design Type

[Rupture Disk Device] RA4, RLP
HolderDesignation: RLP Series, RAH Series
Capacity Tests: Sec. UD at National Board Testing Lab on May 5, 2003
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 1.630 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: ZOOK Canada Inc. {PEL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			13-40 psi		UD
1.5 NPS		1.63 in ²			9-25 psi		UD
10 NPS		50.78 in ²			2-14 psi		UD
12 NPS		71.69 in ²			2-14 psi		UD
2 NPS		2.78 in ²			6-25 psi		UD
3 NPS		5.69 in ²			4-25 psi		UD
4 NPS		9.51 in ²			3-20 psi		UD
6 NPS		19.46 in ²			2-18 psi		UD
8 NPS		33.28 in ²			2-18 psi		UD

Design Name:	RA6 (Air/Gas)	NBCert #	82123
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 10/01/2030

Design Type

[Rupture Disk Device] RA6 (Air/Gas)
HolderDesignation: RAH Series, CWA
Capacity Tests: Sec. UD at National Board Testing Lab on April 14, 2008
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 0.800 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Blowdown Characteristics: Fixed
Flow Area Configuration: MNFA
Designed by: ZOOK Canada Inc. {PEL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			25.8-144 psi		UD
1.5 NPS		2 in ²			20-120 psi		UD
10 NPS		70.52 in ²			12-30 psi		UD
12 NPS		98.33 in ²			12-26 psi		UD
14 NPS		124.7 in ²			9-24 psi		UD
16 NPS		162.9 in ²			7-22 psi		UD
18 NPS		206.1 in ²			6-21 psi		UD
2 NPS		3.36 in ²			18-100 psi		UD
2.5 NPS		4.79 in ²			17-83 psi		UD
20 NPS		254.5 in ²			5-19 psi		UD
24 NPS		366.5 in ²			5-18 psi		UD
3 NPS		7.25 in ²			16-65 psi		UD
4 NPS		12.53 in ²			14-55 psi		UD
6 NPS		26.59 in ²			12-45 psi		UD
8 NPS		45.48 in ²			12-35 psi		UD

Design Name:	RA6 (Liquid)	NBCert #	82112
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	07/23/2031

Design Type

[Rupture Disk Device] RA6 (Liquid)
HolderDesignation: RAH Series, CWA
Capacity Tests: Sec. UD at National Board Testing Lab on September 26, 2008
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
Certified Value: 0.980 Unitless
Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: ZOOK Canada Inc. {PEL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			22-200 psi		UD
1.5 NPS		2 in ²			20-167 psi		UD
10 NPS		70.52 in ²			12-46 psi		UD
12 NPS		98.33 in ²			12-38 psi		UD
14 NPS		124.7 in ²			9-38 psi		UD
16 NPS		162.9 in ²			7-40 psi		UD
18 NPS		206.1 in ²			6-40 psi		UD
2 NPS		3.36 in ²			18-118 psi		UD
2.5 NPS		4.79 in ²			17-93 psi		UD
20 NPS		254.5 in ²			5-38 psi		UD
24 NPS		366.5 in ²			5-26 psi		UD
3 NPS		7.25 in ²			16-68 psi		UD

4 NPS	12.53 in ²	14-69 psi	UD
6 NPS	26.59 in ²	12-67 psi	UD
8 NPS	45.48 in ²	12-54 psi	UD

Design Name:	RA8 (Gas)	NBCert #	82145
--------------	-----------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	10/18/2028
--------------	----	------------

Design Type

[Rupture Disk Device] RA8 (Gas)
 HolderDesignation: RAH Series, CWA
 Capacity Tests: Sec. UD at National Board Testing Lab on October 1, 2007
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.590 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: ZOOK Canada Inc. {PEL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			144-720 psi		UD
1.5 NPS		2 in ²			120-720 psi		UD
10 NPS		70.52 in ²			30-180 psi		UD
12 NPS		98.33 in ²			26-155 psi		UD
14 NPS		124.7 in ²			24-125 psi		UD
16 NPS		162.9 in ²			22-100 psi		UD
18 NPS		206.1 in ²			21-85 psi		UD
2 NPS		3.36 in ²			100-720 psi		UD
2.5 NPS		4.79 in ²			83-720 psi		UD
20 NPS		254.5 in ²			19-75 psi		UD
24 NPS		366.5 in ²			18-70 psi		UD
3 NPS		7.25 in ²			65-720 psi		UD
4 NPS		12.53 in ²			55-520 psi		UD
6 NPS		26.59 in ²			45-285 psi		UD
8 NPS		45.48 in ²			35-210 psi		UD

Design Name:	RA8 (Liquid)	NBCert #	82134
--------------	--------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer	UD	07/23/2031
--------------	----	------------

Design Type

[Rupture Disk Device] RA8 (Liquid)
 HolderDesignation: RAH Series, CWA
 Capacity Tests: Sec. UD at National Board Testing Lab on April 16, 2008
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value: 1.160 Unitless
 Media - Test: Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: ZOOK Canada Inc. {PEL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			200-1000 psi		UD
1.5 NPS		2 in ²			167-1000 psi		UD
10 NPS		70.52 in ²			46-275 psi		UD
12 NPS		98.33 in ²			38-225 psi		UD
14 NPS		124.7 in ²			38-200 psi		UD
16 NPS		162.9 in ²			40-180 psi		UD
18 NPS		206.1 in ²			40-160 psi		UD
2 NPS		3.36 in ²			118-850 psi		UD
2.5 NPS		4.79 in ²			93-800 psi		UD
20 NPS		254.5 in ²			38-150 psi		UD
24 NPS		366.5 in ²			26-100 psi		UD
3 NPS		7.25 in ²			68-750 psi		UD
4 NPS		12.53 in ²			69-650 psi		UD
6 NPS		26.5 in ²			67-425 psi		UD
8 NPS		45.48 in ²			54-325 psi		UD

Design Name:	RAUS (Air/Gas)	NBCert #	82167
--------------	----------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	07/23/2031

Design Type

[Rupture Disk Device] RAUS (Air/Gas)
HolderDesignation: RAUS for installation in standard sanitary O.D. tube fittings, RAUS-CWA
Capacity Tests: Sec. UD at National Board Testing Lab on January 30, 2009
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value:11.670 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: ZOOK Canada Inc. {PEL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.36 in ²			83-300 psi		UD
1.5 NPS		0.94 in ²			27-250 psi		UD
2 NPS		1.79 in ²			24-180 psi		UD
3 NPS		4.34 in ²			20-120 psi		UD
4 NPS		7.8 in ²			18-80 psi		UD

Design Name:	RAUS (Liquid)	NBCert #	82156
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	04/17/2026

Design Type

[Rupture Disk Device] RAUS (Liquid)
 HolderDesignation: RAUS installation in standard sanitary O.D. tube fittings, RAUS-CWA
 Capacity Tests: Sec. UD at National Board Testing Lab on January 30, 2009
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krl
 Certified Value:11.670 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Incompressible (Krl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: ZOOK Canada Inc. {PEL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.36 in ²			83-300 psi		UD
1.5 NPS		0.94 in ²			27-250 psi		UD
2 NPS		1.79 in ²			24-180 psi		UD
3 NPS		4.34 in ²			20-120 psi		UD
4 NPS		7.8 in ²			18-80 psi		UD

Design Name: R-D-R Series NBCert # 82022

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	04/26/2026

Design Type

[Rupture Disk Device] R-D-R Series
 HolderDesignation: 1 - 9, 7A, 1U - 6U, ST
 Capacity Tests: Sec. UD at National Board Testing Lab on August 28, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 2.400 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: ZOOK Canada Inc. {PEL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.17 in ²			60-6000 psi		UD
0.75 NPS		0.44 in ²			48-6000 psi		UD
1 NPS		0.71 in ²			30-6000 psi		UD
1.5 NPS		1.54 in ²			20-3000 psi		UD
10 NPS		78.54 in ²			15-750 psi		UD
12 NPS		113.1 in ²			15-750 psi		UD
14 NPS		137.9 in ²			15-750 psi		UD
16 NPS		182.7 in ²			15-500 psi		UD
18 NPS		233.7 in ²			15-475 psi		UD
2 NPS		3.36 in ²			16-3000 psi		UD
20 NPS		291 in ²			15-450 psi		UD
24 NPS		424.6 in ²			15-275 psi		UD
3 NPS		7.39 in ²			15-3000 psi		UD
4 NPS		12.73 in ²			15-3000 psi		UD
6 NPS		28.27 in ²			15-2160 psi		UD
8 NPS		50 in ²			15-1440 psi		UD

Design Name: R-D-VR, R-TLDV-R Series			NBCert # 82033				
Manufacturer/Assembler		Designators		Expiration Date			
Manufacturer		UD		04/26/2026			
Design Type							
[Rupture Disk Device] R-D-VR, R-TLDV-R Series HolderDesignation: 1 - 9, 7A, 1U - 6U Capacity Tests: Sec. UD at National Board Testing Lab on October 30, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 6.210 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: ZOOK Canada Inc. {PEL}							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.13 in²			60-6000 psi		UD
0.75 NPS		0.35 in²			48-6000 psi		UD
1 NPS		0.51 in²			30-6000 psi		UD
1.5 NPS		1.05 in²			20-3000 psi		UD
10 NPS		57.96 in²			15-750 psi		UD
12 NPS		85.54 in²			15-750 psi		UD
14 NPS		110.2 in²			15-750 psi		UD
16 NPS		146.2 in²			15-500 psi		UD
18 NPS		197 in²			15-475 psi		UD
2 NPS		3.19 in²			16-3000 psi		UD
20 NPS		240.7 in²			15-450 psi		UD
24 NPS		348.9 in²			15-275 psi		UD
3 NPS		7.02 in²			15-3000 psi		UD
4 NPS		12.18 in²			15-3000 psi		UD
6 NPS		21.76 in²			15-2160 psi		UD
8 NPS		35.92 in²			15-1440 psi		UD

Design Name: RL-PB-LVR Series		NBCert #	82000
Manufacturer/Assembler	Designators		Expiration Date
Manufacturer	UD		04/26/2026
Design Type			
[Rupture Disk Device] RL-PB-LVR Series HolderDesignation: 1 - 9, 7A, 1U - 6U, ST Capacity Tests: Sec. UD at National Board Testing Lab on November 25, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 5.460 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: ZOOK Canada Inc. {PEL}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.13 in ²			170-30000 psi		UD
0.75 NPS		0.35 in ²			110-15000 psi		UD
1 NPS		0.51 in ²			91-12000 psi		UD
1.5 NPS		1.05 in ²			59-6000 psi		UD
10 NPS		57.96 in ²			15-1400 psi		UD
12 NPS		85.54 in ²			15-1000 psi		UD
14 NPS		110.2 in ²			15-750 psi		UD
16 NPS		146.2 in ²			15-500 psi		UD
18 NPS		197 in ²			15-475 psi		UD
2 NPS		3.19 in ²			36-6000 psi		UD
20 NPS		240.7 in ²			15-450 psi		UD
24 NPS		348.9 in ²			15-275 psi		UD
3 NPS		7.02 in ²			25-6000 psi		UD
4 NPS		12.18 in ²			19-6000 psi		UD
6 NPS		21.76 in ²			15-3600 psi		UD
8 NPS		35.92 in ²			15-2100 psi		UD

Design Name: R-PB-R		NBCert #	82011
Manufacturer/Assembler	Designators	Expiration Date	

Manufacturer UD 12/21/2026

Design Type

[Rupture Disk Device] R-PB-R
 HolderDesignation: 1 - 9, 7A, 1U - 6U, ST
 Capacity Tests: Sec. UD at National Board Testing Lab on January 27, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 0.920 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: ZOOK Canada Inc. {PEL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.25 NPS		0.05 in ²			180-80000 psi		UD
0.5 NPS		0.17 in ²			170-30000 psi		UD
0.75 NPS		0.44 in ²			110-15000 psi		UD
1 NPS		0.71 in ²			68-12000 psi		UD
1.5 NPS		1.54 in ²			27-6000 psi		UD
10 NPS		78.54 in ²			15-1400 psi		UD
12 NPS		113.1 in ²			15-1000 psi		UD
14 NPS		137.9 in ²			15-750 psi		UD
16 NPS		182.7 in ²			15-500 psi		UD
18 NPS		233.7 in ²			15-475 psi		UD
2 NPS		3.36 in ²			16-6000 psi		UD

20 NPS	291 in ²	15-450 psi	UD
24 NPS	424.6 in ²	15-275 psi	UD
3 NPS	7.39 in ²	25-6000 psi	UD
4 NPS	12.73 in ²	19-6000 psi	UD
6 NPS	28.27 in ²	15-3600 psi	UD
8 NPS	50.01 in ²	15-2100 psi	UD

Design Name:	SB90-L Series	NBCert #	82055
--------------	---------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	04/27/2026

Design Type

[Rupture Disk Device] SB90-L Series
HolderDesignation: SB7, SB7A
Capacity Tests: Sec. UD at National Board Testing Lab on December 5, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
Certified Value: 3.490 Unitless
Media - Test: Air/Gas; Certified: Compressible (Krg)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: ZOOK Canada Inc. {PEL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.71 in ²			90-1800 psi		UD
1.5 NPS		1.59 in ²			77-1700 psi		UD
10 NPS		67.2 in ²			15-800 psi		UD
12 NPS		97.59 in ²			15-800 psi		UD
14 NPS		119.5 in ²			15-700 psi		UD
16 NPS		159 in ²			15-700 psi		UD
18 NPS		210.3 in ²			15-700 psi		UD
2 NPS		2.83 in ²			26-1600 psi		UD
20 NPS		261.9 in ²			15-700 psi		UD
24 NPS		382.1 in ²			15-700 psi		UD
3 NPS		6.36 in ²			30-1500 psi		UD
4 NPS		11.31 in ²			25-1500 psi		UD
6 NPS		25.45 in ²			20-850 psi		UD
8 NPS		45.24 in ²			15-800 psi		UD

Design Name:	SFAL & SFA-II-L Series	NBCert #	82044
--------------	------------------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	04/27/2026

Design Type

[Rupture Disk Device] SFAL & SFA-II-L Series
 HolderDesignation: UH Series, FS1U-FS6U, FAH Series, CWA
 Capacity Tests: Sec. UD at National Board Testing Lab on October 30, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 0.390 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: ZOOK Canada Inc. {PEL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.3 in ²			200-6000 psi		UD
0.75 NPS		0.53 in ²			125-6000 psi		UD
1 NPS		0.86 in ²			79-6000 psi		UD
1.5 NPS		2.04 in ²			73-6000 psi		UD
10 NPS		78.85 in ²			22-1480 psi		UD
12 NPS		113.1 in ²			20-740 psi		UD
14 NPS		137.9 in ²			17-500 psi		UD
16 NPS		182.7 in ²			15-285 psi		UD
18 NPS		233.7 in ²			15-285 psi		UD
2 NPS		3.36 in ²			61-3600 psi		UD
20 NPS		291 in ²			15-285 psi		UD
24 NPS		424.6 in ²			15-285 psi		UD
3 NPS		7.39 in ²			40-3600 psi		UD
4 NPS		12.73 in ²			32-3000 psi		UD
6 NPS		28.89 in ²			27-2200 psi		UD
8 NPS		50.03 in ²			25-1480 psi		UD
2.5 NPS	NPS	4.79 in ²	0 in	0 in	45-3600 psi		UD

Design Name: SRA, SRA-L, SRA-C, SRA-LC, SRA-X, RAX NBCert # 82101

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/27/2028

Design Type

[Rupture Disk Device] SRA, SRA-L, SRA-C, SRA-LC, SRA-X, RAX
 HolderDesignation: SRA Seires, RAH Series.
 Capacity Tests: Sec. UD at National Board Testing Lab on August 28, 2002
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krg
 Certified Value: 2.000 Unitless
 Media - Test: Air/Gas; Certified: Compressible (Krg)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: ZOOK Canada Inc. {PEL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			92-3705 psi		UD
1.5 NPS		2.04 in ²			81-3705 psi		UD
10 NPS		78.8 in ²			30-700 psi		UD
12 NPS		112 in ²			27-600 psi		UD

14 NPS	135 in ²	25-500 psi	UD
16 NPS	177 in ²	23-100 psi	UD
18 NPS	224 in ²	22-92 psi	UD
2 NPS	3.36 in ²	60-3705 psi	UD
20 NPS	278 in ²	21-84 psi	UD
24 NPS	402 in ²	20-70 psi	UD
3 NPS	7.39 in ²	55-1480 psi	UD
4 NPS	12.73 in ²	48-1480 psi	UD
6 NPS	28.89 in ²	35-1480 psi	UD
8 NPS	50 in ²	33-700 psi	UD
150 DN	DN	22.99 in ² 0 in 0 in	45-1480 psi UD

Design Name:	Throwaway (TA), Screw Type (ST) Assemblies	NBCert #	82178
--------------	--	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 09/30/2027

Design Type

[Rupture Disk Device] Throwaway (TA), Screw Type (ST) Assemblies
Capacity Tests: Sec. UD at National Board Testing Lab on July 31, 2015
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value:16.080 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Blowdown Characteristics: Fixed
Flow Area Configuration: MNFA
Designed by: ZOOK Canada Inc. {PEL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125 NPS		0.01 in ²			33-3000 psi		UD
0.25 NPS		0.04 in ²			33-3000 psi		UD
0.375 NPS		0.1 in ²			33-3000 psi		UD
0.5 NPS		0.13 in ²			33-3000 psi		UD
0.75 NPS		0.29 in ²			33-3000 psi		UD
1 NPS		0.47 in ²			33-3000 psi		UD

Design Name:	URA-L, URA	NBCert #	82066
--------------	------------	----------	-------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 02/17/2027

Design Type

[Rupture Disk Device] URA-L, URA
HolderDesignation: URA Series, CWA Welded Assembly
Capacity Tests: Sec. UD at National Board Testing Lab on April 30, 2000
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.780 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: ZOOK Canada Inc. {PEL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.86 in ²			22-1000 psi		UD
1.5 NPS		2 in ²			20-900 psi		UD
10 NPS		70.52 in ²			12-200 psi		UD
12 NPS		98.33 in ²			12-150 psi		UD
14 NPS		124.7 in ²			9-175 psi		UD
16 NPS		162.9 in ²			7-85 psi		UD
18 NPS		206.1 in ²			7-75 psi		UD
2 NPS		3.36 in ²			18-850 psi		UD
20 NPS		254.5 in ²			5-60 psi		UD
24 NPS		366.5 in ²			5-50 psi		UD
3 NPS		7.25 in ²			16-750 psi		UD
4 NPS		12.53 in ²			14-650 psi		UD
6 NPS		26.59 in ²			12-400 psi		UD
8 NPS		45.48 in ²			12-250 psi		UD

Design Name: ZANITARY Series, CWA Series NBCert # 82202

Manufacturer/Assembler	Designators	Expiration Date
Manufacturer	UD	10/08/2031

Design Type

[Rupture Disk Device] ZANITARY Series, CWA Series
Capacity Tests: Sec. UD at National Board Testing Lab on July 22, 2019
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 4.080 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: ZOOK Canada Inc. {PEL}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1.5 NPS		1.08 in ²			15-300 psi	Air	UD
1.5 NPS		1.08 in ²			15-300 psi	Water	UD
2 NPS		2.05 in ²			10-180 psi	Air	UD
2 NPS		2.05 in ²			10-180 psi	Water	UD
2.5 NPS		3.25 in ²			10-120 psi	Air	UD
2.5 NPS		3.25 in ²			10-120 psi	Water	UD
3 NPS		4.71 in ²			10-120 psi	Air	UD
3 NPS		4.71 in ²			10-120 psi	Water	UD
4 NPS		8.49 in ²			10-80 psi	Air	UD
4 NPS		8.49 in ²			10-80 psi	Water	UD
1 NPS		0.43 in ²		0 in	35-300 psi	Air	UD
1 NPS		0.43 in ²		0 in	35-300 psi	Water	UD

ZOOK Enterprises, LLC (ZOE)

Nameplate Abbreviation: ZOOK

Chagrin Falls, OH 44022United States

This Company Manufactures or Assembles:

Design Name:	Inverted	NBCert #	76014
Manufacturer/Assembler	Designators	Expiration Date	
Manufacturer	UD	05/27/2031	

Design Type

[Rupture Disk Device] Inverted
HolderDesignation: N/A
Capacity Tests: Sec. UD at National Board Testing Lab on May 27, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.640 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: ZOOK Enterprises, LLC {ZOE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.3 in ²			25-1500 psi		UD
0.75 NPS		0.53 in ²			25-1500 psi		UD
1 NPS		0.78 in ²			10-1500 psi		UD
1 NPS		0.53 in ²	[San]		10-100 psi		UD
1.5 NPS		1.37 in ²	[San]		7-100 psi		UD
1.5 NPS		1.76 in ²			7-1000 psi		UD
10 NPS		78.53 in ²			0.25-150 psi		UD
12 NPS		113.09 in ²			0.25-150 psi		UD
14 NPS		137.88 in ²			0.25-150 psi		UD
16 NPS		182.65 in ²			0.25-150 psi		UD
18 NPS		233.7 in ²			0.25-150 psi		UD
2 NPS		3.14 in ²			3-750 psi		UD
2 NPS		2.6 in ²	[San]		3-100 psi		UD
2.5 NPS		4.78 in ²			3-750 psi		UD
2.5 NPS		4.23 in ²	[San]		2-75 psi		UD
20 NPS		291.03 in ²			0.25-150 psi		UD
24 NPS		424.55 in ²			0.25-150 psi		UD
3 NPS		6.25 in ²	[San]		2-75 psi		UD
3 NPS		7.06 in ²			2-750 psi		UD
3.5 NPS		9.62 in ²			1.5-500 psi		UD
4 NPS		12.56 in ²			1.5-500 psi		UD
4 NPS		11.18 in ²	[San]		1.5-60 psi		UD
5 NPS		19.63 in ²			1.5-500 psi		UD

6 NPS	28.27 in ²	1-450 psi	UD
8 NPS	50.02 in ²	0.5-450 psi	UD

Design Name: Mono	NBCert # 76003
-------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 05/27/2031

Design Type

[Rupture Disk Device] Mono
HolderDesignation: N/A
Capacity Tests: Sec. UD at National Board Testing Lab on May 27, 1998
Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
Certified Value: 0.260 Unitless
Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
Set Pressure Definition: Burst Pressure
Flow Area Configuration: MNFA
Designed by: ZOOK Enterprises, LLC {ZOE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.5 NPS		0.3 in ²			25-150 psi		UD
0.75 NPS		0.53 in ²			25-150 psi		UD
1 NPS		0.78 in ²			10-150 psi		UD
1.5 NPS		1.76 in ²			7-150 psi		UD
10 NPS		78.53 in ²			0.25-125 psi		UD
12 NPS		113.09 in ²			0.25-125 psi		UD
14 NPS		137.88 in ²			0.25-100 psi		UD
16 NPS		182.65 in ²			0.25-100 psi		UD
18 NPS		233.7 in ²			0.25-100 psi		UD
2 NPS		3.14 in ²			3-150 psi		UD
2.5 NPS		4.78 in ²			3-150 psi		UD
20 NPS		291.03 in ²			0.25-50 psi		UD
24 NPS		424.55 in ²			0.25-50 psi		UD
3 NPS		7.06 in ²			2-150 psi		UD
4 NPS		12.56 in ²			1.5-150 psi		UD
5 NPS		19.63 in ²			1.5-150 psi		UD
6 NPS		28.27 in ²			1-150 psi		UD
8 NPS		50.02 in ²			0.5-150 psi		UD

Design Name: Mono W/Ring Vac. Support	NBCert # 76047
---------------------------------------	----------------

Manufacturer/Assembler	Designators	Expiration Date
------------------------	-------------	-----------------

Manufacturer UD 05/27/2031

Design Type

[Rupture Disk Device] Mono W/Ring Vac. Support
 HolderDesignation: N/A
 Capacity Tests: Sec. UD at National Board Testing Lab on May 27, 1998
 Method of Establishing Relieving Capacity: Flow Resistance, 1 Size, Krg
 Certified Value: 6.440 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: ZOOK Enterprises, LLC {ZOE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.44 in ²			10-25 psi		UD

Design Name: Mono Style W/Bar Vacuum Support NBCert # 76058

Manufacturer/Assembler**Designators****Expiration Date**

Manufacturer

UD

02/25/2026

Design Type

[Rupture Disk Device] Mono Style W/Bar Vacuum Support
 HolderDesignation: N/A
 Capacity Tests: Sec. UD at National Board Testing Lab on December 16, 1999
 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl
 Certified Value: 2.400 Unitless
 Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl)
 Set Pressure Definition: Burst Pressure
 Flow Area Configuration: MNFA
 Designed by: ZOOK Enterprises, LLC {ZOE}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.6 in ²			10-150 psi		UD
1.5 NPS		1.34 in ²			7-150 psi		UD
10 NPS		63.53 in ²			0.25-125 psi		UD
12 NPS		89.09 in ²			0.25-125 psi		UD
14 NPS		108.06 in ²			0.25-100 psi		UD
16 NPS		144.52 in ²			0.25-100 psi		UD
18 NPS		181.95 in ²			0.25-100 psi		UD
2 NPS		2.39 in ²			3-150 psi		UD
2.5 NPS		3.65 in ²			3-150 psi		UD
20 NPS		233.28 in ²			0.25-50 psi		UD
24 NPS		354.8 in ²			0.25-50 psi		UD
3 NPS		5.56 in ²			2-150 psi		UD
4 NPS		10.56 in ²			1.5-150 psi		UD
5 NPS		15.88 in ²			1.5-150 psi		UD
6 NPS		22.27 in ²			1-150 psi		UD
8 NPS		40.26 in ²			0.5-150 psi		UD

Design Name: Mono Style W/Cross Vac. Support		NBCert # 76036	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	03/24/2026
Design Type			
[Rupture Disk Device] Mono Style W/Cross Vac. Support HolderDesignation: N/A Capacity Tests: Sec. UD at National Board Testing Lab on November 20, 1998 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value: 5.400 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: ZOOK Enterprises, LLC {ZOE}			
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia. Lift Set Pressure Range Media Designator
1 NPS		0.47 in ²	10-150 psi UD
1.5 NPS		1.05 in ²	7-150 psi UD
10 NPS		50.78 in ²	0.25-125 psi UD
12 NPS		69.09 in ²	0.25-125 psi UD
14 NPS		83.31 in ²	0.25-100 psi UD
16 NPS		112.6 in ²	0.25-100 psi UD
18 NPS		153.7 in ²	0.25-100 psi UD
2 NPS		1.86 in ²	3-150 psi UD
2.5 NPS		2.94 in ²	3-150 psi UD
20 NPS		184.5 in ²	0.25-50 psi UD
24 NPS		294.1 in ²	0.25-50 psi UD
3 NPS		4.31 in ²	2-150 psi UD
4 NPS		8.81 in ²	1.5-150 psi UD
5 NPS		12.7 in ²	1.5-150 psi UD
6 NPS		17.27 in ²	1-150 psi UD
8 NPS		31.82 in ²	0.5-150 psi UD

Design Name: Mono Style W/Plate Vac. Support		NBCert # 76025	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UD	03/24/2026
Design Type			
[Rupture Disk Device] Mono Style W/Plate Vac. Support HolderDesignation: N/A Capacity Tests: Sec. UD at National Board Testing Lab on April 22, 1999 Method of Establishing Relieving Capacity: Flow Resistance, 3 Size, Krgl Certified Value:15.700 Unitless Media - Test: Air/Gas, Water/Liquid (Kr test on Air/Gas); Certified: Compressible and Incompressible (Krgl) Set Pressure Definition: Burst Pressure Flow Area Configuration: MNFA Designed by: ZOOK Enterprises, LLC {ZOE}			

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1 NPS		0.32 in ²			10-150 psi		UD
1.5 NPS		0.72 in ²			7-150 psi		UD
10 NPS		32.66 in ²			0.25-125 psi		UD
12 NPS		47.24 in ²			0.25-125 psi		UD
14 NPS		58.07 in ²			0.25-100 psi		UD
16 NPS		84.49 in ²			0.25-100 psi		UD
18 NPS		104.31 in ²			0.25-100 psi		UD
2 NPS		1.3 in ²			3-150 psi		UD
2.5 NPS		2.04 in ²			3-150 psi		UD
20 NPS		122.49 in ²			0.25-50 psi		UD
24 NPS		190.61 in ²			0.25-50 psi		UD
3 NPS		2.95 in ²			2-150 psi		UD
4 NPS		5.47 in ²			1.5-150 psi		UD
5 NPS		8.39 in ²			1.5-150 psi		UD
6 NPS		12.05 in ²			1-150 psi		UD
8 NPS		21.14 in ²			0.5-150 psi		UD